# California Department of Public Health Webcast

Drinking Water Regulations

Dale Newkirk, P.E.

### **Lecture Objectives**

To learn about the regulations and rules affecting SWSs on the Federal and State levels




### Safe Drinking Water Act

- > Enacted In 1974 and amended in 1986 and 1996
- ➤ Is the foundation which lays the ground work for determining, regulating, and enforcing MCLs, MCLG, DBPs, TT, etc...
- > This is a national regulation which states are expected to achieve at a minimum


### Purpose of Requirements


- > Determine if water quality is acceptable
- > Monitoring depends on classification
- > Primaries vs. Secondary
- > Acute vs. chronic exposure
- Notify health dept. and users of any MCL exceedance



### Schedule of Recently Adopted Regulations

Regulation	Date Effective
Arsenic Rule	January 23, 2006
Public Notification	September 1, 2006
Secondary Maximum Contaminant Levels	September 27, 2006 (in California)
Primary Maximum Contaminant Level for Perchlorate	October 18, 2007 (in California)
Interim Enhanced Surface Water Treatment Rule	January 12, 2008 (in California)
California Code of Regulations Title 22: Waterworks Standards	March 9, 2008





## California Drinking Water Regulations

- State of California has Primacy to regulate and monitor the PWS within its State
- Can be more stringent than federal regulations, however not less stringent (California tends to be more stringent)
- Title 22 California Code of Regulations
- To learn the EPA regulations alone is not enough!

#### Regulations Affecting SWSs Systems Affected Regulations Summary Microbiological TC rule **Coliform MCL** All types and sizes **Volatile Organic Chemicals** MCLs All CWSs and NTNCWs Radionuclide All types and sizes **MCLs** Radon MCLs All types and sizes All CWSs and NTNCWs; **Inorganic Chemicals** MCLs transient systems exempt except for nitrates, nitrites No more than 5% of samples positive for **Total Coliform Rule** All types and sizes Coliform; Distribution system sampling Annual summary of water All CWSs and NTNCWs **Consumer Confidence Report** quality and exceptions to consumer **Public Notification** Notify public of tiered **All PWS** Requirements violations

## Regulations Affecting SWSs

Regulations	Summary	Systems Affected
Surface Water Treatment Rule	3 Log (99.9%) removal of Giardia, 4 Log (99.99%) virus inactivation Filtration treatment specified	All surface water and ground water under he direct influence of surface water
Lead and Copper Rule	Distribution System Action Levels	All CWSs and NTNCWs
Arsenic	MCLs	All CWSs and NTNCWs
Ground Water Rule	Appropriate use of disinfectants, multi-barrier approach	All systems using ground water as source
Long Term 1 Enhanced Surface Water	2 Log removal (99%) of Cryptosporidium, 0.3 NTU for Turbidity; TOC reductions for precursor removal	All surface water and ground water under he direct influence of surface water

#### Regulations Affecting SWSs Regulations **Summary Systems Affected** All conventional (flocculation/coagulation/sedimen Recycling filter backwash with Filter Backwash Rule tation) and direct filtration systems Stage 1 Reduction in DBP MCL and Disinfectants/disinfe CWSs and NTNCWSs that use a maximum residual ction By-Products Rule (D/DBP) chemical disinfectant

Contaminate Candidate
List (CCL)

disinfectants levels set

disinfectants levels set

chemical disinfectant

disinfectants levels set

Chemical disinfectant

All types and sizes

All types and sizes

# General Monitoring Frequency for SWSs

Contaminate	Minimum Monitoring Frequency			
Acute C	ontaminates - Immediate risk to Human Health			
Bacteria	Monthly or quarterly depending on system size and type			
Nitrate	Annually			
Protozoa/viruses				
Chro	Chronic Contaminates - Long-term health effects			
Volatile organics	GWS - quarterly for the first year, annually for the 2 and 3, after that depending on results; SW annually			
Synthetic organics	Larger systems twice in 3 years; smaller systems once in 3 years			
Inorganics/metals	GWS - once every 3 years; SW systems annually			
Lead and Copper	annually			
Radionuclide	once every 4 years			



### Arsenic Rule: Background

- > Rule proposed June 22, 2000
- Final Rule Published in January 2001
- > Effective January 23, 2006
- ▶ Goal
  - Establish an updated regulation to protect the public from health risks caused by arsenic in drinking water







### Arsenic Rule: Key points

- ➤ MCLG = 0 µg/L
- > Feasible MCL = 3 μg/L
- > Final Rule MCL = 10 μg/L
  - MCL was adjusted upwards to where the cost is justified by the benefits
- > Best Available Technology
- Compliance Monitoring and Reporting

#### Arsenic Rule: Monitoring Compliance

- > Initial Monitoring
  - One sample must be collected after effective date of new rule (January 23, 2006)
- > Monitoring
  - If initial monitoring results is <10 μg/L
    - Ground water system must collect one sample every 3 years
    - Surface water systems must collect annual samples
  - If initial monitoring result is >10 μg/L
     System must collect quarterly samples until the systems is reliably and consistently below MCL





# Lead and Copper Rule: Background

- Final Rule Published in January 1991
- ▶ Goal
  - Protect public health by minimizing Pb and Cu levels in drinking water, primarily by reducing water corrosivity. Pb and Cu enter drinking water from corrosion of plumbing materials
- Applies to All CWSs and NTNCWs
- > TT based on Action Levels





### Lead and Copper Rule: Monitoring

Samples must be collected by all CWSs & NTNCWSs at cold water taps in homes/buildings that are at high risk of Pb/Cu contamination

	Pb and Cu Tap and WQP Tap Monitoring					
Size	Population	Number of Pb/Cu Tap Sample Sites		Number of WQP Tap Sampling Sites		
			Reduced	Standard	Reduced	
Lorgo	>100 K	100	50	25	10	
Large	50,001 - 100K	60	30	10	7	
Medium	10,001 - 50 K	60	30	10	7	
iviedium	3,301 - 10K	40	20	3	3	
	501 - 3,300	20	10	2	2	
Small	101 - 500	10	5	1	(1)))	
	≤ 100	5	5		1	

	Lead and Copper Rule:
	Monitoring Frequency
Frequency	Criteria for Reduced Pb/Cu Monitoring Frequency
Bi-annually	N/A
Annual	Serves ≤ 50,000 and is ≤ both ALs for 2 consecutive 6 month monitoring periods  OR
Ailliuai	Meets Optimal Water Quality Parameter (OWQP) specifications for 2 consecutive 6 month monitoring periods
	Serves ≤ 50,000 and is ≤ both ALs for 3 consecutive years of monitoring  OR
	Meets Optimal Water Quality Parameter (OWQP) specifications for 3 consecutive years of monitoring
Triennial	OR
	Has 90th percentile Pb levels ≤ 0.005 mg/L & 90th percentile Cu levels ≤ 0.65 mg/L for 2 consecutive 6 month periods
	OR
	Meets monitoring waiver criteria
Every 9 years	Serves ≤ 3,300 and meets monitoring waiver criteria

### Lead and Copper Sampling

- Choose tap typically used for consumption
- Flush line
- Let water sit undisturbed for minimum 6 hrs
- Sample first draw



# Surface Water Treatment Rule: Background

- > Proposed on June 22, 2000
- Final Rule Published in January 2001
- ▶ Goal
  - Improves public health protection through the control of microbial contaminates, particularly viruses, *Giardia*, and *Cryptosporidium*
- Applies to all public water systems (PWSs) using surface water or ground water under the direct influence of surface water (GWUDI)
- IESWTR and LT1ESWTR build on the existing requirements established in the original SWTR



Surface Water Treatment Rule					
		SWTR 1999	IESWTR 1998	LT1ESWT R 2002	FBRR 2001
	≥ 10,000	X	X		X
Population Served	< 10,000	х	Sanitary Survey Provisions only	x	х
Regulated Pathogen	99.99% (4 log) removal of viruses	х	SWTR	SWTR	SWTR
	99.9% (3 log) removal of Giardia Lamblia	X	SWTR	SWTR	SWTR
	99% (2 log) removal of Cryptosporidium		x	X	IESWTR LT1ESWTR

Surface Water Treatment Rule					
		SWTR 1999	IESWTR 1998	LT1ESWTR 2002	FBRR 2001
Residual Disinfectant	Distribution System Inlet (≥0.2 mg/L)	X	SWTR	SWTR	
Requirements	Distribution System	X	SWTR	SWTR	
	Combined Filter Effluent	X	Х	X	
Turbidity	Individual Filter Effluent		Х	X	
	tion Profiling & chmarking		X	X	
Sanitary Surveys	CWS: Every 3 years NCWS: Every 5 years		X	IESWTR	
Covered Finis	shed Water Storage		Х	X	
Operated by 0	Qualified Personnel	X	SWTR	SWTR	SWTR

### Surface Water Treatment Rule

Turbidity: Monitoring and Reporting Requirements (due each month)	Monitoring Frequency	SWTR (1993)	LT1ESWTR (2005)
CFE 95%	At least every 4 hours*	≤ 0.5 NTU	≤ 0.3 NTU
CFE Max Value	At least every 4 hours*	5 NTU	1 NTU
IFE Monitoring	Monitor continuously every 15 minutes	None	Monitor- exceedance require follow-up action. Systems with 2 or fewer filters may monitor CFE continuously in lieu of IFE.

<sup>\*</sup> Monitoring frequency may be reduced by the state to once per day for system serving less 500 people

#### Surface Water Treatment Rule IFE Follow-Up and Reporting Requirements (Jan. 1, 2005) LT1ESTR (<10,000) Condition **Action** Ву Report 2 Consecutive **Filter Turbidity** recordings > 1.0 NTU value Date taken 15 mins apart Report to State Cause 30 days 2 consecutives Report to State Date filter selfrecordings > 1.0 NTU and conduct a 30 days to report to taken 15 mins apart at filter selfassessment state and selfassessment the same filter for 3 triggered and assessment within months in a row with 14 days completed 14 days 2 consecutive 30 days to report to **Date CPE** recordings > 2.0 NTU Report to State, state, 60 days to triggered Submit CPE taken 15 mins apart at arrange for CPE arrange CPE and 120 days to submit the same filter for 2 and submit CPE **CPE** report months in a row Report report

Surface Water Treatment Rule				
Residual	Disinfectant Monitori	ng and Reportii	ng Requirements	
Location	Concentration	Monitoring Frequency	Report (once a month)	
Distribution system inlet	Residual disinfectant cannot be < 0.2 mg/L for more than 4 hours	Continuous, but may allow systems serving 3,300 or fewer persons to take grab samples from 1 to 4 times per day	Lowest daily value for each day, date, duration Times when < 0.2 mg/L	
Distribution system total coliform sample locations	Residual disinfectant concentration cannot be undetectable in greater than 5% of samples in a month for 2 consecutive months. HPC ≤ 500/mL	Same time as total coliform samples	Number of residual disinfectant or HPC measurement taken in the month resulting in no more than 5% of the measurement as being undetectable in any 2 consecutive months.	

## Consumer Confidence Report Rule: Background

- > Goal
  - Improves public health protection by providing educational material to allow consumers to make educated decisions regarding any potential health risks pertaining to the quality, treatment, and management of their drinking water supply.
- > Applies to all CWSs and NTNCWSs

### Consumer Confidence Report Rule

- > Requires annual consumer confidence report
- > Critical Dates
  - July 1 Deadline for annual distribution of CCR to customers and State agency for report of previous year (Jan. – Dec.)
  - October 1 Deadline for annual submission of proof of distribution to State agency
- Small Water System Flexibility
  - PWSs with <10,000 people may publish their CCR in a local newspaper
  - PWSs with <500 people may provide notice stating the report is available upon request

### Consumer Confidence Report Rule

- ➤ Mandatory Information in CCR
  - Contact information
  - Source of water
  - Definitions
  - Detected Contaminates
  - Explanation of Violations
  - Explanation of Variance/Exemption
  - Required Education Information

#### **Public Notification Rule**

- Requires PWSs to notify the public in the event of contamination violation based on the potential severity of the situation
- > Classifies violations into Tiers
  - Tier 1 24 hours → Immediate notice
  - Tier 2 30 days  $\rightarrow$  As soon as possible
  - Tier 3 1 year → Annual notice
- Amends Consumer Confidence Report (CCR) regulations to conform to changes made in public notification regulations

# Public Notification Rule: Breakdown of Tiers 1, 2, and 3

Tier 1	Tier 2	Tier 3
Notice within 24 Hours	Notice within 30 days	Notice within 1 Year
Fecal Coliform Violations	All MCL, MRDL not already covered by Tier 1	Monitoring or testing procedure violations (not covered by Tier 1 or Tier 2)
Nitrate/Nitrite Violations	Monitoring and testing Violations when Tier 2 notice required	Operation under a variance and exemption
MRDL Violations	Failure to comply with variance and exemption conditions	Special Public Notices (i.e. Fluoride SMCL
Turbidity		
Waterborne disease outbreak		

### Total Coliform Rule: Background

- > Final Rule Published June 1999
- > Goal
  - Improve public health protection by reducing fecal pathogens to minimal levels through control of total coliform bacteria, including fecal coliforms and E. coli.
- > Acute public health effect
- > Applies to all public water systems (PWSs)

#### Total Coliform Rule: Sampling

- Total coliform samples <u>must</u> be at sites which are representative of WQ throughout the distribution system
- Samples must be collected at regular times throughout a month except for GWSs serving ≤ 4,900 persons may collect them on the same day
- ➤ Reduced monitoring may be available for PWSs serving ≤ 1,000 and using GW

### California Minimum # of Routine Total Coliform Samples

Monthly Population Served	Service Connections	Minimum Number of Samples
25 to 1000	15 to 400	1 per month
1,001 to 2,500	401 to 890	2 per month
2,501 to 3,300	891 to 1,180	3 per month

### **Total Coliform Rule: Sampling**


- > If a routine sample is POSTIVE then
  - One repeat sample must be collected from source again
  - One repeat sample must be collected within five service connections upstream and downstream
- Systems that collect ≤ 1 sample/month must collect a 4<sup>th</sup> repeat sample
- > If any repeat sample is POSITIVE
  - The system must analyze the total coliform positive culture for fecal coliforms or E.coli.
  - The system must collect another set of repeat samples unless the MCL has been violated and the system has notified the state.
- A POSITIVE routine or repeat result requires a minimum of 5 routine samples be collected next month


### Total Coliform Rule: Sampling

- ▶ If any repeat sample is POSITIVE
  - The system must analyze the total coliform positive culture for fecal coliforms or E.coli.
  - The system must collect another set of repeat samples unless the MCL has been violated and the system has notified the state.
- A POSITIVE routine or repeat result requires a minimum of 5 routine samples be collected next month

Any of the following criteria shall indicate a possible significant rise in bacterial count:

- A system collecting at least 40 samples per month has a total coliform-positive routine sample followed by two total coliformpositive repeat samples in the repeat sample set;
- A system has a sample which is positive for fecal coliform or E. coli;
- · A system fails the total coliform MCL





# Total Coliform Rule: California Specific Regulation

From §64426. Significant Rise in Bacterial Count the CA regulation states,

When the coliform levels specified in subsection (a) are reached or exceeded, the water supplier shall:

- Contact the Department by the end of the day on which the system is notified of the test result or the system determines that it has exceeded the MCL, unless the notification or determination occurs after the Department office is closed, in which case the supplier shall notify the Department within 24 hours; and
- Submit to the Department information on the current status of physical works and operating procedures which may have caused the elevated bacteriological findings, or any information on community illness suspected of being waterborne.

Total Coliform Rule: Violations			
A Monthly MCL Violation is Triggered if:			
A system collecting fewer than 40 samples per month	Has greater than 1 ROUTINE/REPEAT samples per month which is total coliform-positive		
A system collecting at least 40 samples per month	Has greater than 5.0% percent of the ROUTINE/REPEAT SAMPLES in a month total coliform-positive		
An Acute MCL Violation is Triggered if:			
Any public water system	Has any fecal coliform or E. coli-positive  REPEAT sample OR has a fecal coliform or  E. coli-positive sample followed by total coliform-positive REPEAT sample		

# Total Coliform Rule: Other Requirements

- Systems collecting fewer than 5 routine samples/month
  - Must have a sanitary survey every 5 years
  - 10 years if it is a NCWS using GW
- > Systems using SW or GWUDI
  - Must collect and have analyzed one coliform sample each day the turbidity of the source water exceeds 1 NTU.

### Stage 1 DBP Rule: Background

- > Final Rule Published December 1998
- > Goal
  - Improve public health protection by reducing exposure to disinfection byproducts
- Applies to all CWSs and NTNCWs that add a disinfectant to the drinking water during any part of the treatment process and TNCWSs that use chlorine dioxide (CIO<sub>2</sub>)

### Stage 1 DBP Rule: Regulations

Contaminant	MCL (mg/L)	MCLG (mg/L)
Total Trihalomethanes (TTHM)	0.08	N/A
Five Haloacetic Acids (HAA5)	0.06	N/A
Bromate (plants that use ozone)	0.01	0
Chlorite (plants that use ClO <sub>2</sub> )	1.0	0.8

Disinfectant	MRDL (mg/L)	MRDLG (mg/L)
Chlorine	4.0 as Cl <sub>2</sub>	4.0 as Cl <sub>2</sub>
Chloramine	4.0 as Cl <sub>2</sub>	4.0 as Cl <sub>2</sub>
Chlorine dioxide	0.8	0.8

#### Stage 1 DBP Rule Required % Removal of TOC Source Water TOC Source Water Alkalinity (mg/L as CaCO<sub>3</sub>) (mg/L) > 2.0 to 4.0 15.0% 35.0% 25.0% > 4.0 to 8.0 45.0% 35.0% 25.0% > 8.0 50.0% 40.0% 30.0%

### Stage 1 DBP Rule: Monitoring

Regulation	Regulation Coverage	Monitoring Frequency	Compliance
TTHM/HAA5	SW and GWUDI serving 500-9,999	1/plant/quarter	Running annual average
	SW and GWUDI serving <500	1/plant/year in month of warmest water temperature	Running annual average of increased monitoring
	GW serving <10,000	1/plant/year in month of warmest water temperature	Running annual average of increased monitoring
Bromate	Ozone plants	Monthly	Running annual average
Chlorite	Chlorine dioxide plants	Daily at distribution system entrance; monthly in distribution system	Daily/follow-up monitoring
Chlorine dioxide	Chlorine dioxide plants	Daily at distribution system entrance	Daily/follow-up monitoring
Chlorine/ Chloramines	All systems	Same location and frequency as TCR sampling	Running annual average
DBP Precursors	Conventional filtration	Monthly for TOC and alkalinity	Running annual average

### Radionuclides Rule: Background

- > Final Rule Published December 2000
- > Goal
  - Protect the public against the harmful effects of radionuclides in drinking water
- > Applies to CWSs and NTNCWSs

# Radionuclide Maximum Contaminant Levels (MCLs)

Radionuclide	MCL	DLR
Radium-226	5 pCi/L	1 pCi/L
Radium-228	(combined radium-226 & -228)	1 pCi/L
Gross Alpha particle activity (excluding radon and uranium)	15 pCi/L	3 pCi/L
Uranium	20 pCi/L	1 pCi/L
	(/-)	

### Radiological Compounds

Regulated Contaminates			
Regulated	USEPA		CDPH
Radionuclide	MCL	MCLG	MCL
Beta/photon emitters	4 mrem/yr	0	4 mrem/yr
Gross alpha particle	15 pCi/L	0	5 pCi/L
Combined Radium (226/228)	5 pCi/L	0	5 pCi/L
Uranium	30 μg/L	0	20 μg/L

## RADIOLOGICAL COMPOUNDS cont.


- > New rule-Initial compliance
  - Four quarterly samples collect 1 gallon each
    - Analyze samples for gross alpha first.
    - If GA > 5 pCi/L, analyze for uranium.
    - If the GA uranium > 5 pCi/L, analyze for rad-226.
    - If the rad-226 > 3 pCi/L, analyze for rad-228.
      - Can analyze Rad 226 + 228 combo, but all community ws must analyze 4 quarterly samples for Radium-228 by Dec. 2007

## RADIOLOGICAL COMPOUNDS cont.

- > New rule-Initial compliance
  - Based on average of 4 consecutive quarterly samples.
    - If required to analyze for uranium and/or radium, need four consecutive quarters
    - Can use data back to 2001
  - Dept. may waive final 2 quarters if results from the first 2 quarters are below the DLR.
  - Worksheet available

## RADIOLOGICAL COMPOUNDS cont.

- > New Rule Reduced monitoring
  - Based on the average of initial 4 quarterly samples. Sample during quarter w/highest result.
    - One sample every 9 years if:
      - → average < 3 pCi/L</p>
    - One sample every 6 years if:
      - > 3 pCi/L ≤ average ≤ 7.5 pCi/L
    - One sample every 3 years if:
      - > 7.5 pCi/L < average ≤ 15 pCi/L
    - Quarterly if:
      - > average > 15 pCi/L.



### Ground Water Rule: Background

- Final Rule Published in Fall 2000
- ▶ Goal
  - Establish a targeted strategy to identify ground water systems susceptible to microbial contamination
  - Establish a protective barrier to prevent microbial illness in ground water system



### Ground Water Rule: Requirements

- Sanitary Surveys by State to identify significant deficiencies
- Corrective Action
- Compliance Monitoring for systems that disinfect
- > For systems that **DO NOT** disinfect
  - Hydrogeologic sensitivity assessments
  - Source water monitoring from sensitive aquifers or by systems that have detected fecal indicators in the distribution system

# Long Term 1 Enhanced Surface Water Treatment Rule: Background

- > Final Rule Published in January 2002
- > Goal
  - Improve public health protection through the control of microbial contaminants, particularly Cryptosporidium.
  - Prevent Significant increases in microbial risk that might otherwise occur when systems implement the Stage 1 D/DBP Rule
- Applies to all PWSs that serve surface water or GWUDI to <10,000 people</p>

### LT1ESWTR: Requirements

- > 2-log Crypto. removal
  - Treatment Technique based
- ➤ Changes to Conventional/Direct Filtration
  - Lower turbidity performance standard
    - 0.3 NTU in 95% & never exceed 1 NTU
  - Continuous turbidity of individual filters
  - Disinfection profiles
    - Giardia inactivation is the benchmark
- Slow sand filtration must meet 1 NTU in 95% of samples
- > New finished water reservoirs need covers

### LT1ESWTR: Requirements

#### > Turbidity requirement

- Perform turbidity measurement of CFE at least one every 4 hours
- Continuous on-line measurement of IFE unless two or fewer filters
- Follow up actions required if IFE has two readings > 1 NTU

#### > Disinfection Benchmarking

- Conduct one year of calculation for weekly removal of *Giardia Lamblia*
- Calculate virus removal if disinfectant used is other than chlorine
- Results must be available for LPA to review during sanitary survey
- Can not change disinfection practices without LPA approval

# Filter Backwash Recycling Rule (FBR): Background


- > Final Rule Published June 2001
- > Goal
  - Improved public health protection by assessing and changing where needed, recycle practices for improved contaminant control, particularly microbial contaminants
- > Application
  - Applies to public water systems that use surface water or ground water under the direct influence of surface water

### FBR: Key Terms

- > Spent Filter Backwash Water
  - A stream containing particles that are dislodged from filter media when water is forced back through a filter to clean the filter
- > Thickener Supernatant
  - A stream containing the decant from a sedimentation basin, clarifier or other unit that is used to treat water, solids, semi-solids from the primary treatment processes
- Liquids from Dewatering Processes
  - A stream containing liquids generated from a unit used to concentrate solids for disposal

### FBR: Requirements

- Recycle stream returned to the point of primary coagulant addition (State may modify)
- Direct filtration systems must provide information to State
- One-month, one-time recycle self assessment for certain systems



### Stage 2 D/DBP Rule: Background

- ➤ Final Rule Published January 2006
- > Goal
  - To increase public health protection by reducing the potential risk of adverse health effects associated with DBPs through the distribution system.
- Applies to all PWS that either add a primary or residual disinfectant other than Ultra Violet Light

### Stage 2 D/DBP Rule

Stage 2 DBPR Regulated Contaminants			
Regulated Contaminants	MCLG (mg/L)	MCL (mg/L)	
Total Trihalomethanes (TTHM)		0.080 LRAA	
Chloroform Bromodichloromethane Dibromochloromethane Bromoform	0.07 zero 0.06 zero		
Five Haloacetic Acids (HAA5)		0.060 LRAA	
Monochloroacetic acid Dichloroacetic acid Trichloroacetic acid Bromoacetic acid Dibromoacetic acid	0.07 zero 0.02 - -		

### Stage 2 D/DBP Rule: Monitoring

Source Water Type	Population Size Category	Monitoring Frequency	Total Distribution System Monitoring Locations per Monitoring Period
SW/GWUDI	<500	per year	2
SW/GWUDI	500-3,300	per quarter	2
SW/GWUDI	3,301-9,999	per quarter	2
GW	<500	per year	2
GW	501-9,999	per year	2

### ASBESTOS Rule: Background

- > Applies to CWSs/NTNCWSs only
- > Sample every 9 years
  - Source
  - Distribution system
- Sources of asbestos
  - Source-serpentine formations All SW vulnerable
  - Distribution system-AC/transite pipe




#### **ASBESTOS Rule**

- New Federal standard = 7 million fibers/liter (longer than 10 micrometers)
  - Takes effect January 2006
  - Compliance based on average 4 quarterly samples
  - Can grandfather data, but no average
- > State still needs to adopt a new standard
- > Treatment issues
- > Waivers available to non-vulnerable systems
  - Apply to Health Dept.

### NITRATES: Key Points

- > Acute health effects
- > May increase over time
- > Sources of contamination
- ➤ MCL = 45 ppm as NO<sub>3</sub>
- All water system classifications must test annually
- Nitrites/Nitrate+Nitrite = every 3 years



### **NITRATES**: Key Points

- >1/2 of MCL = quarterly monitoring
- ▶ Confirmation Sampling
  - •Resample w/in 24 hrs and average them, or
  - •Notify users and resample w/in 2 weeks
- >Resolving nitrate contamination

### Primary Inorganics: Key Points





- CWSs/NTNCWSs must comply with all constituents
- > TNCs must test for Flouride (F) only
- GW-Sample every 3 years
- SW-Sample every year
- Increased levels = increase sampling
- Compliance based on annual average of 4 quarterly samples



# Maximum Contaminant Levels of Inorganic Chemicals

Maximum Contaminant Level (mg/L)	Chemical	Maximum Contaminant Level (mg/L)
1	Fluoride	2
0.006	Mercury	0.002
0.05	Nickel	0.1
7 MFL*	Nitrate (as NO <sub>3</sub> )	45
1	Nitrate+Nitrite (sum N²)	10
0.004	Nitrite (as N²)	1
0.005	Selenium	0.05
0.05	Thallium	0.002
0.15		
	Contaminant Level (mg/L)  1  0.006  0.05  7 MFL*  1  0.004  0.005  0.05	Contaminant Level (mg/L)         Chemical Fluoride           1         Fluoride           0.006         Mercury           0.05         Nickel           7 MFL*         Nitrate (as NO₃)           1         Nitrate+Nitrite (sum N₂)           0.004         Nitrite (as N₂)           0.005         Selenium           0.05         Thallium

## Primary Inorganics: Waivers

- Available after 3 rounds of testing and no chemicals exceed MCL
  - GW every 9 years
  - SW every 3 years
- Must apply to Health Department

## VOLATILE & SYNTHETIC ORGANIC COMPOUNDS (VOCs, SOCs)

- > Chronic health effects
- CWSs/NTNCWSs must comply with all constituents
- GW-sample every 3 years after initial compliance
- SW-sample every year after initial compliance







## VOCs and SOCs: Key Points

- > If chemical is detected
  - SWS may do 1 or 2 confirmation samples
    - If chemical is absent in both samples, the positive detection can be disregarded
  - Compliance based on average of 4 quarterly samples
    - <MCL = quarterly monitoring
    - >MCL = contact Health Dept.



#### **VOCs and SOCs**

- If heptachlor and/or heptachlor epoxide are detected
  - Then analyze for both chemicals until there has been no detection of either chemical for one compliance period.
- If trichloroethylene, tetrachloroethylene, 1,2dichloroethane, 1,1,1-trichloroethane, cis-1,2dichloroethylene, trans-1,2-dichloroethylene, or 1,1-dichloroethylene are detected in GW sample
  - Then quarterly monitoring for vinyl Chloride
  - If vinyl chloride is not detected in the first quarterly monitoring sample, monitor once for vinyl chloride during each compliance period.

### **VOCs and SOCs**

- > If >10 times MCL
  - Notify the Department within 48 hours of the receipt of the results
  - Re-sample within 48 hours to confirm the result.
  - notify the Department of the confirmation result within 24 hours
- If the average concentration <10 times the MCL start quarterly monitoring</p>
- If the average concentration >10 times the MCL, use of the contaminated water source shall immediately be discontinued.
- Requires Department approval to return water source

### **VOCs and SOCs: Waivers**

- Waivers are available to non-vulnerable sources
  - VOC: GW every 6 years
  - VOC: SW every 6 years
  - SOC: waive all testing or some panels
  - Must apply to Health Dept.

### **SECONDARY COMPOUNDS**

- > Aesthetic problems-not health concern
  - Affect taste, odor, appearance
- > CWSs no exceed MCL in:
  - New systems must not exceed MCLs
  - New sources must not exceed MCLs
  - Existing systems require investigation/feasibility study
    - Consumer acceptance and economic considerations

GW - sample every 3 years

SW - sample every year

# **Secondary Maximum Contaminant Levels**

Constituents	Maximum Contaminant Levels/Units	Constituents	Maximum Contaminant Levels/Units
Aluminum	0.2 mg/L	Methyl-tert-butyl ether (MTBE)	0.005 mg/L
Color	15 Units	OdorThreshold	3 Units
Copper	1.0 mg/L	Silver	0.1 mg/L
Corrosivity	Non-corrosive	Thiobencarb	0.001 mg/L
Foaming Agents (MBAS)	0.5 mg/L	Turbidity	5 Units
Iron	0.3 mg/L	Zinc	5.0 mg/L
Manganese	0.05 mg/L		

# Secondary Maximum Contaminant Levels Ranges

#### **Maximum Contaminant Level Ranges Upper Short Term Constituent, Units** Recommended **Total Dissolved Solids** 500 1,000 1,500 (mg/L) **Specific Conductance** 900 2,200 1,600 (micromhos) Chloride (mg/L) 250 500 600 Sulfate (mg/L) 250 500 600

## SECONDARY COMPOUNDS

#### > Waivers

- Available after 3 rounds of testing and no chemicals exceed MCL
- Lasts for 9 years
- Apply to Health Dept.

#### > NTNCWSs/TNCWSs

- Monitor once
- Surface sources serve >1000 people = every 3 years

## Last Point: Standby Sources

- Can only be used for short-term emergencies of 5 consecutive days or less, and for less than a total of 15 calendar days/year
- Sample every 9 years for inorganic/organic/radiological compounds
- Nitrates ≥ ½MCL sample annually and w/in 24 hours when source is activated

