




Standard Definitions for Water Losses

*A compendium of terms and acronyms
and their associated definition in common
use in the field of water loss management*



David Pearson

Standard Definitions for Water Losses

Standard Definitions for Water Losses

Author: David Pearson

Editor: Andrew Donnelly

Abstract

A compendium of terms and acronyms and their associated definition in common use in the field of water loss management

Editorial Panel

Bambos Charalambous	Mohammed Shafei
Stuart Hamilton	Stuart Stapely
Will Jernigan	Richard Taylor
Roland Liemberger	Stuart Trow
Mark Nicol	Alan Wyatt
Jo Parker	Gary Wyeth



Published by

IWA Publishing
Alliance House
12 Caxton Street
London SW1H 0QS, UK
Telephone: +44 (0)20 7654 5500
Fax: +44 (0)20 7654 5555
Email: publications@iwap.co.uk
Web: www.iwapublishing.com

First published 2019
© 2019 IWA Publishing

Apart from any fair dealing for the purposes of research or private study, or criticism or review, as permitted under the UK Copyright, Designs and Patents Act (1998), no part of this publication may be reproduced, stored or transmitted in any form or by any means, without the prior permission in writing of the publisher, or, in the case of photographic reproduction, in accordance with the terms of licenses issued by the Copyright Licensing Agency in the UK, or in accordance with the terms of licenses issued by the appropriate reproduction rights organization outside the UK. Enquiries concerning reproduction outside the terms stated here should be sent to IWA Publishing at the address printed above.

The publisher makes no representation, express or implied, with regard to the accuracy of the information contained in this book and cannot accept any legal responsibility or liability for errors or omissions that may be made.

Disclaimer

The information provided and the opinions given in this publication are not necessarily those of IWA and should not be acted upon without independent consideration and professional advice. IWA and the Editors and Authors will not accept responsibility for any loss or damage suffered by any person acting or refraining from acting upon any material contained in this publication.

British Library Cataloguing in Publication Data

A CIP catalogue record for this book is available from the British Library

ISBN: 9781789060874 (Paperback)

ISBN: 9781789060881 (eBook)

DOI: 10.2166/9781789060881

This eBook was made Open Access in November 2019

© 2019 The Author(s)

This is an Open Access book distributed under the terms of the Creative Commons Attribution Licence (CC BY 4.0), which permits copying, adaptation and redistribution, provided the original work is properly cited (<http://creativecommons.org/licenses/by/4.0/>).



Contents

List of Acronyms	xi
Standard Symbols for Numeric Values	xiii
Standard Abbreviations for Units	xv
Standard Abbreviations for Pipe Materials	xvii
Water Resources	1
Potable Water	1
NON-potable Water	1
Raw Water	1
Yield of Water Resource System	1
Deployable Output	1
Available Supply	1
Outage	1
Demand	1
Water Resource Zone (WRZ)	1
Water Supply Zone (WSZ)	1
Supply Reliability	2
Headroom	2
Water Supply Coverage	2
Water Supply Network	2
Water Distribution Network	2
Network Hierarchy	2
Drought	2
Drought Restrictions	2
Supply	2
Rotational Supply	2
Rotational Supply Designation	2
Supply Time (ST)	3
Intermittent Water Supply (IWS)	3
Distribution Network Assets	3
Aqueduct	3
Transmission Main	3
Service Reservoir (SR)	3
Main	3

Edge of Street (EoS)	4
Service Pipe	4
Service Connection	4
Shared Connection	4
Short-side Connection	5
Long-side Connection	5
Private Service Pipe	5
Common Private Service Pipe	6
Private Service Pipe Connection	7
Legal Connection	8
Illegal Connection	8
Connection Density	8
Connection Ratio	8
Active Property	8
Inactive Property	8
Property	8
Property Density	8
Occupancy	8
Step Valve	8
Circulating Valve	8
Boundary Valve	8
Meter Box	9
Stop Tap Chamber	9
External Stop Tap	10
Internal Stop Tap	10
Stop Tap	10
Tapping	10
Tapping Point	10
Tapping Tee	10
Ferrule	11
Appurtenances	12
Fittings	12
Wash Out (WO)	12
Fire Hydrant (FH)	12
Hydrant	12
Air Valve (AV)	12
Sluice Valve (SV)	12
Butterfly Valve	13
Pressure Control Valve	13
Altitude Control Valve	13
Pressure Sustaining Valve (PSV)	14
Pressure Reducing Valve (PRV)	14
Pressure Relief Valve	14
Flow Metering	14
Volumetric Meter	14
Positive Displacement Meter	15
Turbine Meter	15
Electromagnetic Meter (EM)	15
Ultrasonic Meter	15
Full-bore Meter	15
Insertion Meter	15
Meter Calibration	16
Meter Verification	16

Flow	16
Flow Meter	16
Flow Logger	16
Pulse Unit	16
Abstraction Meter	16
Production Meter	16
Distribution Input Meter	16
DMA Meter	16
Bulk Meter	16
Non-revenue Meter	16
Revenue Meter	17
Meter Reading Lag	17
Automatic Meter Reading (AMR)	17
Advanced Metering Infrastructure (AMI)	17
Smart Meter	17
IWA Standard Water Balance	17
System Input Volume	17
Authorised Consumption	17
Revenue Water	18
Billed Authorised Consumption	18
Billed Metered Consumption	18
Billed Unmetered Consumption	18
Unbilled Authorised Consumption	18
Unbilled Metered Consumption	18
Unbilled Unmetered Consumption	19
Non-Revenue Water (NRW)	19
Unaccounted for Water (UFW)	19
Water Losses	19
Non-technical Losses	19
Apparent Losses (AL)	19
Unauthorised Consumption	19
Data Handling and Billing Errors	19
Underestimation of Unmeasured Consumption	19
Customer Metering Inaccuracies	19
Technical Losses	20
Real Losses (RL)	20
Leakage and Overflows from Utility Storage Tanks	20
Leakage on Service Connections up to the Point of Customer Metering	20
Leakage on Transmission and/or Distribution Mains	20
Point of Supply	20
Plumbing Losses	20
Consumption	20
Per Capita Consumption (PCC)	20
Per Household Consumption (PHC)	21
Small Area Monitor (SAM)	21
Individual Household Monitor (IHM)	21
Diurnal Demand Pattern	21
Leakage Management	21
Leakage Control	21
Leakage	21
Daily Leakage	22
Night Leakage	22
Zone	23
District Metered Area (DMA)	23

Net Flow	23
Sub-DMA	23
Attributes	23
Minimum Night Flow (MNF)	23
Minimum Flow (MF)	25
Total Integrated Flow Method (TIF Method)	25
Minimum Night Flow Method (MNF Method)	25
Legitimate Night Consumption (LNC)	25
Legitimate Domestic Night Consumption (LDNC)	25
Legitimate Non-household Night Consumption (LNHHNC)	25
Continuous Logged User (CLU)	26
Operability Test	26
Top Down Leakage Assessment (TD)	26
Bottom Up Leakage Assessment (BU)	26
Downstream Leakage	26
Upstream Leakage	26
Minimum Achieved Night Flow	26
Minimum Achievable Night Flow (Mabl)	26
Unavoidable Annual Real Losses (UARL)	26
Background Leakage	27
Unavoidable Background Leakage (UBL)	27
Infrastructure Condition Factor (ICF)	27
Burst Frequency	28
Mains Burst Frequency	28
Service Pipe Burst Frequency	28
Service Connection Burst Frequency	28
Private Service Pipe Burst Frequency	28
Natural Rate of Rise of Leakage (NRR)	28
Smart Network	28
Leaks	29
Circumferential Break	29
Longitudinal Break	29
Split	29
Other Failure Modes	29
Leak	29
Leak on Main	29
Leak on Service Connection	29
Leak on Private Service Pipe	29
Leak on Appurtenances	29
Reported Leak	29
Unreported Leak	30
Leak Duration	31
Awareness Time	31
Location Time	31
Repair Time	31
Leakage Detection	31
Active Leakage Control (ALC)	31
Leakage Detection Survey	31
Regular Sounding	32
Passive Leakage Control	32
Reactive Survey	32
Locate, Localise, Pinpoint	32
Area of Interest (AOI)	32
Equivalent Service Pipe Burst (ESPB)	32

Leakage Detection Techniques	32
Leak Noise Correlator (LNC)	32
Correlator Survey	33
Stop Tap Sounding Survey	33
Mains Appurtenances Only Sounding Survey	34
Surface Sounding	34
Manual Listening Stick	34
Electronic Listening Stick	34
Ground Microphone	34
Pressure Zero Test (PZT)	34
Acoustic (Noise) Loggers	35
Correlating Acoustic Loggers (CAL)	36
Remote Sensing	36
Non-Intrusive Leak Detection	37
Intrusive Leak Detection	37
Ground Penetrating Radar (GPR)	37
Gas Injection	38
Step Test	38
Temporary DMA Rezoning Test	38
Leak Repairs	38
Repair Clamp	39
Piece Through Repair	39
Pressure Management (PM)	39
Pressure Gauge	40
Pressure Logger	40
Pressure	40
Transients	40
Pressure Reduction	40
Fixed Outlet Pressure Management	41
Time Modulated Pressure Management	41
Flow Modulated Pressure Management	41
Critical Pressure Control Pressure Management	42
Discrete Pressure Area (DPA)	42
Pressure Managed Area (PMA)	42
Critical Point (CP)	42
Average Zone Point (AZP)	42
Average Zone Pressure	42
Average Zone Night Pressure (AZNP)	43
Average Operating Pressure (AOP)	43
Hour to Day Factor (HDF)	43
Fixed and Variable Area Discharge (FAVAD)	43
N1 Factor	43
N1 Step Test	44
N2 Factor	44
N3 Factor	44
Mains and Service Pipe Rehabilitation	44
Mains Relining	44
Open Cut Replacement	44
Pipe Bursting	44
Slip Lining	45
Roll Down	45
Die Drawing	45
Service Pipe Rehabilitation	45
Pipe Condition Surveying	45

Pigging Chamber	45
Mains Flushing	45
Leakage Modelling	45
Demand Calibration	45
Component Loss Model (CLM)	46
Hydraulic Modelling	46
Economic Level of Leakage (ELL)	46
Apparent Loss Management	47
Meter Under-Registration (MUR)	48
Economic Level of Apparent Losses (ELAL)	48
Performance Indicators (PIS)	49
Performance Indicators for Non-Revenue Water	49
Performance Indicator for Apparent Losses	49
Performance Indicators for Real Losses	49
Current Annual Real Losses (CARL)	50
Infrastructure Leakage Index (ILI)	50
Losses per Connection (when system pressurised)	50
Losses per Unit Length of Main (when system pressurised)	50
Pressure Management Index (PMI)	51
Normalised Mains Burst Frequency	51
Normalised Service Pipe Burst Frequency	51
Normalised Service Connection Burst Frequency	51
Normalised Private Service Pipe Burst Frequency	51
Financial	51
Marginal Cost of Water (MCW)	51
Marginal Value of Water (MVW)	52
Marginal Cost of Revenue (MCR)	52
Capital Expenditure (CAPEX)	52
Operational Expenditure (OPEX)	52
Discounted Cash Flow (DCF)	52
Information Technology	52
Geographical Information System (GIS)	52
Work Management System (WMS)	52
Leakage Management System (LMS)	53
Customer Contact System	53
Customer Billing System	53
Waste Notice System	53
Index	55

List of Acronyms

AL	Apparent Losses
ALC	Active Leakage Control
AMI	Advanced Metering Infrastructure
AMR	Automatic Meter Reading
AOI	Area of Interest
AOP	Average Operating Pressure
AV	Air Valve
AZNP	Average Zone Night Pressure
AZP	Average Zone Point
BABE	Burst and Background Estimation
BU	Bottom Up Leakage Assessment
CAL	Correlating Acoustic Loggers
CAPEX	Capital Expenditure
CARL	Current Annual Real Losses
CLM	Component Loss Model
CLU	Continuous Logged User
CP	Critical Point
DCF	Discounted Cash Flow
DMA	District Metered Area
DPA	Discrete Pressure Area
ELAL	Economic Level of Apparent Losses
ELL	Economic Level of Leakage
EM	Electromagnetic Meter
EoS	Edge of Street
ESPB	Equivalent Service Pipe Burst
FAVAD	Fixed and Variable Area Discharge
FH	Fire Hydrant
GIS	Geographical Information System
GPR	Ground Penetrating Radar
HDF	Hour to Day Factor
ICF	Infrastructure Condition Factor
IHM	Individual Household Monitor

ILI	Infrastructure Leakage Index
IWS	Intermittent Water Supply
LCA	Leakage Control Area
LDNC	Legitimate Domestic Night Consumption
LMS	Leakage Management System
LNC	Leak Noise Correlator
LNC	Legitimate Night Consumption
LNHHNC	Legitimate Non-household Night Consumption
Mabl	Minimum Achievable Night Flow
MCR	Marginal Cost of Revenue
MCW	Marginal Cost of Water
MF	Minimum Flow
MinHist	Minimum Historic Night Flow
MNF	Minimum Night Flow
MNF Method	Minimum Night Flow Method
MUR	Meter Under-Registration
MVW	Marginal Value of Water
NDF	Night Day Factor
NPV	Net Present Value
NRR	Natural Rate of Rise of Leakage
NRW	Non-Revenue Water
OPEX	Operational Expenditure
PCC	Per Capita Consumption
PHC	Per Household Consumption
PIM	Pipeline Insertion Method
PLC	Programmable Logic Controller
PIs	Performance Indicators
PM	Pressure Management
PMA	Pressure Managed Area
PMI	Pressure Management Index
PRV	Pressure Reducing Valve
PSV	Pressure Sustaining Valve
PZT	Pressure Zero Test
RL	Real Losses
SAM	Small Area Monitor
SR	Service Reservoir
ST	Supply Time
SV	Sluice Valve
TD	Top Down Leakage Assessment
TIF Method	Total Integrated Flow Method
UARL	Unavoidable Annual Real Losses
UBL	Unavoidable Background Leakage
UFW	Unaccounted for Water
WMS	Work Management System
WO	Wash Out
WRZ	Water Resource Zone
WSZ	Water Supply Zone

Standard Symbols for Numeric Values

Symbol	Prefix	Name	Value	Scientific
k	Kilo	Thousand	1,000	10^3
M	Mega	Million	1,000,000	10^6
m	Milli	Thousandth	0.001	10^{-3}

Standard Abbreviations for Units

Abbreviation	Unit
Length	
m	metre
km	kilometre (1000 m)
mile	mile
ft	feet
in	inch
Volume	
l	litre
m ³	cubic metre (=1000l)
MI	megalitre (=1,000,000l, 1000 m ³)
g	gallons (Imperial or US)
ft ³	cubic feet
CCF	100 cubic feet
AF	acre-foot
Time	
s	second
h	hour
d	day
wk	week
yr	year
Pressure	
m	metre
bar	bar
kPa	kilopascal
p	pounds
psi	pounds/inch ²
Other	
c	capita (person)
conn	connection
prop	property
hd	household

Notes: There should be no space between the number and the unit, e.g. 7h, 6m, 2wk.
There should be no "s" after the abbreviation when greater than 1, e.g. 7h, 6m, 2wk.
Use "/" for "per", e.g. MI/d, l/c/d, h/d.

Standard Abbreviations for Pipe Materials

Generic	Abbreviation	Specific	Abbreviation	Normal Application
Cast iron	CI	Vertically cast		Mains
		Spun		Mains
		Cement Mortar Lined	CICL	Mains
Ductile iron	DI	Cement Mortar Lined	DICL	Mains
Steel	ST			Mains
Polyvinyl chloride	PVC	Unplasticised	uPVC	Mains
		Modified	mPVC	Mains
		Molecularly orientated	moPVC	Mains
Asbestos cement	AC			Mains
Glass reinforced plastic	GRP	Chopped fibre		Mains
		Filament wound		Mains
Polyethylene	PE	Medium density	MDPE	Mains and services
		High density	HDPE	Mains and services
		Polyethylene terephthalate	PET	Service relining
Lead	Pb			Services
Copper	Cu			Services
Galvanised iron	GI			Services

WATER RESOURCES

Potable Water

Potable water is water that is “safe” for human consumption, usually following treatment and disinfection. Different countries will have different standards for water for human consumption, for example the WHO and EU standards.

NON-potable Water

Non-potable water is water that has not been treated or disinfected in order to make it “safe” for human consumption (see [potable water](#)).

Raw Water

Raw water is water abstracted for human consumption but prior to being treated to make it “safe” for human consumption (see [non-potable water](#), [potable water](#))

Yield of Water Resource System

The yield of a water resource system is the rate at which water can be put into [supply](#) and that can be sustained through a [drought](#) of the design severity. The design severity may be an occurrence once in every 100 years, once in every 50 years, the worst historic or another severity determined by regulators or the operator.

Deployable Output

The deployable output of a water resource system is the water that can be supplied by the system taking into account any constraint on the available [yield](#) due to limitations in treatment capacity, transfer or transmission capacity.

Available Supply

The available supply is the total of the [deployable output](#) from all the sources within a [water resource zone](#) taking into account planned [outages](#) that might be expected.

Outage

Outage is the loss of [available supply](#) when a piece of plant, such as a borehole pump, treatment works, [service reservoir](#) or distribution pump for example, is not available for use. Outage could be caused by external factors such as interruptions to electrical supply, chemical availability etc. or may be due to internal decisions such as planned maintenance or when plant is unavailable due to unforeseen circumstances such as mechanical failure. Outage can have a severe impact on [available supply](#) and hence [reliability of supply](#) (see [headroom](#)).

Demand

Demand is the total of [consumption](#) and [real losses](#).

Water Resource Zone (WRZ)

A [water resource zone](#) is an interconnected area of [supply](#), often with multiple sources, where all customers have the [same reliability of supply](#). The [ELL](#) should be evaluated at the WRZ level.

Water Supply Zone (WSZ)

A [water supply zone](#) is the area where all the customers in that zone are receiving water supplied from a single source or combination of sources. It is usually defined for water quality monitoring purposes.

Supply Reliability

Supply reliability is defined as the ability of a utility to provide a consistent [supply](#) of water at the required time. The level of supply reliability can be assessed using [headroom](#).

Headroom

Headroom is the difference between [available supplies](#) and [demand](#) within a [water resource zone](#). There will be a design headroom for a [WRZ](#) taking into account the likely short-term rise in [demand](#) during a drought, possible [drought restrictions](#) to limit or mitigate [demand](#), the type of [water supply system](#) and actions that could be taken in the event of a drought in order to enhance/sustain supplies. The balance between actual headroom and design headroom defines the supply reliability.

Water Supply Coverage

Water supply coverage delineates the area and properties that are connected to the [water supply system](#). In an area where only part of the population is served this refers to the ratio between the supplied population and total population in the administrative area of the utility. The area supplied is referred to as the Water Operational Area.

Water Supply Network

A water supply network is a collection of assets, such as impounding reservoirs, boreholes, treatment works, aqueducts and any necessary associated pumps and pumping station delivering raw water to the treatment works for purification. It usually includes the treated water assets down to and including the [service reservoirs](#) prior to the [water distribution network](#). This would include trunk mains and possibly pumping stations. Although the demarcation between supply network and [distribution network](#) is often used within utilities for organisational purposes, the water supply network can be considered to include the [water distribution network](#) that delivers water to customers from a logistical point of view.

Water Distribution Network

A water distribution network is a collection of assets, primarily mains and service pipes but may include booster pumping stations, which deliver water from a [water supply network](#) to customer premises.

Network Hierarchy

The network hierarchy defines the different levels from [sub-DMA](#) through [DMAs](#) and [zones](#) within a water supply network and their association all the way up to the utility as a whole. It is essential for the reporting of key parameters, such as leakage, at different levels within the utility. It is a fundamental component of a [leakage management system](#).

Drought

A drought is a prolonged period of low rainfall that places [supply reliability](#) at risk.

Drought Restrictions

Drought restrictions are actions that can be taken by a utility, following the necessary legal approval, to restrict normal legitimate use by customers during a [drought](#). An example of a drought restriction would be, for example, a hosepipe ban for garden watering.

Supply

Supply is the provision of potable water into the [water distribution network](#) for [consumption](#) by customers.

Rotational Supply

A system with regular [intermittent water supply](#) such that there is a relatively consistent pattern as to when [supply](#) is available. See also [rotational supply designation](#).

Rotational Supply Designation

In systems with [rotational supply](#), namely a consistent pattern of when [supply](#) is available, it is often useful to describe the availability pattern of [supply](#) in the form of hours per day and days per week, i.e. $h/d \times d/wk$. Thus, a pattern of supply of 8 hours per day every day would have the designation of 8×7 and a system with 24-hour supply for 2 days a week would

have the designation 24×2. This pattern is therefore aligned with the common use of 24×7 to designate customer service that is available at all times.

Supply Time (ST)

The average period per day that the system is pressurised in [intermittent water supply](#) situations. A system is defined as being pressurised when there is sufficient [pressure](#) in the system to maintain [supply](#) to customers. The figure is used in the calculation of [performance indicators](#) (ILI, l/conn/d, m³/km/d) to ensure that the [PI](#) reflects the fact that the system may not be pressurised for the full day and therefore [leakage](#) will appear lower if the time that the system is pressurised is not taken into account. [Supply time](#) can be calculated from the [rotational supply designation](#) as $(h/d \times d/wk)/7$. Thus, a system which is pressurised for 4 hours a day, 3 days a week has a [supply time](#) of $(4 \times 3)/7 = 1.7$ h/d.

Intermittent Water Supply (IWS)

[Intermittent water supply](#) is a course of action where the [supply](#) to parts of a [water resource zone](#) is cut off, usually in rotation, with the intention of preserving limited resources. This is an action that would be considered where the actual [headroom](#) is significantly less than the design [headroom](#). Intermittent supply is not always managed and may occur when the [service reservoir](#) runs empty. The extent of IWS will depend on the degree of this deficit. IWS usually takes the form of rotating [supply](#) to different areas so that the restriction is suffered by all customers, though it is common to arrange for [supply](#) to critical customers, such as hospitals, to be maintained at all times. It is also frequent for areas to be shut off entirely. The repeated emptying and filling of the system causes severe problems with [bursts](#) and thus leakage, due to [pressure fluctuations](#) every time the system is recharged. Thus, the action can be, to a certain extent, self-defeating. It is recommended that complete shut off is avoided if possible and that a minimum [pressure](#) is maintained in the system. It is recommended by the IWA Water Loss Specialist Group (WLSG) that all possible methods of reducing leakage and controlling demand are employed so that continuous [supply](#) is maintained and IWS avoided. See also [rotational supplies](#) and [rotational supply designation](#).

DISTRIBUTION NETWORK ASSETS

Aqueduct

An aqueduct is a generic term for a system for transferring water. It has a very wide definition, often being used to describe the conduit for transferring [non-potable water](#) from source to treatment works but occasionally it may be used for the conduit transferring [potable water](#) to a conurbation. It may be in the form of an open or closed conduit, channels, tunnel sections, multiple pipe sections, etc.

Transmission Main

A transmission main is used for the transfer of potable water between treatment works and [service reservoirs](#) or between [service reservoirs](#). It is normal practice for utilities to avoid supplying water to customers from transmission mains unless there are particular circumstances or reasons for doing so. Transmission mains are referred to as trunk mains in the UK and as primary mains in some countries.

Service Reservoir (SR)

A [service reservoir](#) is a structure that holds water and is usually located at the edges of towns or within towns and defines the start of the [water distribution network](#). A [service reservoir](#) is fed by a [transmission main](#) and will feed distribution [mains](#) or possibly a [transmission main](#) to another [service reservoir](#). The main functions of a [service reservoir](#) are to provide the necessary head so that water can be supplied to customers within the supply area by gravity, to even out the [diurnal demand pattern](#) in order to minimise the maximum capacity needed at treatment works and [transmission mains](#) and also to provide emergency capacity to improve security of [supply](#) to the [distribution network](#) in the case of failure at the treatment works or a [burst](#) on the [transmission main](#). Smaller [service reservoirs](#) are sometimes referred to as tanks. See [Figure 1](#).

Main

A water main or distribution main is a pipe used for the “general” [supply](#) of water, usually supplying several properties and being within the reticulation of the network. A utility can be requisitioned to allow a connection for domestic purposes from a water main and be reimbursed for the cost. It may become difficult to decide the demarcation as to whether a pipe is a

1 Partly above/partly below ground



2 Above Ground



3 Water tower



4 Water tower



5 Water Tower



Figure 1 Typical [service reservoirs](#) (Sources: K Atkinson (1, 2, 3, 5) and D Pearson (4)).

main or a [service pipe](#) at the very end of a rural network. Sometimes referred to as a water main, distribution main or secondary main (as opposed to trunk main).

Edge of Street (EoS)

The boundary of the street in which a main is laid.

Service Pipe

A service pipe is the section of pipe which connects a water main with a building. It includes both the [service connection](#) and [private service pipe](#), see [Figure 4](#).

Service Connection

That part of the [service pipe](#) that runs from the [main](#) to the [edge of street](#), see [Figure 4](#). There will usually be an [external stop tap](#), and possibly a [revenue meter](#), at the demarcation between the service connection and the [private service pipe](#).

The service connection may run up to the building wall itself if this is at the [edge of the street](#), see [Figure 5](#). In this case the [external stop tap](#), and possible [revenue meter](#), may be above or below ground or may be just inside the building itself.

A service connection may supply one (see [Figure 4](#)) or more than one [property](#) (see [Figure 5](#)). This generally applies in organised systems or developed countries and is the ideal arrangement, but may however be less well defined in some other countries.

The service connection is owned by the utility and the maintenance of it is their responsibility. The service connection is referred to as a communication pipe in the UK.

Shared Connection

A [service connection](#) that supplies more than one [property](#), see [Figure 5](#).

Short-side Connection

A [service connection](#) from a [main](#) taken to premises that are on the same side of the road as the main, see [Figures 1.4 and 1.5](#).

Long-side Connection

A [service connection](#) from a [main](#) taken to premises that are on the other side of the road to the main, see [Figures 1.4 and 1.5](#).

Private Service Pipe

The private service pipe is the pipe that runs from the street boundary where the [main](#) is laid, to the internal [stop tap](#) in a property or [supply](#) location, see [Figure 2](#). This pipe may often be laid underground and referred to as the underground private service




Figure 2 Diagram of a service connection Case 1 (Source: D Pearson).




Figure 3 Diagram of a service connection Case 2 (Source: D Pearson).




Figure 4 Diagram illustrating separate connection of properties to a water main (Source: D Pearson).

pipe, but can also be above ground, such as in a block of flats, see Figure 6. The supply pipe is owned by the owner of the property and maintenance is their responsibility. The private service pipe is referred to as a supply pipe in the UK.

The service connection is owned by the utility and the maintenance of it is their responsibility. A service connection may supply more than one private service pipe, see Figures 1.2 and 1.3. Referred to as a communication pipe in the UK.

Common Private Service Pipe

A private service pipe that feeds more than one customer, see Figure 6.




Figure 5 Diagram illustrating a shared connection to two properties (Source: D Pearson).




Figure 6 Diagram to show the private supply pipe arrangement for blocks of flats (Source: D Pearson).

Private Service Pipe

The length, in a utility or zone, of the **private service pipes** between the **external stop tap** and the **point of supply**. It is used in the calculation of **UARL** and **UBL**. The private supply pipe length for different supply arrangements is shown in the relevant diagrams (Figures 1.2–1.7). Care has to be taken in the estimation of private service pipe length when the properties are internally or externally metered (Figure 4 and Figure 5) and in the case of flats (Figure 6) or multiple properties (see Figure 7).




Figure 7 Diagram showing a common private service pipe (Source: D Pearson).

Connection

A connection is where a [service pipe](#) is connected to a [main](#) by a [tapping point](#). A connection can be either [legal](#) or [illegal](#).

Legal Connection

A [connection](#) which has been installed onto a [main](#) or another [service pipe](#) by or with the permission and authority of the utility.

Illegal Connection

A [connection](#) which has been installed onto a [main](#) or another [service pipe](#) without the permission or authority of the utility.

Connection Density

The ratio of the number of connections per unit length of [main](#), i.e. no/km. Utilities do not generally know the number of [connections](#) on their system and therefore it is more common for them to express connection density in the form of connected properties or customers per unit length of main. This can however distort the value depending on the [connection ratio](#) and it is best to make it clear whether connection or [property density](#) is being used.

Connection Ratio

The ratio of [connections](#) to the number of [properties](#) or billed premises in an area of [supply](#), such as a [WRZ](#), [DMA](#) or other zone. The connection ratio will have a value from 0 to 100% and will be dependent on the predominant supply arrangement. For example, the supply arrangement in the case of separate connections ([Figure 2](#)) would have a connection ratio of 1 or 100% whilst the supply arrangement in the case of shared services ([Figure 3](#)) would have a connection ratio of 0.6 or 60%. The connection ratio in the case of common private service pipes ([Figure 6](#)) or a block of flats ([Figure 7](#)) will only be a few percent.

Active Property

A [property](#) that is occupied, either continuously or occasionally, and which therefore could have [consumption](#). A second home would be classed as active, as it will have consumption even if only occasionally.

Inactive Property

A [property](#) which is vacant and therefore has no [consumption](#). Sometimes referred to as a void property.

Property

The definition of property can be complicated in practice. For the purposes of [leakage management](#), it is easier to obtain the count of billed accounts from the [customer billing system](#) and it is therefore sensible to use a definition that reflects this, i.e. a property is synonymous with a billed account; be that a house, flat, industrial premise or commercial unit.

Property Density

The ratio of the number of billed properties (i.e. customers) per unit length of main, i.e. no/km.

Occupancy

Occupancy is the estimated population in an area (e.g. [DMA](#), [zone](#) etc.) divided by the number of domestic properties (billed accounts) in the same area. The estimated population can be difficult to obtain but some countries have good quality census data. The billed accounts are obtained from a mapping of the area boundary between the [GIS](#) and the [customer billing system](#).

Step Valve

A [sluice valve](#) used to shut off a step in a [step test](#).

Circulating Valve

A [sluice valve](#) used to isolate sections of a [DMA](#) in order to create steps for a [step test](#).

Boundary Valve

A [sluice valve](#) which is shut in order to create the boundary of a [zone](#), [PMA](#) or [DMA](#).

Meter Box

The piece of furniture located at the property boundary that usually contains a [revenue meter](#) and [external stop tap](#), see [Figure 8](#). Sometimes referred to as a boundary box.




Figure 8 Typical external meter box and Installation (Sources: Plasson (1), J Parker (2), Mueller Water Products Inc. (3)).

Stop Tap Chamber

The piece of furniture located at the property boundary that provides access to the [external stop tap](#), in countries where the [external stop tap](#) is located below ground and where the property is not externally [metered](#), see [Figure 9](#). It is often



Figure 9 Typical external stop tap chambers (Sources: Plasson (1), Mueller Water Products Inc. (2)).

constructed of concrete segments or plastic ducting. Alternatively, it may be an integral part of the stop tap that brings a telescopic spindle up to the surface thereby avoiding the risk of the chamber filling with water and debris. Sometimes referred to as a stop tap box.

External Stop Tap

A stop tap that is at or close to the street boundary. This stop tap is owned by the water utility and maintenance is their responsibility. In some countries the water utility meter and associated stop tap must be within 1 metre of the first draw off from a service, hence their location inside the property. Additionally, in some countries, a separate water utility stop tap is not used, with the cock on the [tapping point](#) being used to isolate the main. Sometimes referred to as a stop cock. In the United States, this is referred to as a curb stop.

Internal Stop Tap

A stop tap that is adjacent to the outside wall of a [property](#) or immediately inside the [property](#). This is owned by the owner of the property and maintenance is their responsibility.

Stop Tap

A stop tap or stop valve (see [Figure 10](#)) is used to regulate or control the flow of water from a [main](#) into and within both residential and commercial buildings. Sometimes referred to as a stop valve.



Figure 10 Typical external stop taps (Sources: Plasson (1, 2, 3) and Mueller Water Products Inc (4)).

Tapping

Tapping is the process of drilling through the pipe wall of a water [main](#) to provide a means of connection to the main. This could be a small diameter tapping (~20 mm) for a [service connection](#) ([tapping point](#)) or it may be a larger diameter (~60 mm) for the purpose of installing an [insertion meter](#), see [Figure 11](#).

Tapping Point

Tapping Point is the generic name for the [connection](#) from the [main](#) to the [service connection](#). It can be either a [ferrule](#) or a [tapping tee](#).

Tapping Tee

A tapping tee is the name for the [connection](#) from the [main](#) to the [service connection](#) in the case of PVC or PE [mains](#). It is normal to have some form of saddle which is either fixed mechanically or welded to the main in order to provide support to the connection. The fitting usually contains its own cutter (self-tapper) which is wound down to drill through the plastic pipe to make the connection. The fitting may well contain a [ferrule](#) so that the supply can be turned on or off once the main has been tapped, see [Figure 12](#).

1 Demo with gauging probe



2 Installation on pipe

**Figure 11** Typical large diameter tapping (Source: K Atkinson (1, 2)).

1



2



3 Installation

**Figure 12** Typical tapping tees and installation (Sources: Aliaxis UK (1), Mueller Water Products Inc. (2), J Parker(3)).

Ferrule

A ferrule is the [connection](#) from the [main](#) to the [service pipe](#) in the case of a metallic pipe. They are usually made from brass and are tapered, see [Figure 13](#). The main is drilled and the ferrule is then tapped into the [main](#). Some ferrules may include a valve so that the [supply](#) can be shut off at the [main](#). In such cases, they are referred to as ferrule cocks or corporation stop cocks.

**Figure 13** Typical ferrule and installation (Sources: Mueller Water products Inc. (1), K Atkinson (2)).

Appurtenances

A generic term to describe apparatus that is attached to **mains**. This includes **sluice valves**, **hydrants**, **air valves** and **PRVs**.

Fittings

A generic term to describe tees, bends and couplings etc. on **mains**.

Wash Out (WO)

A **wash out** is either a **sluice valve** or a **hydrant** which has been provided by the utility, usually but not necessarily at dead ends, for the purpose of **flushing** or emptying the **network**.

Fire Hydrant (FH)

A **fire hydrant**, sometimes called a fireplug, is a **hydrant** by which **firefighters** can gain access to a **supply** of water. It may be paid for by the fire brigade and is normally also maintained by them. It is normally designated and labelled FH.

Hydrant

A hydrant is a fitting positioned on a **main** or on a short branch to the side of the **main** from which water can be discharged. There are two prime purposes for a hydrant, namely, **firefighting** and **mains flushing**. If a hydrant is provided by the utility for the purposes of **mains flushing** it is normally designated and labelled **WO**. A hydrant can be above ground, as depicted in the following illustrations, see **Figure 14**. A hydrant provides access to the **main** which can be useful for the purposes of measuring **pressure**, **correlating** a leak using a **hydrophone**, access for **intrusive leak detection** equipment or internal inspection of **pipe condition**.

1 Above ground



2 Below ground (sectioned)



3 Below ground (sectioned)



Figure 14 Typical hydrants (Sources: Mueller Water Products Inc. (1), K Atkinson (2, 3)).

Air Valve (AV)

An **air valve** is a valve designed to allow air, that may have accumulated at high points in a water **main**, to be expelled or allow air into the main when these are drained for maintenance or repair. They may also be installed at other strategic points, other than at the highest point on a main, see **Figure 15**.

Sluice Valve (SV)

A sluice or gate valve is a valve which opens by lifting an internal gate or wedge allowing water to pass through and when in the closed position prevents water from passing, see **Figure 16**. They are located on the network by the utility for the purposes of isolating or separating lengths of pipe for maintenance or repair of **leaks**, other interventions such as **step tests** or for the creation

of [district metered areas](#) or [waste areas](#). Large diameter (~350 mm) [sluice valves](#) can be fitted with a small bypass valve to equalise pressures across the valve before attempts are made to open the principal valve. Also referred to as a gate valve.



Figure 15 Typical [air valves](#) (sections) (Source: Mueller Water Products Inc.).



Figure 16 Typical [sluice valves](#) (Sources: Mueller Water Products Inc. (1, 2), K Atkinson (3, 4)).

Butterfly Valve

A butterfly valve is a valve that is operated with a disc turning through 90 degrees to allow or to stop the flow of water, see [Figure 17](#). It is generally fitted on larger diameter mains where a [sluice valve](#) would be too large such that it might be close to or above ground level. Butterfly valves can be fitted with a small bypass valve to equalise pressures across the valve before attempts are made to open the principal valve.

Pressure Control Valve

The generic family of control valves that operate on the basis of pressure within the water supply or water distribution network. These include [pressure reducing valves](#), [pressure sustaining valves](#), pressure relief valves and [altitude control valves](#).

Altitude Control Valve

A type of [pressure control valve](#) that is controlled by the absolute pressure at a location on the network. They are used to control the filling of [service reservoirs](#).



Figure 17 Typical butterfly valves and installation (Sources: Mueller Water Products Inc. (1), K Atkinson (2, 3)).

Pressure Sustaining Valve (PSV)

A type of [pressure control valve](#) that is used to ensure that the pressure at a point in the network is sustained.

Pressure Reducing Valve (PRV)

A [pressure reducing valve](#) is a control valve that reduces the pressure of water to a desired value at its outlet as it passes through, see [Figure 18](#). They are sometimes referred to as [pressure management](#) valves. [Pressure reducing valves](#) are a specific application within the more generic family of [pressure control valves](#).



Figure 18 Typical PRV and installation (Sources: Mueller Water Products Inc. (1), K Atkinson (2, 3))

Pressure Relief Valve

A pressure relief valve is a control valve that relieves the pressure of water to a desired value by allowing the water to be discharged from the network.

FLOW METERING

Volumetric Meter

A volumetric meter is an instrument which measures either directly or indirectly, the volume, as opposed to the mass, of water passing through the instrument. Many volumetric meters actually measure the velocity of flow rather than directly measuring the volumetric flow rate. A [positive displacement meter](#) is an example of a direct volumetric meter and a [turbine meter](#) is an example of an indirect volumetric meter.

Positive Displacement Meter

A positive displacement meter uses a fixed volume chamber, or chambers, which is filled with water when it passes through the meter. The meter estimates the [flow](#) by counting the number of chambers that are filled in a given time period. It is a type of [volumetric meter](#) that directly measures the volumetric flow rate.

Turbine Meter

A turbine meter uses a turbine to measure the speed of water flowing through the meter. The meter can have single or multiple jets driving the turbine. The volume is estimated from the velocity using the cross section of the meter. It is a type of [volumetric meter](#) that indirectly measures the flow rate.

Electromagnetic Meter (EM)

An [electromagnetic meter](#) is a meter that uses the principle of Faraday's Law to estimate the velocity of water passing through the meter. A current is generated as the water flows through an electromagnetic field with the current being proportional to the velocity of the water. The volume is estimated from the velocity using the cross section of the meter.

Ultrasonic Meter

An ultrasonic meter uses the principle of the Doppler effect or transit time to estimate the velocity of water flowing through the meter. The meter has transmitters that emit ultrasound both with and against the direction of flow. For a Doppler ultrasonic meter, the velocity of flow is proportional to the difference in the amplitude of the sound received by sensors after passing through the water. For a transit time ultrasonic meter, the velocity of flow is proportional to the difference in travel time between the two signals. Ultrasonic meters are available as either a fixed [full-bore meter](#) inserted into the pipeline or as a meter strapped on or bolted around the outside of the existing pipe. This could be a permanent or temporary arrangement.

Full-bore Meter

A full-bore meter is a meter where the full flow passes through the meter. The installation therefore involves replacing a whole section of the pipe by the meter. They can be used on [mains](#) and [service pipes](#). Installation costs can be high on existing large diameter mains.

Insertion Meter

An insertion meter is a meter that can be inserted into an existing pipe through a tapping on the top of the pipe, see [Figure 19](#). It is used on larger diameter [mains](#) and not [service pipes](#). The tapping and meter insertion can be made under pressure and therefore there is no disruption to [supply](#) to customers and costs are minimised. This type of meter can therefore cost significantly less than a [full-bore meter](#) for the same diameter [main](#). On very large diameter [mains](#), a multi-point insertion probe with more than one velocity sensor can be used. The velocity sensor, which is located on the insertion probe, may be a [turbine meter](#), an [electro-magnetic](#) or an [ultrasonic meter](#). The accuracy of an insertion meter is less than that of a [full-bore meter](#) because it is necessary to allow for the velocity profile across the [main](#) either by sampling at different depths, using a standard depth, or by integrating the velocities from multiple sensors.

1 Turbine insertion probe



2 Probe and loggers



Figure 19 Typical insertion probes (Source: D Pearson (1, 2)).

Meter Calibration

Over time, meter performance can drift away from the manufacturer's original calibration. Meter calibration is the process of checking that a meter's calibration coefficients are as defined by the manufacturer when the meter was supplied. A good earth connection is also critical for all electronic meters and therefore should be checked during the calibration process.

Meter Verification

Even though a meter may be [calibrated](#) correctly, it may not measure flows accurately because of the installation arrangement. Meter accuracy is very susceptible to poor installation, for example, incorrect orientation, or being located too close to bends, pumps or other installations which may affect the water flow. Meter performance should therefore be verified on a regular (say ~1–3 years) basis. This could simply be by comparing the measured flow to flows measured at other meters either upstream or downstream. Where this verification indicates that there may be problems, then more sophisticated verification should be undertaken. This could involve installation of multiple [insertion probes](#) near the meter, using a temporary external strap-on [ultrasonic](#) meter or checking the volume registered through the meter against that registered in a [service reservoir](#) supplied or emptied solely via the meter.

Flow

Flow is the rate at which water passes a particular point in the network. Units of flow are typically L/s, m³/h, gal/min.

Flow Meter

A flow meter is a device for measuring the flow of water at a point in a system. It may be a meter installed to aid management of a [water supply network](#) or [water distribution network](#) or it may be a [revenue meter](#).

Flow Logger

An electronic device that can store the readings from a [flow meter](#), for later interrogation or uploading to a central computer system or cloud based application, such as a [leakage management system](#). The [flow](#) that is recorded will be the average flow registered on the [flow meter](#) over the relevant time period, often 15 minutes but can be some other time period.

Pulse Unit

An electronic device that is attached to a [flow meter](#) and converts the output of the meter into an electronic output that can be recorded on a [flow logger](#).

Abstraction Meter

A [meter](#) that measures the volume of [raw water](#) abstracted from a source, such as a borehole, river intake or sea water intake.

Production Meter

A [meter](#) that measures the volume of potable water put into supply at a treatment works or desalination plant.

Distribution Input Meter

A [meter](#) that measures the flow that defines the input into the [water supply network](#) of a utility. It will normally be a [production meter](#) but may be a [meter](#) measuring any imports to or exports from the utility.

DMA Meter

A [meter](#) that measures the flow into or out of a [DMA](#).

Bulk Meter

A bulk meter is any [meter](#) on the [water supply network](#) or [water distribution network](#) that is not a [revenue meter](#).

Non-revenue Meter

Any meter that is not a [revenue meter](#), for example a [DMA meter](#), [bulk meter](#), or [production meter](#).

Revenue Meter

A revenue meter is a [meter](#) that is used for the purpose of billing [consumption](#) to [properties](#), be that for domestic, commercial, municipal or industrial purposes. It will invariably be a [full-bore meter](#) on a [service pipe](#).

Meter Reading Lag

Manual [revenue meters](#) are often read on a regular cycle. Reading cycles may be monthly or may be read at much less frequent intervals. For example, in the UK, domestic customer meters are only read once every six months. This means that the water [supplied](#) and water [consumed](#) figures can be out of phase, a phenomenon referred to as meter lag. The longer the meter reading cycle the higher will be the potential impact of the meter reading lag. The impact of meter reading lag is more significant during periods of fluctuations in [demand](#) such as short-term weather-related [demand](#) or when [drought restrictions](#) are introduced. The use of rolling 12-month average rather than spot monthly [top down leakage](#) will reduce, but may not entirely remove, the impact of meter lag.

Automatic Meter Reading (AMR)

[Automatic meter reading](#) is the technology of automatically collecting consumption, diagnostic and status data from [revenue meters](#) and transferring that data to a [customer billing system](#) for billing, troubleshooting and analysis. In general, AMR is used to describe the process where [revenue meter](#) data is downloaded automatically replicating the normal billing cycle, possibly on a more frequently basis, for example, volumes every day, week, month or quarter.

Advanced Metering Infrastructure (AMI)

[Advanced metering infrastructure](#) is the collective term to describe the whole infrastructure from true smart meters to two-way communication networks to control centre equipment and all the applications that enable the gathering and transfer of water usage information in near real-time.

Smart Meter

In strict terms, a meter is considered to be smart if it can be controlled by a network operator, allowing for example, [consumption](#) to be controlled in periods of high [demand](#). In practice the word smart is commonly used for meters without this control function, but where 15-minute (or more frequent) data can be remotely collected. Because of the immediacy and frequency of data collection, Smart meters are more useful to support [leakage management](#) than [AMR meters](#).

IWA STANDARD WATER BALANCE

The IWA Water Loss Specialist Group has developed a standard water balance, see [Figure 20](#), and standardised terminology and definitions for the components of the water balance. In order to ensure consistency of assessment and reporting of losses, it is paramount that this water balance and respective definitions of the components are adhered to when undertaking any form of water loss study, auditing or reporting.

System Input Volume

The system input volume is the volume of treated water, be that produced by the utility themselves or imported into the area from another utility, input to the section of the [water supply system](#) to which the water balance calculation relates. It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Authorised Consumption

The volume of metered and/or unmetered water taken by registered customers, the water supplier and others who are implicitly or explicitly authorised to do so by the water supplier, for residential, commercial, municipal and industrial purposes. This also includes water used by the military, government and other users, even if these are provided free of charge. It also includes water exported across the utility's boundaries.

Authorised consumption may include items such as water taken for firefighting, fire training exercises, flushing of mains and sewers, street cleaning, watering of municipal gardens, public fountains and frost protection, amongst others. These may be billed or unbilled, metered or unmetered. It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

System Input Volume (allow for known errors)	Authorised Consumption	Billed Authorised Consumption	Billed metered consumption	Revenue Water
			Billed unmetered consumption	
		Unbilled Authorised Consumption	Unbilled metered consumption	Non-Revenue Water
			Unbilled unmetered consumption	
	Water Loss	Apparent Losses	Unauthorised consumption	
			Data handling and billing errors	
			Underestimation of unmeasured consumption	
			Customer metering inaccuracies	
		Real Losses	Leakage on transmission and distribution mains	
			Leakage and overflows at utility's storage tanks	
			Leakage on service connections up to the point of customer metering	

Figure 20 The IWA Standard Water Balance (Source: IWA).

Revenue Water

The volume of water for which income is obtained. It is the sum of [billed authorised consumption](#) including [water exported](#) across the utility's boundaries for which income is received. It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Billed Authorised Consumption

Those components of [authorised consumption](#) which are billed and produce revenue. It is equal to [billed metered consumption](#) plus [billed unmetered consumption](#) and also known as revenue water. It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Billed Metered Consumption

All metered consumption which is also billed. This encompasses all groups of customers such as domestic, commercial, industrial or institutional and includes [water exported](#) across the utility's boundaries which is metered and billed. It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Billed Unmetered Consumption

All billed consumption which is calculated based on estimates or norms but is not metered. This may be a very small component within fully metered systems, for example, billing based on estimates for the period a customer meter is out of order but can be the key consumption component in systems without universal metering. This component may also include [water exported](#) across the utility's boundaries which is unmetered but billed. It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Unbilled Authorised Consumption

Unbilled authorised consumption are those components of [authorised consumption](#) which comprise legitimate usage, but which are not billed and therefore do not produce revenue. Unbilled authorised consumption is equal to [unbilled metered consumption](#) plus [unbilled unmetered consumption](#). It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Unbilled Metered Consumption

Unbilled metered consumption is metered consumption which is, for any reason, unbilled. This may, for example, include metered consumption by the utility itself or water provided to institutions free of charge, including any [water exported](#) across the utility's boundaries which is metered but unbilled. It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Unbilled Unmetered Consumption

Unbilled unmetered consumption is any kind of [authorised consumption](#), including any [water exported](#) across the utility's boundaries, which is neither billed nor metered. This component typically includes items such as firefighting, flushing of mains and sewers, street cleaning or frost protection, amongst others. In a well-run utility, it is a small component of total [authorised consumption](#). It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Non-Revenue Water (NRW)

[Non-revenue water](#) are those components of [system input volume](#) which are not billed and do not produce revenue, i.e. not [revenue water](#). It is equal to [unbilled authorised consumption](#) plus [real losses](#) and [apparent losses](#). It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Unaccounted for Water (UFW)

The term [unaccounted for water](#) (UFW) was commonly used in the past, but because of the widely varying interpretations and definitions of the term, it is strongly recommended, by the IWA WLSG, that this term no longer be used.

Water Losses

The difference between [system input volume](#) and [authorised consumption](#). Water losses can be considered as a total volume for the whole system, for partial systems such as transmission or distribution schemes, or individual zones. Water losses consist of [real losses](#) and [apparent losses](#). It is a component in the [IWA Standard Water Balance](#), see [Figure 20](#).

Non-technical Losses

This is a term used in some countries for [apparent losses](#). However, it is a confusing and misleading term since many of the issues relating to [apparent losses](#) are in fact technical. The IWA WLSG therefore recommends that this term is no longer used.

Apparent Losses (AL)

[Apparent losses](#) include all types of inaccuracies associated with customer metering as well as data handling errors, such as meter reading and billing, plus [unauthorised consumption](#) from theft or illegal use. It is a component of water losses in the [IWA Standard Water Balance](#), see [Figure 20](#). [Apparent losses](#) are often referred to as commercial losses in low- and middle-income countries and by development banks.

Unauthorised Consumption

Unauthorised consumption is any unauthorised use of water. This may include water illegally withdrawn from hydrants, for example, for unauthorised construction purposes, illegal connections, bypasses to consumption meters or meter tampering. It is a component of [apparent losses](#) in the [IWA Standard Water Balance](#), see [Figure 20](#).

Data Handling and Billing Errors

The volume of true consumption which is not recorded on the billing system due to billing or data handling errors. These could include transcription errors, consumption on premises that have not been registered on the billing system due to internal procedural errors, premises incorrectly flagged on the billing system (e.g. flagged as demolished but still live), etc. It is a component of [apparent losses](#) in the [IWA Standard Water Balance](#), see [Figure 20](#).

Underestimation of Unmeasured Consumption

The volume by which the true consumption of unmeasured customers is underestimated. This may be household or non-household use. This will be a particular problem where unmeasured consumption is high, for example in countries where domestic premises are not metered, or where there are unmeasured communal water supplies in improvised housing areas. In practice true consumption may be overestimated in which case [apparent losses](#) (and possibly [real losses](#)) could be understated. It is a component of [apparent losses](#) in the [IWA Standard Water Balance](#), see [Figure 20](#).

Customer Metering Inaccuracies

The volume by which meters under-record the true volume consumed by customers. The level of customer metering inaccuracy depends on meter type, meter class, meter sizing (in relation to the flow), meter age, installation details (e.g. close to bends, near

pumps etc.) and the size of roof tanks, if the meter feeds roof tanks. The actual in-situ performance is assessed as [meter under registration](#). It is a component of [apparent losses](#) in the [IWA Standard Water Balance](#), see [Figure 20](#).

Technical Losses

This is a term used in some countries for [real losses](#). However, it is a confusing and misleading term since many of the issues relating to [apparent losses](#) are also technical. The IWA WLSG therefore recommend that this term is no longer used.

Real Losses (RL)

Real Losses from the pressurised system ([transmission mains](#), [mains and service pipes](#)) and the utility's [service reservoirs](#), from the [distribution input meters](#) up to the [point of supply](#). It is a component of water losses in the [IWA Standard Water Balance](#), see [Figure 20](#). [Real losses](#) are often referred to as physical losses in low- and middle-income countries and by development banks.

Leakage and Overflows from Utility Storage Tanks

Water lost from leaking storage tank structures ([service reservoirs](#)) or overflows from such tanks caused by operational or technical problems, for example, a failed level control mechanism or leaking tank joints. It is a component of [real losses](#) in the [IWA Standard Water Balance](#), see [Figure 20](#).

Leakage on Service Connections up to the Point of Customer Metering

Water lost from leaks and breaks of [service pipes](#) from and including the [tapping point](#) up to the [point of supply](#). Leakage on service [pipes](#) may be [reported breaks](#) but will predominately be small [unreported leaks](#) which may run for long periods, often years. They may be leaks that are below the level of detection and therefore contribute to [background leakage](#). It is a component of [real losses](#) in the [IWA Standard Water Balance](#), see [Figure 20](#).

Leakage on Transmission and/or Distribution Mains

Water lost from leaks and breaks on transmission and distribution pipelines and [appurtenances](#). These may either be small leaks which are still unreported, such as leaking joints, or large bursts which were reported and repaired but obviously leaked for a certain period before that. It is a component of [real losses](#) in the [IWA Standard Water Balance](#), see [Figure 20](#).

Point of Supply

For an unmetered property, the point of supply is typically taken to be at the first point of use, usually the kitchen sink. However, for metered properties, the point of supply is taken to be the outlet of the [revenue meter](#); whether this is at the property line or within the building, see [Figure 4](#).

Plumbing Losses

Plumbing losses constitute the element of [consumption](#) which is not used within the premise. They are made up of losses such as dripping taps, overflowing cisterns or leaks on pipework downstream of the [point of supply](#). Plumbing losses will be included in the [consumption](#) if the premise is metered. Plumbing losses will be included in the [night flow](#) measured on a [DMA](#) or [waste area](#).

Consumption

Consumption is all water taken into premises, whether domestic, commercial, industrial or institutional among others, be that for use or because of [plumbing losses](#). When considering the [water balance](#) for a whole system, then consumption will include all consumption on premises together with water directly taken off the system, whether recorded, billed, unbilled, authorised or unauthorised, namely being the equivalent to [authorised consumption](#) plus [apparent losses](#), see [Figure 20](#).

Per Capita Consumption (PCC)

[Per capita consumption](#) is the average daily [consumption](#) per person in an area, be that a [DMA](#), [zone](#) or any other level in the [network hierarchy](#). If all the [properties](#) are [metered](#) then this value can be obtained from the [billing system](#) using the following equation:

$$PCC_{est} = \frac{\text{Measured Consumption on metered domestic properties}}{\text{Number of metered domestic properties} \times \text{occupancy}}$$

When domestic [properties](#) are not [metered](#) it is necessary to estimate PCC (or [PHC](#)) in order to provide an estimate of the unmeasured household consumption, which will be a significant component of [billed unmetered consumption](#), to be used in the [IWA Standard Water Balance](#). Estimation of PCC is usually carried out using a [small area monitor](#) or [individual household monitor](#) studies. It is critical that consumption does not include non-household consumption nor any [leakage](#) on the [mains](#) or [service connections](#). Typical units of PCC are l/c/d or gal/c/d.

Per Household Consumption (PHC)

[Per household consumption](#) is the average daily [consumption](#) per domestic [property](#) in an area, be that [DMA](#), [zone](#) or any other level in the [network hierarchy](#). If all the [properties](#) are [metered](#) then this value can be obtained from the [billing system](#) using the following equation:

$$PHC_{est} = \frac{\text{Measured Consumption on metered domestic properties}}{\text{Number of domestic properties}}$$

PHC is more reliable than [PCC](#) where [occupancy](#) rates are not known. When domestic [properties](#) are not metered it is necessary to estimate PHC (or [PCC](#)) in order to provide an estimate of the unmeasured household consumption which will be a significant component of [billed unmetered consumption](#), to be used in the [IWA Standard Water Balance](#) ([Figure 20](#)). Estimation of PHC is usually carried out using a [small area monitor](#) or [individual household monitor](#) studies. It is critical that consumption does not include non-household consumption nor any [leakage](#) on the [mains](#) or [service connections](#). Typical units of PHC are l/prop/d or gal/prop/d.

Small Area Monitor (SAM)

A [small area monitor](#) is used to estimate either [PCC](#) or [PHC](#) of unmeasured customers. Each SAM usually comprises approximately 50–100 domestic properties in order to reduce the risk of [leakage](#) on the [mains](#) or [service connections](#). Flows are monitored into the area and the [PCC](#) or [PHC](#) evaluated. A mix of property types and socio-economic groupings of occupants across the SAMs should be used in order to ensure a representative sample of the population as a whole.

Individual Household Monitor (IHM)

An [individual household monitor](#) is used to estimate either [PCC](#) or [PHC](#) of unmeasured customers. An IHM comprises a number of domestic properties (usually several hundred), distributed across the area being considered, where the customer is metered, either internally or externally, but is not charged on their consumption, with the hope of them not changing their water use. [Consumption](#) is monitored and the [PCC](#) or [PHC](#) evaluated. An IHM needs to include a mix of property types and socio-economic groupings of occupants in order to ensure a representative sample of the population as a whole.

Diurnal Demand Pattern

The term relates to the normal pattern of [demand](#) over a day which exhibits a distinct pattern of higher [consumption](#) during the day and significantly lower [consumption](#) at night, see [Figure 21](#).

LEAKAGE MANAGEMENT

Leakage management is the process of managing leakage from measurement, monitoring, prioritising detection and leakage detection itself. Strategic leakage management looks at establishing the optimum balance of activities, such as [pressure management](#) and leakage detection, to achieve targets or the necessary [headroom](#) in order to secure reliable supplies or avoid [intermittent supplies](#).

Leakage Control

Leakage control is the process of undertaking a series of activities to control the actual level of [leakage](#). The main activities that can be used to control leakage are: [active leakage control](#), [pressure management](#), effective and speedy [repairs](#) and [mains rehabilitation](#). These can be represented diagrammatically as acting on the level of leakage, see [Figure 22](#).

Leakage

Leakage is the loss of water from a water distribution system due to [leaks](#).




Figure 21 Typical diurnal demand pattern (Source: D Pearson).




Figure 22 The four primary methods of managing **real losses** (Source: D Pearson).

Daily Leakage

The daily volume of **leakage**, usually calculated at **DMA** level but can be evaluated at **zone** level, assessed either using the **TIF method**, or from the **night leakage** multiplied by the **HDF**. The most commonly used units would be, for example, m^3/d , Ml/d or gal/d .

Night Leakage

Night leakage is the leakage during 1 h at the time of the **minimum flow**, which usually occurs in the middle of the night. It is assessed using the **minimum flow method**, usually at a **DMA** level but can be evaluated at **zone** level. The most commonly used units would be, for example, m^3/h or gal/h .

Zone

Zone is a term that is often used for larger sections of a network, which may comprise several **DMA**s or which may not have any **DMA**s at all, but which is too large to be considered as a **DMA**.

District Metered Area (DMA)

A DMA is a section of the **distribution network**, commonly where **sluice valves** have been shut off, usually permanently, so that demand in the area can be monitored by the flow through one or more **meters** for the purpose of **leakage management**, see **Figure 23**. There may be more than one DMA meter measuring the flows into and out of the DMA. All unmetered connections along the boundary of the DMA must be valved off (closed). There is no fixed rule on the size of DMA's. If they are too small then there is a higher cost for monitoring (**meters**, **pulse units**, **flow loggers**) and analysis. If they are too large then the resolution for discerning when **leakage** is accumulating is reduced. It is generally recommended that DMA's are between 6–10 km and 500–2500 **properties**. DMA boundaries should be chosen to take advantage of natural hydraulic boundaries in order to minimise the number of meters. They should be chosen to separate domestic and industrial/commercial areas where possible. They should also be designed along the contours of the area in order to minimise the difference in elevation across the DMA to aid **pressure management**. DMA's are sometimes referred to as sectors and the process of setting up DMA's referred to as sectorisation.




Figure 23 Illustration of a **district metered area** (Source: D Pearson).

Net Flow

The net flow is the flow into an area (e.g. **zone**, **DMA** or **sub-DMA**) taking into account the additions and subtraction of **flows** measured at the inlet and outlet **meters** of the area. It is equivalent to the **demand** on the area. It is now common usage to use “net” rather than “nett” in the English language.

Sub-DMA

A sub-DMA is an area within a **DMA** that is monitored in order to localise the area where a leak may have broken out within the **DMA**. The valving and/or recording of the flows of a sub-DMA may be temporary or permanent. The metering of a sub-DMA may be temporary, using a meter installed on a trailer and an overland bypass between hydrants. Previously referred to as a waste area or leakage control area.

Attributes

Attributes are the physical parameters of a particular area, be that a **zone** or a **DMA**. Typical attributes are length of **mains**, number of **properties**, number of **connections**, **AZNP** and **HDF**.

Minimum Night Flow (MNF)

The **minimum night flow** is the minimum 1 h flow rate recorded during the night period, normally defined as being between midnight and 6am. The **minimum night flow** in urban situations normally occurs during the early morning period,

commonly between 2 and 4am, see Figure 24. The term **minimum night flow** is therefore common parlance for the **minimum flow** because of this. The **minimum night flow** is the most meaningful piece of data as far as estimating **night leakage** is concerned, see **minimum night flow method**. The term night line is also often used for Minimum Night Flow. See also **minimum flow**.

Tracking the **minimum night flow** over a period of time can show whether unreported leakage is accumulating on the area (DMA, sub-DMA or Zone) and is therefore a key activity in leakage management.




Figure 24 Diagram illustrating **minimum night flow** period (Source: D Pearson).

Figure 25 shows a plot of 15 minute interval **net flow** into a DMA, i.e. as per Figure 24, for a period of around 20 weeks. This shows that the **minimum night flow** has a distinct weekly cycle with the MNF on a Saturday night about $2 \text{ m}^3/\text{h}$ higher than during the week. It is therefore essential not to believe that this increase could be a **leak** and respond too quickly. Second, the graph shows that there has been an increase in the MNF from about 13 to $19 \text{ m}^3/\text{h}$ over the analysis period, thus indicating a rise in **leakage** due to **unreported leaks** during this period. It is also interesting to note that the amplitude of the **diurnal demand pattern** has remained consistent during the period. This indicates that there has been no change in the status of the DMA during this period and that the boundary has remained tight.




Figure 25 Typical pattern of 15 minute flows over a period of 20 weeks (Source: D Pearson).

Minimum Flow (MF)

The [minimum flow](#) is the minimum 1 hour flow rate recorded during a 24-h period. The [minimum flow](#) in urban situations normally occurs during the early morning period, commonly between 2 and 4am and is referred to as the [minimum night flow](#). However, in some locations the [minimum flow](#) may occur outside of this night period due to other water use [demands](#), such as agriculture or the use of night time electricity, and therefore the more generic title of [minimum flow](#) is more suitable. In the case of systems with [intermittent water supply](#), the [minimum flow](#) has to be taken during periods when the system is pressurised, although even then customer tanks may still be filling and therefore this flow has to be interpreted with care.

Total Integrated Flow Method (TIF Method)

The total integrated flows are the daily volumes of the [water balance](#) components, such as the average daily [net flow](#) and measured [consumption](#). [Leakage](#) in an area, such as a [DMA](#) or zone, can be estimated by carrying out a [water balance](#) using the TIF components and comparing this to the estimate derived from the using the [minimum night flow method](#) (see also [operability test](#)).

Minimum Night Flow Method (MNF Method)

The [minimum night flow method](#) is used to estimate [night leakage](#) in a [DMA](#) or [zone](#) using the [minimum night flow](#), provided there is no [service reservoir](#) in the [zone](#) which could be filling or emptying during this period. During the [minimum night flow](#) period, [consumption](#) is at a minimum and therefore [leakage](#) is at a maximum proportion of the total flow, see [Figure 21](#). Estimation of the [leakage](#) component of the [minimum night flow](#) is undertaken by subtracting from the [minimum night flow](#), an assessment, estimated or logged during the period of [minimum flow](#), of [night consumption](#) for all the customers connected in the [DMA](#) or [zone](#) being studied.

The [minimum night flow method](#) cannot generally be used with systems with [intermittent water supplies](#), as the system may be shut off or depressurised during the period of [minimum night flow](#) and therefore there will be little or no [leakage](#) at that time. Even if the system is [pressurised](#) during the night, the consumption pattern can be unreliable as customers cisterns may be filling or customers may be storing water ready for the next period without [supply](#).

Legitimate Night Consumption (LNC)

[Legitimate night consumption](#) is the consumption of authorised users during the period when the [minimum night flow](#) is assessed. Total night consumption is the sum of both [domestic night consumption](#) and [non-household night consumption](#). It has been given the label “night” as this is the most common situation. The label “minimum” cannot be used as it must be the consumption assessed at the time coincident with the time when the [minimum night flow](#) is assessed, which may not actually be the minimum consumption. Night consumption will include [plumbing losses](#) as well as actual customer use. The term is normally prefaced by the word “legitimate” in order to imply that it is assessed for the case of normal legitimate use and not unauthorised use, e.g. theft.

Legitimate Domestic Night Consumption (LDNC)

Domestic night consumption is the assessed consumption of authorised domestic users during the period when the [minimum night flow](#) is assessed. Domestic night consumption is generally consistent and can be estimated from data taken from a statistical sample of domestic users. It is normal to express this in the form of l/prop/h in situations where domestic properties are generally unmeasured but expressed in the form of a percentage of the average daily consumption where domestic properties are generally metered. See also [night consumption](#). The term is normally prefaced by the word “legitimate” in order to imply that it is assessed for the case of normal legitimate use and not unauthorised use, e.g. theft. The night consumption will include [plumbing losses](#) in addition to customer use.

Legitimate Non-household Night Consumption (LNHHNC)

Non-household night consumption is the assessed consumption of all authorised users other than domestic (i.e. commercial, municipal and industrial etc.) during the period when the [minimum night flow](#) is assessed. It is normal to express this in the form of l/prop/h for unmetered non-household types and in the form of a percentage of the average daily billed volume in the case of metered non-household types. The latter ratios are usually estimated from data taken from a statistical sample of non-household users, often stratified by type and size. If the consumption of a particular user is not consistent from one night to another it is often necessary to [continuously log](#) this user in order to establish their night consumption. The term is

normally prefaced by the word “legitimate” in order to imply that it is assessed for the case of normal legitimate use and not unauthorised use, e.g. theft. The night consumption will include [plumbing losses](#) in addition to customer use.

Continuous Logged User (CLU)

When a particular non-household customer’s use during the [minimum night flow](#) period is significant and variable then it may be necessary to log the user on a continuous basis so that their consumption can be subtracted from the [minimum night flow](#). The general availability and deployment of [smart meters](#) is making this aspect of [leakage management](#) easier.

Operability Test

The operability test is a technique used to give confidence as to whether a [DMA](#) is correctly isolated, verify that there are no meter scaling errors and that the DMA [attributes](#) are reasonably correct. In the test, [leakage](#) assessed using the [minimum night flow method](#) is compared to that derived using the [total integrated flow method](#) components on the same area. Either the [leakage](#) from the two methods is compared or the implied household consumption from equating the leakage is compared to the expected household consumption as the pass/fail criteria for the operability test. It is usually assessed on an individual [DMA](#) basis but can then be accumulated to higher levels in the [network hierarchy](#).

Top Down Leakage Assessment (TD)

The assessment of [leakage](#) in a [zone](#) by carrying out a water balance on that zone as a whole, namely water in minus water out. The [IWA Standard Water Balance](#) should be used for this assessment.

Bottom Up Leakage Assessment (BU)

The assessment of [leakage](#) in a [zone](#) by adding up the [leakage](#) assessed on the individual components, such as [DMAs](#), [service reservoirs](#) and [trunk mains](#). Allowance must be made for [leakage](#) in areas that are not monitored and also for [leakage](#) in areas where data is believed to be inaccurate.

Downstream Leakage

This is the [leakage](#) in the area of the [network](#) covered by [DMAs](#).

Upstream Leakage

This is the [leakage](#) in the [water supply network](#) upstream of [DMAs](#). This, therefore, can include [leakage](#) on [transmission mains](#), [service reservoirs](#) and on [distribution mains](#) between [service reservoirs](#) and [DMA meters](#). It will include [leakage](#) on unmonitored areas if these are not estimated as part of [downstream leakage](#). Monitoring of upstream leakage includes the whole system [from distribution input meters](#) down to the [DMA meters](#).

Minimum Achieved Night Flow

The minimum achieved night flow is the [minimum night flow](#) that has been achieved in a [DMA](#) over a long period, usually greater than four years, provided that the [DMA](#) boundary, pressure regime and water use regime have not changed significantly within this period.

Minimum Achievable Night Flow (Mabl)

The [minimum achievable night flow](#) is an assessment of the [minimum night flow](#) that may be expected in a [DMA](#), considering a realistic estimate of the [infrastructure condition factor](#), [average zone night pressure](#) and assessed [night consumption](#).

Unavoidable Annual Real Losses (UARL)

The volume of [unavoidable annual real losses](#) represents the lowest technically achievable annual volume of [real losses](#) for a well-maintained and well-managed system. The standard equation for calculating UARL for individual systems was developed and tested by the IWA Water Loss Task Force (the predecessor of the IWA WLSG). It allows for:

- [Background leakage](#) – small leaks with flow rates too low for acoustic detection if not visible
- Leakage from [reported leaks](#) – based on average frequencies, typical flow rates and target average durations
- Leakage from [unreported leaks](#) – based on average frequencies, typical flow rates and target average durations
- Pressure/leakage rate relationships, with a linear relationship being assumed ($N1=1$)

The UARL equation requires data on only four key system-specific factors:

- Length of mains including all pipelines, except **service pipes** (L_m) in km
- Number of **connections** (N_c)
- **Length of private service pipe** between property boundary and customer **revenue meter** or notional point of delivery (L_p) in km

Note: This is not the same as the total length of **service pipes**. Losses on the **service connection**, between the **tapping point** on the main and the property boundary, are included in the allowance per service connection. The additional allowance for the **private service pipe** was included to take into account longer leak run-times in situations where visible leaks would not be seen by the public. In most urban situations, if the customer **revenue meter** is at the property boundary, then the length of **private service pipe** between property boundary and customer **revenue meter** will be nil.

- **Average operating pressure** (AOP) when system is pressurised (wsp) in m

The formula for UARL is:

$$UARL(l/d) = (18 \times L_m + 0.80 \times N_c + 25 \times L_p) \times AOP_{w.s.p.}$$

A second order adjustment of the coefficients in the equation can be applied if it is considered that a linear relationship to pressure is not appropriate. The formula can also be adjusted for use with very small zones (<3000 connections).

Background Leakage

Background leakage is the sum of individual small leaks, such as weeps and drips, that persist with flow rates too low to be detected by an **active leakage control** campaign, unless either detected by chance or until they gradually worsen to the point that they can be detected. Background leakage should not be confused with **unavoidable losses** (UARL) as the latter includes an allowance for losses from bursts in addition to background leakage. The level of background leakage depends on the overall infrastructure condition, the pipe material(s), the quality of installation and the soil. It is, furthermore, heavily influenced by **pressure**, with **N1** being typically 1.5 or higher.

Unavoidable Background Leakage (UBL)

The UBL is the estimate level of **background leakage** that may be expected on the area being monitored (**zone**, **DMA** or **sub-DMA**) using the IWA WLSG's background leakage factors used in the estimation of the **UARL**, taking the actual **AZNP** (when system is pressurised) into account using an **N1** equal to 1.5.

The unit factors for UBL recommended by the IWA WLSG are:

Mains	20l/km/h at 50 m pressure
Service connections	1.25l/connection/h at 50 m pressure
Private Service Pipes	33.3l/km/h at 50 m pressure

The formula for UBL is:

$$UBL(l/h) = (20 \times L_m + 1.25 \times N_c + 33.3 \times L_p) \times AZNP_{w.s.p.}^{1.5}$$

where L_m is the length of **mains** in km, N_c =number of **connections**, L_p is length of **private service pipe** in km and **AZNP** is pressure at the **average zone point** at the time of the **minimum night flow** in m.

Infrastructure Condition Factor (ICF)

The **infrastructure condition factor** is the ratio of the actual **background leakage** to **unavoidable background leakage** that may be expected on the same area (**zone**, **DMA** or **sub-DMA**). ICF can be estimated at **DMA**, and then evaluated at higher levels in the **network hierarchy**. The ICF can provide a reflection of asset condition. New fully welded PE systems could be expected to have an ICF close to 0, whereas the ICF for an older system in poor condition may be about 3. Where ICF on a **DMA** is estimated to be greater than 3, there should be rigorous checks to ensure that the **attributes** are correct and that the **boundary valves** are closed. ICFs of greater than 3 can indicate that there are active **leaks** running in the **DMA**.

Burst Frequency

The IWA WLSG recommend that utilities use appropriate [work management systems](#) to record whether leaks occur on [mains](#), [service connections](#), [private service pipes](#) or [appurtenances](#). This level of detailed record keeping can then be used to compare system performance to that used in the calculation of the unavoidable losses and support decisions on the benefits of [pressure management](#), the need for refurbishment, the selection of materials and the appropriateness of construction details.

Mains Burst Frequency

The average frequency (i.e. number per year) of bursts that occur on the [mains](#) in a [network](#) or part of a [network](#), e.g. [DMA](#). In order to provide a statistically robust estimate it is better if this frequency is the average over several years ($>\sim 4$ years). It is essential that the [pressure](#) regime and network boundary is consistent over this period. See also [normalised mains burst frequency](#).

Service Pipe Burst Frequency

The average frequency (i.e. number per year) of bursts that occur on the [service pipes](#) in a network or part of a network, e.g. [DMA](#). In order to provide a statistically robust estimate it is better if this frequency is the average over several years ($>\sim 4$ years). It is essential that the [pressure](#) regime and network boundary is consistent over this period. It is often useful to split the frequency of bursts between those occurring on [service connections](#) and those occurring on [private service pipes](#). See [service connection burst frequency](#) and [private service pipe burst frequency](#). See also [normalised service pipe burst frequency](#).

Service Connection Burst Frequency

The average frequency (i.e. number per year) of bursts that occur on the [service connections](#) in a network or part of a network, e.g. [DMA](#). In order to provide a statistically robust estimate it is better if this frequency is the average over several years ($>\sim 4$ years). It is essential that the [pressure](#) regime and network boundary is consistent over this period. See also [normalised service connection burst frequency](#).

Private Service Pipe Burst Frequency

The average frequency (i.e. number per year) of bursts that occur on the [private service pipes](#) in a network or part of a network, e.g. [DMA](#). In order to provide a statistically robust estimate it is better if this frequency is the average over several years ($>\sim 4$ years). It is essential that the [pressure](#) regime and network boundary is consistent over this period. See also [normalised private service pipe burst frequency](#).

Natural Rate of Rise of Leakage (NRR)

The [natural rate of rise of leakage](#) relates to the underlying rate at which [leakage](#) increases within a system given the absence of any interventions to reduce [leakage](#). It is caused by the gradual growth of existing [leaks](#) and the breaking out of new [leaks](#). The most common NRR is if no [unreported leaks](#) were [detected](#) and [repaired](#). This is referred to as NRRd (or simply NRR) where “d” stands for [detected](#). It is feasible to consider NRRg which is the gross NRR if no [leaks](#), either [reported](#) or [unreported](#), were [repaired](#).

Smart Network

A smart network contains built-in diagnostic equipment or systems, such as remotely monitored flow, sound and pressure sensors or remote-controlled valves, which allow the system to be managed or controlled from a remote location for efficient management, thus allowing it to perform in an economic and efficient manner. With ever developing technology, digitisation has accelerated the collection and dissemination of actionable information both on the supply and the demand side to all stakeholder groups including utilities managers themselves, their workforce, their contractors, their customers and owners. This will have a profound effect in the future and the phrase “digital water” has been coined to reflect this. In many respects the more sophisticated [leakage management systems](#) could be considered as being a “digital twin” of the network holding, for example, a [hydraulic model](#) of the network as well as inventories and details of all the sensors and assets within the network.

LEAKS

Circumferential Break

A [break](#) on a pipe that runs around the circumference of the pipe.

Longitudinal Break

A [break](#) on a pipe that runs along the direction of pipe.

Split

A failure where a crack opens and runs along the direction of the pipe. It is common on a plastic (PE and PVC) pipe.

Other Failure Modes

There are other failure modes such as flaps, corrosion holes or blow outs, depending on the pipe material and operating conditions.

Leak

A leak is a failure of the [water supply network](#) such that there is an unplanned loss of water from the [water supply network](#). It is a generic term that can be used on any size or type of asset, from a [service pipe](#) to a [trunk main](#) or [service reservoir](#) or any fitting from a [gate valve](#) to a [customer meter](#). In some utilities, the word “burst” may have a specific connotation in relation to a leak that is large enough to cause a supply disruption or severe impact on customers or general public. The word “break” is common parlance for a leak on a pipe in North America. From the [leakage management](#) perspective there is no difference between leak, burst or break.

Leak on Main

A [leak](#) that has occurred on a water [main](#) by either a pipe break or failure at this point – this includes joints, pipe breakage or at the [tapping point](#) connection. The latter may be caused by the [tapping point](#) failure, which should be assigned as a [leak on service connection](#), or a split in the main where the [tapping point](#) is located, which should be assigned as a [leak on main](#). This would be confirmed on excavation. [Figure 26](#) shows a typical leak on main.

Leak on Service Connection

A [leak](#) that has been located on a [service connection](#), namely a [leak](#) that is after the connection to the [main](#). This includes [leaks](#) at the [tapping point](#) itself and anywhere on the [service connection](#) up to the [stop tap/meter](#) at the customer boundary. Sometimes referred to as a leak on communication pipe (UK) or a mains side leak.

Leak on Private Service Pipe

A [leak](#) that has been located on the [private service pipe](#) which runs from the customer boundary or [meter](#) to the internal [stop tap](#) of the property. This is considered to be on private property and the repair is, thus, usually the responsibility of the owner. Sometimes referred to as a leak on a supply pipe (UK) or a property/customer side leak.

Leak on Appurtenances

This the generic term for [leaks](#) on assets such as external [stop taps](#), [customer meters](#), [DMA meters](#), [PRVs](#), [gate valves](#) and [hydrants](#). A [work management system](#) will usually identify which asset is leaking, although the allocation may have to be corrected following excavation.

Reported Leak

A [leak](#) that has been reported to the water utility by means of a notification from the public, often as a visible leak, leakage management software (i.e. alarm management or critical event management routines) or other technology such as [remote sensing](#) or permanently deployed [acoustic loggers](#), among other means.

Some utilities only use this term for leaks actually reported by customers, whilst others use the term visible leak or surfacing leak. It is feasible that a visible or surfacing leak may not be reported by the public and is found by [active leakage detection](#). The critical factor is how long the leak is likely to run before being [located](#). A reported leak will have an [awareness](#) and [location time](#) of only a few days (say $\sim$ 10–20 days). These leaks are sometimes referred to as reactive leaks.



Figure 26 Typical leaks (Sources: Severn Trent Water (1, 3, 4, 5), K Atkinson (2)).

It is recommended that only the term reported leak is used in the categorisation of [leaks](#), with a relatively short awareness plus location time, within a [work management system](#) and [leakage management system](#), in order to aid the construction of a [component loss model](#).

Unreported Leak

A [leak](#) that has been found that was not made aware to the water utility by any means and has had to be found by [active leakage detection](#) in response to rising night flows. It is usually found using acoustic means.

Some utilities use the term non-visible leak or non-surfacing leak for a [leak](#) found by acoustic sounding only and where there is no indication of a [leak](#) being present by any water visible in the vicinity, other than possible sustained vegetation growth. An unreported leak will have a long [awareness](#) and [location time](#), usually of the order of 100 or more days.

It is recommended that only the term unreported leak is used in the categorisation of [leaks](#), with a relatively long awareness plus location time, within a [work management system](#) and [leakage management system](#), in order to aid the construction of a [component loss model](#).

Leak Duration

The total length of time a [leak](#) runs from the time of breaking out until the water loss stops, usually by it being [repaired](#). The length of time for which a leak runs consists of three separate time components – [awareness](#), [location](#) and [repair](#) time, see [Figure 27](#).




Figure 27 Representation of the duration of a leak (Source: D Pearson).

Awareness Time

Awareness time is the time from when a [leak](#) breaks out until the water utility becomes aware of its existence. The utility may become aware of a leak from customer contact, an alarm from [leakage management software](#), an alarm from permanently deployed [noise loggers](#) or simply from visual inspection of the night flow. The awareness time is influenced by the type of monitoring system that is adopted. Where there is no monitoring system and the utility relies purely on regular sounding to identify if a [leak](#) has broken out, then the awareness time of an [unreported leak](#) will be very long and equal to half the time between regular surveys.

Location Time

The location time is the time between a utility being aware of a [leak](#) until it is [pinpointed](#) and the [repair](#) request issued. For [reported leaks](#), this is the time it takes for the water utility to investigate the report of a [leak](#) and to correctly locate its position so that a [repair](#) can be undertaken. For [unreported leaks](#) in systems with no monitoring and hence high [awareness times](#), the location time will be short, simply being the time to [pinpoint](#) any [leak](#). For [unreported leaks](#) in systems with monitoring the [awareness time](#) will be low, but the location time will include the time between the utility being aware of the leak and the time before the [leak](#) is [pinpointed](#). This can be very long (several months), awaiting the [DMA](#) being allocated for an [active leakage control survey](#). It will then also include the time to [localise](#) and [pinpoint](#) the [leak](#). Often, not all [leaks](#) will be found on the first survey and these will continue to run until the next survey.

Repair Time

The repair time is the time that a leak runs between being [pinpointed](#) and when the water ceases being lost. Generally, the latter is the time when the [leak](#) is [repaired](#), but in some circumstances the leak may stop running by being valved off.

LEAKAGE DETECTION

Leakage detection is the process of [locating](#) and [pinpointing](#) water leaks.

Active Leakage Control (ALC)

[Active leakage control](#) is the process of undertaking [leakage detection surveys](#) on a targeted or regular basis in order to manage leakage within a [water distribution network](#).

Leakage Detection Survey

A leakage detection survey is the activity of proactively and systematically searching for [leaks](#) using planned [leak detection exercises](#) to [localise](#) and then [pinpoint](#) the position of suspected [leaks](#) within a [DMA](#), a [sub-DMA](#) or any other area. The trigger for a [leakage detection survey](#) may be the time since the previous survey, when the process is referred to as [regular](#)

sounding, or when the [net flow](#) registered on a [DMA](#) has reached some threshold. It is usually expected that a [leakage detection survey](#) should find more than one [leak](#). It is also referred to as an intervention.

Regular Sounding

Regular sounding is the process of carrying out a [leakage detection survey](#) on a regular time basis, e.g. once every 12 months, rather than based on the [minimum flow](#) or other measure on a [DMA](#).

Passive Leakage Control

Passive leakage control is the name of the process of managing [leakage](#) purely by carrying out [reactive surveys](#) within a [water distribution network](#).

Reactive Survey

A leak detection exercise that is only completed in response to customer contact or [supply](#) difficulties, namely it is reactive, usually with the intention of finding only one specific [leak](#). It has no planning, targeting or programme of works.

Locate, Localise, Pinpoint

The process within a [leak detection survey](#) in which the location of a potential [leak](#) is systematically narrowed down from within a [DMA](#) or sub-area to a particular street or section of main and, finally, pinpointed to a precise reference location, such as in front of a specific house number. When a leak has been pinpointed it is normal for a cross or square, with or without letters showing reason, to be spray painted on the ground to confirm the location for the [repair](#) team to excavate.

Area of Interest (AOI)

An [area of interest](#) is an approximate location where a [leak](#) is suspected and awaiting validation to confirm whether it is in fact a leak or not, and if a leak accurate [pinpointing](#). AOIs may have been identified by [acoustic loggers](#) or other [detection technique](#). All leak positions remain as an AOI until they have been confirmed either to be a [leak](#) or positively confirmed not to be a [leak](#).

Equivalent Service Pipe Burst (ESPB)

An [equivalent service pipe burst](#) is the flow rate expected from a [service pipe leak](#), being 1.6 m³/h at 50 m pressure, adjusted for the actual pressure, using $N1 = 0.5$. The rate at which the [minimum flow](#) on a [DMA](#) is above the expected target (possibly the [minimum achieved night flow](#)) is converted into the number of ESPBs. This value gives the detection technician an indication of the number of [leaks](#) that they would expect to [locate](#) during a [leakage detection survey](#).

LEAKAGE DETECTION TECHNIQUES

Leakage detection techniques are the methods and technologies available to leakage detection technicians to [localise and pinpoint leaks](#) during a [leakage detection survey](#) or a [reactive survey](#).

Leak Noise Correlator (LNC)

A [leak noise correlator](#) (or simply “correlator”) is a piece of equipment that indicates the position of a [leak](#) along a [main](#) by analysing the sound heard at two [appurtenances](#), typically valves and/or hydrants, see [Figure 28](#). The correlator can use either accelerometers or hydrophones to pick up the noise. An accelerometer is attached magnetically to the fitting and will pick up noise transmitted through the pipe wall, whereas a hydrophone must be in contact with the water through an opened [hydrant](#) or connection on the pipe and listens to the sound transmitted through the water itself.


Referring to [Figure 29](#), the position of the leak is given by the formula:

$$L = (D - (V \times t))/2$$

where L = distance of the leak from Sensor 1; D = distance between the two sensors; V = velocity of sound between the two sensors; and t = time shift between the sound arriving at Sensor 2 compared to Sensor 1

Information on pipe material and pipe length between the listening devices is required in order to evaluate V . The more accurate this information then the more precise will be the predicted [location](#) of the [leak](#). A three-point correlator, as shown in [Figure 28](#), will make the estimation of V , and hence the predicted [location](#) of the [leak](#), more accurate. The location should always be confirmed by [surface sounding](#).


1 Principle



2 Accelerometer on valve



3 Hydrophone on meter box



4 Hand held correlator display



5 Computer display of result




Figure 28 Photographs showing use of leak noise correlator (Sources: Primayer (1, 5), EPAL (Lisbon) (2, 4), K Atkinson (3)).




Figure 29 Evaluation of position of leak using a correlator (Source: D Pearson).

Correlator Survey

A correlator survey is a mode that can be used to quickly scan an area in order to localise the position of a leak. In this mode it is not necessary to identify pipe material and lengths accurately and so the survey can be effected quickly. Once the leak has been localised, then more precise information on pipe material and lengths can be provided and the correlator used to more accurately estimate the location of the leak.

Stop Tap Sounding Survey

Stop tap sounding, colloquially referred to as “stop tap bashing”, is the process of using a sounding stick to sound every external stop tap in order to test for noise from any leaks. It is essential in this process that the end of the sounding stick makes good contact on the head or crutch of the stop tap. This high-resolution method generally finds the greatest number of leaks.

Mains Appurtenances Only Sounding Survey

This activity covers the low-resolution sounding on [appurtenances](#) only and is used mainly for locating [leaks](#) on metallic [mains](#). This approach should not be used if the pipe material is non-metallic or the main between listening points contains a section of non-metallic material such as a plastic [piece-through repair](#), as the sound does not travel along the pipe as well in these circumstances.

Surface Sounding

The process of sounding the ground surface with a [manual listening stick](#) or [electronic listening stick](#) in order to pinpoint the position of a leak.

Manual Listening Stick

A listening stick is a stethoscope that is used to sound [appurtenances](#), [stop taps](#) or the ground surface to help confirm the presence of a [leak](#) by transmitting the sound up to the operative's ear, see [Figure 30](#). There are diverse types of sticks using different materials such as wood and/or metal and some have different earpiece attachments to transfer the sound to the operator's ear. Operatives tend to have their own personal preference of type of stick. It can also be used to check whether a [sluice valve](#) is passing water, when checking [DMA](#) boundary valves or carrying out a [step test](#).



Figure 30 Photographs showing use of manual listening stick (Sources: K Atkinson (1), United Utilities (2)).

Electronic Listening Stick

An electronic listening stick is a rod that uses electronic filtering and amplification to listen for [leak](#) noise, available in several levels of sophistication, see [Figure 31](#).

Ground Microphone

A piece of equipment that uses a microphone together with electronic filtering and amplification to listen for [leak](#) noise when placed on the ground surface. They are used for confirming and [pinpointing](#) the precise location of a [leak](#) following a [correlator](#) survey. Often colloquially referred to as an “Elephant’s Foot”, see [Figure 32](#).

Pressure Zero Test (PZT)

A [pressure zero test](#) is a process used to confirm that [boundary valves](#) which have been shut in order to create a [DMA](#) are in fact still shut and not passing water in or out of the [DMA](#). Initially the [valves](#) are sounded using a [listening stick](#) to ensure there is no sound being emitted from a potential water passage. A [pressure gauge](#) is then fitted to a [hydrant](#) within the [DMA](#) and the main inlet(s) and outlet(s) to the [DMA](#) are closed, see [Figure 33](#). The [pressure](#) on the [gauge](#) should drop gradually to zero. Should [pressure](#) be sustained or fall dramatically to zero, then this indicates that one or more of the [boundary valves](#) are open or not water-tight. It can be useful to install a [pressure gauge](#) on a [hydrant](#) outside the [DMA](#) to confirm that the pressures recorded



Figure 31 Photograph showing use of electronic listening stick (Source: S Hamilton).



Figure 32 Photographs showing use of ground microphone (Sources: EPAL (Lisbon) (1), K Atkinson (2), S Hamilton (3)).

are different. The [pressure gauge](#) should be left in place for a period of approximately 15 minutes to ensure that the system does not pressurise through a passing [valve](#). It is also recommended that [pressure loggers](#) are installed along the boundary both inside and outside the [DMA](#). These can be downloaded later as a check and also for audit purposes. In some countries, this may be referred to as a Zero Pressure Test (ZPT).

Acoustic (Noise) Loggers

Acoustic loggers are electronic devices used to record the noise on [appurtenances](#), such as [valves](#) and [hydrants](#), see [Figure 34](#). They can be programmed to listen at certain times of the day, such as the middle of the night, when there should be limited extraneous noise on the system. They can also be programmed to interpret sound in terms of consistency, noise level and



Figure 33 Photographs showing hydrant being used during a PZT (Source: K Atkinson (1, 2)).




Figure 34 Photographs showing of acoustic loggers (Sources: EPAL (Lisbon) (1), K Atkinson (2, 3)).

frequency and thereby infer whether the noise would indicate that there is a [leak](#) in the vicinity. They have a magnetic base so that they can be attached to the metallic spindle of a [valve](#) or [hydrant](#).

Correlating Acoustic Loggers (CAL)

These are loggers that have combined the functionality of [acoustic loggers](#) and [correlators](#). This has been possible because of the improved time stamping on GPRS networks and the use of GPS technology. The data from the correlating loggers is combined with information about pipe lengths and materials (derived from the utility's [GIS](#)) in order to provide a more precise [area of interest](#) about a [leak](#) for confirmation and [pinpointing](#). These loggers can be installed on a lift and shift basis or installed on a permanent basis and communicate over proprietary radio networks, or cellular (2G, 3G or 4G). When installed on a permanent basis they can change the economics of the [active leakage control](#) process significantly. See [Figure 35](#).

Remote Sensing

Remote sensing is a generic term that is used to describe several techniques which do not involve physical [leak detection](#) on the ground. The techniques include flying over the area using a plane, helicopter or drone, as well as satellite surveillance. The

1 Installation on hydrant




2 Installed on hydrant



3 Installed on valve



4 Results displayed on Google Maps



5 Results displayed on Google Earth




Figure 35 Photographs showing [correlating acoustic loggers](#) (Sources: Mueller Water Products Inc (1, 2), Anglian Water/Primayer (3), Primayer (4), Gutermann (5)).

technology usually uses different wavelengths, including infra-red, in order to look for areas where vegetation is being sustained or where ground reflection is different and therefore identifies an [area of interest](#) for further investigation.

Non-Intrusive Leak Detection

Any leak detection technique, such as [gas detection](#), [correlation](#), [stop tap sounding](#); that does not involve having a sensor passing down the inside of the pipe. See [intrusive leak detection](#) for comparison.

Intrusive Leak Detection

The process involves a sensor travelling along the inside of the pipe. The sensor identifies the existence and location of a [leak](#) either through sound or the change in the pressure profile within the pipe. The sensors can be either tethered or free floating. The sensors are usually tracked at ground level using technology such as Bluetooth. Intrusive detection techniques require access to the water within a main in order to “launch” the sensor. This can be either through an existing [hydrant](#), new or existing [piggings chambers](#), or new or existing [tapping](#) points. Free floating equipment will also require some form of reception arrangement for the recovery of the sensor. There are a number of proprietary intrusive [leak detection](#) techniques and associated equipment available. Also known as in-pipe leak detection.

Ground Penetrating Radar (GPR)

There have been many attempts at developing ground probing radar with the hope of identifying the location of a [leak](#). Various types of ground probing radar have been investigated, either independently or combined, including ground penetrating imaging radar and surface magnetic resonance sensors. It is generally accepted that the results from the technology have been disappointing, being both difficult to interpret and often inconclusive.

Gas Injection

Gas injection is a technique where gas, usually a mixture of hydrogen or helium and nitrogen, is injected into the water [main](#) or [service pipe](#). The ground above the main is then swept using a sensor that can pick up the presence of the gas, see [Figure 36](#). The gas must be approved for use with potable water.



Figure 36 Gas injection leak detection technique (Sources: Primayer (1, 3), EPAL (Lisbon) (2)).

Step Test

A step test is a technique used to [localise](#) a [leak](#) within a [DMA](#). It is designed so that sections of a [DMA](#) can be shut off in sequence by the closing of a single [valve](#). This may involve identification, usually as part of the design process, of what are referred to as [circulating valves](#) so that the [DMA](#) is reduced to a series of “branches”. When the [circulating valves](#) have been shut, the [step valves](#) are shut in sequence and the flow at the [DMA meter](#) is noted, logged or transmitted to the operatives. As each step valve is shut the flow through the [DMA meter](#) is given time to stabilise, which may only take a few minutes. As the [step valves](#) are shut, the preceding [step valves](#) can be opened or left shut. The step with the largest drop is the one that contains the greatest [leakage](#), but if there are several steps with drops in flow, then this indicates that there are several [leaks](#) rather than a single large [leak](#). A step test should be carried out at night or when there is minimal [consumption](#) in order to reduce any disruption to customers. Any known essential night users must be identified, and temporary arrangements made to maintain [supply](#). In some cases, customers will need to be notified, such as by placing of cards through doors beforehand, to warn them of possible loss of [supply](#) or discoloured water in the morning. However, such risks can be minimised by using real time data transmission and careful [valve](#) operation. See also [temporary DMA rezoning test](#).

Temporary DMA Rezoning Test

The temporary DMA rezoning test is a development of the “traditional” [step test](#), which involves the sequential transfer of sections of a [DMA](#) that would have been isolated by closure of [step valves](#) in a normal [step test](#), onto the adjacent [DMA](#) so that [supply](#) is maintained. This process therefore avoids service cuts and loss of [pressure](#) in the network.

LEAK REPAIRS

A leak repair is the process of repairing the fault that is causing the [leak](#). [Leaks on mains](#) are repaired by either a single [repair clamp](#) or with a new section of pipe in what is referred to as a [piece through repair](#). Leaks on [appurtenances](#) such as [valves](#) and [hydrants](#) usually require repacking of the gland or complete replacement of the [fitting](#) itself. [Leaks on service connections](#) are usually repaired by replacing the defective pipe section with a new one using two compression couplings, equivalent to a [piece through repair](#). In exceptional circumstances it may be deemed appropriate to replace the whole [service connection](#). This method is often chosen if the [service connection](#) is made of a non-preferred material, such as lead. Repairs are not normally carried out for [leaks on private service pipes](#) as these are the responsibility of the owner of the associated property, but if they are carried out by the utility for whatever reason, then they would be the same as the repair of a [leaks on service connection](#).

Repair Clamp

A repair clamp is a fitting that normally comes in two halves and includes a gasket over the full length of the clamp, see [Figure 37](#). The clamp is split and placed round the [main](#) at the leak location. It is then clamped and tightened so that the gasket is squeezed around the pipe over the hole in order to stop the [leak](#). A repair using a clamp can be undertaken without shutting off the water, thereby reducing the risk of contamination and [pressure transients](#) on refilling, though it will usually require [pressure](#) to be significantly reduced while the repair is undertaken. A repair clamp can be used to repair a hole but is not recommended for a circumferential split. A repair clamp will not significantly affect noise transmission along the pipe wall and will therefore have little impact on [leak detection](#).

1 Mains



2 Services



3 Installation



Figure 37 Typical repair clamps and installation (Sources: Plasson (1, 2), K Atkinson (3)).

Piece Through Repair

A piece through repair involves cutting out a section of pipe and inserting a new one in the original pipe using a coupling at each end, see [Figure 38](#). It is common to use a short length of plastic pipe (PE or PVC) for the insert even if the original main is metallic. Unfortunately, this can make future [leak detection](#) more difficult as the section of plastic pipe acts as an insulator and reduces noise transmission along the length of the original pipe. The use of plastic pipe in a piece through will also reduce the accuracy of the location of a leak using a [correlator](#). A piece through requires a complete water shut off and hence care with disinfection and recharging.

1 Mains



2 Services



3 Installation on main



Figure 38 Typical repair couplings and installation (Sources: Mueller Water Products Inc. (1), Plasson (2), D Pearson (3)).

PRESSURE MANAGEMENT (PM)

[Pressure management](#) is probably the most cost-efficient method of controlling leakage. [Pressure management](#) includes all the processes involved in monitoring and controlling pressures within the [supply](#) and [distribution networks](#). The knowledge associated with [pressure management](#) is now so well developed that the savings to be expected from the deployment of [pressure reduction](#) can be readily predicted.

Pressure Gauge

A gauge connected to a water [main](#) or [service pipe](#) for measuring pressure in the [main](#) or [service pipe](#). The [pressure](#) can be read manually or recorded on a [pressure logger](#).

Pressure Logger

An electronic device that can store the readings from a pressure transducer, for later interrogation or uploading to a central computer system or cloud based application, such as a [leakage management system](#). The [pressure](#) that is recorded will be the instantaneous pressure registered on the pressure transducer at the relevant time.

Pressure

Pressure is the force exerted by the water within a pipe. It is equivalent to how high the water would rise in an open tube if this was connected to the side of the pipe at the point of interest. Pressure is measured on the network using a [pressure gauge](#). The units of pressure are typically m, bar, psi (pounds per square inch).

Transients

Transients are very high frequency [pressure](#) surges within the [distribution network](#) created by operational changes, pump starts or stops or draw-off from the network. The surges can be of very high amplitude, i.e. pressure range, and therefore can cause severe shocks and stress to the system and create [leaks](#), see [Figure 39](#). They require high frequency logging of at least 10 times per second to detect their presence. They can usually be mitigated, if not removed, by improved pump start controls, improved operation of [valves](#), installation of surge suppression vessels or replacement of equipment on customer draw-offs with soft closing solenoids rather than simple rapid-acting solenoid valves or float valves.




Figure 39 Graph showing typical pressure transient (Source: United Utilities).

Pressure Reduction

Reducing [pressure](#) in a network has a significant impact on [leakage](#) as it reduces flow from existing [leaks](#) or new [leaks](#) when they occur. It also reduces losses from [background leakage](#) and the frequency at which new [leaks](#) break out on [mains](#) and [services](#). [Pressure management](#) is a very economic method of [leakage](#) control. [Pressure management](#) may be achieved through the installation of break pressure tanks, [pressure reducing valves](#) or through pump controls. The use of [PRVs](#) is the most common technique.

There are four primary methods of pressure management using a [PRV](#); namely: [fixed outlet](#), [time modulated](#), [flow modulated](#) and [critical pressure control](#). When considering the impact of [pressure management](#) on [leakage](#), it is necessary to consider the impact on the [pressure](#) over the day as a whole. The conversion from hourly [leakage](#) to daily [leakage](#) using the [hour to day factor](#) is critical and must be considered.

Fixed Outlet Pressure Management

In fixed outlet [pressure management](#), the [PRV](#) is set to deliver a set [pressure](#) at the outlet of the valve. This is the simplest form of [pressure management](#), see [Figure 40](#). The [HDF](#) for fixed outlet [pressure management](#) will be below 24 hours and is typically between 20–23 hours. In the example in [Figure 40](#) it is 22.6 hours.




Figure 40 Example pressure profile with fixed outlet [pressure management](#) (Source: D Pearson).

Time Modulated Pressure Management

In time modulated [pressure management](#), the [pressure](#) setting at the [PRV](#) outlet is changed based on the time of day. The most common modulation regime is to reduce [pressure](#) at night when [consumption](#) is low and [pressure](#) would normally rise. It is common to reduce [pressure](#) between midnight and 6am although these hours may be changed to suit local circumstances, see [Figure 41](#). In the case of time modulated pressure control the [HDF](#) will be greater than 24 hours and is typically in the region of 26–30 hours or even higher. In the example in [Figure 41](#) it is 32.1 hours.




Figure 41 Example pressure profile with time modulated [pressure management](#) (Source: D Pearson).

Flow Modulated Pressure Management

Flow modulation is a more sophisticated method where the pressure setting at the [PRV](#) outlet is based on the flow through the valve, normally being measured by a flow [meter](#) next to the [PRV](#). In this case, control can be set to inversely mirror the hydraulic

variation of **pressure** across the **PMA** as a function of **demand** in the area. Control can be based on **pressure** at the **average zone point** or the **critical point**. Under flow modulation the **pressure** at the relevant control point will be relatively constant and vary slightly around the desired control level, see Figure 42. With flow modulation, the **HDF** is much closer to 24 hours and will typically be between 23–25 hours. In the example in Figure 42 it is 24 hours.




Figure 42 Example pressure profile with flow modulated **pressure management** (Source: D Pearson).

Critical Pressure Control Pressure Management

In critical pressure control, the **PRV** or pump may be controlled to deliver a certain minimum pressure at a remote point within a **PMA**, usually either the **average zone point** or **critical point**. This requires a control loop and some sort of control unit such as a programmable logic controller (PLC). With **critical point pressure management**, the **HDF** is much closer to 24 hours. A more generic title used in North America is remote node control pressure management.

Discrete Pressure Area (DPA)

A **DPA** is a discrete area within the network where **pressure** is subject to the same pressure regime, either natural or managed through a **PRV**. Many water utilities may refer to these as hydraulic zones.

Pressure Managed Area (PMA)

A **PMA** is a **DPA** where the **pressure** regime is controlled by one or more **PRVs**.

Critical Point (CP)

A **CP** is the point of lowest available head within a **DPA**. Monitoring the **pressure** at the **CP** is useful in establishing whether the Standard of Service for **pressure** is being delivered to all customers. It is also useful for setting the controls of a **PRV** if the **DPA** is **pressure managed**.

Average Zone Point (AZP)

The **AZP** is the point in a **DPA** which is representative of the average **pressure** experienced by all **properties** in the **DPA**. The average height of properties in a **DPA** can be calculated using **GIS**, if this contains the height of each property, or manually by counting the **properties** between contours on a map.

Average Zone Pressure

The average **pressure** measured at the **average zone point** over a day.

Average Zone Night Pressure (AZNP)

The AZNP is the average pressure across a [DPA](#) during the period when the leakage is assessed for leakage monitoring purposes using the [minimum night flow method](#). This will normally be during the night but not necessarily, see [minimum night flow](#). The pressure will also normally be at its maximum at the time of [minimum flow](#), *but not necessarily*, depending on the type of [pressure management](#). The AZNP should be measured at the [Average Zone Point](#). The AZNP of an area such as a [zone](#) or a [DMA](#) with several [DPAs](#), should be calculated by property weighting the AZNPs of all the individual [DPAs](#) that make up the area.

Average Operating Pressure (AOP)

In the case of a system with [continuous supply](#), the AOP is the average pressure experienced by all the [properties](#) in a [DPA](#) over an entire day and is equivalent to $AZNP \times HDF/24$. The AOP for areas such as a [zone](#) or a [DMA](#) with several [DPAs](#) should be calculated by property weighting the AOPs of all the individual [DPAs](#) that make up the area.

In the case of systems with [intermittent water supplies](#), the AOP should only be evaluated for the period when the system is pressurised.

Hour to Day Factor (HDF)

[Leakage](#) can be assessed either from a water balance using the [TIF](#) components or from using the [minimum night flow method](#). One of the most common errors in leakage calculations is the assumption that [night leakage](#) per hour can simply be multiplied by 24 hours/day to assess [daily leakage](#); or that [daily leakage](#) from a water balance can be converted to [night leakage](#) by dividing by 24 hours/day. Given that leak flow rates and the [N1](#) exponent vary with the [average zone pressure](#), an [hour to day factor](#) of 24 hours/day is only valid when the [average zone pressure](#) is constant, or almost constant, over 24 hours in a day. The equation relating [daily leakage](#) to [night leakage](#) (measured during the hour of [minimum night flow](#)) is:

$$DailyLeakage(volume/day) = NightLeakage(volume/hour) \times HDF(hours/day)$$

In practice, the HDF can vary from less than 10 hours/day for gravity systems with high [leakage](#) and frictional losses, to more than 60 hours/day for [flow modulated](#) systems. Therefore, the assumption of a fixed HDF of 24 hours/day can introduce large systematic errors into [leakage](#) calculations based on [night flows](#).

The HDF is calculated by summing the correction factor $(P_i/AZNP)^{N1}$ for each hour or quarter hour during the day where the [pressure](#) P_i is assessed at the [average zone point](#) at time i . [N1](#) should be assessed from an [N1 step test](#) or by taking a view on the mains material type and the level of leakage. In the absence of any other data, then it is sensible to use $N1 = 1$.

The HDF for an area such as a [zone](#) or a [DMA](#) with several [DPAs](#) should be calculated by property weighting the HDFs of all the individual [DPAs](#) that make up the zone. Also sometimes referred to as the [night day factor](#) or T factor, although it is considered that [hour to day factor](#) is preferable.

Fixed and Variable Area Discharge (FAVAD)

FAVAD stands for [Fixed and Variable Area Discharge](#) relationship. It was developed by John May in 1994. It describes the fact that [leakage](#) on the network will occur through a mixture of holes, some of which will have paths which do not vary with [pressure](#) and some of which will have paths that do vary with [pressure](#).

N1 Factor

The [N1](#) factor is used to calculate the [leakage](#) versus [pressure](#) relationship:

$$L_1 = L_0 \times (P_1/P_0)^{N1}$$

where L is the [leakage](#) and P is the [pressure](#). The higher the [N1](#) value, the more sensitive existing [leak](#) flow rates will be to changes in [pressure](#). [N1](#) factors range between 0.5 with corrosion holes only in metallic systems and 1.5, with occasional values of up to 2.5. In [distribution systems](#) with a mix of pipe materials and low [leakage](#), [N1](#) factors may be of the order of 1–1.15. Therefore, a linear relationship can be assumed initially until [N1 Step Tests](#) are carried out to derive a more accurate [N1](#) factor. Recent developments have shown that when the [FAVAD](#) principles are applied then [N1](#) is a function of [pressure](#), but that this does not become significant until pressures are below 25 m.

N1 Step Test

The N1 step test, sometimes referred to as a pressure step test, is used to determine the **N1** value for areas of the **distribution network**. **Net flow** to the area, e.g. a **zone** or a **DMA**, and **pressure** at the **Average Zone Point** are recorded. During the test, **pressure** in the area is reduced in a series of steps by changing the settings on a **PRV**. This pressure reduction, together with the corresponding net inflow reduction, form the basis for the calculation of **N1**.

N2 Factor

The N2 factor was introduced when it was believed that the relation between burst frequency and **pressure** could be expressed as:

$$BF_1 = BF_0 \times (P_1/P_0)^{N2}$$

where BF is the burst frequency in no/yr and P is the **pressure**. It has now been found to be slightly more complicated, having an offset for non-pressure dependant bursts. So, the relationship is now considered to be:

$$BF_1 = (BF_0 - BF_{npd}) \times (P_1/P_0)^{N2} + BF_{npd}$$

where BF_{npd} is the burst frequency of non-pressure dependent leaks. The formula has to be applied separately for **mains burst frequency** and **_Service_Pipe_Burst_1 service pipe burst frequency**. N2 is of the order of 3.

N3 Factor

The N3 factor is used to describe the **pressure/consumption** relationship:

$$C_1 = C_0 \times (P_1/P_0)^{N3}$$

where C is the **consumption**. There is a different N3 factor for internal use, e.g. toilet cistern, or external use, e.g. hosepipe watering. Typical values of N3 are 0–0.2 for internal use and 0.5–0.75 for external use.

MAINS AND SERVICE PIPE REHABILITATION

Rehabilitation is the generic term covering any form of renovation or replacement of pipes to restore or upgrade its performance. **Mains** and **service pipe** rehabilitation can therefore be carried out to assist **leakage management**. Rehabilitation is undertaken to reduce repetitive **detection** and **repair** (find and fix) activity and should therefore be targeted at high **burst** frequency **mains** and/or **service pipes**.

Mains Relining

Mains relining is a technique for pipe refurbishment and may be also be carried out to improve water quality. Typical relining materials are cement, epoxy or polyurethane. While many of these linings do not have any structural capability and will not stop or reduce **burst** frequency, some newer semi-structural linings now exist which will cover small holes. There is, however, evidence that pipe **burst** frequencies increase following relining because of the stress that the pipes are subjected to in the cleaning process. There can also be severe problems with damage to **tapping points** due to scraping, which is usually used as part of the cleaning process. Therefore, relining should not be considered for refurbishment of pipes for leakage control reasons.

Open Cut Replacement

Open cut replacement is where a full-length trench is excavated down to the pipe, the old pipe removed and a new one installed. This process causes maximum disruption to the general public in the locality.

Pipe Bursting

Pipe bursting is a technique for mains replacement using what is referred to as a trenchless technique in order to minimise the level of disruption to the public. In this case, an entry and exit pit are excavated at about 100 m intervals, usually coinciding with existing **valves** or **hydrants**. A pneumatic percussive “torpedo” is then pulled through, breaking (bursting) the existing **main** and pushing the fragments into the surrounding ground. The torpedo pulls through a sacrificial duct made from PE or PVC at the same time. There is also the pipe cutting or splitting method where the existing **main** is sliced and levered open. A new PE **main** is then slip-lined through the duct. Excavations must be made in order to replace each service **connections**. The technique is also referred to as the pipeline insertion method (PIM).

Slip Lining

In slip lining, a new PE [main](#) is inserted through the existing [main](#). It therefore has a smaller diameter than the original [main](#). The diameter needed should be validated using [hydraulic modelling](#). Significant reductions in [leakage](#) contribute to allowing smaller diameter [mains](#) to be used.

Roll Down

Roll down is a similar technique to [die drawing](#). The PE pipe is folded or passed through rollers to reduce its diameter, rather than put under tension, prior to insertion.

Die Drawing

Die drawing is where a PE pipe is drawn through a die to reduce its diameter. While the pipe is still under tension it is pulled through the existing [main](#), after it has been cleaned. When the tension is released the pipe attempts to return to its original diameter until it creates an interference fit with the existing pipe. In this case the new PE pipe can create a leak-proof lining which may or may not be structural. The technique is also referred to as swage lining.

Service Pipe Rehabilitation

It is generally more economic to relay a new [service pipe](#) along a new line rather than refurbish the existing [service pipe](#). This can be carried out by digging a new trench or by using a mole to install a new pipe without the need to dig a new trench. This is sometimes referred to as directional drilling.

There are several techniques for in-situ service pipe refurbishment. One technique called pipe pulling involves pulling the existing pipe through the ground while pulling a new pipe in behind it. Another technique is to line the service pipe with a plastic liner (usually made from PET) which can be inserted and then subsequently inflated inside the pipe.

Pipe Condition Surveying

Pipe condition surveying is the process of establishing the general condition of a water [main](#). In the case of metallic pipes, this can involve the estimation of the residual life of a water [main](#) taking into account both internal and external corrosion. It can also include the investigation of any build-up of deposits within the main. Any examination of the internal condition is carried out in a similar fashion to [intrusive leak detection](#) and will require access into the main through [hydrants](#), [tapings](#) or [pigging chambers](#).

Pigging Chamber

A pigging chamber is a specific piece of furniture which allows access to a water [main](#) for the insertion of a swab (pig) for the purpose of [mains cleaning or flushing](#), see [Figure 43](#). There will also be a pigging chamber for receiving and recovering the swab. They will generally be used on larger diameter mains when a [hydrant](#) cannot be used.

Mains Flushing

Mains flushing is a process for cleaning a [distribution network](#) to remove deposits and encrustations with the intention of reducing the risk of customers experiencing discoloured water. There are several techniques of mains flushing including air scouring, swabbing and ice pigging. Most techniques can be adjusted to give different levels of aggression depending on the extent and types of deposits within the [mains](#). Customers must be warned prior to any cleaning exercise. [Hydraulic modelling](#) can be used to check whether the velocities required in order to re-suspend deposits in the [mains](#) can be achieved. Existing [hydrants](#) can be used by most techniques but some may need the construction of bespoke entrance and exit apparatus (e.g. [pigging chambers](#)) which adds significantly to the cost.

LEAKAGE MODELLING

Leakage modelling is the generic term for the process of computer simulation and analysis of leakage using the relationship of leakage to the pressure, bursts and run times, that have now been established and understood.

Demand Calibration

Demand calibration is a methodology to analyse 24-hour [net flow](#) and [pressure](#) data of a hydraulically discreet part of the distribution system, e.g. a [zone](#) or a [DMA](#), using the [N1](#) pressure-leakage relationship principles and results of the [N1 Step](#)



Figure 43 Typical pigging chamber (Source: K Atkinson).

Test. Using this technique the **net flow** can be split into **consumption** and **leakage**, which can be further split into **background leakage** and leakage from **bursts**, both **reported** and **unreported**.

Component Loss Model (CLM)

A **component loss model** (CLM) can be constructed to estimate each of type of leakage (**background**, **reported bursts** and **unreported bursts**) on each of the various components of the network, such as **mains**, **service connections**, **private service pipes** and even **trunk mains** and **plumbing systems**. By including the relationship of **leakage** to the extent of the assets, the **burst frequencies**, the **pressure** and the **awareness**, **location** and **repair** times, and calibrating this to the existing **leakage**, it is possible to use the CLM to forecast possible options to reduce **leakage**. Also known as the burst and background estimation (BABE) model or Real Loss Component Analysis.

Hydraulic Modelling

A hydraulic model is a computer representation of a **distribution system** which models the **flows** and **pressures** within the network. The model uses standard head-flow equations, such as Hazen–Williams or Colebrook–Wight, to relate head loss through a pipe as a function of the **flow**. Standard pipe roughness values based on material and age are used. Calibration is the process of adjusting the pipe roughness so that the difference between predicted **pressures** and actual recorded **pressures** are minimised. **Leakage**, established by a simple water balance for the period being modelled, is usually distributed evenly across all nodes within the model. Techniques have been developed which attempt to predict where **leaks** are on the system by changing the distribution of **leakage** to further improve the calibration. There are several well-developed modelling packages.

Economic Level of Leakage (ELL)

The ELL is the level of **leakage** at which the cost of undertaking additional **leakage control** activity is equal to the cost of producing the water that would be saved by this additional **leakage control**, i.e. the total cost of **leakage control** and production cost of **leakage** is at a minimum, see **Figure 44**.




Figure 44 Figure to illustrate the concept of ELL (Source: D Pearson).

In the illustration shown in Figure 44, only the level of **active leakage control** is varied in order to find the optimum economic balance. This is the only true operational cost that can impact on the level of **leakage**. This is referred to as the short-run economic level. However, there are capital interventions, such as **pressure management** and **mains rehabilitation**, that can be undertaken to reduce **leakage**. The economic level of **pressure management** and rehabilitation can and should be assessed. In this case, because capital costs are being investigated, this is referred to as the long-run **economic level of leakage**.

Should there be no constraints on water available for **supply** then the cost of water lost is assessed using the **marginal cost of water production**, namely power, chemicals and sludge disposal. However, if water **supply** is constrained, then it may be more economic to undertake further **leakage control** rather than develop a new water resource. In this case, the **marginal cost of water** is increased to include the discounted cost of developing the next resource. This is referred to as **the marginal value of water**. Where any water that is saved from leakage reduction can be resold, then the **marginal cost of revenue** should be used.

APPARENT LOSS MANAGEMENT

Apparent loss management encompasses activities designed to manage, control and reduce all aspects of **apparent losses**. The areas of **apparent losses** can be grouped into four different and distinct areas. These are illustrated in Figure 45.

Typical activities designed to control **apparent losses** in each of the four areas are listed below:

Customer metering inaccuracies

- Programme to replace meters on a regular cycle
- Correct sizing verification of average flow volume against meter size
- Programme to replace meters with those of a higher class
- Physical surveys to check for installation arrangements
- Physical site check of meters with zero and/or low consumption registered in the billing system

Data handling and billing errors

- Checks of the customer billing register against other databases, such as postal or police address files
- Regular changing of meter reader routes
- Billing database checks for flagged premises
- Physical survey of premises indicated as demolished

Underestimation of unmeasured consumption

- Ensure metering of communal and other supplies even if the customer is not charged on meter readings
- Increase statistical size and socio-economic groupings of consumption monitors used to estimate unmeasured domestic consumption
- Consider a programme to extend metering of non-household premises




Figure 45 The four areas of [apparent losses](#) (Source: D Pearson).

Unauthorised consumption

- Physical surveys to identify illegal connections
- Install lead seals on meter screws/nuts
- Physical survey of unmeasured fire supplies to check for abusive consumption
- Random excavation based on billing consumption records

Meter Under-Registration (MUR)

[Meter under-registration](#) (MUR) is the amount that any [flow meter](#) under-records or over-records the true volume of water that passes through the [meter](#).

MUR is defined, in ISO 4064, as:

$$MUR = (Volume_{Actual} - Volume_{Measured}) / Volume_{Actual}$$

Thus, MUR is between -100 and +100% and the actual volume that should be recorded is:

$$Volume_{Actual} = Volume_{Measured} / (1 - MUR)$$

Economic Level of Apparent Losses (ELAL)

The ELAL is the level of [apparent losses](#) where the marginal cost of carry out further measures to reduce [apparent losses](#) is equal to the [marginal cost of revenue](#) that would be gained by reducing [apparent losses](#). The concept of ELAL is exactly the same as the concept of the [economic level of leakage \(ELL\)](#). [Figure 46](#) illustrates the example of where the level of [unauthorised consumption](#) is managed by carrying out surveys to identify [illegal connections](#) and theft. The cost of carrying out the surveys increases as the frequency of the surveys is increased. [Unauthorised consumption](#), and hence revenue lost, will be lower with more frequent surveys. There will be an economic balance where the increase in survey costs will outweigh the increase in revenue. This will then be the [economic level of apparent losses](#). The same process has to be repeated for all the different activities that could be carried out to [control apparent losses](#). Each activity has to be carried out at the frequency when the marginal cost of carrying out the work to reduce losses is equal to the [marginal cost of revenue](#).




Figure 46 Figure to illustrate the concept of ELAL (Source: D Pearson).

PERFORMANCE INDICATORS (PIS)

A performance indicator is a measurable value that demonstrates how effectively a utility is achieving key objectives. Organisations use [performance indicators](#) at multiple levels to evaluate their success at reaching targets. They can also be used to compare performance and set targets between [zones](#) within a large utility. In addition, they can also be used to compare performance between different utilities, although care must be taken in their interpretation, particularly if different utilities have differing external factors, costs and constraints.

No single performance indicator will be fit-for-all-purposes or wholly indicative of water system efficiency. [Performance indicators](#) have, therefore, to be selected carefully and chosen to be fit-for-purpose for a given situation.

Performance Indicators for Non-Revenue Water

It is difficult to find a suitable [PI](#) for [NRW](#) as [NRW](#) is a mixture of both [apparent losses](#) and [real losses](#) and the [PIs](#) for these components individually are quite different. It is common to express [NRW](#) as a percentage of [system input volume](#) and performance targets set using this measure. However, the IWA WLSG recommends that this measure **should not** be used as it is totally inappropriate.

If a single [PI](#) for [NRW](#) is required, then this should be in the form of [NRW](#) per [connection](#) i.e.:

$$NRW/Connection = NRW_{wsp} \times (24/ST)/Number\ of\ Connections$$

Alternatively, it is recommended that [NRW](#) is split into the two main components of [real losses](#) and [apparent losses](#), even if this split is estimated, with [PIs](#) then being set and tracked for the two components i.e. [PI for real losses](#) and [PI for apparent losses](#).

Performance Indicator for Apparent Losses

The most suitable [PI](#) for [apparent losses](#) is to express these in relation to the volume which should have been measured as the [authorised consumption](#) if there were no [apparent losses](#). Thus:

$$PI_{AL} = AL/(AC + AL)\%$$

Thus, PI_{AL} can be between 0 and 100%. This is equivalent to the definition of [meter under-registration \(MUR\)](#).

Performance Indicators for Real Losses

[Real losses](#) (or physical losses) cannot be totally eliminated. It is therefore inappropriate to use a measure that implies that [real losses](#) can be reduced to zero. In order to address this the concept of the [unavoidable level of losses](#) has been developed. The recommended [PI](#) for [real losses](#) is then derived by expressing [current losses](#) as ratio of [unavoidable level of losses](#). This is referred to as the [infrastructure leakage index](#).

Current Annual Real Losses (CARL)

CARL is the current best estimate of the average [real losses](#) over a year evaluated using the [IWA Standard Water Balance](#). It can be in the form of volume per year or volume per day. In the case of a system with [intermittent water supply](#), CARL should be evaluated when the system is pressurised.

Infrastructure Leakage Index (ILI)

The ILI is a measure of how well a [distribution](#) network is managed, maintained, repaired and rehabilitated as regards control of [real \(physical\) losses](#), at the current operating pressure. It is the ratio of [current annual volume of real losses \(CARL\)](#) to [unavoidable annual volume of real losses \(UARL\)](#).

$$ILI = CARL/UARL$$

In the case of a system with [intermittent water supply](#) the calculation of ILI must take into account the [supply time](#). The calculation is therefore:

$$ILI = CARL_{wsp} \times (24/ST)/UARL$$

[CARL](#) and UARL must be evaluated in the same units, typically m³/d, m³/yr, Ml/d, Ml/yr, gal/d/, gal/yr. As a ratio, the ILI has no units and thus facilitates comparisons between countries that use different measurement units, namely metric, U.S. or imperial.

Since the UARL takes pressure into account, ILI is only a measure of leakage detection and repair performance. [Average operating pressure](#) should be stated along with the ILI so a view can be taken as to whether an opportunity exists to undertake [pressure management](#).

Losses per Connection (when system pressurised)

As a faster and simpler performance index, to be used for target setting and tracking progress in an individual system, unit losses per [connection](#) can be used, usually expressed in the form of l/conn/d or gal/conn/d. It is therefore not necessary to know the length of [mains](#) or the [pressure](#). The slight downside is that it tends to disadvantage systems with a very low [connection density](#), and it is therefore not recommended for use on systems with a connection density less than 20 connections/km. If the number of connections is not known, a sensible estimate should be made based on a knowledge of likely connection ratio to billed premises.

For a system with continuous supply, the calculation is:

$$Losses/Connection = Leakage/Number\ of\ connections$$

In the case of a system with [intermittent water supply](#) the calculation of losses per connection must take into account the [supply time](#). The calculation is therefore:

$$Losses/Connection = Leakage_{wsp} \times (24/ST)/Number\ of\ connections$$

Systems which are [metered](#) at the property boundary will have lower losses per connection than comparable systems which are [metered](#) internally or unmetered as leakage in these latter systems will include leakage on [private service pipes](#). Losses per connection are usually expressed as l/conn/d or g/conn/d.

Losses per Unit Length of Main (when system pressurised)

Unit losses per length of main, usually expressed in the form of m³/km/d, is more appropriate for systems with a connection density of less than 20 connections/km.

For a system with continuous supply, the calculation is:

$$Losses/Unit\ length\ of\ Main = Leakage/Length\ of\ Mains$$

In the case of a system with [intermittent water supply](#) the calculation of losses per connection must take into account the [supply time](#). The calculation is therefore:

$$Losses/Unit\ length\ of\ Main = Leakage_{wsp} \times (24/ST)/Length\ of\ Mains$$

Systems which are [metered](#) at the property boundary will have lower losses per unit length of main than comparable systems which are [metered](#) internally or unmetered as leakage in these latter systems will include leakage on [private service pipes](#). Losses per length of main are usually expressed as $\text{m}^3/\text{km}/\text{d}$ or $\text{g}/\text{mile}/\text{d}$.

Pressure Management Index (PMI)

The PMI has been suggested as a way of measuring network performance in respect to [pressure management](#). In this case, the [average zone pressure](#) is expressed as a ratio of the Standard of Service on pressure, be that statutory, regulatory or simply a guidance level.

Normalised Mains Burst Frequency

In order to compare [mains burst frequencies](#) between areas it is necessary to express burst frequencies per unit length of mains. This is referred to as the normalised mains burst frequency. It is common to express the normalised mains burst frequency as no/100 km/yr. Alternatively, no/100 ml/yr can be used.

Normalised Service Pipe Burst Frequency

In order to compare [service pipe burst frequencies](#) between areas it is necessary to express burst frequencies per unit number of [connections](#). This is referred to as the normalised service pipe burst frequency. It is common to express the normalised service pipe burst frequency as no/1000 conns/yr. However, expressing this as a ratio of the number of [connections](#) can be misleading depending on the [connection ratio](#). It is, therefore, more sensible to split the frequency of bursts between those occurring on [service connections](#) and those occurring on [private service pipes](#). See [normalised service connection burst frequency](#) and [normalised private service pipe burst frequency](#).

Normalised Service Connection Burst Frequency

In order to compare [service connection burst frequencies](#) between areas it is necessary to express burst frequencies per unit number of [connections](#). This is referred to as the normalised service connection burst frequency. It is common to express the normalised service connection burst frequency as no/1000 conns/yr.

Normalised Private Service Pipe Burst Frequency

In order to compare [private service pipe burst frequencies](#) between areas it is necessary to express burst frequencies per unit number of [properties](#). This is referred to as the normalised private service pipe burst frequency. It is common to express the normalised mains burst frequency as no/1000 props/yr.

FINANCIAL

Marginal Cost of Water (MCW)

The [marginal cost of water](#) is defined as the additional cost of producing or purchasing and distributing an additional unit of water, such as 1MI. In the case of a water source, it is the marginal cost of power used in the abstraction, treatment works and distribution pumping, the marginal cost of chemicals and the marginal cost of sludge disposal from the treatment works. It does not include any capital items, such as treatment works, or revenue items, such as manpower or maintenance costs, which would not be readily saved by reducing output by 1 MI/d. The marginal cost is often derived by adding the annual costs of the items mentioned and dividing by the annual output. This is the *unit* cost of water. It is not necessarily the same as the [marginal cost](#) when the cost-vs-output relationship is not constant. In the case of water imported from another utility, it is the volumetric charge rate paid to the supplier of the water.

The [marginal cost of water](#) is used when evaluating the short run [economic level of leakage \(ELL\)](#). The [ELL](#) should be evaluated at [WRZ](#) level. In theory the maximum [marginal cost of water](#) of any sources or supply feeding a [WRZ](#) should be used in the calculation of the [ELL](#) on the basis that it would be sensible to pass on leakage reductions by reducing production or purchase at the most expensive source or supply of water. However, the average marginal cost of all sources in or supplies to a [WRZ](#) is often used instead of the maximum. The [marginal cost of water](#) for the [WRZ](#) is either the maximum or average [marginal cost of water](#) of the sources feeding the zone plus the marginal cost of distribution pumping.

The units of MCW are typically $\text{€}/\text{m}^3$, $\text{£}/\text{MI}$, $\text{\$/MI}$, p/m^3 , c/gal .

Marginal Value of Water (MVW)

Where the [headroom](#) in a [WRZ](#) is very low, it may be necessary to evaluate whether it is more cost efficient to carry out additional [leakage control activity](#) rather than develop a new resource. In this case, the additional cost of constructing the water resource and associated treatment works (including annual maintenance) has to be added to the [marginal cost of water](#) of the [WRZ](#). This total is referred to as the marginal [value](#) rather than [cost](#) of water. This is then used in the [ELL](#) assessment to evaluate the level of additional leakage measures, such as additional [active leakage control](#) and additional [pressure management](#). The units of the [marginal value of water](#) are the same as those for the [marginal cost of water](#).

Marginal Cost of Revenue (MCR)

The [marginal cost of revenue](#) is the loss in income when a unit of water is not charged/recovered. It is therefore the volumetric charge on the tariff. The cost of revenue is used to judge the value of carrying out activities to reduce [apparent losses](#). At the [economic level of apparent losses](#), the marginal cost of additional apparent loss control will equal the [marginal cost of revenue](#). The units of the [marginal cost of revenue](#) are the same as those for the [marginal cost of water](#).

Capital Expenditure (CAPEX)

[Capital expenditure](#) or CAPEX is the cost of developing or providing non-consumable parts for the product or system. [Capital expenditures](#) is the cost to purchase major physical goods or services that will be used for more than one year. For example, a utility may have [capital expenditure](#) to increase or improve its fixed assets. Examples of [capital expenditure](#) associated with [leakage control](#) and water loss management would include the purchase of [PRVs](#), [DMA meters](#), [pressure loggers](#), [flow loggers](#), [correlators](#) and [acoustic sensors](#). It is the asset depreciation, based on its financial life, rather than the expenditure on capital items themselves that impacts on the “bottom line” of a utility. In the case of municipal utilities, [capital expenditure](#) will be controlled, and hence possibly limited, by central or local government. In the case of corporate or private utilities [capital expenditure](#) will be controlled by internal budgetary control and the ability to raise money on the financial markets.

Operational Expenditure (OPEX)

[Operational expenditure](#) or OPEX is the ongoing cost for running a product, business or system. It may also be referred to as revenue expenditure. Examples of [operational expenditure](#) associated with [leakage control](#) and water loss management would include staff salaries, rent, administration, travel and cost of outsourced [leakage detection](#) resources.

Discounted Cash Flow (DCF)

Often it is necessary to combine the effect of both operating and capital costs. This process is referred to as [discounted cash flow](#) (DCF) analysis if the capital cost is discounted into an equivalent revenue stream or net present value (NPV) analysis if the revenue stream is converted into an equivalent lump sum. In either case, a discount rate must be used to carry out the conversion and is usually provided by national, federal or local government.

INFORMATION TECHNOLOGY

Geographical Information System (GIS)

A geographic information system (GIS) is designed to capture, store, manipulate, analyse, manage and present spatial or geographic data, for example, providing information on the location and [attributes](#) of water [mains](#) or [DMAs](#).

Work Management System (WMS)

A computer system used to record physical work undertaken on assets and track the progress of work. Also sometimes referred to as an asset management system or maintenance management system. It is common to have separate systems for “point” assets such as pumps, treatment works, for example, and “linear” assets such as water mains or sewers. A linear asset management system is useful in leakage management as it is the primary source for information on the number of leaks on the various assets and the time that leaks run prior to repair. It is feasible, but not common, to include [non-revenue meters](#), [PRVs](#) and, say, [air valves](#) on a point asset management system so that warranty issues and regular maintenance schedules on these assets can be managed. A point asset [work management system](#) can be designed to record and manage activity on [leak detection surveys](#) or this may be held on a separate system or possibly the [leakage management system](#).

Leakage Management System (LMS)

A computer system for managing all aspects of [leakage management](#). It will have access to all [flow](#) and [pressure](#) monitoring data on the [network](#). It can be separate from or integrated with the [GIS](#), [work management](#) and [customer billing system](#) so that relevant information on [DMA](#) boundaries, [property](#) counts, lengths of [main](#), [leakage detection surveys](#), [leaks](#) found and repaired, can be viewed and compared against the [flows](#) and [pressures](#) on the system. The [leakage management system](#) will have details of the [network hierarchy](#) so that leakage can be reported at multiple levels within the utility.

Customer Contact System

A computer system that records and tracks all customer contacts with a utility. This will include all contacts including no water, poor [pressure](#), visible [leak](#) and water quality concerns, among other issues. The system is relevant to [leakage management](#) as it records when customers report a visible [leak](#) and tracks progress and results of subsequent inspections.

Customer Billing System

A computer system that has information on consumers and their [consumption](#). This is critical for [leakage management](#). The customer billing system will usually also include all information on the [revenue meters](#) including type, manufacturer, model, class, date purchased and date installed for example, in order to assist with all aspects of managing the meter stock.

Waste Notice System

A computer system used to manage the process of issuing and monitoring waste notices issued to owners of premises for the repair of leaks on [private service pipes](#) or repair of [plumbing losses](#). Also sometimes referred to as leak notice systems or defective fittings notice systems.

Index

A

Abstraction Meter, 16
Accelerometers – *See* leak noise correlator
Acoustic (Noise) Loggers, 29, 31–33, 35–37, 39
Active Leak – *See* reported leak and unreported leak
Active Leakage Control (ALC), 21, 27, 31, 36, 47, 52
Active Property, 8
Advanced Metering Infrastructure (AMI), 17
Air Valve (AV), 12–13, 52
Altitude Control Valve, 13
Apparent Loss Management, 47
Apparent Losses (AL), 18–20, 47–49, 52
Appurtenances, 12, 20, 28–29, 32, 34–35, 38
Aqueduct, 2–3
Area of Interest (AOI), 32, 36
Asset Management System – *See* work management system
Attributes, 23, 26–27, 52
Authorised Consumption, 17–20, 48–49
Automatic Meter Reading (AMR), 17
Available Supply, 1
Average Operating Pressure (AOP), 27, 43, 50
Average Zone Night Pressure (AZNP), 26–27, 43
Average Zone Point (AZP), 27, 42–44
Average Zone Pressure, 42–43, 51
Awareness Time, 31

B

Background Leakage, 20, 26–27, 40, 46
Background Losses – *See* background leakage
Billed Authorised Consumption, 18–19
Billed Metered Consumption, 18
Billed Unmetered Consumption, 18–19, 21
Bottom Up Leakage Assessment (BU), 26

Boundary Box – *See* meter box
Boundary Valve, 8, 27, 34
Break – *See* leak
Bulk Meter, 16
Burst – *See* leak
Burst and Background Estimation (BABE)
 Model – *See* component loss model
Burst Frequency, 28, 44, 51
Butterfly Valve, 13–14

C

Capital Expenditure (CAPEX), 52
Circulating Valve, 8, 38
Circumferential Break, 29
Commercial Losses – *See* apparent losses
Common Private Service Pipe, 6–8
Communication Pipe – *See* service connection
Component Loss Model (CLM), 30, 46
Connection, 3–6, 8, 10–11, 16, 18–21, 23, 27–29, 32, 38, 44, 46, 48–51
Connection Density, 8, 50
Connection Ratio, 8, 50–51
Consumption, 1–2, 8, 17–21, 25–26, 38, 41, 44, 46–49, 53
Continuity of Supply – *See* intermittent water supply
Continuous Logged User (CLU), 26
Corporation Stop Cock – *See* ferrule
Correlating Acoustic Loggers, 36–37
Correlator Survey, 33–34
Critical Point (CP), 42
Critical Pressure Control Pressure Management, 42
Cul-de-sac Monitor – *See* small area monitor
Curb Stop – *See* external stop tap
Current Annual Real Losses (CARL), 50

Customer Billing System, 8, 17, 53
 Customer Contact System, 53
 Customer Meter – *See* revenue meter
 Customer Metering Inaccuracies, 18–19, 47

D

Daily Leakage, 22, 40, 43
 Data Handling and Billing Errors, 18–19, 47
 Defective Fittings Notice System – *See* waste notice system
 Demand, 1–3, 17, 21–25, 28, 42, 45
 Demand Calibration, 45
 Deployable Output, 1
 Die Drawing, 45
 Discounted Cash Flow (DCF), 52
 Discrete Pressure Area (DPA), 42
 Distribution Input Meter, 16, 20, 26
 Distribution Main – *See* main
 Distribution Network Assets, 3
 District Metered Area (DMA), 8, 13, 16, 20, 23–29, 31–32, 34–35, 38, 43–45, 52–53
 Diurnal Demand Pattern, 3, 21–22, 24
 DMA Meter, 16, 23, 26, 29, 38, 52
 Downstream Leakage, 26
 Drought, 1–2, 17
 Drought Restrictions, 2, 17

E

Economic Level of Apparent Losses (ELAL), 48–49, 52
 Economic Level of Leakage (ELL), 1, 46–48, 51, 51–52
 Edge of Street (EoS), 4
 Electromagnetic Meter (EM), 15
 Electronic Listening Stick, 34–35
 Equivalent Service Pipe Burst (ESPB), 32
 External Stop Tap, 4, 7, 9–10, 29, 33

F

Ferrule, 10–11
 Ferrule Cock – *See* ferrule
 Financial, 51–52
 Fire Hydrant (FH), 12
 Fittings, 12, 53
 Fixed and Variable Area Discharge (FAVAD), 43
 Fixed Outlet Pressure Management, 41
 Flow, 10, 13–16, 18–28, 30–32, 38, 40–48, 52–53
 Flow Logger, 16, 23, 52
 Flow Meter, 14, 16, 41, 48
 Flow Metering, 14
 Flow Modulated Pressure Management, 41–42
 Full-bore Meter, 15, 17

G

Gas Injection, 38
 Gate Valve – *See* sluice valve
 Geographical Information System (GIS), 8, 36, 52–53
 Ground Microphone, 34–35
 Ground Penetrating Radar (GPR), 37

H

Headroom, 1–3, 21, 52
 Hour to Day Factor (HDF), 23, 40–43
 Hydrant, 12, 19, 23, 29, 32, 34–38, 44–45
 Hydraulic Modelling, 45–46
 Hydrophones – *See* leak noise correlator

I

Illegal Connection, 8, 19, 48
 Inactive Property, 8
 Individual Household Monitor (IHM), 21
 Information Technology, 52
 Infrastructure Condition Factor (ICF), 26–27
 Infrastructure Leakage Index (ILI), 49–50
 In-pipe Leak Detection – *See* intrusive leak detection
 Insertion Meter, 10, 15
 Intermittent Water Supply (IWS), 2–3, 25, 50
 Internal Stop Tap, 5, 10, 29
 Intervention – *See* leakage detection survey
 Intrusive Leak Detection, 12, 37, 45
 IWA Standard Water Balance, 17–21, 26, 50

L

Leak, 2–3, 8, 12, 16–18, 20–34, 36–40, 43–53
 Leak Duration, 31
 Leak Noise Correlator, 32–33
 Leak Notice System – *See* waste notice system
 Leak on Appurtenances, 29
 Leak on Communication Pipe – *See* leak on service connection
 Leak on Main, 29
 Leak on Private Service Pipe, 29
 Leak on Service Connection, 29
 Leak on Supply Pipe – *See* leak on private service pipe
 Leak Repairs, 38
 Leakage, 2–3, 8, 16–18, 20–32, 36, 38–40, 43–53
 Leakage and Overflows from Utility Storage Tanks, 20
 Leakage Control, 21, 23, 27, 31–32, 36, 40, 44, 46–47, 52
 Leakage Control Area (LCA) – *See* sub-DMA
 Leakage Detection, 21, 29–32, 50, 52–53
 Leakage Detection Survey, 31–32, 53
 Leakage Detection Techniques, 32
 Leakage Management, 2, 8, 16–17, 21, 23–24, 26, 28–31, 40, 44, 52–53
 Leakage Management System (LMS), 2, 16, 28, 30, 40, 52–53
 Leakage Modelling, 45
 Leakage on Service Connections up to the Point of Customer Metering, 18, 20
 Leakage on Transmission and/or Distribution Mains
 Leaks, 12, 20–21, 24, 26–34, 38, 40, 44, 46, 52–53
 Legal Connection, 8, 19, 48
 Legitimate Domestic Night Consumption (LDNC), 25
 Legitimate Night Consumption (LNC), 25
 Legitimate Non-household Night Consumption (LNHHNC), 25
 Locate, Localise, Pinpoint, 32
 Location Time, 29–31
 Longitudinal Break, 29
 Long-side Connection, 5

Losses per Connection (when system pressurised), 50
 Losses per Unit Length of Main (when system pressurised), 50–51

M

Main, 1–6, 8, 10–13, 15, 17–21, 23–24, 26–30, 32, 34, 37–40, 43–47, 49–53
 Mains and Service Pipe Rehabilitation, 44
 Mains Appurtenances Only Sounding Survey, 34
 Mains Burst Frequency, 28, 44, 51
 Mains Flushing, 12, 45
 Mains Relining, 44
 Mains Side Leak – *See* leak on service connection
 Maintenance Management System – *See* work management system
 Manual Listening Stick, 34
 Marginal Cost of Revenue (MCR), 47–48, 52
 Marginal Cost of Water (MCW), 47, 51–52
 Marginal Value of Water (MVW), 47, 52
 Meter Box, 9, 33
 Meter Calibration, 16
 Meter Reading Lag, 17
 Meter Under-Registration (MUR), 20, 48–49
 Meter Verification, 16
 Minimum Achievable Night Flow (Mabl), 26
 Minimum Achieved Night Flow, 26, 32
 Minimum Flow (MF), 22, 24–25, 32, 43
 Minimum Historic Night Flow (MinHist) – *See* minimum achieved night flow
 Minimum Night Flow (MNF), 23–27, 43
 Minimum Night Flow Method (MNF Method), 24–26, 43
 Multi-jet Meter – *See* turbine meter

N

N1 Factor, 43
 N1 Step Test, 43–45
 N2 Factor, 44
 N3 Factor, 44
 Natural Rate of Rise of Leakage (NRR), 28
 Net Flow, 23–25, 32, 44–46
 Net Present Value (NPV) – *See* capital expenditure
 Network Hierarchy, 2, 20–21, 26–27, 53
 Night Day Factor (NDF) – *See* hour to day factor
 Night Leakage, 22, 24–25, 43
 Night Line – *See* minimum night flow
 Non-Intrusive Leak Detection, 37
 Non-potable Water, 1, 3
 Non-revenue Meter, 16, 52
 Non-Revenue Water (NRW), 18–19, 49
 Non-surfacing leak – *See* reported leak and unreported leak
 Non-technical Losses, 19
 Non-visible Leak – *See* reported leak and unreported leak
 Normalised Mains Burst Frequency, 28, 51
 Normalised Private Service Pipe Burst Frequency, 28, 51
 Normalised Service Connection Burst Frequency, 28, 51
 Normalised Service Pipe Burst Frequency, 28, 51

O

Occupancy, 8, 20–21
 Open Cut Replacement, 44
 Operability Test, 25–26

Operational Expenditure (OPEX), 52
 Other Failure Modes, 29
 Outage, 1

P

Passive Leakage Control, 32
 Per Capita Consumption (PCC), 20–21
 Per Household Consumption (PHC), 21
 Performance Indicator for Apparent Losses, 49
 Performance Indicators (PIs), 3, 49
 Performance Indicators for Non-Revenue Water, 49
 Performance Indicators for Real Losses, 49
 Physical Losses – *See* real losses
 Piece Through Repair, 38–39
 Piezometer – *See* pressure gauge
 Pigging Chamber, 37, 45–46
 Pipe Bursting, 44
 Pipe Condition Surveying, 45
 Pipe Saddles – *See* tapping tee
 Pipeline Insertion Method (PIM) – *See* pipe bursting
 Plumbing Losses, 20, 25–26, 53
 Point of Interest – *See* area of interest
 Point of Supply, 7, 20
 Positive Displacement Meter, 14–15
 Potable Water, 1–3, 16, 38
 Pressure, 3, 9, 12–15, 21, 23, 26–28, 32, 34–35, 37–47, 50–53
 Pressure Control Valve, 13–14
 Pressure Gauge, 34–35, 40
 Pressure Logger, 35, 40, 52
 Pressure Managed Area (PMA), 8, 42
 Pressure Management (PM), 14, 21, 23, 28, 39–43, 47, 50–52
 Pressure Management Index (PMI), 51
 Pressure Management Valve – *See* pressure reducing valve
 Pressure Reducing Valve (PRV), 13–14, 40, 42, 44
 Pressure Reduction, 39–40, 44
 Pressure Relief Valve, 13–14
 Pressure Step Test – *See* N1 Step Test
 Pressure Sustaining Valve (PSV), 13–14
 Pressure Zero Test (PZT), 34, 36
 Primary Main – *See* transmission main
 Private Service Pipe, 4–8, 27–29, 38, 46, 50–51, 53
 Private Service Pipe Burst Frequency, 28, 51
 Private Service Pipe Length, 7
 Production Meter, 16
 Property, 4–6, 8–10, 20–21, 27, 29, 38, 42–43, 50–51, 53
 Property Density, 8
 Property Side Leak – *See* leak on private service pipe
 Pulse Unit, 16, 23

R

Rationing – *See* intermittent water supply
 Raw Water, 1–2, 16
 Reactive Leak – *See* reported leak and unreported leak
 Reactive Survey, 32
 Real Losses (RL), 1, 18–20, 22, 26, 49–50
 Recurring Burst Frequency – *See* natural rate of rise of leakage
 Regular Sounding, 31–32

Remote Node Control Pressure Management – *See* critical pressure control pressure management
 Remote Sensing, 29, 36
 Repair Clamp, 38–39
 Repair Time, 31, 46
 Reported Leak, 20, 24, 26, 28–31
 Revenue Meter, 4, 9, 16–17, 20, 27, 52–53
 Revenue Water, 18–19, 49
 Roll Down, 45
 Rotational Supply, 2–3
 Rotational Supply Designation, 2–3

S

Secondary Main – *See* main
 Sectorisation – *See* district metered area
 Sectors – *See* district metered area
 Service Connection, 4–6, 10, 18, 20–21, 27–29, 38, 44, 46, 51
 Service Connection Burst Frequency, 28, 51
 Service Pipe, 2, 4–8, 11, 15, 17, 20, 27–29, 32, 38, 40, 44–46, 50–51, 53
 Service Pipe Burst Frequency, 28, 44, 51
 Service Pipe Rehabilitation, 44–45
 Service Reservoir (SR), 1–4, 13, 16, 20, 25–26, 29
 Shared Connection, 4, 6
 Short-side Connection, 5
 Single Jet Meter – *See* turbine meter
 Slip Lining, 45
 Sluice Valve (SV), 8, 12–13, 23, 34
 Small Area Monitor (SAM), 21
 Smart Meter, 17, 26
 Smart Network, 28
 Sounding Stick – *See* either manual listening stick or electronic listening stick
 Split, 28–29, 39, 44, 46, 49, 51
 Step Test, 8, 12, 34, 38, 43–45
 Step Valve, 8, 38
 Stop Cock – *See* external stop tap
 Stop Tap, 4–5, 7, 9–10, 29, 33–34, 37
 Stop Tap Box – *See* stop tap chamber
 Stop Tap Chamber, 9
 Stop Tap Sounding Survey, 33
 Stop Valve – *See* stop tap
 Sub-DMA, 2, 23–24, 27, 31
 Supply, 1–8, 10–13, 15–17, 20, 25–26, 28–29, 32, 38–39, 43, 47, 50–51
 Supply Pipe – *See* private service pipe
 Supply Reliability, 2
 Supply Time (ST), 3, 49–50
 Surface Sounding, 32, 34
 Surfacing Leak – *See* reported leak and unreported leak
 Swage Lining – *See* die drawing
 System Input Volume, 17–19, 49

T

T Factor – *See* hour to day factor

Tapping, 8, 10–11, 15, 20, 27, 29, 37, 44
 Tapping Point, 8, 10, 20, 27, 29, 37, 44
 Tapping Tee, 10–11
 Technical Losses, 19–20
 Temporary DMA Rezoning Test, 38
 Time Modulated Pressure Management, 41
 Top Down Leakage Assessment (TD), 26
 Total Integrated Flow Method (TIF Method), 25–26
 Transients, 39–40
 Transmission Main, 3, 20, 26
 Trunk Main – *See* transmission main
 Turbine Meter, 14–15

U

Ultrasonic Meter, 15–16
 Unaccounted for Water (UFW), 19
 Unauthorised Consumption, 18–19, 48
 Unavoidable Annual Real Losses (UARL), 7, 26–27, 50
 Unavoidable Background Leakage (UBL), 7, 27
 Unbilled Authorised Consumption, 18–19
 Unbilled Metered Consumption, 18
 Unbilled Unmetered Consumption, 18–19
 Underestimation of Unmeasured Consumption, 18–19, 47
 Underground Supply Pipe (UGSP) – *See* private service pipe
 Unreported Leak, 20, 24, 26, 28, 30–31
 Upstream Leakage, 26

V

Visible Leak – *See* reported leak and unreported leak
 Void Property – *See* inactive property
 Volumetric Meter, 14–15

W

Wash Out (WO), 12
 Waste Area – *See* sub-DMA
 Waste Notice System, 53
 Water Distribution Network, 2–3, 13, 16, 31–32
 Water Losses, 19–20
 Water Main – *See* main
 Water Operational Area – *See* water supply coverage
 Water Resource Zone (WRZ), 1–3, 51–52
 Water Resources, 1
 Water Supply Coverage, 2
 Water Supply Network, 2, 16, 26, 29
 Water Supply Zone (WSZ), 1
 Water Tower – *See* service reservoir
 Work Management System (WMS), 28–30, 52

Y

Yield of Water Resource System, 1

Z

Zone, 1–3, 7–8, 19–27, 42–45, 49, 51

Standard Definitions for Water Losses

*A compendium of terms and acronyms
and their associated definition in common
use in the field of water loss management*



iwapublishing.com

 @IWAPublishing

ISBN: 9781789060874 (paperback)

ISBN: 9781789060881 (eBook)

ISBN 978-1-78906-087-4



9 781789 060874