

Contents

Chapter One - Introduction	2
Chapter two - Loads calculations	10
Chapter Three - Psychometry	166
Chapter Four - Air distribution	192
Chapter Five - Duct Design	213
Chapter Six - Units Selection	244
Chapter Seven - Chilled Water System	252
Chapter Eight — Operation Control By BMS	261

Chapter One

Introduction



1.1. Air conditioning

Air conditioning has been defined as the simultaneous control of temperature, humidity, air movement, and the quality of air in a given space. Air conditioning is able to provide widely varying atmospheric conditions from those necessary for drying processes to those necessary for high humidity process application. Air conditioning can maintain any atmospheric condition regardless of variations in outdoor weather. The range of temperatures and humidities used in comfort air conditioning is a small band. The location of this band on the psychrometric chart depends on the season of the year.

1.2. Classifications of the air conditioning systems

There are several different ways of classifying air conditioning systems.

1.2.1. classification based on major function:

a) Comfort air conditioning systems:

Their purpose is to create atmospheric conditions conducive to human health, comfort, and efficiency. Air conditioning systems in homes, offices, restaurants, theaters, hospitals, schools and mosques are of the air round year air conditioning system.

b) Industrial air conditioning systems:

The purpose of these systems is to control atmospheric conditions primarily for the proper conduct of research and manufacturing operations.

Manufacturing tolerances in the electronics, space and computer industries and in all high-speed automated manufacturing are such as to require absolute control of temperature, moisture and air purity. Air conditioning systems in paper mills, textile mills, candy factories, and printing or photo processing plants are also essential for these industries. Some of these industrial systems incidentally serve human comfort, but some do not. It should be noted that the major emphasis in this project will be on comfort air conditioning systems.

1.2.2. Classification based on season of the year:

a) Winter air conditioning systems:

These systems, when properly designed and installed to maintain indoor atmospheric conditions for winter comfort, namely, temperature, humidity, air purity, and air movement. The major problems of winter air conditioning are to heat the air and bring the moisture content (humidity) up to an acceptable level. Winter heating is accomplished by distributing heated air to spaces by ductwork or by distributing heat in the space by fin-tube, radiation or by convectors or fan-coils. Heat is supplied by furnaces or boilers fired with gas, oil or coal, or by

Chapter One

electrical resistance heaters. Humidification of the heated space is often necessary to attain comfortable condition. Humidifier may be of the simple pan type or spray type. Electrical heating by resistance elements, infrared radiation heat or with heat pumps is finding increasing application in residential, commercials, and industrial fields.

b) Summer air condoning systems:

These systems control all the four atmospheric conditions for summer comfort. The major problems are to cool the air to remove excess moisture from it. Cooling is ordinarily accomplished by mechanical refrigeration. Removed of the moisture “dehumidification” is accomplished as condensation of water vapor in the air occurs on cold coil surfaces.

c) Year-round air conditioning systems:

These systems are composed of heating and coiling equipments with automatic controls and associated components to produce the four atmospheric conditions for human comfort at all times of the year.

1.2.3. Classification based on equipment arrangement :

a) Central station system:

This type of system is one in which various apparatus components are selected by the designer, purchased from manufacturer, and erected on the job, usually in a central equipment room or mechanical room. The entire process of air conditioning is done in the central station or mechanical room, and the conditioned air is delivered to various rooms of the building through sheet-metal ducts, some large-capacity systems are of this type, but these systems are not well adapted to hotel and office-building installations where individual room control is essential. In recent years this type of system is declining in favor, being largely replaced by the (combination system). The central air conditioning system is generally used for the load above 25 tons of refrigeration and 2500 (m³/min) of conditioned air.

The central plants require the following components:

1. Cooling and dehumidifying coil.
2. Heating coils.
3. Blower with motor.
4. Sprays for cooling dehumidifying or washing.
5. Air cleaning equipment.
6. Control devices.

Advantages:

1. The capital cost and running cost are less per unit refrigeration.
2. It can be located away from the air conditioned places.

3. Noise and vibration troubles are less.
4. Better accessibility for maintenance.

b) Unitary Air Conditioning Systems:

The last five years have seen, and most further predictions to, a continually increasing use of unitary systems. These systems make use of air conditioners, which are completely factory assembled or packaged. Single air conditioners may serve various areas. Many of the current unitary or packaged units are designed to be located outside the conditioned space such as on the rooftop or on the ground in order to minimize lost floor space.

The unitary air conditioned systems are classified as follows:

i. Remote air conditioning unit systems :

All the components of the system are assembled in the factory. The remote air conditioning unit separated from the refrigeration condensing unit and heating plant.

ii. Self contained air conditioning unit:

All the components including condensing and heating unit are assembled in one closure.

iii. Unitary system for multistory building:

This is a combination of unitary and central air conditioning system.

Advantages:

1. Zoning or extensive duct work is eliminated.
2. Unitary system can meet requirements of room separately.
3. Individual room temperature control is a specific feature of this system.

iv. District air conditioning system:

District ceiling systems are not as popular as district heating systems very recently the use of district cooling system is economically justified. In general the larger the plant, the greater is the advantage.

Advantages:

1. Initial cost is less.
2. Less operating cost.
3. Noise of machines, cooling towers and pumps are completely eliminated.

Disadvantages:

1. The protection of underground pipes against corrosion and electrolytic action is necessary.
2. The pipe cost is higher.
3. The heat loss increases with an increase in pipe length.

Chapter One

4. Chilled water pumping cost is higher.

c) combination Systems:

This type of system combines the features of central-station and unitary systems. The heating and refrigeration equipment is in a central mechanical room. Heat energy is supplied in pipes to several unit air conditioners in the form of steam or hot water .Chilled water from the central refrigerating equipment is also piped to the air conditioners.

An air conditioning unit may be installed in and serve a single room or it may have its own equipment room and serve an enter zone. Heating and cooling units composed of fans, coils, filters, dampers, and controls and known as fan-coil air handlers, may be provide year-round air conditioning in rooms or zones, and fin-tube radiation and convectors may supply additional heating. The performance of the air conditioning unit is governed by a thermostat in each room it serves. The tables 1 and II below show the different methods of applications, related machines and apparatus.

Table (1-1) central air conditioning systems

Methods of Air Conditioning	Example of Application	Product
Single Duct System	Small building and factories	Air conditioners to Assembled on Site
Duel Duct System	High-Class large Building	Air Conditioners to be Assembled on Site
Multi-Zone System	Medium and Small Building	Air Handling units, and Air Conditioners to be Assembled on
Individual floor unit	Extremely forge building	Air Handling Unit. Etc
Fan Coil unit System	Individual room of Hospitals, window Side	Fan Coil unites
induction Unit System	of general Building	Induction unit

Types available in the markets:

a) Room coolers:

These units are in small capacity ranging from (0.25-1.5) tons and do not in cooperated the heating facilities.

b) Store coolers:

These are self containing units fixed in decorative cabinets and installed directly on the sale's floor of the store.

c) A year round air conditioning unit:

This is used for both heating & cooling with the help of heat pumps.

1.3. Comfort Air Conditioning

1.3.1. Factors affecting comfort air conditioning :

a) Air movement:

Air should circulate freely in the room to which it is delivered. This will allow it to absorb heat and moisture uniformly throughout the entire room during the cooling cycle and to deliver heat and moisture uniformly during the heating cycle.

b) Air cleaning:

Air should be cleaned - that is, freed of dust and soot particles and odor. Air cleanliness is important from the stand point of human health. Also, the walls and ceilings of rooms should be supplied with filtered air.

c) Humidity of air:


It means the change of moisture contents of air during summer or winter in order to produce comfortable and healthy conditions.

d) Temperature of air:

The control of temperature means the maintenance of any desired temperature within an enclosed, space even though die Temperature of the outside air is above or below die desired room temperature.

Chapter Two

Load Calculations



2.1 Introduction

The first step in the designing or selection of the air conditioning system is to estimate the cooling and / or heating loads of the conditioned space. The ultimate objective of this step is the appropriate sizing of the cooling and / or heating system.

This involves the sizing or rating of individual space or room.

Some references give approximate load figures or ranges for different air conditioned spaces in the form of load per unit floor area , per room or per person ,but this figures cant be relied upon under all conditions and are not intended to replace detailed and rigorous load estimations .

2.2 Different heat sources for air conditioning systems

It is necessary for air conditioning designers to know about the heat sources and their nature before taking the job of Air conditioning systems. The nature of heat sources which contribute heat to air conditioning systems used for summer is discussed in this chapter.

The Air conditioning systems used have to carry out two types of loads ,which can be classified into many types of loads according to type of heat and the place which it produced .

Cooling load calculations deal with heat gains of two kinds according to their nature:

i. ***Sensible heat :***

Which, as it flows into or produced in a space, will tend to cause a temperature rise in the space.

ii. ***latent heat :***

In the form of moisture, which although it does not cause a temperature rise , does change the condition of the air in the space , resulting in a higher humidity.

2.2.1 Sensible heat gains to the space include :

- i. Heat transmission through the building structure as a result of Conduction, Convection and Radiation.
- ii. Heat entering the space as a result of solar radiation through windows and other transparent components.
- iii. Sensible heat produced by occupants.
- iv. Sensible heat brought in as a result of ventilation and infiltration of air .
- v. Sensible heat produced by lights and other exist equipments.
- vi. Sensible heats to be extracted from the products exist in the Conditioned space especially for the “industrial Air Conditioning system “.

2.2.2 Latent heat (moisture gain) may be classified as :

- i. Latent heat from outside air required for ventilation or infiltration.
- ii. Latent heat from occupants.
- iii. Latent heat from moisture producing equipments such as “cooking, hot bath, hair drier, etc”.
- iv. Latent heat from the products.

A further load classification which is frequently used is based on “***the source of heat***” loads classified as:

- a. External loads, if the loads are coming from outside the conditioned space they may be either sensible or latent.
- b. Internal loads, if the loads are produced within the conditioned space. These, too, may be sensible or latent.

Table (2-1) can easily identify the type of cooling load, sensible or latent, external or internal.

Table (2-1)

	Sensible	Latent	External	Internal
Heat Transfer load	✓		✓	
Solar load	✓		✓	
Occupants loads	✓	✓		✓
Ventilation , Infiltration Loads	✓	✓	✓	
Lighting Loads	✓			✓
Equipments Loads	✓	✓		✓

From the previous table it is shown that some loads are both sensible and latent Which appear in occupants, ventilation, infiltration and equipments load.

2.3 Variability of the cooling loads

The actual cooling load in a building is a function of time and of the so called fly wheel effect of the buildings. Fly wheel effect is observed as the building masses store heat during the hot part of the day and release it later .conversely , a buildings may be sub cooled during the night and early hours of the day and thus ready to absorb a greater amount of heat later ,at sunny hours . This is the “heat inertia” of buildings. The flow of heat through walls, roofs, and ceilings of building is very complicated because of load variation with the time of the day, the nature of wind and weather, the presence of trees or shading devices that block solar radiation, and the relative humidity.

Heat transmission is a function of time, and consequently the minimum rate of heat gain into the conditioned space may lag by several hours, the minimum rate of heat absorption by the outer layers of the building. Further more owing to dissipation and absorption of heat within walls and attics, the maximum rate of gain into the conditioned space is never as great as the maximum rate of heat entry at the outside surfaces. Buildings store heat, absorb and dissipate some of it, and transmit the rest into the conditioned space at some later time, the lag varying from 1 to as much as 8 or 10 hr.

Chapter Two

The rate of space gain may conceivably peak as late as 8 or 9 p.m. when the actual outdoor peak occurs at 4 p.m. This lag depends on the building construction, the size and orientation of glass surfaces and percentage of the total load which is due to radiation through glass and which has no transmission – lag characteristics.

2.4 Inside design conditions

The inside design conditions may be varying according to the following:

- Type of building and use of building.
- Length of duration of occupancy.
- Degree of activity of occupants.
- radiant –heat sources such as large glass areas exposed to solar radiation
- Outside design conditions and daily peak temperatures.

Table (2-2) provides recommended summer and winter inside design conditions for common building types and conditions.

Table (2-2) Source: Carrier Air conditioning co., Handbook of air conditioning system design, New York, 1966

Application	Summer		Winter		Pressure	All exhaust air	Return air to AHU
	T _{db} °C	RH %	T _{db} °C	RH %			
Hospitals	22 - 26	40 - 50	20 - 27	30 - 60	-	Optional	Optional
examination room	24	50	24	30	-	Optional	Optional
paitiant care	24	50	24	30	P	Optional	Refused
Offices	23 - 26	40 - 50	21 - 23	20 - 30	-	Optional	Optional
Kitchines	26 - 31	-	21 - 23	-	N	Required	Refused
Grandstands	23 - 26	50 - 55	21 - 23	40- 50	-	Optional	Required
café - Restraunt	23 - 26	50 - 60	21- 23	20- 30	N	Refused	Refused
X- ray	22.5 - 2.5	30 - 60	22.5 - 2.5	30 - 60	N	Refused	Required
CT scan	22.5 - 2.5	30 - 60	22.5 - 2.5	30 - 60	N	Refused	Required
Urodynamic	22 - 24	40 - 50	21- 23	30 - 60	N	Optional	Optional
Endoscopy	22 - 24	40 - 50	21- 23	30 - 60	N	Optional	Optional
Laboratories	21 - 24	50 - 60	21 - 24	50 - 60	-	Refused	Optional
Waiting	23 - 24	50	22 - 23	30	-	Optional	Optional
blood sampling	21 - 24	50 - 60	21 - 24	50 - 60	-	Refused	Required
blood detonation	21 - 24	50 - 60	21 - 24	50 - 60	-	Refused	Required
sterlization	22 - 24	40 - 50	21- 23	30 - 60	-	Refused	Required
changing room	24	50	22	30	-	Refused	Required
Medecation	22-24	50	22	30	-	Refused	Required
Pharmacy	22-24	50	22	30		Refused	Required

2.5 Outside design condition

The outside design condition vary markedly with the locality, they are determined by averaging conditions which occur over a number of years. For Mansoura city the outside design conditions will vary with the following variation with the solar time.

Because the lack of the sources of temperature variation during the day, we will establish the following relation which might give a good approximation for temperature variation during the day .the procedures for this derivation assume that

the temperature variation will be sinusoidal curve from maximum temperature $T_{\max}$ to minimum temperature $T_{\min}$.

$$t = t_{av} + A \sin (\omega \tau + \phi) \quad ^\circ \text{C}$$

where:

$$t_{av} = (T_{\max} + T_{\min})/2$$

$$A: \text{ is the amplitude of the wave } = (T_{\max} - T_{av}) \quad [^\circ \text{C}]$$

$$\omega = 2\pi/24. \quad [\text{hr}^{-1}]$$

$$\tau: \text{ is the solar time (equal zero at 12 pm) } \quad [\text{hr}]$$

Table (2-3) :

The values calculated previous is estimated at the following condition for Mansoura city

time	Temp (oC)
8:00	29.2
9:00	30.75
10:00	32.56
11:00	34.5
12:00	36.44
1:00	38.25
2:00	39.8
3:00	41
4:00	41.7
5:00	42

Let us now show how the heating loads for Air conditioning systems to be calculated, and how we use the tables required for this design .and moisture content near to 15.57 g / kg .and approximately assumed to be constant with time.

2.6 External load calculations

2.6.1 Heat transfer load:

Heat enters the buildings by the means of conduction, convection and radiation. We shall develop now the procedures for calculating the heat transfer load. the heat transfer through walls, ceiling and roofs to the conditioned space can be assumed to be steady ,but the variation of the outside conditions with stability of the inside design conditions , make the heat transfer through buildings to be unsteady heat transfer .In our project we will variety the Outside design conditions with the solar time by hours as it shown above in Table (2-3) in summer for cooling loads respectively, and after that we will estimate the loads for this variation and draw the relation between the load and the solar time for this load and the other loads ,getting the total load for the conditioned space at the several times in the hottest day which occur in July although the longest day occur in June 21 , choosing the maximum total load to be design load after multiplied by safety factor as we will discuss .

Heat transfer through the buildings can be easily estimated by the following heat transfer relations.

$$Q = U \cdot A \cdot (T_o - T_i) \text{ Watt} \quad \text{Eqn (2-1)}$$

Where :

Q: is the heat transferred to the conditioned space in units of(watt).

To: is the outside Ambient temperature in units of (°C)

Ti : is the inside design condition in units of (°C).

A : is the heat transfer area in (m²).

U : is the overall heat transfer coefficient in (W/m².k).

The overall heat transfer coefficient is given by the following relation.

$$\frac{1}{U} = \frac{1}{h_i} + \frac{1}{h_o} + \sum \frac{\delta}{k} \quad \text{Eqn (2 - 2)}$$

Where :

ho: is the convection heat transfer coefficient on the outer surface.

hi : is the convection heat transfer coefficient on the inner surface.

Σ δ/k : thermal resistances of material used for construction of the wall .

Table (2-4) gives the thermal conductivity of some materials and the recommended thickness of the wall construction.

Table (2-4) Source: “modern Air Conditioning Practice “ASHRAE handbook

Materials	Thermal conductivity
Common brick	0.72
Cement plaster	0.72
Glass	0.75
Sand	0.3
Concrete Tile	1.1
Concrete	0.72
Wood	0.16

Which we can be easily know the thermal resistance for each wall construction. but for the convection heat transfer coefficient values for our needs as shown in the Table (2-5) according to the wind velocity .The convective heat transfer coefficient also can be approximately selected from the flowing table(2-5)

Table (2-5) Source: ASHRAE handbook.

Direction of heat flow		Surface position	h (w / m ² .k)
Still Air	Upward	Horizontal	9.26
	Horizontal	Vertical	8.29
	Down word	Horizontal	6.13
Moving Air	Wind 6 m/s	Any position	34
	Wind 3 m/s	Any position	22.7

2.6.2 Solar load:

As discussed later the heat transferred from walls due to the temperature difference between outer and inner conditions can be calculated, but it is known that solar radiation received at the earth's surface on a plane perpendicular to the sun rays may amount to about 860 watt per unit area of the surface on a clear day at the sea level. Time of day and latitude are the factors which most affect the value of the direct solar radiation.

Glass surfaces are usually not horizontal or perpendicular to the sun's rays, although they may be nearly so on east and west exposure in early morning.

Solar radiation which falls on glass has three components:

- i. The larger portion is transmitted directly into the interior of the building.
- ii. Some is absorbed by the glass.
- iii. Some is reflected. As shown in fig (A).




Fig (A)

The sum of 1 and 2 is the total rate of heat gain to the space, and although the direct radiation which passes into the space must first be absorbed by walls or furnishings before it can give up its heat to the air, it is common practice to treat this rate of heat gain as instantaneous, without allowing any time lag.

2.6.2.1 Heat flow due to solar radiation through walls :

$$Q_{\text{sun, wall}} = U_{\text{wall}} * A * \Delta T_{\text{sun}}$$

Eqn (2 - 3)

Heat gain through the exterior construction (walls and roofs) is normally calculated at the time greatest heat flow. It is caused by solar heat being absorbed at the exterior surface and by the temperature difference between the outdoor and indoor.

Both heat sources are highly variable through out any one day and therefore, result in unsteady state flow individual situation. However be handled best by means of an equivalent temperature difference across the structure. The heat flow through the wall structure tray can be calculated using the equation (2 – 3).

Where :

Chapter Two

Q : Heat transfer in (Watt).

U : Overall heat transfer coefficient in (W/m².C).

ΔT_{sun} : temperature difference for walls due to solar radiation (°C)

2.6.2.2 Heat flow due to solar radiation through glass

As the distance traveled or the amount of haze increase, the diffuse radiation component decrease. As either or both these effect is to reduce the total quantity of heat reaching the earth surface. Ordinary glass is specific as crystal glass of single thickness and single or double strength. The solar heat gain through ordinary glass depends on,

- Location on the earth surface (Latitude).
- Time of day.
- Time of year.
- Facing direction of the window.

Ordinary glass absorbs a small portion of the solar heat(5% – 6%) and the reflects or transmits the resultant as shown above in fig (A). The amount reflected or transmitted depends on the glass of incidence.

The heat gain by glass can be calculated from the following equation :

$$Q_{\text{sun, glass}} = A * \left(\frac{W}{m^2}\right)_{\text{glass}} * S.C \quad \text{Eqn (2-4)}$$

Where :

A : area of glass in every direction m².

$\left(\frac{W}{m^2}\right)$: heat gain throw glass from Table (2- 7) .

S.C : shading coefficient from Table (2 - 8) .

Table (2- 6) indicates amount of watts per meter square for glass walls fitted in all directions and the selected values for this amount for building peak time estimations for June month .

Table (2-6) Source: "air conditioning" C.P Arora

Solar radiation (W/m²) for 30 North Latitude at 21-June

Direction	Solar time									
	8:00	9:00	10:00	11:00	12:00	1:00	2:00	3:00	4:00	5:00
NE	410	305	173	60	44	44	44	44	38	32
SE	284	284	230	139	54	44	44	44	38	32
SW	38	44	44	44	54	138	230	284	284	237
NW	38	44	44	44	44	60	173	310	410	438

Table (2- 7) indicates the influence of shading coefficient and the selected value for shading coefficient. *Source: "air conditioning" Dr. Ramadan Mahmoud*

No. of glass plates	without shading	with internal blind
Single glass		
Regular sheet	0.83	0.64
with stand Plate	0.69	0.57
with reflec. Layer	0.4	0.33
Double glass		
Regular sheet	0.88	0.57
with reflec. Layer	0.4	0.34

2.6.2.3 Infiltration and ventilation :

It is obvious that the ventilation and the infiltration are linked together .The ventilation (supply of outside air) is provided to the conditioned space in order to minimize odor , concentration of smoke , carbon dioxide and other undesirable gases so that freshness of air could be maintained . The quantity of outside air used for ventilation should provide at least one-half air change per hour in buildings with normal ceiling heights. Also , if the infiltration air quantity is larger than the ventilation quantity , then the latter should be increased to at least equal to the infiltration air .The outside air adds sensible as well as latent heat .The load due to infiltration may be readily calculated by using the design conditions and the following equations :

Sensible heat gain by ventilated air can be calculated as:

$$Q_{vent,s} = CMM * \frac{1}{v_o} * C_{p_{air}} * (t_o - t_r) \quad \text{Watt}$$

$$Q_{vent,s} = 0.0204 * CMM * (t_o - t_r) \quad \text{KWatt} \quad \text{Eqn (2-5)}$$

And latent heat gain by ventilated air can be calculated by :

$$Q_{vent,l} = CMM * \left(\frac{1}{v_o} \right) * \Delta\omega * h_{fg} \quad \text{Watt}$$

$$Q_{vent,l} = 50 * CMM * \Delta\omega * 10^{-3} \quad \text{KWatt} \quad \text{Eqn (2 - 6)}$$

The only unknown parameter is "CMM" and can be obtained by the following methods:

a. Air change method :

$$CMM = \frac{V * N}{60} \quad \text{cmm} \quad \text{Eqn (2-7)}$$

Where:

$$V = W * H * L \quad (\text{m}^3) \quad \text{Eqn (2 - 8)}$$

W : width of the room

H : height of the room

L : length of the room

Chapter Two

N : number of air change of the space Cmm : cubic meter per minute.

b. Occupancy ventilation rate :

$$Q = n * \left(\frac{L}{s \cdot person} \right) * 60 * 10^3 \quad Cmm \quad Eqn (2-9)$$

Where :

n : number of persons .

$\left(\frac{L}{s \cdot person} \right)$: rate of ventilation of one person estimated by (liter per second) and can be obtained from Table (2 -10).

Table (2-9) source: "ASHRAE hospital"

Application	L/s/p	L/s/m ²	ζ
examination room	12	1.8	2
paitiant care	14	2.8	3
Offices	10	1.8	2
Kitchines	10	7	6
Grandstands	8	6.7	6
café - Restraunt	10	1.8	2
X- ray	14	2	2
CT scan	14	2	2
Urodynamic	14	1	1
Endoscopy	14	1	1
Laboratories	14	2.8	3
Waiting	14	6.7	7
blood sampling	14.00	6.70	7.00
blood detonation	14.00	6.70	7.00
sterlization	14	2.8	3
changing room	0	2.5	1
Medecation	14	2.8	3
Pharmacy	14	2.8	3

c. Space area ventilation rate :

$$Q_v = A_f * \left(\frac{L}{sec \cdot m^2} \right) * 60 \quad cmm \quad Eqn (2 -10)$$

Where:

A_f : the area of the floor (m²)

$\left(\frac{L}{sec \cdot m^2} \right)$: rate of ventilation per square meter in second

2.7 Internal loads

2.7.1 Occupants load:

The amount of heat which people give off to the surrounding air depends on their size and the degree of muscular activity at the time. The heat dissipated will be partly sensible, partly latent as detailed above in table (2-1). The following Table (2- 11) gives heat – dissipation values for a person 70 kg weight and 172 cm tall for several different degrees of activity. To obtain the heat load due to occupants, the design occupancy is multiplied by the proper factor selected from the following table. The heat transferred from occupants can be easily calculated from the following relation :

$$Q = \left(\frac{q}{\text{person}} \right) * n_{\text{person}} \quad \text{Watt} \quad \text{Eqn (2-11)}$$

Where:

N_{person} : Number of person in the conditioned space

$\left(\frac{q}{\text{person}} \right)$: is the heat released from one person

Table 2-10 Sensible and latent heat for different occupants' activities:

Source: "air conditioning" Dr. Ramadan Mahmoud

Activity	Sensible heat (W)	Latent heat (W)
Comfort sitting	72	31
sitting light work	72	45
Sitting and eating	75	95
Moderately active office work	73	59
walking	81	81

2.7.2 Electric lights, motors appliances loads :

A part of internal loads which must be considered is light, equipments motor and appliance load. Heat dissipated from lights and the equipments motors are both sensible, but for another certain appliance (clothes dryers, hair dryers (helmet).... Etc) are examples for latent heats can be dissipated from appliances.

a. Lights:

Lighting loads can be easily estimated from the following equation.

$$Q = \sum I_n + 1.25 * \sum F$$

Where:

I_n : watts of incandescent lamps.

F : watts of fluorescent lamps .

Hint:

“For fluorescent lamps loads are increased by 25 % especially for transformer which exist in the room .Another table can easily give the recommended light intensity (W / m^2) for some applications shown in Table (2 – 13).

Table (2-11) Source: "Air conditioning principles, applications book" Dr .R Mahmoud

Building type	W / m ²
Offices	60
Industries	45
Schools ,Universities	40
Houses , theater , Hotels	20
Restaurants	17
Hospitals , libraries, museums	15

b. Motors:

Load gain from motors and from equipments can easily determined from the following relation.

$$Q = (1 - \eta) * \text{motor Power } (P_o). \quad \text{Watt}$$

Where:

η : motor or equipment efficiency .Table (2-14) gives motor power and the recommended efficiency .

Table (2-12) Source: "ASHRAE handbook ".

Motor power	Efficiency
Lower than 200 watt	0.6
From 375 - 750 watt	0.7
From 1000 - 4000 watt	0.8
From 5500 - 15000 watt	0.85
Above 15000 watt	0.88
From 746 – 3730 watt	0.75 – 0.82
Down 746 watt	0.6 – 0.7

Working data

In door data:

Ti °C	hi kJ/kg.K	Φi %	Wi gv/kga
24	47.9	50	9.34
26	53	50	10.54

Out door data

Time	To °C	ho kJ/kg.K	Φo %	Wo gv/kga	Vo m³/kg	Po kg/m³
8.00	29.20	69.13	60.76	15.57	0.88	1.14
9.00	30.75	70.74	55.58	15.57	0.88	1.13
10.00	32.56	72.61	50.16	15.57	0.89	1.13
11.00	34.50	74.62	45.00	15.57	0.89	1.12
12.00	36.44	76.62	40.43	15.57	0.90	1.11
1.00	38.25	78.50	36.64	15.57	0.90	1.11
2.00	39.80	80.10	33.71	15.57	0.91	1.10
3.00	41.00	81.34	31.63	15.57	0.91	1.10
4.00	41.70	82.07	30.48	15.57	0.91	1.09
5.00	42.00	82.38	30.00	15.57	0.92	1.09

Shading coeficient: constant for all glass windows

S.C.
0.34

Convection Heat Transfer Coefficient

Position Of Surface	Direction	hi (w/m².k)	h _o (w/m².k)
Horizontal	Downword	7	13
Vertical	Horizontal	8	10

Thermal Conductivity

Item	K
Limestone	0.93
Cement plaster	0.72
Common Brick	0.72
Still Air	0.02624
Concrete	1.72

Chapter Two

Overall Heat Transfer Coeff

Item	U (w/m ² .k)	α
Wall "A"	0.12754	0.65
Wall "B"	1.4389	0.65
Wall "C"	1.78896	0.4
Wall "D"	0.3943	0.4
Wall "E"	2.33	0.65
Wall "F"	2.003	0.65
Wall "H"	1.16	-
Wall "I"	0	-
Wall "G_1"	2.1818	0.65
Wall "G_2"	1.565	0.65
Glass	1.1	Non

Outdoor Temperatures

time	Temp (oC)
8:00	29.2
9:00	30.75
10:00	32.56
11:00	34.5
12:00	36.44
1:00	38.25
2:00	39.8
3:00	41
4:00	41.7
5:00	42

Solar radiation (W/m²) for 30 North Latitude at 21-June

Direction	Solar time									
	8:00	9:00	10:00	11:00	12:00	1:00	2:00	3:00	4:00	5:00
NE	410	305	173	60	44	44	44	44	38	32
SE	284	284	230	139	54	44	44	44	38	32
SW	38	44	44	44	54	138	230	284	284	237
NW	38	44	44	44	44	60	173	310	410	438


Types of building walls

Walls (A)

Components:

- 1- cement plaster
- 2- common brick
- 3- still air
- 4- common brick
- 5- cement plaster

$$U=0.12754 \text{ W/m}^2.\text{k}$$




Walls (B)

Components:

- 1- cement plaster
- 2- common brick
- 3- concrete column
- 4- cement plaster

$$U=1.4389 \text{ W/m}^2.\text{k}$$




Walls (C)

Components:

- 1- black or dark grey limestone
- 2- cement plaster
- 3- concrete column
- 4- cement plaster

$$U=1.78896 \text{ W/m}^2.\text{k}$$




Walls (D)

Components:

1. black or dark grey limestone
2. cement plaster
3. common brick
4. still air
5. common brick
6. cement plaster

$$U=0.3943 \text{ W/m}^2.\text{k}$$




Walls (E)

Components:

1. cement plaster
2. concrete wall
3. cement plaster

$$U=2.33 \text{ W/m}^2.\text{k}$$




Chapter Two

Walls (F)

Components:

1. cement plaster
2. concrete wall
3. cement plaster

$$U=2.003 \text{ W/m}^2.\text{k}$$




Wall (F)

Walls (G_1)

Components:

1. cement plaster
2. wall on half brick
3. cement plaster

$$U=2.1818 \text{ W/m}^2.\text{k}$$




Wall (G_1)

Walls (G_2)

Components:

1. cement plaster
2. wall on full brick
3. cement plaster

$$U=1.565 \text{ W/m}^2.\text{k}$$




Wall (G_2)

Walls (I) 'raiser wall'

Components:

1. cement plaster
2. common brick
3. still air
4. common brick
5. still air
6. common brick
7. cement plaster

$$U=0 \text{ W/m}^2.\text{k}$$




Wall (I)

Walls (H)

Components:

1. cement plaster
2. common brick
3. still air
4. common brick
5. cement plaster

$$U=1.16 \text{ W/m}^2.\text{k}$$



Wall (H)

Ground Floor Calculations

For air Conditioning machine 1

Room 0-13

A. External Loads

1-Wall Load

Direction	Time	Type	U (w/m2.k)	A (m2)	ΔT (K)	Q (W)	Qt (W)
NE	08:00	Wall "A"	0.13	7.17	5.20	4.76	40.99
		Wall "B"	1.44	1.41		10.51	
		Wall "C"	1.79	1.20		11.12	
		Wall "D"	0.39	2.27		4.66	
		Glass	1.10	1.74		9.95	
	09:00	Wall "A"	0.13	7.17	6.75	6.17	53.20
		Wall "B"	1.44	1.41		13.65	
		Wall "C"	1.79	1.20		14.43	
		Wall "D"	0.39	2.27		6.04	
		Glass	1.10	1.74		12.91	
	10:00	Wall "A"	0.13	7.17	8.56	7.83	67.47
		Wall "B"	1.44	1.41		17.31	
		Wall "C"	1.79	1.20		18.30	
		Wall "D"	0.39	2.27		7.66	
		Glass	1.10	1.74		16.37	
	11:00	Wall "A"	0.13	7.17	10.50	9.60	82.76
		Wall "B"	1.44	1.41		21.23	
		Wall "C"	1.79	1.20		22.45	
		Wall "D"	0.39	2.27		9.40	
		Glass	1.10	1.74		20.08	
	12:00	Wall "A"	0.13	7.17	12.44	11.38	98.05
		Wall "B"	1.44	1.41		25.15	
		Wall "C"	1.79	1.20		26.59	
		Wall "D"	0.39	2.27		11.14	
		Glass	1.10	1.74		23.79	
	13:00	Wall "A"	0.13	7.17	14.25	13.03	112.32
		Wall "B"	1.44	1.41		28.81	
		Wall "C"	1.79	1.20		30.46	
		Wall "D"	0.39	2.27		12.76	
		Glass	1.10	1.74		27.25	
	14:00	Wall "A"	0.13	7.17	15.80	14.45	124.53
		Wall "B"	1.44	1.41		31.94	
		Wall "C"	1.79	1.20		33.78	
		Wall "D"	0.39	2.27		14.15	
		Glass	1.10	1.74		30.22	
	15:00	Wall "A"	0.13	7.17	17.00	15.55	133.99
		Wall "B"	1.44	1.41		34.37	

Chapter Two

	16:00	Wall "C"	1.79	1.20	17.70	36.34	139.51
		Wall "D"	0.39	2.27		15.22	
		Glass	1.10	1.74		32.51	
		Wall "A"	0.13	7.17		16.19	
		Wall "B"	1.44	1.41		35.78	
	17:00	Wall "C"	1.79	1.20	18.00	37.84	141.87
		Wall "D"	0.39	2.27		15.85	
		Glass	1.10	1.74		33.85	
		Wall "A"	0.13	7.17		16.46	
		Wall "B"	1.44	1.41		36.39	
	17:00	Wall "C"	1.79	1.20	18.00	38.48	141.87
		Wall "D"	0.39	2.27		16.11	
		Glass	1.10	1.74		34.43	

2-Sun Load

Direction	Time	Type	U (w/m2.k)	A (m2)	I (W/m2)	ΔTs (K)	Q (W)	Qt (W)
NE	08:00	Wall "A"	0.13	7.17	410.00	26.65	24.37	370.37
		Wall "B"	1.44	1.41		26.65	53.88	
		Wall "C"	1.79	1.20		16.40	35.06	
		Wall "D"	0.39	2.27		16.40	14.68	
		Glass	1.10	1.74			242.38	
	09:00	Wall "A"	0.13	7.17	305.00	19.83	18.13	275.52
		Wall "B"	1.44	1.41		19.83	40.08	
		Wall "C"	1.79	1.20		12.20	26.08	
		Wall "D"	0.39	2.27		12.20	10.92	
		Glass	1.10	1.74			180.31	
	10:00	Wall "A"	0.13	7.17	173.00	11.25	10.28	156.28
		Wall "B"	1.44	1.41		11.25	22.73	
		Wall "C"	1.79	1.20		6.92	14.79	
		Wall "D"	0.39	2.27		6.92	6.20	
		Glass	1.10	1.74			102.27	
	11:00	Wall "A"	0.13	7.17	60.00	3.90	3.57	54.20
		Wall "B"	1.44	1.41		3.90	7.88	
		Wall "C"	1.79	1.20		2.40	5.13	
		Wall "D"	0.39	2.27		2.40	2.15	
		Glass	1.10	1.74			35.47	
	12:00	Wall "A"	0.13	7.17	44.00	2.86	2.62	39.75
		Wall "B"	1.44	1.41		2.86	5.78	
		Wall "C"	1.79	1.20		1.76	3.76	
		Wall "D"	0.39	2.27		1.76	1.58	
		Glass	1.10	1.74			26.01	
	13:00	Wall "A"	0.13	7.17	44.00	2.86	2.62	39.75
		Wall "B"	1.44	1.41		2.86	5.78	
		Wall "C"	1.79	1.20		1.76	3.76	
		Wall "D"	0.39	2.27		1.76	1.58	
		Glass	1.10	1.74			26.01	
	14:00	Wall "A"	0.13	7.17	44.00	2.86	2.62	39.75

Load calculations

		Wall "B"	1.44	1.41		2.86	5.78	
		Wall "C"	1.79	1.20		1.76	3.76	
		Wall "D"	0.39	2.27		1.76	1.58	
		Glass	1.10	1.74			26.01	
	15:00	Wall "A"	0.13	7.17	44.00	2.86	2.62	39.75
		Wall "B"	1.44	1.41		2.86	5.78	
		Wall "C"	1.79	1.20		1.76	3.76	
		Wall "D"	0.39	2.27		1.76	1.58	
		Glass	1.10	1.74			26.01	
	16:00	Wall "A"	0.13	7.17	38.00	2.47	2.26	34.33
		Wall "B"	1.44	1.41		2.47	4.99	
		Wall "C"	1.79	1.20		1.52	3.25	
		Wall "D"	0.39	2.27		1.52	1.36	
		Glass	1.10	1.74			22.46	
	17:00	Wall "A"	0.13	7.17	32.00	2.08	1.90	28.91
		Wall "B"	1.44	1.41		2.08	4.21	
		Wall "C"	1.79	1.20		1.28	2.74	
		Wall "D"	0.39	2.27		1.28	1.15	
		Glass	1.10	1.74			18.92	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
2.00	10.00	2.50	2.00

A (m2)	23.04
H (m)	2.60
V (m3)	59.90

Method	CMM
Based on No Of Persons	1.20
Based on Area	3.46
NO Of Air Changing Times	2.00

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
08:00	3.46	366.61	1076.89	1443.50
09:00	3.46	475.89	1076.89	1552.78
10:00	3.46	603.50	1076.89	1680.39
11:00	3.46	740.28	1076.89	1817.16
12:00	3.46	877.05	1076.89	1953.94
13:00	3.46	1004.66	1076.89	2081.55
14:00	3.46	1113.94	1076.89	2190.83
15:00	3.46	1198.54	1076.89	2275.43
16:00	3.46	1247.89	1076.89	2324.78
17:00	3.46	1269.04	1076.89	2345.93

Chapter Two

B. Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
2.00	sitting	66.00	31.00	132.00	62.00	194.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
fluorescent	8.00	40.00	1.25	400.00

Variation of load with time

Q occ_s	Q occ_l	Q lig_s	Q eq_s	Q eq_l
400.00	132.00	62.00	0.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_l	RSH	RLH	RTH
0.33	40.99	370.37	366.61	1076.89	943.36	62.00	1005.36
0.38	53.20	275.52	475.89	1076.89	860.72	62.00	922.72
0.42	67.47	156.28	603.50	1076.89	755.75	62.00	817.75
0.46	82.76	54.20	740.28	1076.89	668.96	62.00	730.96
0.50	98.05	39.75	877.05	1076.89	669.80	62.00	731.80
0.54	112.32	39.75	1004.66	1076.89	684.06	62.00	746.06
0.58	124.53	39.75	1113.94	1076.89	696.28	62.00	758.28
0.63	133.99	39.75	1198.54	1076.89	705.74	62.00	767.74
0.67	139.51	34.33	1247.89	1076.89	705.84	62.00	767.84
0.71	141.87	28.91	1269.04	1076.89	702.78	62.00	764.78

Room 0-15

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT (K)	Q (W)	Qt (W)
NE	08:00	Wall "A"	0.13	2.04	5.20	1.36	30.33
		Wall "B"	1.44	1.24		9.25	
		Wall "C"	1.79	1.05		9.78	
		Glass	1.10	1.74		9.95	
	09:00	Wall "A"	0.13	2.04	6.75	1.76	39.38
		Wall "B"	1.44	1.24		12.01	
		Wall "C"	1.79	1.05		12.70	
		Glass	1.10	1.74		12.91	
	10:00	Wall "A"	0.13	2.04	8.56	2.23	49.94
		Wall "B"	1.44	1.24		15.23	
		Wall "C"	1.79	1.05		16.10	
		Glass	1.10	1.74		16.37	
	11:00	Wall "A"	0.13	2.04	10.50	2.74	61.25
		Wall "B"	1.44	1.24		18.68	
		Wall "C"	1.79	1.05		19.75	
		Glass	1.10	1.74		20.08	
	12:00	Wall "A"	0.13	2.04	12.44	3.24	72.57
		Wall "B"	1.44	1.24		22.13	
		Wall "C"	1.79	1.05		23.40	
		Glass	1.10	1.74		23.79	
	13:00	Wall "A"	0.13	2.04	14.25	3.72	83.13
		Wall "B"	1.44	1.24		25.35	
		Wall "C"	1.79	1.05		26.81	
		Glass	1.10	1.74		27.25	
	14:00	Wall "A"	0.13	2.04	15.80	4.12	92.17
		Wall "B"	1.44	1.24		28.11	
		Wall "C"	1.79	1.05		29.72	
		Glass	1.10	1.74		30.22	
	15:00	Wall "A"	0.13	2.04	17.00	4.43	99.17
		Wall "B"	1.44	1.24		30.24	
		Wall "C"	1.79	1.05		31.98	
		Glass	1.10	1.74		32.51	
	16:00	Wall "A"	0.13	2.04	17.70	4.61	103.26
		Wall "B"	1.44	1.24		31.49	
		Wall "C"	1.79	1.05		33.30	
		Glass	1.10	1.74		33.85	
	17:00	Wall "A"	0.13	2.04	18.00	4.69	105.01
		Wall "B"	1.44	1.24		32.02	
		Wall "C"	1.79	1.05		33.86	
		Glass	1.10	1.74		34.43	

Chapter Two

2-Sun Load

Direction	Time	Type	U	A	I	ΔT_s	Q (W)	Qt (W)
NE	08:00	Wall "A"	0.13	2.04	410.00	26.65	6.95	348.89
		Wall "B"	1.44	1.24		26.65	47.41	
		Wall "C"	1.79	1.05		16.40	30.85	
		Glass	1.10	1.89			263.68	
	09:00	Wall "A"	0.13	2.04	305.00	19.83	5.17	266.77
		Wall "B"	1.44	1.30		19.83	37.08	
		Wall "C"	1.79	1.30		12.20	28.37	
		Glass	1.10	1.89			196.15	
	10:00	Wall "A"	0.13	2.04	173.00	11.25	2.93	151.32
		Wall "B"	1.44	1.30		11.25	21.03	
		Wall "C"	1.79	1.30		6.92	16.09	
		Glass	1.10	1.89			111.26	
	11:00	Wall "A"	0.13	2.04	60.00	3.90	1.02	52.48
		Wall "B"	1.44	1.30		3.90	7.30	
		Wall "C"	1.79	1.30		2.40	5.58	
		Glass	1.10	1.89			38.59	
	12:00	Wall "A"	0.13	2.04	44.00	2.86	0.75	38.49
		Wall "B"	1.44	1.30		2.86	5.35	
		Wall "C"	1.79	1.30		1.76	4.09	
		Glass	1.10	1.89			28.30	
	13:00	Wall "A"	0.13	2.04	44.00	2.86	0.75	38.49
		Wall "B"	1.44	1.30		2.86	5.35	
		Wall "C"	1.79	1.30		1.76	4.09	
		Glass	1.10	1.89			28.30	
	14:00	Wall "A"	0.13	2.04	44.00	2.86	0.75	38.49
		Wall "B"	1.44	1.30		2.86	5.35	
		Wall "C"	1.79	1.30		1.76	4.09	
		Glass	1.10	1.89			28.30	
	15:00	Wall "A"	0.13	2.04	44.00	2.86	0.75	38.49
		Wall "B"	1.44	1.30		2.86	5.35	
		Wall "C"	1.79	1.30		1.76	4.09	
		Glass	1.10	1.89			28.30	
	16:00	Wall "A"	0.13	2.04	38.00	2.47	0.64	33.24
		Wall "B"	1.44	1.30		2.47	4.62	
		Wall "C"	1.79	1.30		1.52	3.53	
		Glass	1.10	1.89			24.44	
	17:00	Wall "A"	0.13	2.04	32.00	2.08	0.54	27.99
		Wall "B"	1.44	1.30		2.08	3.89	
		Wall "C"	1.79	1.30		1.28	2.98	
		Glass	1.10	1.89			20.58	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
2.00	10.00	2.50	2.00

A (m2)	19.38
H (m)	2.60
V (m3)	50.39

Method	CMM
Based on No Of Persons	1.20
Based on Area	2.91
NO Of Air Changing Times	1.68

Time	CMMmax	Qs(W)	QL(W)	Qtot (W)
08:00	2.91	308.37	905.82	1214.20
09:00	2.91	400.29	905.82	1306.12
10:00	2.91	507.63	905.82	1413.45
11:00	2.91	622.68	905.82	1528.50
12:00	2.91	737.73	905.82	1643.55
13:00	2.91	845.06	905.82	1750.89
14:00	2.91	936.98	905.82	1842.81
15:00	2.91	1008.15	905.82	1913.97
16:00	2.91	1049.66	905.82	1955.48
17:00	2.91	1067.45	905.82	1973.27

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
2.00	sitting	66.00	31.00	132.00	62.00	194.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8.00	40.00	1.25	400.00

Chapter Two

Variation of load with time

Qs	Qs	QI	Qs	QI
400.00	132.00	62.00	0.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_I	RSH	RLH	RTH
08:00	30.33	348.89	308.37	905.82	911.22	62.00	973.22
09:00	39.38	266.77	400.29	905.82	838.15	62.00	900.15
10:00	49.94	151.32	507.63	905.82	733.25	62.00	795.25
11:00	61.25	52.48	622.68	905.82	645.73	62.00	707.73
12:00	72.57	38.49	737.73	905.82	643.06	62.00	705.06
13:00	83.13	38.49	845.06	905.82	653.62	62.00	715.62
14:00	92.17	38.49	936.98	905.82	662.66	62.00	724.66
15:00	99.17	38.49	1008.15	905.82	669.66	62.00	731.66
16:00	103.26	33.24	1049.66	905.82	668.49	62.00	730.49
17:00	105.01	27.99	1067.45	905.82	665.00	62.00	727.00

Room 0-23

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q (W)	Q(Total) ,W
SE	08:00	Wall "A"	0.13	5.14	5.20	3.41	14.04
		Glass	1.10	1.86		10.63	
	09:00	Wall "A"	0.13	5.14	6.75	4.42	18.22
		Glass	1.10	1.86		13.80	
	10:00	Wall "A"	0.13	5.14	8.56	5.61	23.10
		Glass	1.10	1.86		17.50	
	11:00	Wall "A"	0.13	5.14	10.50	6.88	28.34
		Glass	1.10	1.86		21.46	
	12:00	Wall "A"	0.13	5.14	12.44	8.15	33.58
		Glass	1.10	1.86		25.43	
	13:00	Wall "A"	0.13	5.14	14.25	9.33	38.46
		Glass	1.10	1.86		29.13	
	14:00	Wall "A"	0.13	5.14	15.80	10.35	42.65
		Glass	1.10	1.86		32.30	
	15:00	Wall "A"	0.13	5.14	17.00	11.14	45.88
		Glass	1.10	1.86		34.75	
	16:00	Wall "A"	0.13	5.14	17.70	11.59	47.77
		Glass	1.10	1.86		36.18	
	17:00	Wall "A"	0.13	5.14	18.00	11.79	48.58
		Glass	1.10	1.86		36.79	

Direction	Time	Type	U	A	ΔT	Q (W)	Q(Total) ,W
NE	08:00	Wall "A"	0.13	7.06	5.20	4.68	31.86
		Glass	1.10	3.75		21.46	
		Wall "D"	0.39	2.78		5.71	
	09:00	Wall "A"	0.13	7.06	6.75	6.08	41.35
		Glass	1.10	3.75		27.86	
		Wall "D"	0.39	2.78		7.41	
	10:00	Wall "A"	0.13	7.06	8.56	7.71	52.44
		Glass	1.10	3.75		35.33	
		Wall "D"	0.39	2.78		9.40	
	11:00	Wall "A"	0.13	7.06	10.50	9.46	64.32
		Glass	1.10	3.75		43.34	
		Wall "D"	0.39	2.78		11.53	
	12:00	Wall "A"	0.13	7.06	12.44	11.20	76.21
		Glass	1.10	3.75		51.35	
		Wall "D"	0.39	2.78		13.66	
	13:00	Wall "A"	0.13	7.06	14.25	12.83	87.30
		Glass	1.10	3.75		58.82	
		Wall "D"	0.39	2.78		15.64	
	14:00	Wall "A"	0.13	7.06	15.80	14.23	96.79
		Glass	1.10	3.75		65.21	
		Wall "D"	0.39	2.78		17.35	

Chapter Two

	15:00	Wall "A"	0.13	7.06	17.00	15.31	104.14
		Glass	1.10	3.75		70.17	
		Wall "D"	0.39	2.78		18.66	
	16:00	Wall "A"	0.13	7.06	17.70	15.94	108.43
		Glass	1.10	3.75		73.06	
		Wall "D"	0.39	2.78		19.43	
	17:00	Wall "A"	0.13	7.06	18.00	16.21	110.27
		Glass	1.10	3.75		74.30	
		Wall "D"	0.39	2.78		19.76	

Time	Qt(W)
08:00	45.89
09:00	59.57
10:00	75.54
11:00	92.66
12:00	109.78
13:00	125.76
14:00	139.44
15:00	150.03
16:00	156.20
17:00	158.85

Load calculations

2-Sun Load

Direction	Time	Type	U	A	I	ΔT_s	Q	Qtot
SE	08:00	Wall "A"	0.13	5.14	284.00	18.46	12.09	191.52
		Glass	1.10	1.86			179.43	
	09:00	Wall "A"	0.13	5.14	284.00	18.46	12.09	191.52
		Glass	1.10	1.86			179.43	
	10:00	Wall "A"	0.13	5.14	230.00	18.46	12.09	157.40
		Glass	1.10	1.86			145.31	
	11:00	Wall "A"	0.13	5.14	139.00	18.46	12.09	99.91
		Glass	1.10	1.86			87.82	
	12:00	Wall "A"	0.13	5.14	54.00	18.46	12.09	46.21
		Glass	1.10	1.86			34.12	
	13:00	Wall "A"	0.13	5.14	44.00	18.46	12.09	39.89
		Glass	1.10	1.86			27.80	
	14:00	Wall "A"	0.13	5.14	44.00	18.46	12.09	39.89
		Glass	1.10	1.86			27.80	
	15:00	Wall "A"	0.13	5.14	44.00	18.46	12.09	39.89
		Glass	1.10	1.86			27.80	
	16:00	Wall "A"	0.13	5.14	38.00	18.46	12.09	36.10
		Glass	1.10	1.86			24.01	
	17:00	Wall "A"	0.13	5.14	32.00	18.46	12.09	32.31
		Glass	1.10	1.86			20.22	

Direction	Time	Type	U	A	I	ΔT_s	Q	Qtot
NE	08:00	Wall "A"	0.13	7.06	410.00	26.65	24.00	576.33
		Glass	1.10	3.75			523.07	
		Wall "D"	0.39	2.78		16.40	29.26	
	09:00	Wall "A"	0.13	7.06	305.00	26.65	24.00	442.37
		Glass	1.10	3.75			389.11	
		Wall "D"	0.39	2.78		16.40	29.26	
	10:00	Wall "A"	0.13	7.06	173.00	26.65	24.00	273.97
		Glass	1.10	3.75			220.71	
		Wall "D"	0.39	2.78		16.40	29.26	
	11:00	Wall "A"	0.13	7.06	60.00	26.65	24.00	129.81
		Glass	1.10	3.75			76.55	
		Wall "D"	0.39	2.78		16.40	29.26	
	12:00	Wall "A"	0.13	7.06	44.00	26.65	24.00	109.39
		Glass	1.10	3.75			56.13	
		Wall "D"	0.39	2.78		16.40	29.26	
	13:00	Wall "A"	0.13	7.06	44.00	26.65	24.00	109.39
		Glass	1.10	3.75			56.13	
		Wall "D"	0.39	2.78		16.40	29.26	
	14:00	Wall "A"	0.13	7.06	44.00	26.65	24.00	109.39
		Glass	1.10	3.75			56.13	
		Wall "D"	0.39	2.78		16.40	29.26	
	15:00	Wall "A"	0.13	7.06	44.00	26.65	24.00	109.39
		Glass	1.10	3.75			56.13	

Chapter Two

	16:00	Wall "D"	0.39	2.78	38.00	16.40	29.26	101.74
		Wall "A"	0.13	7.06		26.65	24.00	
		Glass	1.10	3.75			48.48	
		Wall "D"	0.39	2.78		16.40	29.26	
	17:00	Wall "A"	0.13	7.06	32.00	26.65	24.00	94.08
		Glass	1.10	3.75			40.83	
		Wall "D"	0.39	2.78		16.40	29.26	

Time	Qt(W)
08:00	767.85
09:00	633.89
10:00	431.37
11:00	229.72
12:00	155.60
13:00	149.28
14:00	149.28
15:00	149.28
16:00	137.84
17:00	126.39

3-Ventilation Load

No Of Person	L/s.p	ζ
25.00	14.00	3.00

A (m2)	112.16
H (m)	2.60
V (m3)	291.62

Method	CMM
Based on No Of Persons	13.30
Based on Area	21.00
NO Of Air Changing Times	7.39

Time	CMMmax	Qs(W)	QL(W)	Qtot (W)
08:00	21.00	2227.68	6543.60	8771.28
09:00	21.00	2891.70	6543.60	9435.30
10:00	21.00	3667.10	6543.60	10210.70
11:00	21.00	4498.20	6543.60	11041.80
12:00	21.00	5329.30	6543.60	11872.90
13:00	21.00	6104.70	6543.60	12648.30
14:00	21.00	6768.72	6543.60	13312.32
15:00	21.00	7282.80	6543.60	13826.40
16:00	21.00	7582.68	6543.60	14126.28
17:00	21.00	7711.20	6543.60	14254.80

B. Internal Loads**1-Occupancy Load**

No.Persons	Work	qs/p	Qs	QL	Qs.tot	QL.tot	Qtot (W)
25.00	sitting	66.00	1650.00	775.00	1866.00	955.00	2821.00
3.00	light	72.00	216.00	180.00			

2-Light Load

Type	No .	W/Lamp	Q (W)
Economical	30.00	26.00	780.00
spot	4.00	35.00	140.00
exit	2.00	60.00	120.00

3-Equipment

Type	No Of Device	W/device	Q (W)
cooler	1.00	320.00	320.00

Variation of load with time

Q occ_s	Q occ_l	Q ligh_s	Q eq_s
1040.00	1866.00	955.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	RSH	RLH	RTH
08:00	45.89	767.85	6543.60	4039.74	955.00	4994.74
09:00	59.57	633.89	6543.60	3919.46	955.00	4874.46
10:00	75.54	431.37	6543.60	3732.92	955.00	4687.92
11:00	92.66	229.72	6543.60	3548.38	955.00	4503.38
12:00	109.78	155.60	6543.60	3491.39	955.00	4446.39
13:00	125.76	149.28	6543.60	3501.04	955.00	4456.04
14:00	139.44	149.28	6543.60	3514.72	955.00	4469.72
15:00	150.03	149.28	6543.60	3525.31	955.00	4480.31
16:00	156.20	137.84	6543.60	3520.04	955.00	4475.04
17:00	158.85	126.39	6543.60	3511.24	955.00	4466.24

Chapter Two

Room 0-42

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q	Qtot W
NE	08:00	Glass	1.10	3.44	5.20	19.65	23.95
		Wall "A"	0.13	4.71		3.13	
		Wall "D"	0.39	0.57		1.18	
	09:00	Glass	1.10	3.44	6.75	25.51	31.09
		Wall "A"	0.13	4.71		4.06	
		Wall "D"	0.39	0.57		1.53	
	10:00	Glass	1.10	3.44	8.56	32.35	39.43
		Wall "A"	0.13	4.71		5.15	
		Wall "D"	0.39	0.57		1.94	
	11:00	Glass	1.10	3.44	10.50	39.68	48.37
		Wall "A"	0.13	4.71		6.31	
		Wall "D"	0.39	0.57		2.37	
	12:00	Glass	1.10	3.44	12.44	47.01	57.31
		Wall "A"	0.13	4.71		7.48	
		Wall "D"	0.39	0.57		2.81	
	13:00	Glass	1.10	3.44	14.25	53.85	65.64
		Wall "A"	0.13	4.71		8.57	
		Wall "D"	0.39	0.57		3.22	
	14:00	Glass	1.10	3.44	15.80	59.71	72.78
		Wall "A"	0.13	4.71		9.50	
		Wall "D"	0.39	0.57		3.57	
	15:00	Glass	1.10	3.44	17.00	64.25	78.31
		Wall "A"	0.13	4.71		10.22	
		Wall "D"	0.39	0.57		3.84	
	16:00	Glass	1.10	3.44	17.74	67.04	81.72
		Wall "A"	0.13	4.71		10.67	
		Wall "D"	0.39	0.57		4.01	
	17:00	Glass	1.10	3.44	18.00	68.03	82.92
		Wall "A"	0.13	4.71		10.82	
		Wall "D"	0.39	0.57		4.07	

2-Sun Load

Direction	Time	Type	U	A	ΔT s	I	Q	Q tot (W)
NE	08:00	glass		3.44		410.00	478.93	498.66
		wall"A"	0.13	4.71	26.65		16.02	
		wall"D"	0.39	0.57	16.40		3.71	
	09:00	glass		3.44		305.00	356.27	370.95
		wall"A"	0.13	4.71	19.83		11.92	
		wall"D"	0.39	0.57	12.20		2.76	
	10:00	glass		3.44		173.00	202.08	210.41
		wall"A"	0.13	4.71	11.25		6.76	
		wall"D"	0.39	0.57	6.92		1.57	
	11:00	glass		3.44		60.00	70.09	72.97
		wall"A"	0.13	4.71	3.90		2.34	
		wall"D"	0.39	0.57	2.40		0.54	
	12:00	glass		3.44		44.00	51.40	53.51
		wall"A"	0.13	4.71	2.86		1.72	
		wall"D"	0.39	0.57	1.76		0.40	
	13:00	glass		3.44		44.00	51.40	53.51
		wall"A"	0.13	4.71	2.86		1.72	
		wall"D"	0.39	0.57	1.76		0.40	
	14:00	glass		3.44		44.00	478.93	481.04
		wall"A"	0.13	4.71	2.86		1.72	
		wall"D"	0.39	0.57	1.76		0.40	
	15:00	glass		3.44		44.00	51.40	53.51
		wall"A"	0.13	4.71	2.86		1.72	
		wall"D"	0.39	0.57	1.76		0.40	
	16:00	glass		3.44		38.00	44.39	46.22
		wall"A"	0.13	4.71	2.47		1.48	
		wall"D"	0.39	0.57	1.52		0.34	
	17:00	glass		3.44		32.00	37.38	38.92
		wall"A"	0.13	4.71	2.08		1.25	
		wall"D"	0.39	0.57	1.28		0.29	

Chapter Two

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5	12	1.80	2.

A (m2)	16.63
H (m)	2.60
V (m3)	43.24

Method	CMM
Based on No Of Persons	3.60
Based on Area	1.80
NO Of Changing Times	1.44

Time	CMM	Qs(W)	QL(W)	Qtot (W)
08:00	3.60	381.89	1121.76	1503.65
09:00	3.60	495.72	1121.76	1617.48
10:00	3.60	628.65	1121.76	1750.41
11:00	3.60	771.12	1121.76	1892.88
12:00	3.60	913.59	1121.76	2035.35
13:00	3.60	1046.52	1121.76	2168.28
14:00	3.60	1160.35	1121.76	2282.11
15:00	3.60	1248.48	1121.76	2370.24
16:00	3.60	1302.83	1121.76	2424.59
17:00	3.60	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

No Of Pers	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot
5.00	Light	72.00	60.00	360.00	300.00	660.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8.00	20.00	1.25	200.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot
CPU	1.00	55.00	55.00	474.00
Monitor	1.00	55.00	55.00	
scan light	1.00	100.00	100.00	
abjora	1.00	60.00	60.00	
scan device	1.00	204.00	204.00	

Variation of load with time

Q occ_s	Q occ_I	Q lig_s	Q eq_s	Q eq_I
360.00	300.00	200.00	474.00	0.00

Time	Q wall_s	Q sun_s	Q ven_s	Q ven_I	RSH	RLH	RTH
08:00	23.95	498.66	381.89	1121.76	1556.61	300.00	1856.61
09:00	31.09	370.95	495.72	1121.76	1436.05	300.00	1736.05
10:00	39.43	210.41	628.65	1121.76	1283.84	300.00	1583.84
11:00	48.37	72.97	771.12	1121.76	1155.34	300.00	1455.34
12:00	57.31	53.51	913.59	1121.76	1144.82	300.00	1444.82
13:00	65.64	53.51	1046.52	1121.76	1153.16	300.00	1453.16
14:00	72.78	481.04	1160.35	1121.76	1587.83	300.00	1887.83
15:00	78.31	53.51	1248.48	1121.76	1165.83	300.00	1465.83
16:00	81.72	46.22	1302.83	1121.76	1161.94	300.00	1461.94
17:00	82.92	38.92	1321.92	1121.76	1155.84	300.00	1455.84

Chapter Two

Room 0-43

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT (K)	Q (W)	Qtot W
NE	8:00	Glass	1.10	3.44	5.20	19.65	38.12
		Wall "A"	0.13	4.04		2.68	
		Wall "B"	1.44	1.03		7.67	
		Wall "C"	1.79	0.87		8.12	
	9:00	Glass	1.10	3.44	6.75	25.51	49.48
		Wall "A"	0.13	4.04		3.48	
		Wall "B"	1.44	1.03		9.96	
		Wall "C"	1.79	0.87		10.53	
	10:00	Glass	1.10	3.44	8.56	32.35	62.75
		Wall "A"	0.13	4.04		4.41	
		Wall "B"	1.44	1.03		12.63	
		Wall "C"	1.79	0.87		13.36	
	11:00	Glass	1.10	3.44	10.50	39.68	76.97
		Wall "A"	0.13	4.04		5.41	
		Wall "B"	1.44	1.03		15.50	
		Wall "C"	1.79	0.87		16.39	
	12:00	Glass	1.10	3.44	12.44	47.01	91.19
		Wall "A"	0.13	4.04		6.41	
		Wall "B"	1.44	1.03		18.36	
		Wall "C"	1.79	0.87		19.41	
	13:00	Glass	1.10	3.44	14.25	53.85	104.46
		Wall "A"	0.13	4.04		7.34	
		Wall "B"	1.44	1.03		21.03	
		Wall "C"	1.79	0.87		22.24	
	14:00	Glass	1.10	3.44	15.80	59.71	115.83
		Wall "A"	0.13	4.04		8.14	
		Wall "B"	1.44	1.03		23.32	
		Wall "C"	1.79	0.87		24.66	
	15:00	Glass	1.10	3.44	17.00	64.25	124.62
		Wall "A"	0.13	4.04		8.76	
		Wall "B"	1.44	1.03		25.09	
		Wall "C"	1.79	0.87		26.53	
	16:00	Glass	1.10	3.44	17.74	67.04	130.05
		Wall "A"	0.13	4.04		9.14	
		Wall "B"	1.44	1.03		26.18	
		Wall "C"	1.79	0.87		27.69	
	17:00	Glass	1.10	3.44	18.00	68.03	131.95
		Wall "A"	0.13	4.04		9.27	
		Wall "B"	1.44	1.03		26.56	
		Wall "C"	1.79	0.87		28.09	

2-Sun Load

Direction	Time	Type	U	A	ΔT s	I	Q	Q tot W
NE	8:00	glass		3.44		410.00	478.93	557.58
		wall"A"	0.13	4.04	26.65		13.73	
		wall"B"	1.44	1.03	26.65		39.33	
		wall"C"	1.79	0.87	16.40		25.59	
	9:00	glass		3.44		305.00	356.27	414.78
		wall"A"	0.13	4.04	19.83		10.21	
		wall"B"	1.44	1.03	19.83		29.26	
		wall"C"	1.79	0.87	12.20		19.04	
	10:00	glass		3.44		173.00	202.08	235.27
		wall"A"	0.13	4.04	11.25		5.79	
		wall"B"	1.44	1.03	11.25		16.60	
		wall"C"	1.79	0.87	6.92		10.80	
	11:00	glass		3.44		60.00	70.09	81.60
		wall"A"	0.13	4.04	3.90		2.01	
		wall"B"	1.44	1.03	3.90		5.76	
		wall"C"	1.79	0.87	2.40		3.75	
	12:00	glass		3.44		44.00	51.40	59.84
		wall"A"	0.13	4.04	2.86		1.47	
		wall"B"	1.44	1.03	2.86		4.22	
		wall"C"	1.79	0.87	1.76		2.75	
	13:00	glass		3.44		44.00	51.40	59.84
		wall"A"	0.13	4.04	2.86		1.47	
		wall"B"	1.44	1.03	2.86		4.22	
		wall"C"	1.79	0.87	1.76		2.75	
	14:00	glass		3.44		44.00	478.93	487.37
		wall"A"	0.13	4.04	2.86		1.47	
		wall"B"	1.44	1.03	2.86		4.22	
		wall"C"	1.79	0.87	1.76		2.75	
	15:00	glass		3.44		44.00	51.40	59.84
		wall"A"	0.13	4.04	2.86		1.47	
		wall"B"	1.44	1.03	2.86		4.22	
		wall"C"	1.79	0.87	1.76		2.75	
	16:00	glass		3.44		38.00	44.39	51.68
		wall"A"	0.13	4.04	2.47		1.27	
		wall"B"	1.44	1.03	2.47		3.65	
		wall"C"	1.79	0.87	1.52		2.37	
	17:00	glass		3.44		32.00	37.38	43.52
		wall"A"	0.13	4.04	2.08		1.07	
		wall"B"	1.44	1.03	2.08		3.07	
		wall"C"	1.79	0.87	1.28		2.00	

Chapter Two

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5	12	1.8	2

A (m2)	17.52
H (m)	2.6
V (m3)	45.552

Method	CMM
Based on No Of Persons	3.6
Based on Area	1.89216
NO Of Air Changing Times	1.5184

Time	CMM	Qs(W)	QL(W)	Qtot (W)
8:00	3.6	381.89	1121.76	1503.65
9:00	3.6	495.72	1121.76	1617.48
10:00	3.6	628.65	1121.76	1750.41
11:00	3.6	771.12	1121.76	1892.88
12:00	3.6	913.59	1121.76	2035.35
13:00	3.6	1046.52	1121.76	2168.28
14:00	3.6	1160.35	1121.76	2282.11
15:00	3.6	1248.48	1121.76	2370.24
16:00	3.6	1302.83	1121.76	2424.59
17:00	3.6	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

NoOf Pers	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot W
5	Work	72	60	360	300	660

2- Light load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Fluorescent	8	20	1.25	200

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot
CPU	1	55	55	474
Monitor	1	55	55	
scan light	1	100	100	
abjora	1	60	60	
scan device	1	204	204	

Variation of load with time

Q occ_s	Q oc_l	Q lig_s	Q eq_s	Q eq_l
360	300	200	474	0

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_l	RSH	RLH	RTH
08:00	38.12	557.58	381.89	1121.76	1629.70	300.00	1929.70
09:00	49.48	414.78	495.72	1121.76	1498.27	300.00	1798.27
10:00	62.75	235.27	628.65	1121.76	1332.02	300.00	1632.02
11:00	76.97	81.60	771.12	1121.76	1192.57	300.00	1492.57
12:00	91.19	59.84	913.59	1121.76	1185.03	300.00	1485.03
13:00	104.46	59.84	1046.52	1121.76	1198.30	300.00	1498.30
14:00	115.83	487.37	1160.35	1121.76	1637.19	300.00	1937.19
15:00	124.62	59.84	1248.48	1121.76	1218.46	300.00	1518.46
16:00	130.05	51.68	1302.83	1121.76	1215.73	300.00	1515.73
17:00	131.95	43.52	1321.92	1121.76	1209.47	300.00	1509.47

Chapter Two

Room 0-44

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT (K)	Q (W)	Qtot W
NE	08:00	Glass	1.10	3.44	5.20	19.65	23.95
		Wall "A"	0.13	4.71		3.13	
		Wall "D"	0.39	0.57		1.18	
	09:00	Glass	1.10	3.44	6.75	25.51	31.09
		Wall "A"	0.13	4.71		4.06	
		Wall "D"	0.39	0.57		1.53	
	10:00	Glass	1.10	3.44	8.56	32.35	39.43
		Wall "A"	0.13	4.71		5.15	
		Wall "D"	0.39	0.57		1.94	
	11:00	Glass	1.10	3.44	10.50	39.68	48.37
		Wall "A"	0.13	4.71		6.31	
		Wall "D"	0.39	0.57		2.37	
	12:00	Glass	1.10	3.44	12.44	47.01	57.31
		Wall "A"	0.13	4.71		7.48	
		Wall "D"	0.39	0.57		2.81	
	13:00	Glass	1.10	3.44	14.25	53.85	65.64
		Wall "A"	0.13	4.71		8.57	
		Wall "D"	0.39	0.57		3.22	
	14:00	Glass	1.10	3.44	15.80	59.71	72.78
		Wall "A"	0.13	4.71		9.50	
		Wall "D"	0.39	0.57		3.57	
	15:00	Glass	1.10	3.44	17.00	64.25	78.31
		Wall "A"	0.13	4.71		10.22	
		Wall "D"	0.39	0.57		3.84	
	16:00	Glass	1.10	3.44	17.74	67.04	81.72
		Wall "A"	0.13	4.71		10.67	
		Wall "D"	0.39	0.57		4.01	
	17:00	Glass	1.10	3.44	18.00	68.03	82.92
		Wall "A"	0.13	4.71		10.82	
		Wall "D"	0.39	0.57		4.07	

2-Sun Load

Direction	Time	Type	U	A	ΔT	I	Q (W)	Q tot (W)
NE	8:00	glass		3.44		410.00	478.93	498.66
		Wall"A"	0.13	4.71	26.65		16.02	
		Wall"D"	0.39	0.57	16.40		3.71	
	9:00	glass		3.44		305.00	356.27	370.95
		Wall"A"	0.13	4.71	19.83		11.92	
		Wall"D"	0.39	0.57	12.20		2.76	
	10:00	glass		3.44		173.00	202.08	210.41
		Wall"A"	0.13	4.71	11.25		6.76	
		Wall"D"	0.39	0.57	6.92		1.57	
	11:00	glass		3.44		60.00	70.09	72.97
		Wall"A"	0.13	4.71	3.90		2.34	
		Wall"D"	0.39	0.57	2.40		0.54	
	12:00	glass		3.44		44.00	51.40	53.51
		Wall"A"	0.13	4.71	2.86		1.72	
		Wall"D"	0.39	0.57	1.76		0.40	
	13:00	glass		3.44		44.00	51.40	53.51
		Wall"A"	0.13	4.71	2.86		1.72	
		Wall"D"	0.39	0.57	1.76		0.40	
	14:00	glass		3.44		44.00	51.40	53.51
		Wall"A"	0.13	4.71	2.86		1.72	
		Wall"D"	0.39	0.57	1.76		0.40	
	15:00	glass		3.44		44.00	51.40	53.51
		Wall"A"	0.13	4.71	2.86		1.72	
		Wall"D"	0.39	0.57	1.76		0.40	
	16:00	glass		3.44		38.00	44.39	46.22
		Wall"A"	0.13	4.71	2.47		1.48	
		Wall"D"	0.39	0.57	1.52		0.34	
	17:00	glass		3.44		32.00	37.38	38.92
		Wall"A"	0.13	4.71	2.08		1.25	
		Wall"D"	0.39	0.57	1.28		0.29	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5	12	1.8	2

A (m2)	16.63
H (m)	2.6
V (m3)	43.238

Chapter Two

Method	CMM
Based on No Of Persons	3.6
Based on Area	1.80
NO Of Air Changing Times	1.44

Time	CMM	Qs(W)	QL(W)	Qtot (W)
8:00	3.6	381.89	1121.76	1503.65
9:00	3.6	495.72	1121.76	1617.48
10:00	3.6	628.65	1121.76	1750.41
11:00	3.6	771.12	1121.76	1892.88
12:00	3.6	913.59	1121.76	2035.35
13:00	3.6	1046.52	1121.76	2168.28
14:00	3.6	1160.35	1121.76	2282.11
15:00	3.6	1248.48	1121.76	2370.24
16:00	3.6	1302.83	1121.76	2424.59
17:00	3.6	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

NoOf Pers	Work	qs/p	qL/p	Qs	QL	Qtot (W)
5	Light Work	72	60	360	300	660

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8	20	1.25	200

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot
CPU	1	55	55	474
Monitor	1	55	55	
scan light	1	100	100	
abjora	1	60	60	
scan device	1	204	204	

Variation of load with time

Q occ_s	Q occ_I	Q lig_s	Q equ_s	Q equip_I
360	300	200	474	0

Time	Q wall_s	Q su_s	Q ven_s	Q vent_I	RSH	RLH	RTH
08:00	23.9540	498.657	381.888	1121.76	1556.6	300	1856.611
09:00	31.0942	370.952	495.72	1121.76	1436	300	1736.047
10:00	39.4320	210.409	628.6464	1121.76	1283.8	300	1583.841
11:00	48.3688	72.9742	771.12	1121.76	1155.3	300	1455.343
12:00	57.3055	53.5144	913.5936	1121.76	1144.8	300	1444.82
13:00	65.6433	53.5144	1046.52	1121.76	1153.2	300	1453.158
14:00	72.7835	53.5144	1160.352	1121.76	1160.3	300	1460.298
15:00	78.3114	53.5144	1248.48	1121.76	1165.8	300	1465.826
16:00	81.7202	46.2170	1302.826	1121.76	1161.9	300	1461.937
17:00	82.9179	38.9195	1321.92	1121.76	1155.8	300	1455.838

Room 0-45**A-External Loads****1-Wall Load**

Direction	Time	Type	U	A	ΔT	Q (W)	Qtot W
NE	8:00	Glass	1.10	3.44	5.20	19.65	38.12
		Wall "A"	0.13	4.04		2.68	
		Wall "B"	1.44	1.03		7.67	
		Wall "C"	1.79	0.87		8.12	
	9:00	Glass	1.10	3.44	6.75	25.51	49.48
		Wall "A"	0.13	4.04		3.48	
		Wall "B"	1.44	1.03		9.96	
		Wall "C"	1.79	0.87		10.53	
	10:00	Glass	1.10	3.44	8.56	32.35	62.75
		Wall "A"	0.13	4.04		4.41	
		Wall "B"	1.44	1.03		12.63	
		Wall "C"	1.79	0.87		13.36	
	11:00	Glass	1.10	3.44	10.50	39.68	76.97
		Wall "A"	0.13	4.04		5.41	
		Wall "B"	1.44	1.03		15.50	
		Wall "C"	1.79	0.87		16.39	
	12:00	Glass	1.10	3.44	12.44	47.01	91.19
		Wall "A"	0.13	4.04		6.41	
		Wall "B"	1.44	1.03		18.36	
		Wall "C"	1.79	0.87		19.41	
	13:00	Glass	1.10	3.44	14.25	53.85	104.46
		Wall "A"	0.13	4.04		7.34	
		Wall "B"	1.44	1.03		21.03	
		Wall "C"	1.79	0.87		22.24	
	14:00	Glass	1.10	3.44	15.80	59.71	115.83
		Wall "A"	0.13	4.04		8.14	
		Wall "B"	1.44	1.03		23.32	
		Wall "C"	1.79	0.87		24.66	
	15:00	Glass	1.10	3.44	17.00	64.25	124.62
		Wall "A"	0.13	4.04		8.76	
		Wall "B"	1.44	1.03		25.09	
		Wall "C"	1.79	0.87		26.53	
	16:00	Glass	1.10	3.44	17.74	67.04	130.05
		Wall "A"	0.13	4.04		9.14	
		Wall "B"	1.44	1.03		26.18	
		Wall "C"	1.79	0.87		27.69	
	17:00	Glass	1.10	3.44	18.00	68.03	131.95
		Wall "A"	0.13	4.04		9.27	
		Wall "B"	1.44	1.03		26.56	
		Wall "C"	1.79	0.87		28.09	

2-Sun Load

Direction	Time	Type	U	A	ΔT s	I	Q (W)	Qtot (W)
NE	8:00	glass		3.44		410.00	478.93	557.58
		wall"A"	0.13	4.04	26.65		13.73	
		wall"B"	1.44	1.03	26.65		39.33	
		wall"C"	1.79	0.87	16.40		25.59	
	9:00	glass		3.44		305.00	356.27	414.78
		wall"A"	0.13	4.04	19.83		10.21	
		wall"B"	1.44	1.03	19.83		29.26	
		wall"C"	1.79	0.87	12.20		19.04	
	10:00	glass		3.44		173.00	202.08	235.27
		wall"A"	0.13	4.04	11.25		5.79	
		wall"B"	1.44	1.03	11.25		16.60	
		wall"C"	1.79	0.87	6.92		10.80	
	11:00	glass		3.44		60.00	70.09	81.60
		wall"A"	0.13	4.04	3.90		2.01	
		wall"B"	1.44	1.03	3.90		5.76	
		wall"C"	1.79	0.87	2.40		3.75	
	12:00	glass		3.44		44.00	51.40	59.84
		wall"A"	0.13	4.04	2.86		1.47	
		wall"B"	1.44	1.03	2.86		4.22	
		wall"C"	1.79	0.87	1.76		2.75	
	13:00	glass		3.44		44.00	51.40	59.84
		wall"A"	0.13	4.04	2.86		1.47	
		wall"B"	1.44	1.03	2.86		4.22	
		wall"C"	1.79	0.87	1.76		2.75	
	14:00	glass		3.44		44.00	51.40	59.84
		wall"A"	0.13	4.04	2.86		1.47	
		wall"B"	1.44	1.03	2.86		4.22	
		wall"C"	1.79	0.87	1.76		2.75	
	15:00	glass		3.44		44.00	51.40	59.84
		wall"A"	0.13	4.04	2.86		1.47	
		wall"B"	1.44	1.03	2.86		4.22	
		wall"C"	1.79	0.87	1.76		2.75	
	16:00	glass		3.44		38.00	44.39	51.68
		wall"A"	0.13	4.04	2.47		1.27	
		wall"B"	1.44	1.03	2.47		3.65	
		wall"C"	1.79	0.87	1.52		2.37	
	17:00	glass		3.44		32.00	37.38	43.52
		wall"A"	0.13	4.04	2.08		1.07	
		wall"B"	1.44	1.03	2.08		3.07	
		wall"C"	1.79	0.87	1.28		2.00	

Chapter Two

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5	12	1.8	2

A (m2)	17.52
H (m)	2.6
V (m3)	45.552

Method	CMM
Based on No Of Persons	3.6
Based on Area	1.89216
NO Of Air Changing Times	1.5184

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
8:00	3.6	381.888	1121.76	1503.648
9:00	3.6	495.72	1121.76	1617.48
10:00	3.6	628.6464	1121.76	1750.406
11:00	3.6	771.12	1121.76	1892.88
12:00	3.6	913.5936	1121.76	2035.354
13:00	3.6	1046.52	1121.76	2168.28
14:00	3.6	1160.352	1121.76	2282.112
15:00	3.6	1248.48	1121.76	2370.24
16:00	3.6	1302.826	1121.76	2424.586
17:00	3.6	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

No Of Pers	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
5	Light Work	72	60	360	300	660

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8	20	1.25	200

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
CPU	1	55	55	474
Monitor	1	55	55	
scan light	1	100	100	
Table light	1	60	60	
scan device	1	204	204	

Variation of load with time

Q occ_s	Q occ_I	Q ligh_s	Q equ_s	Q equ_I
360	300	200	474	0

Time	Q wal_s	Qsun_s	Q ven_s	Q vent_I	RSH	RLH	RTH
8:00	38.1200	557.579	381.888	1121.76	1629.7	300	1929.7
9:00	49.4827	414.785	495.72	1121.76	1498.26	300	1798.3
10:00	62.7514	235.271	628.6464	1121.76	1332.02	300	1632
11:00	76.9731	81.5970	771.12	1121.76	1192.57	300	1492.6
12:00	91.1948	59.8378	913.593	1121.76	1185.03	300	1485
13:00	104.463	59.8378	1046.52	1121.76	1198.30	300	1498.3
14:00	115.826	59.8378	1160.35	1121.76	1209.66	300	1509.7
15:00	124.623	59.8378	1248.48	1121.76	1218.46	300	1518.5
16:00	130.048	51.67813	1302.826	1121.76	1215.72	300	1515.7
17:00	131.954	43.5184	1321.92	1121.76	1209.47	300	1509.5

Chapter Two

Room 0-47

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q (W)	Q t(W)
NE	0.33	Wall "A"	0.13	4.74	5.20	3.14	17.34
		Wall "B"	1.44	1.90		14.20	
	0.38	Wall "A"	0.13	4.74	6.75	4.08	22.51
		Wall "B"	1.44	1.90		18.43	
	0.42	Wall "A"	0.13	4.74	8.56	5.17	28.55
		Wall "B"	1.44	1.90		23.38	
	0.46	Wall "A"	0.13	4.74	10.50	6.35	35.02
		Wall "B"	1.44	1.90		28.68	
	0.50	Wall "A"	0.13	4.74	12.44	7.52	41.49
		Wall "B"	1.44	1.90		33.97	
	0.54	Wall "A"	0.13	4.74	14.25	8.61	47.53
		Wall "B"	1.44	1.90		38.92	
	0.58	Wall "A"	0.13	4.74	15.80	9.55	52.70
		Wall "B"	1.44	1.90		43.15	
	0.63	Wall "A"	0.13	4.74	17.00	10.28	56.70
		Wall "B"	1.44	1.90		46.43	
	0.67	Wall "A"	0.13	4.74	17.70	10.70	59.04
		Wall "B"	1.44	1.90		48.34	
	0.71	Wall "A"	0.13	4.74	18.00	10.88	60.04
		Wall "B"	1.44	1.90		49.16	

Direction	Time	Type	U	A	ΔT	Q (W)
NW	0.33	Adj Wall	0.10	14.35	5.20	7.52
	0.38	Adj Wall	0.10	14.35	6.75	9.76
	0.42	Adj Wall	0.10	14.35	8.56	12.37
	0.46	Adj Wall	0.10	14.35	10.50	15.18
	0.50	Adj Wall	0.10	14.35	12.44	17.98
	0.54	Adj Wall	0.10	14.35	14.25	20.59
	0.58	Adj Wall	0.10	14.35	15.80	22.83
	0.63	Adj Wall	0.10	14.35	17.00	24.57
	0.67	Adj Wall	0.10	14.35	17.70	25.58
	0.71	Adj Wall	0.10	14.35	18.00	26.01

Time	Qt(W)
0.33	24.86
0.38	32.27
0.42	40.92
0.46	50.20
0.50	59.47
0.54	68.13

0.58	75.54
0.63	81.27
0.67	84.62
0.71	86.05

2-Sun Load

Direction	Time	Type	U	A	I	ΔT_s	Q (W)	Q t(W)
NE	0.33	Wall "A"	0.13	4.74	410.00	26.65	16.11	88.89
		Wall "B"	1.44	1.90		26.65	72.78	
	0.38	Wall "A"	0.13	4.74	305.00	19.83	11.98	66.13
		Wall "B"	1.44	1.90		19.83	54.14	
	0.42	Wall "A"	0.13	4.74	173.00	11.25	6.80	37.51
		Wall "B"	1.44	1.90		2.86	30.71	
	0.46	Wall "A"	0.13	4.74	60.00	2.86	1.73	9.54
		Wall "B"	1.44	1.90		2.86	7.81	
	0.50	Wall "A"	0.13	4.74	44.00	2.86	1.73	9.54
		Wall "B"	1.44	1.90		3.51	7.81	
	0.54	Wall "A"	0.13	4.74	44.00	2.86	1.73	9.54
		Wall "B"	1.44	1.90		8.97	7.81	
	0.58	Wall "A"	0.13	4.74	44.00	2.86	1.73	9.54
		Wall "B"	1.44	1.90		14.95	7.81	
	0.63	Wall "A"	0.13	4.74	44.00	2.86	1.73	9.54
		Wall "B"	1.44	1.90		18.46	7.81	
	0.67	Wall "A"	0.13	4.74	38.00	2.47	1.49	8.24
		Wall "B"	1.44	1.90		18.46	6.75	
	0.71	Wall "A"	0.13	4.74	32.00	2.08	1.26	6.94
		Wall "B"	1.44	1.90		15.41	5.68	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
2.00	14.00	2.50	1.00

A (m2)	15.46
H (m)	2.60
V (m3)	40.20

Method	CMM
Based on No Of Persons	1.68
Based on Area	2.32
NO Of Air Changing Times	0.67

Chapter Two

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
08:00	2.32	246.00	722.60	968.60
09:00	2.32	319.33	722.60	1041.93
10:00	2.32	404.95	722.60	1127.55
11:00	2.32	496.73	722.60	1219.33
12:00	2.32	588.51	722.60	1311.11
13:00	2.32	674.13	722.60	1396.73
14:00	2.32	747.46	722.60	1470.06
15:00	2.32	804.23	722.60	1526.83
16:00	2.32	837.34	722.60	1559.94
17:00	2.32	851.54	722.60	1574.14

B-Internal Loads

1-Occupancy Load

No Of Persons	Type Of Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
2.00	Comfort. sitting	66.00	31.00	132.00	62.00	194.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
florescent	8.00	40.00	1.25	400.00

Variation of load with time

Qs	Qs	Ql	Qs	Ql
400.00	132.00	62.00	0.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_l	RSH	RLH	RTH
08:00	24.86	88.89	246.00	722.60	645.75	62.00	707.75
09:00	32.27	66.13	319.33	722.60	630.40	62.00	692.40
10:00	40.92	37.51	404.95	722.60	610.43	62.00	672.43
11:00	50.20	9.54	496.73	722.60	591.74	62.00	653.74
12:00	59.47	9.54	588.51	722.60	601.01	62.00	663.01
13:00	68.13	9.54	674.13	722.60	609.67	62.00	671.67
14:00	75.54	9.54	747.46	722.60	617.08	62.00	679.08
15:00	81.27	9.54	804.23	722.60	622.81	62.00	684.81
16:00	84.62	8.24	837.34	722.60	624.86	62.00	686.86
17:00	86.05	6.94	851.54	722.60	624.99	62.00	686.99

Room 0-48

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q (W)	Q t(W)
SW	08:00	Wall "A"	0.13	5.72	5.20	3.79	17.02
		Wall "B"	1.44	1.77		13.23	
	09:00	Wall "A"	0.13	5.72	6.75	4.92	22.09
		Wall "B"	1.44	1.77		17.17	
	10:00	Wall "A"	0.13	5.72	8.56	6.24	28.02
		Wall "B"	1.44	1.77		21.78	
	11:00	Wall "A"	0.13	5.72	10.50	7.66	34.37
		Wall "B"	1.44	1.77		26.71	
	12:00	Wall "A"	0.13	5.72	12.44	9.07	40.72
		Wall "B"	1.44	1.77		31.65	
	13:00	Wall "A"	0.13	5.72	14.25	10.39	46.64
		Wall "B"	1.44	1.77		36.25	
	14:00	Wall "A"	0.13	5.72	15.80	11.52	51.72
		Wall "B"	1.44	1.77		40.19	
	15:00	Wall "A"	0.13	5.72	17.00	12.40	55.64
		Wall "B"	1.44	1.77		43.25	
	16:00	Wall "A"	0.13	5.72	17.70	12.91	57.94
		Wall "B"	1.44	1.77		45.03	
	17:00	Wall "A"	0.13	5.72	18.00	13.13	58.92
		Wall "B"	1.44	1.77		45.79	

Direction	Time	Type	U	A (m2)	ΔT (K)	Q (W)
NW	08:00	Adj Wall	0.10	15.78	5.20	8.26
	09:00	Adj Wall	0.10	15.78	6.75	10.73
	10:00	Adj Wall	0.10	15.78	8.56	13.60
	11:00	Adj Wall	0.10	15.78	10.50	16.69
	12:00	Adj Wall	0.10	15.78	12.44	19.77
	13:00	Adj Wall	0.10	15.78	14.25	22.65
	14:00	Adj Wall	0.10	15.78	15.80	25.11
	15:00	Adj Wall	0.10	15.78	17.00	27.02
	16:00	Adj Wall	0.10	15.78	17.70	28.13
	17:00	Adj Wall	0.10	15.78	18.00	28.61

Time	Qt(W)
08:00	25.28
09:00	32.82
10:00	41.62
11:00	51.06
12:00	60.49
13:00	69.29
14:00	76.83
15:00	82.66
16:00	86.06
17:00	87.52

Chapter Two

2-Sun Load

Direction	Time	Type	U	A	I	ΔT_s	Q (W)	Q t(W)
SW	08:00	Wall "A"	0.13	5.72	38.00	2.47	1.80	8.08
		Wall "B"	1.44	1.77		2.47	6.28	
	09:00	Wall "A"	0.13	5.72	44.00	2.86	2.09	9.36
		Wall "B"	1.44	1.77		2.86	7.28	
	10:00	Wall "A"	0.13	5.72	44.00	2.86	2.09	9.36
		Wall "B"	1.44	1.77		2.86	7.28	
	11:00	Wall "A"	0.13	5.72	44.00	2.86	2.09	9.36
		Wall "B"	1.44	1.77		2.86	7.28	
	12:00	Wall "A"	0.13	5.72	54.00	3.51	2.56	11.49
		Wall "B"	1.44	1.77		3.51	8.93	
	13:00	Wall "A"	0.13	5.72	138.00	8.97	6.54	29.36
		Wall "B"	1.44	1.77		8.97	22.82	
	14:00	Wall "A"	0.13	5.72	230.00	14.95	10.90	48.93
		Wall "B"	1.44	1.77		14.95	38.03	
	15:00	Wall "A"	0.13	5.72	284.00	18.46	13.46	60.42
		Wall "B"	1.44	1.77		18.46	46.96	
	16:00	Wall "A"	0.13	5.72	284.00	18.46	13.46	60.42
		Wall "B"	1.44	1.77		18.46	46.96	
	17:00	Wall "A"	0.13	5.72	237.00	15.41	11.23	50.42
		Wall "B"	1.44	1.77		15.41	39.19	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
2.00	10.00	2.50	2.00

A (m2)	17.37
H (m)	2.60
V (m3)	45.16

Method	CMM
Based on No Of Persons	1.20
Based on Area	2.61
NO Of Air Changing Times	1.51

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
08:00	2.61	276.39	811.87	1088.27
09:00	2.61	358.78	811.87	1170.65
10:00	2.61	454.98	811.87	1266.86
11:00	2.61	558.10	811.87	1369.97
12:00	2.61	661.21	811.87	1473.09
13:00	2.61	757.42	811.87	1569.29
14:00	2.61	839.80	811.87	1651.68
15:00	2.61	903.59	811.87	1715.46
16:00	2.61	940.79	811.87	1752.67
17:00	2.61	956.74	811.87	1768.61

B-Internal Loads**1-Occupancy Load**

Persons	Work	qs/p (	qL/p (W)	Qs (W)	QL (W)	Qt (W)
2.00	sitting	66.00	31.00	132.00	62.00	194.00

2-Light Load

Type	No. lamps	W/Lamp	F	Q (W)
florescent	8	40.00	1.25	400.00

Variation of load with time

Qs	Qs	Ql	Qs	Ql
400.00	132.00	62.00	0.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent I	Qs tot	Ql tot	Q tot (W)
08:00	25.28	8.08	276.39	811.87	565.37	62.00	627.37
09:00	32.82	9.36	358.78	811.87	574.18	62.00	636.18
10:00	41.62	9.36	454.98	811.87	582.98	62.00	644.98
11:00	51.06	9.36	558.10	811.87	592.42	62.00	654.42
12:00	60.49	11.49	661.21	811.87	603.98	62.00	665.98
13:00	69.29	29.36	757.42	811.87	630.65	62.00	692.65
14:00	76.83	48.93	839.80	811.87	657.76	62.00	719.76
15:00	82.66	60.42	903.59	811.87	675.08	62.00	737.08
16:00	86.06	60.42	940.79	811.87	678.49	62.00	740.49
17:00	87.52	50.42	956.74	811.87	669.95	62.00	731.95

Room 0-49

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q (W)	Qtot W
SW	8:00	Glass	1.10	3.44	5.20	19.65	23.95
		Wall "A"	0.13	4.71		3.13	
		Wall "D"	0.39	0.57		1.18	
	9:00	Glass	1.10	3.44	6.75	25.51	31.09
		Wall "A"	0.13	4.71		4.06	
		Wall "D"	0.39	0.57		1.53	
	10:00	Glass	1.10	3.44	8.56	32.35	39.43
		Wall "A"	0.13	4.71		5.15	
		Wall "D"	0.39	0.57		1.94	
	11:00	Glass	1.10	3.44	10.50	39.68	48.37
		Wall "A"	0.13	4.71		6.31	
		Wall "D"	0.39	0.57		2.37	
	12:00	Glass	1.10	3.44	12.44	47.01	57.31
		Wall "A"	0.13	4.71		7.48	
		Wall "D"	0.39	0.57		2.81	
	13:00	Glass	1.10	3.44	14.25	53.85	65.64
		Wall "A"	0.13	4.71		8.57	
		Wall "D"	0.39	0.57		3.22	
	14:00	Glass	1.10	3.44	15.80	59.71	72.78
		Wall "A"	0.13	4.71		9.50	
		Wall "D"	0.39	0.57		3.57	
	15:00	Glass	1.10	3.44	17.00	64.25	78.31
		Wall "A"	0.13	4.71		10.22	
		Wall "D"	0.39	0.57		3.84	
	16:00	Glass	1.10	3.44	17.74	67.04	81.72
		Wall "A"	0.13	4.71		10.67	
		Wall "D"	0.39	0.57		4.01	
	17:00	Glass	1.10	3.44	18.00	68.03	82.92
		Wall "A"	0.13	4.71		10.82	
		Wall "D"	0.39	0.57		4.07	

2-Sun Load

Direction	Time	Type	U	A	ΔT s	I	Q (W)	Q Total
SW	8:00	glass		3.44		284.00	331.74	345.41
		A	0.13	4.71	18.46		11.10	
		D	0.39	0.57	11.36		2.57	
	9:00	glass		3.44		284.00	331.74	345.41
		A	0.13	4.71	18.46		11.10	
		D	0.39	0.57	11.36		2.57	

Load calculations

	10:00	glass		3.44		230.00	268.67	279.73
		A	0.13	4.71	14.95		8.99	
		D	0.39	0.57	9.20		2.08	
	11:00	glass		3.44		139.00	162.37	169.06
		A	0.13	4.71	9.04		5.43	
		D	0.39	0.57	5.56		1.26	
	12:00	glass		3.44		54.00	63.08	65.68
		A	0.13	4.71	3.51		2.11	
		D	0.39	0.57	2.16		0.49	
	13:00	glass		3.44		44.00	51.40	53.51
		A	0.13	4.71	2.86		1.72	
		D	0.39	0.57	1.76		0.40	
	14:00	glass		3.44		44.00	331.74	333.86
		A	0.13	4.71	2.86		1.72	
		D	0.39	0.57	1.76		0.40	
	15:00	glass		3.44		44.00	51.40	53.51
		A	0.13	4.71	2.86		1.72	
		D	0.39	0.57	1.76		0.40	
	16:00	glass		3.44		38.00	44.39	46.22
		A	0.13	4.71	2.47		1.48	
		D	0.39	0.57	1.52		0.34	
	17:00	glass		3.44		32.00	37.38	38.92
		A	0.13	4.71	2.08		1.25	
		D	0.39	0.57	1.28		0.29	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5.00	12.00	1.80	2.00

A (m2)	16.52
H (m)	2.60
V (m3)	38.91

Method	CMM
Based on No Of Persons	3.60
Based on Area	1.78
NO Of Air Changing Times	1.30

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
8:00	3.60	381.89	1121.76	1503.65
9:00	3.60	495.72	1121.76	1617.48
10:00	3.60	628.65	1121.76	1750.41
11:00	3.60	771.12	1121.76	1892.88
12:00	3.60	913.59	1121.76	2035.35

Chapter Two

13:00	3.60	1046.52	1121.76	2168.28
14:00	3.60	1160.35	1121.76	2282.11
15:00	3.60	1248.48	1121.76	2370.24
16:00	3.60	1302.83	1121.76	2424.59
17:00	3.60	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

NoOf Pers	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
5.00	Light	72.00	60.00	360.00	300.00	660.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8.00	20.00	1.25	200.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
CPU	1.00	55.00	55.00	474.00
Monitor	1.00	55.00	55.00	
scan light	1.00	100.00	100.00	
abjora	1.00	60.00	60.00	
scan device	1.00	204.00	204.00	

Variation of load with time

Q occ_s	Q occ_l	Q lig_s	Q eq_s	Q eq_l
360.00	300.00	200.00	474.00	0.00

Time	Q wal_s	Q sun_s	Q ven_s	Q vent_l	RSH	RLH	RTH
8:00	23.95	345.41	381.89	1121.76	1403.37	300.00	1703.37
9:00	31.09	345.41	495.72	1121.76	1410.51	300.00	1710.51
10:00	39.43	279.73	628.65	1121.76	1353.17	300.00	1653.17
11:00	48.37	169.06	771.12	1121.76	1251.43	300.00	1551.43
12:00	57.31	65.68	913.59	1121.76	1156.98	300.00	1456.98
13:00	65.64	53.51	1046.52	1121.76	1153.16	300.00	1453.16
14:00	72.78	333.86	1160.35	1121.76	1440.64	300.00	1740.64
15:00	78.31	53.51	1248.48	1121.76	1165.83	300.00	1465.83
16:00	81.72	46.22	1302.83	1121.76	1161.94	300.00	1461.94
17:00	82.92	38.92	1321.92	1121.76	1155.84	300.00	1455.84

Room 0-50**A-External Loads****1-Wall Load**

Direction	Time	Type	U	A	ΔT	Q	Qtot W
NE	8:00	Glass	1.10	3.44	5.20	19.65	38.12
		Wall "A"	0.13	4.04		2.68	
		Wall "B"	1.44	1.03		7.67	
		Wall "C"	1.79	0.87		8.12	
	9:00	Glass	1.10	3.44	6.75	25.51	49.48
		Wall "A"	0.13	4.04		3.48	
		Wall "B"	1.44	1.03		9.96	
		Wall "C"	1.79	0.87		10.53	
	10:00	Glass	1.10	3.44	8.56	32.35	62.75
		Wall "A"	0.13	4.04		4.41	
		Wall "B"	1.44	1.03		12.63	
		Wall "C"	1.79	0.87		13.36	
	11:00	Glass	1.10	3.44	10.50	39.68	76.97
		Wall "A"	0.13	4.04		5.41	
		Wall "B"	1.44	1.03		15.50	
		Wall "C"	1.79	0.87		16.39	
	12:00	Glass	1.10	3.44	12.44	47.01	91.19
		Wall "A"	0.13	4.04		6.41	
		Wall "B"	1.44	1.03		18.36	
		Wall "C"	1.79	0.87		19.41	
	13:00	Glass	1.10	3.44	14.25	53.85	104.46
		Wall "A"	0.13	4.04		7.34	
		Wall "B"	1.44	1.03		21.03	
		Wall "C"	1.79	0.87		22.24	
	14:00	Glass	1.10	3.44	15.80	59.71	115.83
		Wall "A"	0.13	4.04		8.14	
		Wall "B"	1.44	1.03		23.32	
		Wall "C"	1.79	0.87		24.66	
	15:00	Glass	1.10	3.44	17.00	64.25	124.62
		Wall "A"	0.13	4.04		8.76	
		Wall "B"	1.44	1.03		25.09	
		Wall "C"	1.79	0.87		26.53	
	16:00	Glass	1.10	3.44	17.74	67.04	130.05
		Wall "A"	0.13	4.04		9.14	
		Wall "B"	1.44	1.03		26.18	
		Wall "C"	1.79	0.87		27.69	
	17:00	Glass	1.10	3.44	18.00	68.03	131.95
		Wall "A"	0.13	4.04		9.27	
		Wall "B"	1.44	1.03		26.56	
		Wall "C"	1.79	0.87		28.09	

Chapter Two

2-Sun Load

Direction	Time	Type	U	A	ΔT s	I	Q	Qtot W
NE	8:00	glass		3.44		284.00	331.74	386.23
		A	0.13	4.04	18.46		9.51	
		B	1.44	1.03	18.46		27.24	
		C	1.79	0.87	11.36		17.73	
	9:00	glass		3.44		284.00	331.74	386.23
		A	0.13	4.04	18.46		9.51	
		B	1.44	1.03	18.46		27.24	
		C	1.79	0.87	11.36		17.73	
	10:00	glass		3.44		230.00	268.67	312.79
		A	0.13	4.04	14.95		7.70	
		B	1.44	1.03	14.95		22.06	
		C	1.79	0.87	9.20		14.36	
	11:00	glass		3.44		139.00	162.37	189.03
		A	0.13	4.04	9.04		4.65	
		B	1.44	1.03	9.04		13.33	
		C	1.79	0.87	5.56		8.68	
	12:00	glass		3.44		54.00	63.08	73.44
		A	0.13	4.04	3.51		1.81	
		B	1.44	1.03	3.51		5.18	
		C	1.79	0.87	2.16		3.37	
	13:00	glass		3.44		44.00	51.40	59.84
		A	0.13	4.04	2.86		1.47	
		B	1.44	1.03	2.86		4.22	
		C	1.79	0.87	1.76		2.75	
	14:00	glass		3.44		44.00	51.40	59.84
		A	0.13	4.04	2.86		1.47	
		B	1.44	1.03	2.86		4.22	
		C	1.79	0.87	1.76		2.75	
	15:00	glass		3.44		44.00	51.40	59.84
		A	0.13	4.04	2.86		1.47	
		B	1.44	1.03	2.86		4.22	
		C	1.79	0.87	1.76		2.75	
	16:00	glass		3.44		38.00	44.39	51.68
		A	0.13	4.04	2.47		1.27	
		B	1.44	1.03	2.47		3.65	
		C	1.79	0.87	1.52		2.37	
	17:00	glass		3.44		32.00	37.38	43.52
		A	0.13	4.04	2.08		1.07	
		B	1.44	1.03	2.08		3.07	
		C	1.79	0.87	1.28		2.00	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5.00	12.00	1.80	2.00

A (m2)	17.52
H (m)	2.60
V (m3)	38.91

Method	CMM
Based on No Of Persons	3.60
Based on Area	1.89
NO Of Air Changing Times	1.30

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
8:00	3.60	381.89	1121.76	1503.65
9:00	3.60	495.72	1121.76	1617.48
10:00	3.60	628.65	1121.76	1750.41
11:00	3.60	771.12	1121.76	1892.88
12:00	3.60	913.59	1121.76	2035.35
13:00	3.60	1046.52	1121.76	2168.28
14:00	3.60	1160.35	1121.76	2282.11
15:00	3.60	1248.48	1121.76	2370.24
16:00	3.60	1302.83	1121.76	2424.59
17:00	3.60	1321.92	1121.76	2443.68

B-Internal Loads**1-Occupancy Load**

No Of Pers	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
5.00	Light	72.00	60.00	360.00	300.00	660.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8.00	20.00	1.25	200.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
CPU	1.00	55.00	55.00	474.00
Monitor	1.00	55.00	55.00	
scan light	1.00	100.00	100.00	
abjora	1.00	60.00	60.00	
scan device	1.00	204.00	204.00	

Chapter Two

Variation of load with time

Q occ_s	Q occ_I	Q lig_s	Q eq_s	Q eq_I
360.00	300.00	200.00	474.00	0.00

Time	Q wall_s	Qsun_s	Q vent_s	Q vent_I	RSH	RLH	RTH
8:00	38.12	386.23	381.89	1121.76	1458.35	300.00	1758.35
9:00	49.48	386.23	495.72	1121.76	1469.71	300.00	1769.71
10:00	62.75	312.79	628.65	1121.76	1409.54	300.00	1709.54
11:00	76.97	189.03	771.12	1121.76	1300.01	300.00	1600.01
12:00	91.19	73.44	913.59	1121.76	1198.63	300.00	1498.63
13:00	104.46	59.84	1046.52	1121.76	1198.30	300.00	1498.30
14:00	115.83	59.84	1160.35	1121.76	1209.66	300.00	1509.66
15:00	124.62	59.84	1248.48	1121.76	1218.46	300.00	1518.46
16:00	130.05	51.68	1302.83	1121.76	1215.73	300.00	1515.73
17:00	131.95	43.52	1321.92	1121.76	1209.47	300.00	1509.47

Room 0-51

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q	Qtot ,W
SW	8:00	Glass	1.10	3.44	5.20	19.65	23.95
		Wall "A"	0.13	4.71		3.13	
		Wall "D"	0.39	0.57		1.18	
	9:00	Glass	1.10	3.44	6.75	25.51	31.09
		Wall "A"	0.13	4.71		4.06	
		Wall "D"	0.39	0.57		1.53	
	10:00	Glass	1.10	3.44	8.56	32.35	39.43
		Wall "A"	0.13	4.71		5.15	
		Wall "D"	0.39	0.57		1.94	
	11:00	Glass	1.10	3.44	10.50	39.68	48.37
		Wall "A"	0.13	4.71		6.31	
		Wall "D"	0.39	0.57		2.37	
	12:00	Glass	1.10	3.44	12.44	47.01	57.31
		Wall "A"	0.13	4.71		7.48	
		Wall "D"	0.39	0.57		2.81	
	13:00	Glass	1.10	3.44	14.25	53.85	65.64
		Wall "A"	0.13	4.71		8.57	
		Wall "D"	0.39	0.57		3.22	
	14:00	Glass	1.10	3.44	15.80	59.71	72.78
		Wall "A"	0.13	4.71		9.50	
		Wall "D"	0.39	0.57		3.57	
	15:00	Glass	1.10	3.44	17.00	64.25	78.31
		Wall "A"	0.13	4.71		10.22	
		Wall "D"	0.39	0.57		3.84	
	16:00	Glass	1.10	3.44	17.74	67.04	81.72
		Wall "A"	0.13	4.71		10.67	
		Wall "D"	0.39	0.57		4.01	
	17:00	Glass	1.10	3.44	18.00	68.03	82.92
		Wall "A"	0.13	4.71		10.82	
		Wall "D"	0.39	0.57		4.07	

2-Sun Load

Direction	Time	Type	U	A (m2)	ΔT sun	I	Q	Q Total
SW	8:00	glass		3.44		284.00	331.74	345.41
		A	0.13	4.71	18.46		11.10	
		D	0.39	0.57	11.36		2.57	
	9:00	glass		3.44		284.00	331.74	345.41
		A	0.13	4.71	18.46		11.10	
		D	0.39	0.57	11.36		2.57	

Chapter Two

	10:00	glass		3.44		230.00	268.67	279.73
		A	0.13	4.71	14.95		8.99	
		D	0.39	0.57	9.20		2.08	
	11:00	glass		3.44		139.00	162.37	169.06
		A	0.13	4.71	9.04		5.43	
		D	0.39	0.57	5.56		1.26	
	12:00	glass		3.44		54.00	63.08	65.68
		A	0.13	4.71	3.51		2.11	
		D	0.39	0.57	2.16		0.49	
	13:00	glass		3.44		44.00	51.40	53.51
		A	0.13	4.71	2.86		1.72	
		D	0.39	0.57	1.76		0.40	
	14:00	glass		3.44		44.00	51.40	53.51
		A	0.13	4.71	2.86		1.72	
		D	0.39	0.57	1.76		0.40	
	15:00	glass		3.44		44.00	51.40	53.51
		A	0.13	4.71	2.86		1.72	
		D	0.39	0.57	1.76		0.40	
	16:00	glass		3.44		38.00	44.39	46.22
		A	0.13	4.71	2.47		1.48	
		D	0.39	0.57	1.52		0.34	
	17:00	glass		3.44		32.00	37.38	38.92
		A	0.13	4.71	2.08		1.25	
		D	0.39	0.57	1.28		0.29	

3-Ventilation Load

No Of Persons	L/s.p	L/s.m2	ζ
5.00	12.00	1.80	2.00

A (m2)	163.63
H (m)	2.60
V (m3)	38.91

Method	CMM
Based on No Of Persons	3.60
Based on Area	17.67
NO Of Air Changing Times	1.30

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
8:00	3.60	381.89	1121.76	1503.65
9:00	3.60	495.72	1121.76	1617.48
10:00	3.60	628.65	1121.76	1750.41
11:00	3.60	771.12	1121.76	1892.88
12:00	3.60	913.59	1121.76	2035.35
13:00	3.60	1046.52	1121.76	2168.28

14:00	3.60	1160.35	1121.76	2282.11
15:00	3.60	1248.48	1121.76	2370.24
16:00	3.60	1302.83	1121.76	2424.59
17:00	3.60	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

No Of Pers	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
5.00	Light Work	72.00	60.00	360.00	300.00	660.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8.00	20.00	1.25	200.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
CPU	1.00	55.00	55.00	474.00
Monitor	1.00	55.00	55.00	
scan light	1.00	100.00	100.00	
abjora	1.00	60.00	60.00	
scan device	1.00	204.00	204.00	

Variation of load with time

Q occ_s	Q occ_l	Q light_s	Q equip_s	Q equip_l
360.00	300.00	200.00	474.00	0.00

Time	Q wall_s	Q sun_s	Q vent_s	Q vent_l	RSH	RLH	RTH
8:00	23.95	345.41	381.89	1121.76	1403.3	300.00	1703.3
9:00	31.09	345.41	495.72	1121.76	1410.5	300.00	1710.5
10:00	39.43	279.73	628.65	1121.76	1353.1	300.00	1653.1
11:00	48.37	169.06	771.12	1121.76	1251.4	300.00	1551.4
12:00	57.31	65.68	913.59	1121.76	1156.9	300.00	1456.9
13:00	65.64	53.51	1046.52	1121.76	1153.1	300.00	1453.1
14:00	72.78	53.51	1160.35	1121.76	1160.3	300.00	1460.3
15:00	78.31	53.51	1248.48	1121.76	1165.8	300.00	1465.8
16:00	81.72	46.22	1302.83	1121.76	1161.9	300.00	1461.9
17:00	82.92	38.92	1321.92	1121.76	1155.84	300.00	1455.84

Room 0-52**A-External Loads****1-Wall Load**

Direction	Time	Type	U	A	ΔT	Q	Qtot W
NE	8:00	Glass	1.10	3.44	5.20	19.65	38.12
		Wall "A"	0.13	4.04		2.68	
		Wall "B"	1.44	1.03		7.67	
		Wall "C"	1.79	0.87		8.12	
	9:00	Glass	1.10	3.44	6.75	25.51	49.48
		Wall "A"	0.13	4.04		3.48	
		Wall "B"	1.44	1.03		9.96	
		Wall "C"	1.79	0.87		10.53	
	10:00	Glass	1.10	3.44	8.56	32.35	62.75
		Wall "A"	0.13	4.04		4.41	
		Wall "B"	1.44	1.03		12.63	
		Wall "C"	1.79	0.87		13.36	
	11:00	Glass	1.10	3.44	10.50	39.68	76.97
		Wall "A"	0.13	4.04		5.41	
		Wall "B"	1.44	1.03		15.50	
		Wall "C"	1.79	0.87		16.39	
	12:00	Glass	1.10	3.44	12.44	47.01	91.19
		Wall "A"	0.13	4.04		6.41	
		Wall "B"	1.44	1.03		18.36	
		Wall "C"	1.79	0.87		19.41	
	13:00	Glass	1.10	3.44	14.25	53.85	104.46
		Wall "A"	0.13	4.04		7.34	
		Wall "B"	1.44	1.03		21.03	
		Wall "C"	1.79	0.87		22.24	
	14:00	Glass	1.10	3.44	15.80	59.71	115.83
		Wall "A"	0.13	4.04		8.14	
		Wall "B"	1.44	1.03		23.32	
		Wall "C"	1.79	0.87		24.66	
	15:00	Glass	1.10	3.44	17.00	64.25	124.62
		Wall "A"	0.13	4.04		8.76	
		Wall "B"	1.44	1.03		25.09	
		Wall "C"	1.79	0.87		26.53	
	16:00	Glass	1.10	3.44	17.74	67.04	130.05
		Wall "A"	0.13	4.04		9.14	
		Wall "B"	1.44	1.03		26.18	
		Wall "C"	1.79	0.87		27.69	
	17:00	Glass	1.10	3.44	18.00	68.03	131.95
		Wall "A"	0.13	4.04		9.27	
		Wall "B"	1.44	1.03		26.56	
		Wall "C"	1.79	0.87		28.09	

2-Sun Load

Direction	Time	Type	U	A	ΔT sun	I	Q	Qtot W
NE	8:00	glass		3.44		284.00	331.74	386.23
		A	0.13	4.04	18.46		9.51	
		B	1.44	1.03	18.46		27.24	
		C	1.79	0.87	11.36		17.73	
	9:00	glass		3.44		284.00	331.74	386.23
		A	0.13	4.04	18.46		9.51	
		B	1.44	1.03	18.46		27.24	
		C	1.79	0.87	11.36		17.73	
	10:00	glass		3.44		230.00	268.67	312.79
		A	0.13	4.04	14.95		7.70	
		B	1.44	1.03	14.95		22.06	
		C	1.79	0.87	9.20		14.36	
	11:00	glass		3.44		139.00	162.37	189.03
		A	0.13	4.04	9.04		4.65	
		B	1.44	1.03	9.04		13.33	
		C	1.79	0.87	5.56		8.68	
	12:00	glass		3.44		54.00	63.08	73.44
		A	0.13	4.04	3.51		1.81	
		B	1.44	1.03	3.51		5.18	
		C	1.79	0.87	2.16		3.37	
	13:00	glass		3.44		44.00	51.40	59.84
		A	0.13	4.04	2.86		1.47	
		B	1.44	1.03	2.86		4.22	
		C	1.79	0.87	1.76		2.75	
	14:00	glass		3.44		44.00	51.40	59.84
		A	0.13	4.04	2.86		1.47	
		B	1.44	1.03	2.86		4.22	
		C	1.79	0.87	1.76		2.75	
	15:00	glass		3.44		44.00	51.40	59.84
		A	0.13	4.04	2.86		1.47	
		B	1.44	1.03	2.86		4.22	
		C	1.79	0.87	1.76		2.75	
	16:00	glass		3.44		38.00	44.39	51.68
		A	0.13	4.04	2.47		1.27	

Chapter Two

		B	1.44	1.03	2.47		3.65	
		C	1.79	0.87	1.52		2.37	
	17:00	glass		3.44		32.00	37.38	43.52
		A	0.13	4.04	2.08		1.07	
		B	1.44	1.03	2.08		3.07	
		C	1.79	0.87	1.28		2.00	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5.00	12.00	1.80	2.00

A (m2)	17.52
H (m)	2.60
V (m3)	38.91

Method	CMM
Based on No Of Persons	3.60
Based on Area	1.89
NO Of Air Changing Times	1.30

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
8:00	3.60	381.89	1121.76	1503.65
9:00	3.60	495.72	1121.76	1617.48
10:00	3.60	628.65	1121.76	1750.41
11:00	3.60	771.12	1121.76	1892.88
12:00	3.60	913.59	1121.76	2035.35
13:00	3.60	1046.52	1121.76	2168.28
14:00	3.60	1160.35	1121.76	2282.11
15:00	3.60	1248.48	1121.76	2370.24
16:00	3.60	1302.83	1121.76	2424.59
17:00	3.60	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

No Of Pers	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
5.00	Light Work	72.00	60.00	360.00	300.00	660.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8.00	20.00	1.25	200.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
CPU	1.00	55.00	55.00	474.00
Monitor	1.00	55.00	55.00	
scan light	1.00	100.00	100.00	
abjora	1.00	60.00	60.00	
scan device	1.00	204.00	204.00	

Variation of load with time

Q occ_s	Q occ_l	Q lig_s	Q eq_s	Q eq_l
360.00	300.00	200.00	474.00	0.00

Time	Q wall_s	Qsun_s	Q vent_s	Q vent_l	RSH	RLH	RTH
8:00	38.12	386.23	381.89	1121.76	1458.35	300.00	1758.35
9:00	49.48	386.23	495.72	1121.76	1469.71	300.00	1769.71
10:00	62.75	312.79	628.65	1121.76	1409.54	300.00	1709.54
11:00	76.97	189.03	771.12	1121.76	1300.01	300.00	1600.01
12:00	91.19	73.44	913.59	1121.76	1198.63	300.00	1498.63
13:00	104.46	59.84	1046.52	1121.76	1198.30	300.00	1498.30
14:00	115.83	59.84	1160.35	1121.76	1209.66	300.00	1509.66
15:00	124.62	59.84	1248.48	1121.76	1218.46	300.00	1518.46
16:00	130.05	51.68	1302.83	1121.76	1215.73	300.00	1515.73
17:00	131.95	43.52	1321.92	1121.76	1209.47	300.00	1509.47

Room 0-53

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q	Qtot W
SW	8:00	Glass	1.10	3.44	5.20	19.65	23.95
		Wall "A"	0.13	4.71		3.13	
		Wall "D"	0.39	0.57		1.18	
	9:00	Glass	1.10	3.44	6.75	25.51	31.09
		Wall "A"	0.13	4.71		4.06	
		Wall "D"	0.39	0.57		1.53	
	10:00	Glass	1.10	3.44	8.56	32.35	39.43
		Wall "A"	0.13	4.71		5.15	
		Wall "D"	0.39	0.57		1.94	
	11:00	Glass	1.10	3.44	10.50	39.68	48.37
		Wall "A"	0.13	4.71		6.31	
		Wall "D"	0.39	0.57		2.37	
	12:00	Glass	1.10	3.44	12.44	47.01	57.31
		Wall "A"	0.13	4.71		7.48	
		Wall "D"	0.39	0.57		2.81	
	13:00	Glass	1.10	3.44	14.25	53.85	65.64
		Wall "A"	0.13	4.71		8.57	
		Wall "D"	0.39	0.57		3.22	
	14:00	Glass	1.10	3.44	15.80	59.71	72.78
		Wall "A"	0.13	4.71		9.50	
		Wall "D"	0.39	0.57		3.57	
	15:00	Glass	1.10	3.44	17.00	64.25	78.31
		Wall "A"	0.13	4.71		10.22	
		Wall "D"	0.39	0.57		3.84	
	16:00	Glass	1.10	3.44	17.74	67.04	81.72
		Wall "A"	0.13	4.71		10.67	
		Wall "D"	0.39	0.57		4.01	
	17:00	Glass	1.10	3.44	18.00	68.03	82.92
		Wall "A"	0.13	4.71		10.82	
		Wall "D"	0.39	0.57		4.07	

2-Sun Load

Direction	Time	Type	U	A	ΔT sun	I	Q	Qtot W
SW	8:00	glass		3.44		284.00	331.74	345.41
		A	0.13	4.71	18.46		11.10	
		D	0.39	0.57	11.36		2.57	
	9:00	glass		3.44		284.00	331.74	345.41
		A	0.13	4.71	18.46		11.10	

Load calculations

		D	0.39	0.57	11.36		2.57	
	10:00	glass		3.44		230.00	268.67	279.73
		A	0.13	4.71	14.95		8.99	
		D	0.39	0.57	9.20		2.08	
	11:00	glass		3.44		139.00	162.37	169.06
		A	0.13	4.71	9.04		5.43	
		D	0.39	0.57	5.56		1.26	
	12:00	glass		3.44		54.00	63.08	65.68
		A	0.13	4.71	3.51		2.11	
		D	0.39	0.57	2.16		0.49	
	13:00	glass		3.44		44.00	51.40	53.51
		A	0.13	4.71	2.86		1.72	
		D	0.39	0.57	1.76		0.40	
	14:00	glass		3.44		44.00	51.40	53.51
		A	0.13	4.71	2.86		1.72	
		D	0.39	0.57	1.76		0.40	
	15:00	glass		3.44		44.00	51.40	53.51
		A	0.13	4.71	2.86		1.72	
		D	0.39	0.57	1.76		0.40	
	16:00	glass		3.44		38.00	44.39	46.22
		A	0.13	4.71	2.47		1.48	
		D	0.39	0.57	1.52		0.34	
	17:00	glass		3.44		32.00	37.38	38.92
		A	0.13	4.71	2.08		1.25	
		D	0.39	0.57	1.28		0.29	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5.00	12.00	1.80	2.00

A (m2)	16.63
H (m)	2.60
V (m3)	38.91

Method	CMM
Based on No Of Persons	3.60
Based on Area	1.80
NO Of Air Changing Times	1.30

Time	CMMmax	Qs(W)	QL(W)	Qtot (W)
8:00	3.60	381.89	1121.76	1503.65
9:00	3.60	495.72	1121.76	1617.48
10:00	3.60	628.65	1121.76	1750.41
11:00	3.60	771.12	1121.76	1892.88
12:00	3.60	913.59	1121.76	2035.35

Chapter Two

13:00	3.60	1046.52	1121.76	2168.28
14:00	3.60	1160.35	1121.76	2282.11
15:00	3.60	1248.48	1121.76	2370.24
16:00	3.60	1302.83	1121.76	2424.59
17:00	3.60	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

No Of Pers	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
5.00	Light Work	72.00	60.00	360.00	300.00	660.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8.00	20.00	1.25	200.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
CPU	1.00	55.00	55.00	474.00
Monitor	1.00	55.00	55.00	
scan light	1.00	100.00	100.00	
abjora	1.00	60.00	60.00	
scan device	1.00	204.00	204.00	

Variation of load with time

Q occ_s	Q occ_l	Q lig_s	Q eq_s	Q eq_l
360.00	300.00	200.00	474.00	0.00

Time	Q wall_s	Q sun_s	Q vent_s	Q vent_l	RSH	RLH	RTH
8:00	23.95	345.41	381.89	1121.76	1403.37	300.00	1703.37
9:00	31.09	345.41	495.72	1121.76	1410.51	300.00	1710.51
10:00	39.43	279.73	628.65	1121.76	1353.17	300.00	1653.17
11:00	48.37	169.06	771.12	1121.76	1251.43	300.00	1551.43
12:00	57.31	65.68	913.59	1121.76	1156.98	300.00	1456.98
13:00	65.64	53.51	1046.52	1121.76	1153.16	300.00	1453.16
14:00	72.78	53.51	1160.35	1121.76	1160.30	300.00	1460.30
15:00	78.31	53.51	1248.48	1121.76	1165.83	300.00	1465.83
16:00	81.72	46.22	1302.83	1121.76	1161.94	300.00	1461.94
17:00	82.92	38.92	1321.92	1121.76	1155.84	300.00	1455.84

Room 0-54

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q	Qtot W
NE	8:00	Glass	1.10	3.44	5.20	19.65	36.53
		Wall "A"	0.13	4.04		2.68	
		Wall "B"	1.44	1.90		14.20	
	9:00	Glass	1.10	3.44	6.75	25.51	47.42
		Wall "A"	0.13	4.04		3.48	
		Wall "B"	1.44	1.90		18.43	
	10:00	Glass	1.10	3.44	8.56	32.35	60.14
		Wall "A"	0.13	4.04		4.41	
		Wall "B"	1.44	1.90		23.38	
	11:00	Glass	1.10	3.44	10.50	39.68	73.77
		Wall "A"	0.13	4.04		5.41	
		Wall "B"	1.44	1.90		28.68	
	12:00	Glass	1.10	3.44	12.44	47.01	87.40
		Wall "A"	0.13	4.04		6.41	
		Wall "B"	1.44	1.90		33.97	
	13:00	Glass	1.10	3.44	14.25	53.85	100.11
		Wall "A"	0.13	4.04		7.34	
		Wall "B"	1.44	1.90		38.92	
	14:00	Glass	1.10	3.44	15.80	59.71	111.00
		Wall "A"	0.13	4.04		8.14	
		Wall "B"	1.44	1.90		43.15	
	15:00	Glass	1.10	3.44	17.00	64.25	119.43
		Wall "A"	0.13	4.04		8.76	
		Wall "B"	1.44	1.90		46.43	
	16:00	Glass	1.10	3.44	17.74	67.04	124.63
		Wall "A"	0.13	4.04		9.14	
		Wall "B"	1.44	1.90		48.45	
	17:00	Glass	1.10	3.44	18.00	68.03	126.46
		Wall "A"	0.13	4.04		9.27	
		Wall "B"	1.44	1.90		49.16	

2-Sun Load

Direction	Time	Type	U	A	ΔT sun	I	Q	Qtot W
NE	8:00	glass		3.44		284.00	331.74	391.67
		A	0.13	4.04	18.46		9.51	
		B	1.44	1.90	18.46		50.41	
	9:00	glass		3.44		284.00	331.74	391.67
		A	0.13	4.04	18.46		9.51	

Chapter Two

		B	1.44	1.90	18.46		50.41	
	10:00	glass		3.44		230.00	268.67	317.20
		A	0.13	4.04	14.95		7.70	
		B	1.44	1.90	14.95		40.83	
	11:00	glass		3.44		139.00	162.37	191.70
		A	0.13	4.04	9.04		4.65	
		B	1.44	1.90	9.04		24.67	
	12:00	glass		3.44		54.00	63.08	74.47
		A	0.13	4.04	3.51		1.81	
		B	1.44	1.90	3.51		9.59	
	13:00	glass		3.44		44.00	51.40	60.68
		A	0.13	4.04	2.86		1.47	
		B	1.44	1.90	2.86		7.81	
	14:00	glass		3.44		44.00	51.40	60.68
		A	0.13	4.04	2.86		1.47	
		B	1.44	1.90	2.86		7.81	
	15:00	glass		3.44		44.00	51.40	60.68
		A	0.13	4.04	2.86		1.47	
		B	1.44	1.90	2.86		7.81	
	16:00	glass		3.44		38.00	44.39	52.41
		A	0.13	4.04	2.47		1.27	
		B	1.44	1.90	2.47		6.75	
	17:00	glass		3.44		32.00	37.38	44.13
		A	0.13	4.04	2.08		1.07	
		B	1.44	1.90	2.08		5.68	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5.00	12.00	1.80	2.00

A (m2)	17.52
H (m)	2.60
V (m3)	38.91

Method	CMM
Based on No Of Persons	3.60
Based on Area	1.89
NO Of Air Changing Times	1.30

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
8:00	3.60	381.89	1121.76	1503.65
9:00	3.60	495.72	1121.76	1617.48
10:00	3.60	628.65	1121.76	1750.41
11:00	3.60	771.12	1121.76	1892.88

12:00	3.60	913.59	1121.76	2035.35
13:00	3.60	1046.52	1121.76	2168.28
14:00	3.60	1160.35	1121.76	2282.11
15:00	3.60	1248.48	1121.76	2370.24
16:00	3.60	1302.83	1121.76	2424.59
17:00	3.60	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

No Of Pers	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
5.00	Light Work	72.00	60.00	360.00	300.00	660.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Florescent	8.00	20.00	1.25	200.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot
CPU	1.00	55.00	55.00	474.00
Monitor	1.00	55.00	55.00	
scan light	1.00	100.00	100.00	
abjora	1.00	60.00	60.00	
scan device	1.00	204.00	204.00	

Variation of load with time

Q occ_s	Q occ_l	Q lig_s	Q eq_s	Q eq_l
360.00	300.00	200.00	474.00	0.00

Time	Q wall_s	Qsun_s	Q vent_s	Q vent_l	RSH	RLH	RTH
8:00	36.53	391.67	381.89	1121.76	1462.20	300.00	1762.20
9:00	47.42	391.67	495.72	1121.76	1473.09	300.00	1773.09
10:00	60.14	317.20	628.65	1121.76	1411.33	300.00	1711.33
11:00	73.77	191.70	771.12	1121.76	1299.46	300.00	1599.46
12:00	87.40	74.47	913.59	1121.76	1195.87	300.00	1495.87
13:00	100.11	60.68	1046.52	1121.76	1194.79	300.00	1494.79
14:00	111.00	60.68	1160.35	1121.76	1205.68	300.00	1505.68
15:00	119.43	60.68	1248.48	1121.76	1214.11	300.00	1514.11
16:00	124.63	52.41	1302.83	1121.76	1211.04	300.00	1511.04
17:00	126.46	44.13	1321.92	1121.76	1204.59	300.00	1504.59

Chapter Two

Room 0-55

A-External Loads

Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
3.00	10.00	1.80	2.00

A (m2)	13.39
H (m)	2.60
V (m3)	34.81

Method	CMM
Based on No Of Persons	1.80
Based on Area	1.45
NO Of Air Changing Times	1.16

Time	CMM max	Q s(W)	QL(W)	Q tot (W)
08:00	1.80	190.94	560.88	751.82
09:00	1.80	247.86	560.88	808.74
10:00	1.80	314.32	560.88	875.20
11:00	1.80	385.56	560.88	946.44
12:00	1.80	456.80	560.88	1017.68
13:00	1.80	523.26	560.88	1084.14
14:00	1.80	580.18	560.88	1141.06
15:00	1.80	624.24	560.88	1185.12
16:00	1.80	649.94	560.88	1210.82
17:00	1.80	660.96	560.88	1221.84

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
3.00	Light	72.00	60.00	216.00	180.00	396.00

2-Light Load

Type	No OF Lamps	W/Lamp	F	Q (W)
florescent	8.00	40.00	1.25	400.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)
computer	1.00	110.00	110.00

Variation of load with time

Q occ_s	Q occ_l	Q lig_s	Q eq_s	Q eq_l
400.00	216.00	180.00	110.00	0

Time	Qs	Qs	Qs	Ql	RSH (W)	RLH (W)	RTH (W)
08:00	0.00	0.00	190.94	560.88	726.00	180.00	906.00
09:00	0.00	0.00	247.86	560.88	726.00	180.00	906.00
10:00	0.00	0.00	314.32	560.88	726.00	180.00	906.00
11:00	0.00	0.00	385.56	560.88	726.00	180.00	906.00
12:00	0.00	0.00	456.80	560.88	726.00	180.00	906.00
13:00	0.00	0.00	523.26	560.88	726.00	180.00	906.00
14:00	0.00	0.00	580.18	560.88	726.00	180.00	906.00
15:00	0.00	0.00	624.24	560.88	726.00	180.00	906.00
16:00	0.00	0.00	649.94	560.88	726.00	180.00	906.00
17:00	0.00	0.00	660.96	560.88	726.00	180.00	906.00

Chapter Two

Room 0-59

A-External Loads

1-Wall Load

Direction	Time	Type	U	A (m2)	ΔT (K)	Q (W)	Q t(W)
SW	08:00	Wall "A"	0.13	4.05	5.20	2.68	38.00
		Glass	1.10	3.44		19.69	
		Wall "C"	1.79	0.85		7.95	
		Wall "B"	1.44	1.03		7.67	
	09:00	Wall "A"	0.13	4.05	6.75	3.48	49.33
		Glass	1.10	3.44		25.56	
		Wall "C"	1.79	0.85		10.32	
		Wall "B"	1.44	1.03		9.96	
	10:00	Wall "A"	0.13	4.05	8.56	4.42	62.55
		Glass	1.10	3.44		32.42	
		Wall "C"	1.79	0.85		13.08	
		Wall "B"	1.44	1.03		12.63	
	11:00	Wall "A"	0.13	4.05	10.50	5.42	76.73
		Glass	1.10	3.44		39.76	
		Wall "C"	1.79	0.85		16.05	
		Wall "B"	1.44	1.03		15.50	
	12:00	Wall "A"	0.13	4.05	12.44	6.42	90.91
		Glass	1.10	3.44		47.11	
		Wall "C"	1.79	0.85		19.01	
		Wall "B"	1.44	1.03		18.36	
	13:00	Wall "A"	0.13	4.05	14.25	7.36	104.13
		Glass	1.10	3.44		53.97	
		Wall "C"	1.79	0.85		21.78	
		Wall "B"	1.44	1.03		21.03	
	14:00	Wall "A"	0.13	4.05	15.80	8.16	115.46
		Glass	1.10	3.44		59.84	
		Wall "C"	1.79	0.85		24.15	
		Wall "B"	1.44	1.03		23.32	
	15:00	Wall "A"	0.13	4.05	17.00	8.78	124.23
		Glass	1.10	3.44		64.38	
		Wall "C"	1.79	0.85		25.99	
		Wall "B"	1.44	1.03		25.09	
	16:00	Wall "A"	0.13	4.05	17.70	9.14	129.35
		Glass	1.10	3.44		67.03	
		Wall "C"	1.79	0.85		27.06	
		Wall "B"	1.44	1.03		26.12	
	17:00	Wall "A"	0.13	4.05	18.00	9.29	131.54
		Glass	1.10	3.44		68.17	
		Wall "C"	1.79	0.85		27.51	
		Wall "B"	1.44	1.03		26.56	

2-Sun Load

Direction	Time	Type	U	A	I	ΔT	Q	Q t(W)
SW	0.33	Wall "A"	0.13	4.05	38.00	2.47	1.28	53.18
		Glass	1.10	3.44			44.48	
		Wall "C"	1.79	0.85		1.52	3.78	
		Wall "B"	1.44	1.03		2.47	3.65	
	0.38	Wall "A"	0.13	4.05	44.00	2.86	1.48	61.57
		Glass	1.10	3.44			51.50	
		Wall "C"	1.79	0.85		1.76	4.37	
		Wall "B"	1.44	1.03		2.86	4.22	
	0.42	Wall "A"	0.13	4.05	44.00	2.86	1.48	61.57
		Glass	1.10	3.44			51.50	
		Wall "C"	1.79	0.85		1.76	4.37	
		Wall "B"	1.44	1.03		2.86	4.22	
	0.46	Wall "A"	0.13	4.05	44.00	2.86	1.48	61.57
		Glass	1.10	3.44			51.50	
		Wall "C"	1.79	0.85		1.76	4.37	
		Wall "B"	1.44	1.03		2.86	4.22	
	0.50	Wall "A"	0.13	4.05	54.00	3.51	1.81	75.57
		Glass	1.10	3.44			63.21	
		Wall "C"	1.79	0.85		2.16	5.37	
		Wall "B"	1.44	1.03		3.51	5.18	
	0.54	Wall "A"	0.13	4.05	138.00	8.97	4.63	193.12
		Glass	1.10	3.44			161.54	
		Wall "C"	1.79	0.85		5.52	13.71	
		Wall "B"	1.44	1.03		8.97	13.24	
	0.58	Wall "A"	0.13	4.05	230.00	14.95	7.72	321.86
		Glass	1.10	3.44			269.23	
		Wall "C"	1.79	0.85		9.20	22.85	
		Wall "B"	1.44	1.03		14.95	22.06	
	0.63	Wall "A"	0.13	4.05	284.00	18.46	9.53	397.43
		Glass	1.10	3.44			332.44	
		Wall "C"	1.79	0.85		11.36	28.22	
		Wall "B"	1.44	1.03		18.46	27.24	
	0.67	Wall "A"	0.13	4.05	284.00	18.46	9.53	397.43
		Glass	1.10	3.44			332.44	
		Wall "C"	1.79	0.85		11.36	28.22	
		Wall "B"	1.44	1.03		18.46	27.24	
	0.71	Wall "A"	0.13	4.05	237.00	15.41	7.95	331.66
		Glass	1.10	3.44			277.42	
		Wall "C"	1.79	0.85		9.48	23.55	
		Wall "B"	1.44	1.03		15.41	22.73	

Chapter Two

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
6.00	14.00	6.70	7.00

A (m2)	13.60
H (m)	2.60
V (m3)	35.36

Method	CMM
Based on No Of Persons	5.04
Based on Area	5.47
NO. Of Air Changing Times	4.13

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
08:00	5.47	579.96	1703.58	2283.54
09:00	5.47	752.83	1703.58	2456.41
10:00	5.47	954.70	1703.58	2658.28
11:00	5.47	1171.07	1703.58	2874.65
12:00	5.47	1387.44	1703.58	3091.02
13:00	5.47	1589.32	1703.58	3292.89
14:00	5.47	1762.19	1703.58	3465.77
15:00	5.47	1896.02	1703.58	3599.60
16:00	5.47	1974.10	1703.58	3677.68
17:00	5.47	2007.56	1703.58	3711.14

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
6.00	Light Work	72.00	60.00	432.00	360.00	792.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
florescent	6.00	40.00	1.25	300.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
Device	1.00	500	500	750
Refrigerator	1.00	250	250	

Variation of load with time

Q occ_s	Q occ_l	Q lig_s	Q eq_s	Q eq_l
300.00	432.00	360.00	750.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_l	RSH	RLH	RTH
0.33	38.00	53.18	579.96	1703.58	1573.18	360.00	1933.18
0.38	49.33	61.57	752.83	1703.58	1592.90	360.00	1952.90
0.42	62.55	61.57	954.70	1703.58	1606.13	360.00	1966.13
0.46	76.73	61.57	1171.07	1703.58	1620.30	360.00	1980.30
0.50	90.91	75.57	1387.44	1703.58	1648.47	360.00	2008.47
0.54	104.13	193.12	1589.32	1703.58	1779.25	360.00	2139.25
0.58	115.46	321.86	1762.19	1703.58	1919.32	360.00	2279.32
0.63	124.23	397.43	1896.02	1703.58	2003.66	360.00	2363.66
0.67	129.35	397.43	1974.10	1703.58	2008.77	360.00	2368.77
0.71	131.54	331.66	2007.56	1703.58	1945.19	360.00	2305.19

Room 0-60

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q	Qt (W)
SW	08:00	Wall "A"	0.13	4.74	6.20	3.75	28.76
		Glass	1.10	3.46		23.60	
		Wall "D"	0.39	0.57		1.40	
	09:00	Wall "A"	0.13	4.74	7.75	4.69	35.94
		Glass	1.10	3.46		29.50	
		Wall "D"	0.39	0.57		1.75	
	10:00	Wall "A"	0.13	4.74	9.56	5.78	44.34
		Glass	1.10	3.46		36.39	
		Wall "D"	0.39	0.57		2.16	
	11:00	Wall "A"	0.13	4.74	11.50	6.96	53.34
		Glass	1.10	3.46		43.78	
		Wall "D"	0.39	0.57		2.60	
	12:00	Wall "A"	0.13	4.74	13.44	8.13	62.33
		Glass	1.10	3.46		51.16	
		Wall "D"	0.39	0.57		3.04	
	13:00	Wall "A"	0.13	4.74	15.25	9.23	70.73
		Glass	1.10	3.46		58.05	
		Wall "D"	0.39	0.57		3.45	
	14:00	Wall "A"	0.13	4.74	16.80	10.16	77.92
		Glass	1.10	3.46		63.95	
		Wall "D"	0.39	0.57		3.80	
	15:00	Wall "A"	0.13	4.74	18.00	10.89	83.48
		Glass	1.10	3.46		68.52	
		Wall "D"	0.39	0.57		4.07	
	16:00	Wall "A"	0.13	4.74	18.70	11.31	86.73
		Glass	1.10	3.46		71.19	
		Wall "D"	0.39	0.57		4.23	
	17:00	Wall "A"	0.13	4.74	19.00	11.49	88.12
		Glass	1.10	3.46		72.33	
		Wall "D"	0.39	0.57		4.30	

2-Sun Load

Direction	Time	Type	U	A (m2)	I	ΔT_s	Q	Q t(W)
SW	08:00	Wall "A"	0.13	4.74	38.00	2.47	1.49	46.77
		Glass	1.10	3.46			44.71	
		Wall "D"	0.39	0.57		1.52	0.56	
	09:00	Wall "A"	0.13	4.74	44.00	2.86	1.73	54.15
		Glass	1.10	3.46			51.77	
		Wall "D"	0.39	0.57		1.76	0.65	
	10:00	Wall "A"	0.13	4.74	44.00	2.86	1.73	54.15

Load calculations

		Glass	1.10	3.46			51.77	
		Wall "D"	0.39	0.57		1.76	0.65	
	11:00	Wall "A"	0.13	4.74	44.00	2.86	1.73	54.15
		Glass	1.10	3.46			51.77	
		Wall "D"	0.39	0.57		1.76	0.65	
	12:00	Wall "A"	0.13	4.74	54.00	3.51	2.12	66.46
		Glass	1.10	3.46			63.54	
		Wall "D"	0.39	0.57		2.16	0.79	
	13:00	Wall "A"	0.13	4.74	138.00	8.97	5.43	169.83
		Glass	1.10	3.46			162.38	
		Wall "D"	0.39	0.57		5.52	2.03	
	14:00	Wall "A"	0.13	4.74	230.00	14.95	9.04	283.05
		Glass	1.10	3.46			270.63	
		Wall "D"	0.39	0.57		9.20	3.38	
	15:00	Wall "A"	0.13	4.74	284.00	18.46	11.17	349.51
		Glass	1.10	3.46			334.17	
		Wall "D"	0.39	0.57		11.36	4.18	
	16:00	Wall "A"	0.13	4.74	284.00	18.46	11.17	349.51
		Glass	1.10	3.46			334.17	
		Wall "D"	0.39	0.57		11.36	4.18	
	17:00	Wall "A"	0.13	4.74	237.00	15.41	9.32	291.67
		Glass	1.10	3.46			278.86	
		Wall "D"	0.39	0.57		9.48	3.48	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
6.00	14.00	6.70	7.00

A (m2)	11.43
H (m)	2.60
V (m3)	29.72

Method	CMM
Based on No Of Persons	5.04
Based on Area	4.59
NO Of Air Changing Times	3.47

Chapter Two

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
08:00	5.04	637.46	1570.46	2207.92
09:00	5.04	796.82	1570.46	2367.29
10:00	5.04	982.92	1570.46	2553.38
11:00	5.04	1182.38	1570.46	2752.85
12:00	5.04	1381.85	1570.46	2952.31
13:00	5.04	1567.94	1570.46	3138.41
14:00	5.04	1727.31	1570.46	3297.77
15:00	5.04	1850.69	1570.46	3421.15
16:00	5.04	1922.66	1570.46	3493.12
17:00	5.04	1953.50	1570.46	3523.97

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
6.00	Light Work	72.00	60.00	432.00	360.00	792.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
florescent	6.00	40.00	1.25	300.00

Variation of load with time

Q occ_s	Q occ_l	Q lig_s	Q eq_s	Q eq_l
300.00	432.00	360.00	0.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_l	RSH	RLH	RTH
08:00	28.76	46.77	637.46	1570.46	807.52	360.00	1167.52
09:00	35.94	54.15	796.82	1570.46	822.09	360.00	1182.09
10:00	44.34	54.15	982.92	1570.46	830.49	360.00	1190.49
11:00	53.34	54.15	1182.38	1570.46	839.49	360.00	1199.49
12:00	62.33	66.46	1381.85	1570.46	860.79	360.00	1220.79
13:00	70.73	169.83	1567.94	1570.46	972.56	360.00	1332.56
14:00	77.92	283.05	1727.31	1570.46	1092.97	360.00	1452.97
15:00	83.48	349.51	1850.69	1570.46	1164.99	360.00	1524.99
16:00	86.73	349.51	1922.66	1570.46	1168.24	360.00	1528.24
17:00	88.12	291.67	1953.50	1570.46	1111.79	360.00	1471.79

Room 0-61

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q	Q t(W)
SW	08:00	Wall "A"	0.13	4.05	5.20	2.68	37.84
		Glass	1.10	3.44		19.69	
		Wall "B"	1.44	1.00		7.52	
		Wall "C"	1.79	0.85		7.95	
	09:00	Wall "A"	0.13	4.05	6.75	3.48	49.12
		Glass	1.10	3.44		25.56	
		Wall "B"	1.44	1.00		9.76	
		Wall "C"	1.79	0.85		10.32	
	10:00	Wall "A"	0.13	4.05	8.56	4.42	62.29
		Glass	1.10	3.44		32.42	
		Wall "B"	1.44	1.00		12.37	
		Wall "C"	1.79	0.85		13.08	
	11:00	Wall "A"	0.13	4.05	10.50	5.42	76.41
		Glass	1.10	3.44		39.76	
		Wall "B"	1.44	1.00		15.18	
		Wall "C"	1.79	0.85		16.05	
	12:00	Wall "A"	0.13	4.05	12.44	6.42	90.53
		Glass	1.10	3.44		47.11	
		Wall "B"	1.44	1.00		17.98	
		Wall "C"	1.79	0.85		19.01	
	13:00	Wall "A"	0.13	4.05	14.25	7.36	103.70
		Glass	1.10	3.44		53.97	
		Wall "B"	1.44	1.00		20.60	
		Wall "C"	1.79	0.85		21.78	
	14:00	Wall "A"	0.13	4.05	15.80	8.16	114.98
		Glass	1.10	3.44		59.84	
		Wall "B"	1.44	1.00		22.84	
		Wall "C"	1.79	0.85		24.15	
	15:00	Wall "A"	0.13	4.05	17.00	8.78	123.71
		Glass	1.10	3.44		64.38	
		Wall "B"	1.44	1.00		24.57	
		Wall "C"	1.79	0.85		25.99	
	16:00	Wall "A"	0.13	4.05	17.70	9.14	128.81
		Glass	1.10	3.44		67.03	
		Wall "B"	1.44	1.00		25.59	
		Wall "C"	1.79	0.85		27.06	
	17:00	Wall "A"	0.13	4.05	18.00	9.29	130.99
		Glass	1.10	3.44		68.17	
		Wall "B"	1.44	1.00		26.02	
		Wall "C"	1.79	0.85		27.51	

Chapter Two

2-Sun Load

Direction	Time	Type	U	A (m2)	I	ΔT s	Q	Q t(W)
SW	08:00	Wall "A"	0.13	4.05	38.00	2.47	1.28	51.65
		Glass	1.10	3.44			44.48	
		Wall "B"	1.44	1.00		2.47	3.57	
		Wall "C"	1.79	0.85		1.52	2.32	
	09:00	Wall "A"	0.13	4.05	44.00	2.86	1.48	59.81
		Glass	1.10	3.44			51.50	
		Wall "B"	1.44	1.00		2.86	4.13	
		Wall "C"	1.79	0.85		1.76	2.69	
	10:00	Wall "A"	0.13	4.05	44.00	2.86	1.48	59.81
		Glass	1.10	3.44			51.50	
		Wall "B"	1.44	1.00		2.86	4.13	
		Wall "C"	1.79	0.85		1.76	2.69	
	11:00	Wall "A"	0.13	4.05	44.00	2.86	1.48	59.81
		Glass	1.10	3.44			51.50	
		Wall "B"	1.44	1.00		2.86	4.13	
		Wall "C"	1.79	0.85		1.76	2.69	
	12:00	Wall "A"	0.13	4.05	54.00	3.51	1.81	73.40
		Glass	1.10	3.44			63.21	
		Wall "B"	1.44	1.00		3.51	5.07	
		Wall "C"	1.79	0.85		2.16	3.30	
	13:00	Wall "A"	0.13	4.05	138.00	8.97	4.63	187.57
		Glass	1.10	3.44			161.54	
		Wall "B"	1.44	1.00		8.97	12.97	
		Wall "C"	1.79	0.85		5.52	8.44	
	14:00	Wall "A"	0.13	4.05	230.00	14.95	7.72	312.62
		Glass	1.10	3.44			269.23	
		Wall "B"	1.44	1.00		14.95	21.61	
		Wall "C"	1.79	0.85		9.20	14.06	
	15:00	Wall "A"	0.13	4.05	284.00	18.46	9.53	386.01
		Glass	1.10	3.44			332.44	
		Wall "B"	1.44	1.00		18.46	26.68	
		Wall "C"	1.79	0.85		11.36	17.36	
	16:00	Wall "A"	0.13	4.05	284.00	18.46	9.53	386.01
		Glass	1.10	3.44			332.44	
		Wall "B"	1.44	1.00		18.46	26.68	
		Wall "C"	1.79	0.85		11.36	17.36	
	17:00	Wall "A"	0.13	4.05	237.00	15.41	7.95	322.14
		Glass	1.10	3.44			277.42	
		Wall "B"	1.44	1.00		15.41	22.27	
		Wall "C"	1.79	0.85		9.48	14.49	

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
6.00	14.00	6.70	7.00

A (m2)	12.74
H (m)	2.60
V (m3)	33.12

Method	CMM
Based on No Of Persons	5.04
Based on Area	5.12
NO Of Air Changing Times	3.86

Time	CMMmax	Qs(W)	QL(W)	Qtot (W)
08:00	5.12	543.29	1595.85	2139.14
09:00	5.12	705.23	1595.85	2301.08
10:00	5.12	894.33	1595.85	2490.19
11:00	5.12	1097.02	1595.85	2692.87
12:00	5.12	1299.71	1595.85	2895.56
13:00	5.12	1488.81	1595.85	3084.67
14:00	5.12	1650.76	1595.85	3246.61
15:00	5.12	1776.13	1595.85	3371.98
16:00	5.12	1849.26	1595.85	3445.12
17:00	5.12	1880.61	1595.85	3476.46

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
6	Light	72.00	60.00	432.00	360.00	792.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
economical	8.00	26.00	1.00	208.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)
Refrigerator	1.00	250.00	250.00

Chapter Two

Variation of load with time

Q occ_s	Q occ_I	Q lig_s	Q eq_s	Q eq_I
208.00	432.00	360.00	250.00	0.00

Time	Qs	Qs	Qs	QI	RSH	RLHH	RTH
08:00	37.84	51.65	543.29	1595.85	979.49	360.00	1339.49
09:00	49.12	59.81	705.23	1595.85	998.93	360.00	1358.93
10:00	62.29	59.81	894.33	1595.85	1012.10	360.00	1372.10
11:00	76.41	59.81	1097.02	1595.85	1026.22	360.00	1386.22
12:00	90.53	73.40	1299.71	1595.85	1053.93	360.00	1413.93
13:00	103.70	187.57	1488.81	1595.85	1181.27	360.00	1541.27
14:00	114.98	312.62	1650.76	1595.85	1317.60	360.00	1677.60
15:00	123.71	386.01	1776.13	1595.85	1399.73	360.00	1759.73
16:00	128.81	386.01	1849.26	1595.85	1404.82	360.00	1764.82
17:00	130.99	322.14	1880.61	1595.85	1343.13	360.00	1703.13

Room 0-62

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q	Q t(W)
SW	08:00	Wall "A"	0.13	4.93	5.20	3.27	25.17
		Glass	1.10	3.62		20.72	
		Wall "D"	0.39	0.57		1.18	
	09:00	Wall "A"	0.13	4.93	6.75	4.25	32.67
		Glass	1.10	3.62		26.89	
		Wall "D"	0.39	0.57		1.53	
	10:00	Wall "A"	0.13	4.93	8.56	5.39	41.43
		Glass	1.10	3.62		34.11	
		Wall "D"	0.39	0.57		1.94	
	11:00	Wall "A"	0.13	4.93	10.50	6.61	50.82
		Glass	1.10	3.62		41.83	
		Wall "D"	0.39	0.57		2.37	
	12:00	Wall "A"	0.13	4.93	12.44	7.83	60.20
		Glass	1.10	3.62		49.56	
		Wall "D"	0.39	0.57		2.81	
	13:00	Wall "A"	0.13	4.93	14.25	8.97	68.96
		Glass	1.10	3.62		56.78	
		Wall "D"	0.39	0.57		3.22	
	14:00	Wall "A"	0.13	4.93	15.80	9.94	76.47
		Glass	1.10	3.62		62.95	
		Wall "D"	0.39	0.57		3.57	
	15:00	Wall "A"	0.13	4.93	17.00	10.70	82.27
		Glass	1.10	3.62		67.73	
		Wall "D"	0.39	0.57		3.84	
	16:00	Wall "A"	0.13	4.93	17.70	11.14	85.66
		Glass	1.10	3.62		70.52	
		Wall "D"	0.39	0.57		4.00	
	17:00	Wall "A"	0.13	4.93	18.00	11.32	87.11
		Glass	1.10	3.62		71.72	
		Wall "D"	0.39	0.57		4.07	

Direction	Time	Type	U	A	ΔT	Q	Q t(W)
SE	08:00	Wall "A"	0.13	10.21	5.20	6.77	27.35
		Glass	1.10	3.60		20.57	
	09:00	Wall "A"	0.13	10.21	6.75	8.79	35.50
		Glass	1.10	3.60		26.71	
	10:00	Wall "A"	0.13	10.21	8.56	11.15	45.01
		Glass	1.10	3.60		33.87	
	11:00	Wall "A"	0.13	10.21	10.50	13.67	55.22
		Glass	1.10	3.60		41.54	
	12:00	Wall "A"	0.13	10.21	12.44	16.20	65.42
		Glass	1.10	3.60		49.22	

Chapter Two

	13:00	Wall "A"	0.13	10.21	14.25	18.55	74.94
		Glass	1.10	3.60		56.38	
	14:00	Wall "A"	0.13	10.21	15.80	20.57	83.09
		Glass	1.10	3.60		62.51	
	15:00	Wall "A"	0.13	10.21	17.00	22.14	89.40
		Glass	1.10	3.60		67.26	
	16:00	Wall "A"	0.13	10.21	17.70	23.05	93.08
		Glass	1.10	3.60		70.03	
	17:00	Wall "A"	0.13	10.21	18.00	23.44	94.66
		Glass	1.10	3.60		71.22	

Time	Qt(W)
0.33	52.51
0.38	68.16
0.42	86.44
0.46	106.03
0.50	125.62
0.54	143.90
0.58	159.55
0.63	171.67
0.67	178.74
0.71	181.77

2-Sun Load

Direction	Time	Type	U	A (m2)	I	ΔTs	Q	Q t(W)
SW	08:00	Wall "A"	0.13	4.93	38.00	2.47	1.55	48.91
		Glass	1.10	3.62			46.80	
		Wall "D"	0.39	0.57		1.52	0.56	
	09:00	Wall "A"	0.13	4.93	44.00	2.86	1.80	56.63
		Glass	1.10	3.62			54.19	
		Wall "D"	0.39	0.57		1.76	0.65	
	10:00	Wall "A"	0.13	4.93	44.00	2.86	1.80	56.63
		Glass	1.10	3.62			54.19	
		Wall "D"	0.39	0.57		1.76	0.65	
	11:00	Wall "A"	0.13	4.93	44.00	2.86	1.80	56.63
		Glass	1.10	3.62			54.19	
		Wall "D"	0.39	0.57		1.76	0.65	
	12:00	Wall "A"	0.13	4.93	54.00	3.51	2.21	69.50
		Glass	1.10	3.62			66.50	
		Wall "D"	0.39	0.57		2.16	0.79	
	13:00	Wall "A"	0.13	4.93	138.00	8.97	5.64	177.62
		Glass	1.10	3.62			169.95	
		Wall "D"	0.39	0.57		5.52	2.03	
	14:00	Wall "A"	0.13	4.93	230.00	14.95	9.41	296.03
		Glass	1.10	3.62			283.24	
		Wall "D"	0.39	0.57		9.20	3.38	
	15:00	Wall "A"	0.13	4.93	284.00	18.46	11.61	365.53

Load calculations

		Glass	1.10	3.62			349.74	
		Wall "D"	0.39	0.57		11.36	4.18	
	16:00	Wall "A"	0.13	4.93	284.00	18.46	11.61	365.53
		Glass	1.10	3.62			349.74	
	17:00	Wall "D"	0.39	0.57	237.00	11.36	4.18	305.04
		Wall "A"	0.13	4.93		15.41	9.69	
		Glass	1.10	3.62			291.86	
		Wall "D"	0.39	0.57		9.48	3.48	

Direction	Time	Type	U (w/m2.k)	A (m2)	I (W/m2)	ΔTs (K)	Q (W)	Q t(W)
SE	08:00	Wall "A"	0.13	10.21	284.00	18.46	24.04	371.36
		Glass	1.10	3.60			347.32	
	09:00	Wall "A"	0.13	10.21	284.00	18.46	24.04	371.36
		Glass	1.10	3.60			347.32	
	10:00	Wall "A"	0.13	10.21	230.00	14.95	19.47	300.75
		Glass	1.10	3.60			281.28	
	11:00	Wall "A"	0.13	10.21	139.00	9.04	11.76	181.76
		Glass	1.10	3.60			169.99	
	12:00	Wall "A"	0.13	10.21	54.00	3.51	4.57	70.61
		Glass	1.10	3.60			66.04	
	13:00	Wall "A"	0.13	10.21	44.00	2.86	3.72	57.53
		Glass	1.10	3.60			53.81	
	14:00	Wall "A"	0.13	10.21	44.00	2.86	3.72	57.53
		Glass	1.10	3.60			53.81	
	15:00	Wall "A"	0.13	10.21	44.00	2.86	3.72	57.53
		Glass	1.10	3.60			53.81	
	16:00	Wall "A"	0.13	10.21	38.00	2.47	3.22	49.69
		Glass	1.10	3.60			46.47	
	17:00	Wall "A"	0.13	10.21	32.00	2.08	2.71	41.84
		Glass	1.10	3.60			39.13	

Time	Qt(W)
0.33	420.27
0.38	427.99
0.42	357.38
0.46	238.39
0.50	140.11
0.54	235.15
0.58	353.57
0.63	423.07
0.67	415.22
0.71	346.88

Chapter Two

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5.00	14.00	2.80	3.00

A (m2)	17.96
H (m)	2.60
V (m3)	46.70

Method	CMM
Based on No Of Persons	4.20
Based on Area	3.02
NO. Of Air Changing Times	2.33

Time	CMMmax	Qs(W)	QL(W)	Qtot (W)
08:00	4.20	445.54	1308.72	1754.26
09:00	4.20	578.34	1308.72	1887.06
10:00	4.20	733.42	1308.72	2042.14
11:00	4.20	899.64	1308.72	2208.36
12:00	4.20	1065.86	1308.72	2374.58
13:00	4.20	1220.94	1308.72	2529.66
14:00	4.20	1353.74	1308.72	2662.46
15:00	4.20	1456.56	1308.72	2765.28
16:00	4.20	1516.54	1308.72	2825.26
17:00	4.20	1542.24	1308.72	2850.96

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
5.00	Light	72.00	60.00	360.00	300.00	660.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
florescent	16.00	40.00	1.25	800.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
computer	1.00	110.00	110.00	110.00

Variation of load with time

Q occ_s	Q occ_I	Q light_s	Q eq_s	Q eq_I
800.00	360.00	300.00	110.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_I	RSH	RLH	RTH
8:00	52.51	420.27	445.54	1308.72	1742.78	300.00	2042.78
9:00	68.16	427.99	578.34	1308.72	1766.15	300.00	2066.15
10:00	86.44	357.38	733.42	1308.72	1713.82	300.00	2013.82
11:00	106.03	238.39	899.64	1308.72	1614.42	300.00	1914.42
12:00	125.62	140.11	1065.86	1308.72	1535.74	300.00	1835.74
13:00	143.90	235.15	1220.94	1308.72	1649.05	300.00	1949.05
14:00	159.55	353.57	1353.74	1308.72	1783.12	300.00	2083.12
15:00	171.67	423.07	1456.56	1308.72	1864.74	300.00	2164.74
16:00	178.74	415.22	1516.54	1308.72	1863.96	300.00	2163.96
17:00	181.77	346.88	1542.24	1308.72	1798.65	300.00	2098.65

Chapter Two

Room 0-63

A-External Loads

1-Wall Load

Direction	Time	Type	U	A (m2)	ΔT (K)	Q (W)	Qt (W)
NE	08:00	Wall "A"	0.13	8.93	5.20	5.92	71.08
		Wall "B"	1.44	0.72		5.41	
		Wall "C"	1.79	0.84		7.79	
		Wall "D"	0.39	1.95		4.00	
		Glass	1.10	8.38		47.96	
	09:00	Wall "A"	0.13	8.93	6.75	7.69	92.27
		Wall "B"	1.44	0.72		7.02	
		Wall "C"	1.79	0.84		10.11	
		Wall "D"	0.39	1.95		5.20	
		Glass	1.10	8.38		62.25	
	10:00	Wall "A"	0.13	8.93	8.56	9.75	117.01
		Wall "B"	1.44	0.72		8.91	
		Wall "C"	1.79	0.84		12.82	
		Wall "D"	0.39	1.95		6.59	
		Glass	1.10	8.38		78.94	
	11:00	Wall "A"	0.13	8.93	10.50	11.96	143.52
		Wall "B"	1.44	0.72		10.92	
		Wall "C"	1.79	0.84		15.72	
		Wall "D"	0.39	1.95		8.09	
		Glass	1.10	8.38		96.83	
	12:00	Wall "A"	0.13	8.93	12.44	14.17	170.04
		Wall "B"	1.44	0.72		12.94	
		Wall "C"	1.79	0.84		18.63	
		Wall "D"	0.39	1.95		9.58	
		Glass	1.10	8.38		114.73	
	13:00	Wall "A"	0.13	8.93	14.25	16.23	194.78
		Wall "B"	1.44	0.72		14.82	
		Wall "C"	1.79	0.84		21.34	
		Wall "D"	0.39	1.95		10.97	
		Glass	1.10	8.38		131.42	
	14:00	Wall "A"	0.13	8.93	15.80	17.99	215.97
		Wall "B"	1.44	0.72		16.44	
		Wall "C"	1.79	0.84		23.66	
		Wall "D"	0.39	1.95		12.17	
		Glass	1.10	8.38		145.71	
	15:00	Wall "A"	0.13	8.93	17.00	19.36	232.37
		Wall "B"	1.44	0.72		17.69	
		Wall "C"	1.79	0.84		25.46	
		Wall "D"	0.39	1.95		13.09	
		Glass	1.10	8.38		156.78	
	16:00	Wall "A"	0.13	8.93	17.70	20.16	241.94
		Wall "B"	1.44	0.72		18.41	

Load calculations

		Wall "C"	1.79	0.84		26.50	
		Wall "D"	0.39	1.95		13.63	
		Glass	1.10	8.38		163.24	
	17:00	Wall "A"	0.13	8.93	18.00	20.50	246.04
		Wall "B"	1.44	0.72		18.73	
		Wall "C"	1.79	0.84		26.95	
		Wall "D"	0.39	1.95		13.86	
		Glass	1.10	8.38		166.00	

Direction	Time	Type	U	A	ΔT	Q (W)	Q t(W)
SE	08:00	Wall "A"	0.13	6.40	5.20	4.24	13.58
		Wall "B"	1.44	1.25		9.34	
	09:00	Wall "A"	0.13	6.40	6.75	5.51	17.63
		Wall "B"	1.44	1.25		12.12	
	10:00	Wall "A"	0.13	6.40	8.56	6.98	22.35
		Wall "B"	1.44	1.25		15.37	
	11:00	Wall "A"	0.13	6.40	10.50	8.57	27.42
		Wall "B"	1.44	1.25		18.86	
	12:00	Wall "A"	0.13	6.40	12.44	10.15	32.49
		Wall "B"	1.44	1.25		22.34	
	13:00	Wall "A"	0.13	6.40	14.25	11.62	37.21
		Wall "B"	1.44	1.25		25.59	
	14:00	Wall "A"	0.13	6.40	15.80	12.89	41.26
		Wall "B"	1.44	1.25		28.37	
	15:00	Wall "A"	0.13	6.40	17.00	13.87	44.40
		Wall "B"	1.44	1.25		30.53	
	16:00	Wall "A"	0.13	6.40	17.70	14.44	46.22
		Wall "B"	1.44	1.25		31.78	
	17:00	Wall "A"	0.13	6.40	18.00	14.68	47.01
		Wall "B"	1.44	1.25		32.32	

Time	Qt(W)
8:00	84.66
9:00	109.89
10:00	139.36
11:00	170.94
12:00	202.53
13:00	232.00
14:00	257.23
15:00	276.77
16:00	288.16
17:00	293.05

Chapter Two

2-Sun Load

Direction	Time	Type	U	A	I	ΔT_s	Q	Qt (W)
NE	08:00	Wall "A"	0.13	8.93	410.00	26.65	30.35	1263.98
		Wall "B"	1.44	0.72		26.65	27.72	
		Wall "C"	1.79	0.84		16.40	24.56	
		Wall "D"	0.39	1.95		16.40	12.63	
		Glass	1.10	8.38			1168.72	
	09:00	Wall "A"	0.13	8.93	305.00	19.83	22.58	940.28
		Wall "B"	1.44	0.72		19.83	20.62	
		Wall "C"	1.79	0.84		12.20	18.27	
		Wall "D"	0.39	1.95		12.20	9.39	
		Glass	1.10	8.38			869.42	
	10:00	Wall "A"	0.13	8.93	173.00	11.25	12.81	533.34
		Wall "B"	1.44	0.72		11.25	11.70	
		Wall "C"	1.79	0.84		6.92	10.36	
		Wall "D"	0.39	1.95		6.92	5.33	
		Glass	1.10	8.38			493.14	
	11:00	Wall "A"	0.13	8.93	60.00	3.90	4.44	184.97
		Wall "B"	1.44	0.72		3.90	4.06	
		Wall "C"	1.79	0.84		2.40	3.59	
		Wall "D"	0.39	1.95		2.40	1.85	
		Glass	1.10	8.38			171.03	
	12:00	Wall "A"	0.13	8.93	44.00	2.86	3.26	135.65
		Wall "B"	1.44	0.72		2.86	2.98	
		Wall "C"	1.79	0.84		1.76	2.64	
		Wall "D"	0.39	1.95		1.76	1.36	
		Glass	1.10	8.38			125.42	
	13:00	Wall "A"	0.13	8.93	44.00	2.86	3.26	135.65
		Wall "B"	1.44	0.72		2.86	2.98	
		Wall "C"	1.79	0.84		1.76	2.64	
		Wall "D"	0.39	1.95		1.76	1.36	
		Glass	1.10	8.38			125.42	
	14:00	Wall "A"	0.13	8.93	44.00	2.86	3.26	135.65
		Wall "B"	1.44	0.72		2.86	2.98	
		Wall "C"	1.79	0.84		1.76	2.64	
		Wall "D"	0.39	1.95		1.76	1.36	
		Glass	1.10	8.38			125.42	
	15:00	Wall "A"	0.13	8.93	44.00	2.86	3.26	135.65
		Wall "B"	1.44	0.72		2.86	2.98	
		Wall "C"	1.79	0.84		1.76	2.64	
		Wall "D"	0.39	1.95		1.76	1.36	
		Glass	1.10	8.38			125.42	
	16:00	Wall "A"	0.13	8.93	38.00	2.47	2.81	117.15
		Wall "B"	1.44	0.72		2.47	2.57	
		Wall "C"	1.79	0.84		1.52	2.28	
		Wall "D"	0.39	1.95		1.52	1.17	
		Glass	1.10	8.38			108.32	

Load calculations

	17:00	Wall "A"	0.13	8.93	32.00	2.08	2.37	98.65
		Wall "B"	1.44	0.72		2.08	2.16	
		Wall "C"	1.79	0.84		1.28	1.92	
		Wall "D"	0.39	1.95		1.28	0.99	
		Glass	1.10	8.38			91.22	

Direction	Time	Type	U	A	I	ΔTs	Q	Q t(W)
SE	08:00	Wall "A"	0.13	6.40	284.00	18.46	15.06	48.21
		Wall "B"	1.44	1.25			33.15	
	09:00	Wall "A"	0.13	6.40	284.00	18.46	15.06	48.21
		Wall "B"	1.44	1.25			33.15	
	10:00	Wall "A"	0.13	6.40	230.00	14.95	12.20	39.04
		Wall "B"	1.44	1.25			26.85	
	11:00	Wall "A"	0.13	6.40	139.00	9.04	7.37	23.59
		Wall "B"	1.44	1.25			16.22	
	12:00	Wall "A"	0.13	6.40	54.00	3.51	2.86	9.17
		Wall "B"	1.44	1.25			6.30	
	13:00	Wall "A"	0.13	6.40	44.00	2.86	2.33	7.47
		Wall "B"	1.44	1.25			5.14	
	14:00	Wall "A"	0.13	6.40	44.00	2.86	2.33	7.47
		Wall "B"	1.44	1.25			5.14	
	15:00	Wall "A"	0.13	6.40	44.00	2.86	2.33	7.47
		Wall "B"	1.44	1.25			5.14	
	16:00	Wall "A"	0.13	6.40	38.00	2.47	2.01	6.45
		Wall "B"	1.44	1.25			4.44	
	17:00	Wall "A"	0.13	6.40	32.00	2.08	1.70	5.43
		Wall "B"	1.44	1.25			3.74	

Time	Qt(W)
08:00	1312.19
09:00	988.49
10:00	572.38
11:00	208.57
12:00	144.81
13:00	143.12
14:00	143.12
15:00	143.12
16:00	123.60
17:00	104.08

Chapter Two

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
10.00	14.00	2.80	3.00

A (m2)	28.33
H (m)	2.60
V (m3)	73.66

Method	CMM
Based on No Of Persons	8.40
Based on Area	4.76
NO Of Air Changing Times	3.68

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
08:00	8.40	891.07	2617.44	3508.51
09:00	8.40	1156.68	2617.44	3774.12
10:00	8.40	1466.84	2617.44	4084.28
11:00	8.40	1799.28	2617.44	4416.72
12:00	8.40	2131.72	2617.44	4749.16
13:00	8.40	2441.88	2617.44	5059.32
14:00	8.40	2707.49	2617.44	5324.93
15:00	8.40	2913.12	2617.44	5530.56
16:00	8.40	3033.07	2617.44	5650.51
17:00	8.40	3084.48	2617.44	5701.92

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
10.00	light working	72.00	60.00	720.00	600.00	1320.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
florescent	16.00	40.00	1.25	800.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
computer	2.00	110.00	220.00	910.00
refrigerator	1.00	690.00	690.00	

Variation of load with time

Q occ_s	Q occ_I	Q light_s	Q eq_s	Q eq_I
800.00	720.00	600.00	910.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_I	RSH	RLH	RTH
8:00	84.66	1312.19	891.07	2617.44	3826.85	600.00	4426.85
9:00	109.89	988.49	1156.68	2617.44	3528.38	600.00	4128.38
10:00	139.36	572.38	1466.84	2617.44	3141.74	600.00	3741.74
11:00	170.94	208.57	1799.28	2617.44	2809.51	600.00	3409.51
12:00	202.53	144.81	2131.72	2617.44	2777.34	600.00	3377.34
13:00	232.00	143.12	2441.88	2617.44	2805.11	600.00	3405.11
14:00	257.23	143.12	2707.49	2617.44	2830.35	600.00	3430.35
15:00	276.77	143.12	2913.12	2617.44	2849.88	600.00	3449.88
16:00	288.16	123.60	3033.07	2617.44	2841.76	600.00	3441.76
17:00	293.05	104.08	3084.48	2617.44	2827.13	600.00	3427.13

Chapter Two

Room 0-66

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q (W)
NE	08:00	Wall "A"	0.13	6.50	5.20	4.31
	09:00	Wall "A"	0.13	6.50	6.75	5.60
	10:00	Wall "A"	0.13	6.50	8.56	7.10
	11:00	Wall "A"	0.13	6.50	10.50	8.70
	12:00	Wall "A"	0.13	6.50	12.44	10.31
	13:00	Wall "A"	0.13	6.50	14.25	11.81
	14:00	Wall "A"	0.13	6.50	15.80	13.10
	15:00	Wall "A"	0.13	6.50	17.00	14.09
	16:00	Wall "A"	0.13	6.50	17.70	14.67
	17:00	Wall "A"	0.13	6.50	18.00	14.92

2-Sun Load

Direction	Time	Type	U	A	I	ΔT_s	Q (W)
NE	8:00	Wall "A"	0.13	6.50	410.00	26.65	22.09
	9:00	Wall "A"	0.13	6.50	305.00	19.83	16.44
	10:00	Wall "A"	0.13	6.50	173.00	11.25	9.32
	11:00	Wall "A"	0.13	6.50	60.00	2.86	2.37
	12:00	Wall "A"	0.13	6.50	44.00	2.86	2.37
	13:00	Wall "A"	0.13	6.50	44.00	2.86	2.37
	14:00	Wall "A"	0.13	6.50	44.00	2.86	2.37
	15:00	Wall "A"	0.13	6.50	44.00	2.86	2.37
	16:00	Wall "A"	0.13	6.50	38.00	2.47	2.05
	17:00	Wall "A"	0.13	6.50	32.00	2.08	1.72

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
1.00	10.00	2.50	2.00

A (m2)	7.60
H (m)	2.60
V (m3)	19.76

Method	CMM
Based on No Of Persons	0.60
Based on Area	1.14
NO Of Air Changing Times	0.66

Time	CMMmax	Qs(W)	QL(W)	Qtot
08:00	1.14	120.93	355.22	476.16
09:00	1.14	156.98	355.22	512.20
10:00	1.14	199.07	355.22	554.30
11:00	1.14	244.19	355.22	599.41
12:00	1.14	289.30	355.22	644.53
13:00	1.14	331.40	355.22	686.62
14:00	1.14	367.44	355.22	722.67
15:00	1.14	395.35	355.22	750.58
16:00	1.14	411.63	355.22	766.86
17:00	1.14	418.61	355.22	773.83

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
1.00	sitting	66.00	31.00	66.00	31.00	97.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
spot	8.00	20.00	1.25	200.00

Variation of load with time

Q occ_s	Q occ_l	Q light_s	Q eq_s	Q eq_l
200.00	66.00	31.00	0.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_l	Qs tot (W)	Ql tot (W)	Q tot (W)
0.33	4.31	22.09	120.93	355.22	292.40	31.00	323.40
0.38	5.60	16.44	156.98	355.22	288.03	31.00	319.03
0.42	7.10	9.32	199.07	355.22	282.42	31.00	313.42
0.46	8.70	2.37	244.19	355.22	277.08	31.00	308.08
0.50	10.31	2.37	289.30	355.22	278.68	31.00	309.68
0.54	11.81	2.37	331.40	355.22	280.18	31.00	311.18
0.58	13.10	2.37	367.44	355.22	281.47	31.00	312.47
0.63	14.09	2.37	395.35	355.22	282.46	31.00	313.46
0.67	14.67	2.05	411.63	355.22	282.72	31.00	313.72
0.71	14.92	1.72	418.61	355.22	282.65	31.00	313.65

Chapter Two

Room 0-67

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q	Q
NE	8:00	Wall "A"	0.13	4.68	5.20	3.10	16.72
		Wall "B"	1.44	1.82		13.62	
	9:00	Wall "A"	0.13	4.68	6.75	4.03	21.71
		Wall "B"	1.44	1.82		17.68	
	10:00	Wall "A"	0.13	4.68	8.56	5.11	27.53
		Wall "B"	1.44	1.82		22.42	
	11:00	Wall "A"	0.13	4.68	10.50	6.27	33.76
		Wall "B"	1.44	1.82		27.50	
	12:00	Wall "A"	0.13	4.68	12.44	7.43	40.00
		Wall "B"	1.44	1.82		32.58	
	13:00	Wall "A"	0.13	4.68	14.25	8.51	45.82
		Wall "B"	1.44	1.82		37.32	
	14:00	Wall "A"	0.13	4.68	15.80	9.43	50.81
		Wall "B"	1.44	1.82		41.38	
	15:00	Wall "A"	0.13	4.68	17.00	10.15	54.67
		Wall "B"	1.44	1.82		44.52	
	16:00	Wall "A"	0.13	4.68	17.70	10.56	56.92
		Wall "B"	1.44	1.82		46.35	
	17:00	Wall "A"	0.13	4.68	18.00	10.74	57.88
		Wall "B"	1.44	1.82		47.14	

Direction	Time	Type	U	A	ΔT	Q	Q t(W)
NW	8:00	Wall "A"	0.13	7.57	5.20	5.02	8.91
		Wall "B"	1.44	0.52		3.89	
	9:00	Wall "A"	0.13	7.57	6.75	6.51	11.56
		Wall "B"	1.44	0.52		5.05	
	10:00	Wall "A"	0.13	7.57	8.56	8.26	14.66
		Wall "B"	1.44	0.52		6.40	
	11:00	Wall "A"	0.13	7.57	10.50	10.13	17.99
		Wall "B"	1.44	0.52		7.86	
	12:00	Wall "A"	0.13	7.57	12.44	12.00	21.31
		Wall "B"	1.44	0.52		9.31	
	13:00	Wall "A"	0.13	7.57	14.25	13.75	24.41
		Wall "B"	1.44	0.52		10.66	
	14:00	Wall "A"	0.13	7.57	15.80	15.25	27.07
		Wall "B"	1.44	0.52		11.82	
	15:00	Wall "A"	0.13	7.57	17.00	16.40	29.12
		Wall "B"	1.44	0.52		12.72	
	16:00	Wall "A"	0.13	7.57	17.70	17.08	30.32
		Wall "B"	1.44	0.52		13.24	
	17:00	Wall "A"	0.13	7.57	18.00	17.37	30.84
		Wall "B"	1.44	0.52		13.47	

Time	Qt(W)
8:00	25.63
9:00	33.27
10:00	42.19
11:00	51.75
12:00	61.32
13:00	70.24
14:00	77.88
15:00	83.79
16:00	87.24
17:00	88.72

2-Sun Load

Direction	Time	Type	U	A	I	ΔT_s	Q (W)	Q t(W)
NE	8:00	Wall "A"	0.13	5.72	410.00	26.65	19.43	87.23
		Wall "B"	1.44	1.77		26.65	67.80	
	9:00	Wall "A"	0.13	5.72	305.00	19.83	14.46	64.89
		Wall "B"	1.44	1.77		19.83	50.43	
	10:00	Wall "A"	0.13	5.72	173.00	11.25	8.20	36.81
		Wall "B"	1.44	1.77		2.86	28.61	
	11:00	Wall "A"	0.13	5.72	60.00	2.86	2.09	9.36
		Wall "B"	1.44	1.77		2.86	7.28	
	12:00	Wall "A"	0.13	5.72	44.00	2.86	2.09	9.36
		Wall "B"	1.44	1.77		3.51	7.28	
	13:00	Wall "A"	0.13	5.72	44.00	2.86	2.09	9.36
		Wall "B"	1.44	1.77		8.97	7.28	
	14:00	Wall "A"	0.13	5.72	44.00	2.86	2.09	9.36
		Wall "B"	1.44	1.77		14.95	7.28	
	15:00	Wall "A"	0.13	5.72	44.00	2.86	2.09	9.36
		Wall "B"	1.44	1.77		18.46	7.28	
	16:00	Wall "A"	0.13	5.72	38.00	2.47	1.80	8.08
		Wall "B"	1.44	1.77		18.46	6.28	
	17:00	Wall "A"	0.13	5.72	32.00	2.08	1.52	6.81
		Wall "B"	1.44	1.77		15.41	5.29	

Direction	Time	Type	U	A (m2)	I	ΔT_s	Q	Q t(W)
NW	8:00	Wall "A"	0.13	7.57	38.00	2.47	2.38	4.23
		Wall "B"	1.44	0.52		2.47	1.85	
	9:00	Wall "A"	0.13	7.57	44.00	2.86	2.76	4.90
		Wall "B"	1.44	0.52		2.86	2.14	
	10:00	Wall "A"	0.13	7.57	44.00	2.86	2.76	4.90
		Wall "B"	1.44	0.52		2.86	2.14	
	11:00	Wall "A"	0.13	7.57	44.00	2.86	2.76	4.90
		Wall "B"	1.44	0.52		2.86	2.14	
	12:00	Wall "A"	0.13	7.57	44.00	2.86	2.76	5.39
		Wall "B"	1.44	0.52		3.51	2.63	

Chapter Two

	13:00	Wall "A"	0.13	7.57	54.00	3.51	3.39	6.01
		Wall "B"	1.44	0.52		3.51	2.63	
	14:00	Wall "A"	0.13	7.57	173.00	11.25	10.85	19.27
		Wall "B"	1.44	0.52		11.25	8.42	
	15:00	Wall "A"	0.13	7.57	310.00	20.15	19.44	34.52
		Wall "B"	1.44	0.52		20.15	15.08	
	16:00	Wall "A"	0.13	7.57	410.00	26.65	25.72	45.66
		Wall "B"	1.44	0.52		26.65	19.94	
	17:00	Wall "A"	0.13	7.57	438.00	28.47	27.47	48.77
		Wall "B"	1.44	0.52		28.47	21.30	

Time	Qt(W)
8:00	91.46
9:00	69.79
10:00	41.71
11:00	14.26
12:00	14.75
13:00	15.37
14:00	28.63
15:00	43.88
16:00	53.74
17:00	55.58

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
0.00	10.00	2.50	2.00

A (m2)	6.70
H (m)	2.60
V (m3)	17.42

Method	CMM
Based on No Of Persons	0.00
Based on Area	1.01
NO Of Air Changing Times	0.58

Time	CMMmax	Qs(W)	QL(W)	Qtot
8:00	1.01	106.61	313.16	419.77
9:00	1.01	138.39	313.16	451.55
10:00	1.01	175.50	313.16	488.66
11:00	1.01	215.27	313.16	528.43
12:00	1.01	255.04	313.16	568.20
13:00	1.01	292.15	313.16	605.31
14:00	1.01	323.93	313.16	637.09
15:00	1.01	348.53	313.16	661.69

16:00	1.01	362.89	313.16	676.04
17:00	1.01	369.04	313.16	682.19

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p	qL/p	Qs	QL	Qtot (W)
2.00	sitting	66.00	31.00	132.00	62.00	194.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
fluorescent	4.00	40.00	1.25	200.00

Variation of load with time

Q occ_s	Q occ_l	Q light_s	Q eq_s	Q eq_l
200.00	132.00	62.00	0.00	0.00

Time	Qwal_s	Qsun_s	Q vent_s	Q vent_l	RSH	RLH	RTH
8:00	25.63	91.46	106.61	313.16	449.09	62.00	511.09
9:00	33.27	69.79	138.39	313.16	435.06	62.00	497.06
10:00	42.19	41.71	175.50	313.16	415.90	62.00	477.90
11:00	51.75	14.26	215.27	313.16	398.01	62.00	460.01
12:00	61.32	14.75	255.04	313.16	408.06	62.00	470.06
13:00	70.24	15.37	292.15	313.16	417.61	62.00	479.61
14:00	77.88	28.63	323.93	313.16	438.51	62.00	500.51
15:00	83.79	43.88	348.53	313.16	459.67	62.00	521.67
16:00	87.24	53.74	362.89	313.16	472.98	62.00	534.98
17:00	88.72	55.58	369.04	313.16	476.30	62.00	538.30

Chapter Two

Room 0-46

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q (W)	Qtot
NE	8:00	Glass	1.10	3.44	5.20	19.65	23.95
		Wall "A"	0.13	4.71		3.13	
		Wall "D"	0.39	0.57		1.18	
	9:00	Glass	1.10	3.44	6.75	25.51	31.09
		Wall "A"	0.13	4.71		4.06	
		Wall "D"	0.39	0.57		1.53	
	10:00	Glass	1.10	3.44	8.56	32.35	39.43
		Wall "A"	0.13	4.71		5.15	
		Wall "D"	0.39	0.57		1.94	
	11:00	Glass	1.10	3.44	10.50	39.68	48.37
		Wall "A"	0.13	4.71		6.31	
		Wall "D"	0.39	0.57		2.37	
	12:00	Glass	1.10	3.44	12.44	47.01	57.31
		Wall "A"	0.13	4.71		7.48	
		Wall "D"	0.39	0.57		2.81	
	13:00	Glass	1.10	3.44	14.25	53.85	65.64
		Wall "A"	0.13	4.71		8.57	
		Wall "D"	0.39	0.57		3.22	
	14:00	Glass	1.10	3.44	15.80	59.71	72.78
		Wall "A"	0.13	4.71		9.50	
		Wall "D"	0.39	0.57		3.57	
	15:00	Glass	1.10	3.44	17.00	64.25	78.31
		Wall "A"	0.13	4.71		10.22	
		Wall "D"	0.39	0.57		3.84	
	16:00	Glass	1.10	3.44	17.74	67.04	81.72
		Wall "A"	0.13	4.71		10.67	
		Wall "D"	0.39	0.57		4.01	
	17:00	Glass	1.10	3.44	18.00	68.03	82.92
		Wall "A"	0.13	4.71		10.82	
		Wall "D"	0.39	0.57		4.07	

2-Sun Load

Direction	Time	Type	U	A	ΔT	I	Q (W)
NE	8:00	glass		3.44		410.00	478.93
		A	0.13	4.71	26.65		16.02
		D	0.39	0.57	16.40		3.71
	9:00	glass		3.44		305.00	356.27
		A	0.13	4.71	19.83		11.92
		D	0.39	0.57	12.20		2.76
	10:00	glass		3.44		173.00	202.08
		A	0.13	4.71	11.25		6.76

Load calculations

		D	0.39	0.57	6.92		1.57
	11:00	glass		3.44		60.00	70.09
		A	0.13	4.71	3.90		2.34
		D	0.39	0.57	2.40		0.54
	12:00	glass		3.44		44.00	51.40
		A	0.13	4.71	2.86		1.72
		D	0.39	0.57	1.76		0.40
	13:00	glass		3.44		44.00	51.40
		A	0.13	4.71	2.86		1.72
		D	0.39	0.57	1.76		0.40
	14:00	glass		3.44		44.00	51.40
		A	0.13	4.71	2.86		1.72
		D	0.39	0.57	1.76		0.40
	15:00	glass		3.44		44.00	51.40
		A	0.13	4.71	2.86		1.72
		D	0.39	0.57	1.76		0.40
	16:00	glass		3.44		38.00	44.39
		A	0.13	4.71	2.47		1.48
		D	0.39	0.57	1.52		0.34
	17:00	glass		3.44		32.00	37.38
		A	0.13	4.71	2.08		1.25
		D	0.39	0.57	1.28		0.29

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
5.00	12.00	1.80	2.00

A (m2)	16.52
H (m)	2.60
V (m3)	42.95

Method	CMM
Based on No Of Persons	3.60
Based on Area	1.78
NO Of Air Changing Times	1.43

Time	CMM max	Qs(W)	QL(W)	Qtot (W)
8:00	3.60	381.89	1121.76	1503.65
9:00	3.60	495.72	1121.76	1617.48
10:00	3.60	628.65	1121.76	1750.41
11:00	3.60	771.12	1121.76	1892.88
12:00	3.60	913.59	1121.76	2035.35
13:00	3.60	1046.52	1121.76	2168.28
14:00	3.60	1160.35	1121.76	2282.11

Chapter Two

15:00	3.60	1248.48	1121.76	2370.24
16:00	3.60	1302.83	1121.76	2424.59
17:00	3.60	1321.92	1121.76	2443.68

B-Internal Loads

1-Occupancy Load

No Of Pers	Work	qs/p	qL/p	Qs	QL	Qtot (W)
5.00	Light	72.00	60.00	360.00	300.00	660.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
Fluorescent	8.00	20.00	1.25	200.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot
CPU	1.00	55.00	55.00	474.00
Monitor	1.00	55.00	55.00	
scan light	1.00	100.00	100.00	
abjora	1.00	60.00	60.00	
scan device	1.00	204.00	204.00	

Variation of load with time

Q occ_s	Q occ_l	Q lig_s	Q equ_s	Q equ_l
360.00	300.00	200.00	474.00	0.00

Time	Q wall_s	Q sun_s	Q vent_s	Q vent_l	RSH	RLH	RTH
8:00	23.95	498.66	381.89	1121.76	1556.61	300.00	1856.61
9:00	31.09	370.95	495.72	1121.76	1436.05	300.00	1736.05
10:00	39.43	210.41	628.65	1121.76	1283.84	300.00	1583.84
11:00	48.37	72.97	771.12	1121.76	1155.34	300.00	1455.34
12:00	57.31	53.51	913.59	1121.76	1144.82	300.00	1444.82
13:00	65.64	53.51	1046.52	1121.76	1153.16	300.00	1453.16
14:00	72.78	53.51	1160.35	1121.76	1160.30	300.00	1460.30
15:00	78.31	53.51	1248.48	1121.76	1165.83	300.00	1465.83
16:00	81.72	46.22	1302.83	1121.76	1161.94	300.00	1461.94
17:00	82.92	38.92	1321.92	1121.76	1155.84	300.00	1455.84

For air Conditioning machine 2**Room 0-17 waiting Area****A-External Loads****1-Wall Load**

Direction	Time	Type	U	A	ΔT (K)	Q	Qt
NE	08:00	Wall "A"	0.13	19.76	5.20	13.10	174.96
		Wall "B"	1.44	3.25		24.32	
		Wall "C"	1.79	3.25		30.23	
		Wall "D"	0.39	1.56		3.20	
		Glass	1.10	18.20		104.10	
	09:00	Wall "A"	0.13	19.76	6.75	17.01	227.11
		Wall "B"	1.44	3.25		31.57	
		Wall "C"	1.79	3.25		39.25	
		Wall "D"	0.39	1.56		4.15	
		Glass	1.10	18.20		135.14	
	10:00	Wall "A"	0.13	19.76	8.56	21.57	288.01
		Wall "B"	1.44	3.25		40.03	
		Wall "C"	1.79	3.25		49.77	
		Wall "D"	0.39	1.56		5.27	
		Glass	1.10	18.20		171.37	
	11:00	Wall "A"	0.13	19.76	10.50	26.46	353.28
		Wall "B"	1.44	3.25		49.10	
		Wall "C"	1.79	3.25		61.05	
		Wall "D"	0.39	1.56		6.46	
		Glass	1.10	18.20		210.21	
	12:00	Wall "A"	0.13	19.76	12.44	31.35	418.55
		Wall "B"	1.44	3.25		58.17	
		Wall "C"	1.79	3.25		72.33	
		Wall "D"	0.39	1.56		7.65	
		Glass	1.10	18.20		249.05	
	13:00	Wall "A"	0.13	19.76	14.25	35.91	479.45
		Wall "B"	1.44	3.25		66.64	
		Wall "C"	1.79	3.25		82.85	
		Wall "D"	0.39	1.56		8.77	
		Glass	1.10	18.20		285.29	
	14:00	Wall "A"	0.13	19.76	15.80	39.82	531.60
		Wall "B"	1.44	3.25		73.89	
		Wall "C"	1.79	3.25		91.86	
		Wall "D"	0.39	1.56		9.72	
		Glass	1.10	18.20		316.32	
	15:00	Wall "A"	0.13	19.76	17.00	42.84	571.98
		Wall "B"	1.44	3.25		79.50	
		Wall "C"	1.79	3.25		98.84	

Chapter Two

	16:00	Wall "D"	0.39	1.56	17.70	10.46	595.53
		Glass	1.10	18.20		340.34	
		Wall "A"	0.13	19.76		44.61	
		Wall "B"	1.44	3.25		82.77	
		Wall "C"	1.79	3.25		102.91	
	17:00	Wall "D"	0.39	1.56	18.00	10.89	605.63
		Glass	1.10	18.20		354.35	
		Wall "A"	0.13	19.76		45.36	
		Wall "B"	1.44	3.25		84.18	
		Wall "C"	1.79	3.25		104.65	
		Wall "D"	0.39	1.56		11.07	
		Glass	1.10	18.20		360.36	

Direction	Time	Type	U	A	ΔT	Q	Q tot
SE	8:00	Wall "A"	0.13	9.26	5.20	6.14	146.00
		Wall "G_2"	1.57	17.19		139.86	
	9:00	Wall "A"	0.13	9.26	6.75	7.97	189.52
		Wall "G_2"	1.57	17.19		181.55	
	10:00	Wall "A"	0.13	9.26	8.56	10.11	240.34
		Wall "G_2"	1.57	17.19		230.23	
	11:00	Wall "A"	0.13	9.26	10.50	12.40	294.80
		Wall "G_2"	1.57	17.19		282.41	
	12:00	Wall "A"	0.13	9.26	12.44	14.69	349.27
		Wall "G_2"	1.57	17.19		334.59	
	13:00	Wall "A"	0.13	9.26	14.25	16.82	400.09
		Wall "G_2"	1.57	17.19		383.27	
	14:00	Wall "A"	0.13	9.26	15.80	18.65	443.61
		Wall "G_2"	1.57	17.19		424.96	
	15:00	Wall "A"	0.13	9.26	17.00	20.07	477.30
		Wall "G_2"	1.57	17.19		457.23	
	16:00	Wall "A"	0.13	9.26	17.70	20.90	496.96
		Wall "G_2"	1.57	17.19		476.06	
	17:00	Wall "A"	0.13	9.26	18.00	21.25	505.38
		Wall "G_2"	1.57	17.19		484.13	

Direction	Time	Type	U	A	ΔT	Q	Qtot (W)
SW	8:00	Wall "A"	0.13	48.05	5.20	31.87	219.06
		Wall "B"	1.44	2.81		21.03	
		Wall "C"	1.79	2.39		22.23	
		Wall "D"	0.39	2.25		4.62	
		Glass	1.10	24.36		139.32	
	9:00	Wall "A"	0.13	48.05	6.75	41.36	284.36
		Wall "B"	1.44	2.81		27.29	
		Wall "C"	1.79	2.39		28.86	
		Wall "D"	0.39	2.25		5.99	

load calculations

		Glass	1.10	24.36		180.85	
	10:00	Wall "A"	0.13	48.05	8.56	52.46	360.61
		Wall "B"	1.44	2.81		34.61	
		Wall "C"	1.79	2.39		36.60	
		Wall "D"	0.39	2.25		7.60	
		Glass	1.10	24.36		229.35	
	11:00	Wall "A"	0.13	48.05	10.50	64.34	442.34
		Wall "B"	1.44	2.81		42.45	
		Wall "C"	1.79	2.39		44.89	
		Wall "D"	0.39	2.25		9.32	
		Glass	1.10	24.36		281.33	
	12:00	Wall "A"	0.13	48.05	12.44	76.23	524.07
		Wall "B"	1.44	2.81		50.30	
		Wall "C"	1.79	2.39		53.19	
		Wall "D"	0.39	2.25		11.04	
		Glass	1.10	24.36		333.30	
	13:00	Wall "A"	0.13	48.05	14.25	87.32	600.32
		Wall "B"	1.44	2.81		57.62	
		Wall "C"	1.79	2.39		60.93	
		Wall "D"	0.39	2.25		12.65	
		Glass	1.10	24.36		381.80	
	14:00	Wall "A"	0.13	48.05	15.80	96.82	665.62
		Wall "B"	1.44	2.81		63.88	
		Wall "C"	1.79	2.39		67.55	
		Wall "D"	0.39	2.25		14.02	
		Glass	1.10	24.36		423.33	
	15:00	Wall "A"	0.13	48.05	17.00	104.18	716.17
		Wall "B"	1.44	2.81		68.74	
		Wall "C"	1.79	2.39		72.69	
		Wall "D"	0.39	2.25		15.09	
		Glass	1.10	24.36		455.48	
	16:00	Wall "A"	0.13	48.05	17.70	108.47	745.66
		Wall "B"	1.44	2.81		71.57	
		Wall "C"	1.79	2.39		75.68	
		Wall "D"	0.39	2.25		15.71	
		Glass	1.10	24.36		474.23	
	17:00	Wall "A"	0.13	48.05	18.00	110.30	758.30
		Wall "B"	1.44	2.81		72.78	
		Wall "C"	1.79	2.39		76.96	
		Wall "D"	0.39	2.25		15.98	
		Glass	1.10	24.36		482.27	

Chapter Two

Time	Qt(W)
0.33	540.02
0.38	700.99
0.42	888.96
0.46	1008.70
0.50	1291.89
0.54	1479.86
0.58	1640.83
0.63	1765.45
0.67	1838.14
0.71	1869.30

2-Sun Load

Direction	Time	Type	U	A	I	ΔT_s	Q	Qtot (W)
NE	8:00	Wall "A"	0.13	19.76	410.00	26.65	67.16	2834.31
		Wall "B"	1.44	3.25		26.65	124.63	
		Wall "C"	1.79	3.25		16.40	95.35	
		Wall "D"	0.39	1.56		16.40	10.09	
		Glass	1.10	18.20			2537.08	
	9:00	Wall "A"	0.13	19.76	305.00	19.83	49.96	2108.45
		Wall "B"	1.44	3.25		19.83	92.71	
		Wall "C"	1.79	3.25		12.20	70.93	
		Wall "D"	0.39	1.56		12.20	7.50	
		Glass	1.10	18.20			1887.34	
	10:00	Wall "A"	0.13	19.76	173.00	11.25	28.34	1195.94
		Wall "B"	1.44	3.25		11.25	52.59	
		Wall "C"	1.79	3.25		6.92	40.23	
		Wall "D"	0.39	1.56		6.92	4.26	
		Glass	1.10	18.20			1070.52	
	11:00	Wall "A"	0.13	19.76	60.00	3.90	9.83	414.78
		Wall "B"	1.44	3.25		3.90	18.24	
		Wall "C"	1.79	3.25		2.40	13.95	
		Wall "D"	0.39	1.56		2.40	1.48	
		Glass	1.10	18.20			371.28	
	12:00	Wall "A"	0.13	19.76	44.00	2.86	7.21	304.17
		Wall "B"	1.44	3.25		2.86	13.37	
		Wall "C"	1.79	3.25		1.76	10.23	
		Wall "D"	0.39	1.56		1.76	1.08	
		Glass	1.10	18.20			272.27	
	13:00	Wall "A"	0.13	19.76	44.00	2.86	7.21	304.17
		Wall "B"	1.44	3.25		2.86	13.37	
		Wall "C"	1.79	3.25		1.76	10.23	
		Wall "D"	0.39	1.56		1.76	1.08	
		Glass	1.10	18.20			272.27	

Load calculations

	14:00	Wall "A"	0.13	19.76	44.00	2.86	7.21	304.17
		Wall "B"	1.44	3.25		2.86	13.37	
		Wall "C"	1.79	3.25		1.76	10.23	
		Wall "D"	0.39	1.56		1.76	1.08	
		Glass	1.10	18.20			272.27	
	15:00	Wall "A"	0.13	19.76	44.00	2.86	7.21	304.17
		Wall "B"	1.44	3.25		2.86	13.37	
		Wall "C"	1.79	3.25		1.76	10.23	
		Wall "D"	0.39	1.56		1.76	1.08	
		Glass	1.10	18.20			272.27	
	16:00	Wall "A"	0.13	19.76	38.00	2.47	6.22	262.69
		Wall "B"	1.44	3.25		2.47	11.55	
		Wall "C"	1.79	3.25		1.52	8.84	
		Wall "D"	0.39	1.56		1.52	0.93	
		Glass	1.10	18.20			235.14	
	17:00	Wall "A"	0.13	19.76	32.00	2.08	5.24	221.21
		Wall "B"	1.44	3.25		2.08	9.73	
		Wall "C"	1.79	3.25		1.28	7.44	
		Wall "D"	0.39	1.56		1.28	0.79	
		Glass	1.10	18.20			198.02	

Direction	Time	Type	U	A	I	ΔTs	Q (W)
SE	8:00	Wall "A"	0.13	9.26	284.00	18.46	21.79
	9:00	Wall "A"	0.13	9.26	284.00	18.46	21.79
	10:00	Wall "A"	0.13	9.26	230.00	14.95	17.65
	11:00	Wall "A"	0.13	9.26	139.00	9.04	10.67
	12:00	Wall "A"	0.13	9.26	54.00	3.51	4.14
	13:00	Wall "A"	0.13	9.26	44.00	2.86	3.38
	14:00	Wall "A"	0.13	9.26	44.00	2.86	3.38
	15:00	Wall "A"	0.13	9.26	44.00	2.86	3.38
	16:00	Wall "A"	0.13	9.26	38.00	2.47	2.92
	17:00	Wall "A"	0.13	9.26	32.00	2.08	2.46

Direction	Time	Type	U	A	I	ΔTs	Q	Qtot (W)
SW	8:00	Wall "A"	0.13	48.05	38.00	2.47	15.14	347.67
		Wall "B"	1.44	2.81		2.47	9.99	
		Wall "C"	1.79	2.39		1.52	6.50	
		Wall "D"	0.39	2.25		1.52	1.35	
		Glass	1.10	24.36			314.70	
	9:00	Wall "A"	0.13	48.05	44.00	2.86	17.53	402.56
		Wall "B"	1.44	2.81		2.86	11.56	
		Wall "C"	1.79	2.39		1.76	7.53	
		Wall "D"	0.39	2.25		1.76	1.56	
		Glass	1.10	24.36			364.38	

Chapter Two

	10:00	Wall "A"	0.13	48.05	44.00	2.86	17.53	402.51
		Wall "B"	1.44	2.81		2.86	11.56	
		Wall "C"	1.79	2.39		1.76	7.53	
		Wall "D"	0.39	2.25		1.76	1.56	
		Glass	1.10	24.36			364.38	
	11:00	Wall "A"	0.13	48.05	44.00	2.86	17.53	402.56
		Wall "B"	1.44	2.81		2.86	11.56	
		Wall "C"	1.79	2.39		1.76	7.53	
		Wall "D"	0.39	2.25		1.76	1.56	
		Glass	1.10	24.36			364.38	
	12:00	Wall "A"	0.13	48.05	54.00	3.51	21.51	494.05
		Wall "B"	1.44	2.81		3.51	14.19	
		Wall "C"	1.79	2.39		2.16	9.24	
		Wall "D"	0.39	2.25		2.16	1.92	
		Glass	1.10	24.36			447.20	
	13:00	Wall "A"	0.13	48.05	138.00	8.97	54.97	1262.58
		Wall "B"	1.44	2.81		8.97	36.27	
		Wall "C"	1.79	2.39		5.52	23.60	
		Wall "D"	0.39	2.25		5.52	4.90	
		Glass	1.10	24.36			1142.84	
	14:00	Wall "A"	0.13	48.05	230.00	14.95	91.61	2104.30
		Wall "B"	1.44	2.81		14.95	60.45	
		Wall "C"	1.79	2.39		9.20	39.34	
		Wall "D"	0.39	2.25		9.20	8.17	
		Glass	1.10	24.36			1904.73	
	15:00	Wall "A"	0.13	48.05	284.00	18.46	113.12	2598.35
		Wall "B"	1.44	2.81		18.46	74.64	
		Wall "C"	1.79	2.39		11.36	48.57	
		Wall "D"	0.39	2.25		11.36	10.08	
		Glass	1.10	24.36			2351.93	
	16:00	Wall "A"	0.13	48.05	284.00	18.46	113.12	2598.35
		Wall "B"	1.44	2.81		18.46	74.64	
		Wall "C"	1.79	2.39		11.36	48.57	
		Wall "D"	0.39	2.25		11.36	10.08	
		Glass	1.10	24.36			2351.93	
	17:00	Wall "A"	0.13	48.05	237.00	15.41	94.40	2168.34
		Wall "B"	1.44	2.81		15.41	62.29	
		Wall "C"	1.79	2.39		9.48	40.53	
		Wall "D"	0.39	2.25		9.48	8.41	
		Glass	1.10	24.36			1962.70	

Time	Qt(W)
0.33	3203.77
0.38	2532.80
0.42	1616.15
0.46	828.00
0.50	802.37
0.54	1570.12
0.58	2411.84
0.63	2905.90
0.67	2863.96
0.71	2392.01

3-Ventilation Load

Ti	hi	ϕ_i	Wi
24.00	47.90	50.00	9.34

No Of Person	L/s.p	L/s.m2	ζ
162.00	14.00	6.70	7.00

A (m2)	272.31
H (m)	2.60
V (m3)	708.01

Method	CMMv
Based on No Of Persons	136.08
Based on Area	109.47
NO Of Air Changing Times	82.60

Time	CMM max	Qs(W)	QL(W)	Qtot
8:00	136.08	14435.37	42402.53	56837.89
9:00	136.08	18738.22	42402.53	61140.74
10:00	136.08	23762.83	42402.53	66165.36
11:00	136.08	29148.34	42402.53	71550.86
12:00	136.08	34533.84	42402.53	76936.37
13:00	136.08	39558.46	42402.53	81960.98
14:00	136.08	43861.31	42402.53	86263.83
15:00	136.08	47192.54	42402.53	89595.07
16:00	136.08	49135.77	42402.53	91538.29
17:00	136.08	49968.58	42402.53	92371.10

Chapter Two

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
162.00	Comfort sitting	66.00	31.00	10692.00	5022.00	15714.00

2-Light Load

Type Of Lamps	No OF Lamps	W/Lamp	F	Q (W)
ze2reda	83.00	26.00	1.00	2158.00
ze2reda	70.00	26.00	1.00	1820.00
spot	8.00	35.00	1.00	280.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot
computer	1.00	110.00	110.00	650.00
water cooler	1.00	320.00	320.00	
Television	2.00	110.00	220.00	

Variation of load with time

Qs	Qs	Ql	Qs	Ql
2100.00	10692.00	5022.00	650.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_l	RSH	RLH	RTH
8:00	540.02	3203.77	14435.37	42402.53	17185.79	5022.00	22207.79
9:00	700.99	2532.80	18738.22	42402.53	16675.79	5022.00	21697.79
10:00	888.96	1616.15	23762.83	42402.53	15947.11	5022.00	20969.11
11:00	1008.70	828.00	29148.34	42402.53	15278.70	5022.00	20300.70
12:00	1291.89	802.37	34533.84	42402.53	15536.26	5022.00	20558.26
13:00	1479.86	1570.12	39558.46	42402.53	16491.99	5022.00	21513.99
14:00	1640.83	2411.84	43861.31	42402.53	17494.67	5022.00	22516.67
15:00	1765.45	2905.90	47192.54	42402.53	18113.34	5022.00	23135.34
16:00	1838.14	2863.96	49135.77	42402.53	18144.10	5022.00	23166.10
17:00	1869.30	2392.01	49968.58	42402.53	17703.31	5022.00	22725.31

Waiting Area 0-20

A-External Loads

1-Wall Load

Direction	Time	Type	U	A	ΔT	Q (W)
SE	8:00	Glass	1.10	47.02	5.20	268.95
	9:00	Glass	1.10	47.02	6.75	349.12
	10:00	Glass	1.10	47.02	8.56	442.74
	11:00	Glass	1.10	47.02	10.50	543.08
	12:00	Glass	1.10	47.02	12.44	643.42
	13:00	Glass	1.10	47.02	14.25	737.04
	14:00	Glass	1.10	47.02	15.80	817.20
	15:00	Glass	1.10	47.02	17.00	879.27
	16:00	Glass	1.10	47.02	17.70	915.48
	17:00	Glass	1.10	47.02	18.00	930.99

Direction	Time	Type	U	A	ΔT	Q (W)
SW	8:00	Wall "B"	1.44	10.40	5.20	77.82
	9:00	Wall "B"	1.44	10.40	6.75	101.01
	10:00	Wall "B"	1.44	10.40	8.56	128.10
	11:00	Wall "B"	1.44	10.40	10.50	157.13
	12:00	Wall "B"	1.44	10.40	12.44	186.16
	13:00	Wall "B"	1.44	10.40	14.25	213.24
	14:00	Wall "B"	1.44	10.40	15.80	236.44
	15:00	Wall "B"	1.44	10.40	17.00	254.40
	16:00	Wall "B"	1.44	10.40	17.70	264.87
	17:00	Wall "B"	1.44	10.40	18.00	269.36

Direction	Time	Type	U	A	ΔT	Q (W)
NW	8:00	Adj Wall	0.10	4.08	5.20	2.14
	9:00	Adj Wall	0.10	4.08	6.75	2.77
	10:00	Adj Wall	0.10	4.08	8.56	3.52
	11:00	Adj Wall	0.10	4.08	10.50	4.32
	12:00	Adj Wall	0.10	4.08	12.44	5.11
	13:00	Adj Wall	0.10	4.08	14.25	5.86
	14:00	Adj Wall	0.10	4.08	15.80	6.49
	15:00	Adj Wall	0.10	4.08	17.00	6.99
	16:00	Adj Wall	0.10	4.08	17.70	7.28
	17:00	Adj Wall	0.10	4.08	18.00	7.40

Chapter Two

Time	Qt(W)
8:00	348.91
9:00	452.91
10:00	574.35
11:00	704.52
12:00	834.69
13:00	956.14
14:00	1060.14
15:00	1140.66
16:00	1187.62
17:00	1207.75

2-Sun Load

Direction	Time	Type	A	I	Q (W)
SE	8:00	glass	47.02	284.00	7611.57
	9:00	glass	47.02	284.00	7611.57
	10:00	glass	47.02	230.00	6164.30
	11:00	glass	47.02	139.00	3725.38
	12:00	glass	47.02	54.00	1447.27
	13:00	glass	47.02	44.00	1179.26
	14:00	glass	47.02	44.00	1179.26
	15:00	glass	47.02	44.00	1179.26
	16:00	glass	47.02	38.00	1018.45
	17:00	glass	47.02	32.00	857.64

Direction	Time	Type	A	U	I	ΔT sun	Q (W)
SW	8:00	Wall "B"	10.40	1.44	38.00	2.47	36.96
	9:00	Wall "B"	10.40	1.44	44.00	2.86	42.80
	10:00	Wall "B"	10.40	1.44	44.00	2.86	42.80
	11:00	Wall "B"	10.40	1.44	44.00	2.86	42.80
	12:00	Wall "B"	10.40	1.44	54.00	3.51	52.53
	13:00	Wall "B"	10.40	1.44	138.00	8.97	134.23
	14:00	Wall "B"	10.40	1.44	230.00	14.95	223.72
	15:00	Wall "B"	10.40	1.44	284.00	18.46	276.25
	16:00	Wall "B"	10.40	1.44	284.00	18.46	276.25
	17:00	Wall "B"	10.40	1.44	237.00	15.41	230.53

Time	Qt(W)
8:00	7648.53
9:00	7654.37
10:00	6207.10
11:00	3768.18
12:00	1499.80
13:00	1313.49
14:00	1402.98
15:00	1455.50
16:00	1294.70
17:00	1088.17

3-Ventilation Load

No Of Person	L/s.p	L/s.m2	ζ
125.00	14.00	2.80	3.00

A (m2)	435.02
H (m)	2.60
V (m3)	1131.05

Method	CMMv
Based on No Of Persons	105.00
Based on Area	73.08
NO Of Air Changing Times	56.55

Time	CMM _{max}	Qs(W)	QL(W)	Qtot (W)
8:00	105.00	11138.40	32718.00	43856.40
9:00	105.00	14458.50	32718.00	47176.50
10:00	105.00	18335.52	32718.00	51053.52
11:00	105.00	22491.00	32718.00	55209.00
12:00	105.00	26646.48	32718.00	59364.48
13:00	105.00	30523.50	32718.00	63241.50
14:00	105.00	33843.60	32718.00	66561.60
15:00	105.00	36414.00	32718.00	69132.00
16:00	105.00	37913.40	32718.00	70631.40
17:00	105.00	38556.00	32718.00	71274.00

B-Internal Loads

1-Occupancy Load

No Of Persons	Work	qs/p (W)	qL/p (W)	Qs (W)	QL (W)	Qtot (W)
117.00	sitting	66.00	31.00	7722.00	3627.00	11349.00
8.00	Light Work	72.00	60.00	576.00	480.00	1056.00

Chapter Two

2-Light Load

Type Of Lamps	No Of Lamps	W/Lamp	F	Q (W)
ze2reda	106.00	26.00	1.00	2756.00
spot	25.00	35.00	1.00	875.00
exit	5.00	60.00	1.00	300.00

3-Equipment

Type Of Device	No Of Device	W/device	Q (W)	Q Tot (W)
television	1.00	110.00	110.00	110.00

Variation of load with time

Q occ_s	Q occ_I	Q light_s	Q eq_s	Q eq_I
3931.00	8298.00	4107.00	110.00	0.00

Time	Qwal_s	Qsun_s	Q ven_s	Q vent_I	RSH	RLH	RTH
8:00	348.91	7648.53	11138.40	32718.00	20336.44	4107.00	24443.44
9:00	452.91	7654.37	14458.50	32718.00	20446.28	4107.00	24553.28
10:00	574.35	6207.10	18335.52	32718.00	19120.45	4107.00	23227.45
11:00	704.52	3768.18	22491.00	32718.00	16812.70	4107.00	20919.70
12:00	834.69	1499.80	26646.48	32718.00	14673.49	4107.00	18780.49
13:00	956.14	1313.49	30523.50	32718.00	14608.63	4107.00	18715.63
14:00	1060.14	1402.98	33843.60	32718.00	14802.12	4107.00	18909.12
15:00	1140.66	1455.50	36414.00	32718.00	14935.16	4107.00	19042.16
16:00	1187.62	1294.70	37913.40	32718.00	14821.32	4107.00	18928.32
17:00	1207.75	1088.17	38556.00	32718.00	14634.92	4107.00	18741.92

Ground floor total Load calculations

For 1st machine

Time	TRSH	TRLH	TRTH	RSHF
8:00	35570.0	7056.0	42626.0	0.83
9:00	34358.6	7056.0	41414.6	0.83
10:00	32228.0	7056.0	39284.0	0.82
11:00	30014.4	7056.0	37070.4	0.81
12:00	29307.1	7056.0	36363.1	0.81
1:00	29945.1	7056.0	37001.1	0.81
2:00	31834.1	7056.0	38890.1	0.82
3:00	31192.5	7056.0	38248.5	0.82
4:00	31168.4	7056.0	38224.4	0.82
5:00	30812.1	7056.0	37868.1	0.81

TIME	Qvent_s	Qvent_I	Qvent_T
8:00	11523.5	33547.2	45070.7
9:00	14927.8	33547.2	48475.0
10:00	18903.0	33547.2	52450.3
11:00	23163.8	33547.2	56711.1
12:00	27424.6	33547.2	60971.9
1:00	31399.9	33547.2	64947.1
2:00	34804.2	33547.2	68351.4
3:00	37439.7	33547.2	70986.9
4:00	39012.4	33547.2	72559.6
5:00	39636.0	33547.2	73183.2

TIME	GRSH	GRLH	GRTH	GRSHF
8:00	47093.5	40603.2	87696.7	0.54
9:00	49286.4	40603.2	89889.6	0.55
10:00	51131.1	40603.2	91734.3	0.56
11:00	53178.2	40603.2	93781.4	0.57
12:00	56731.8	40603.2	97335.0	0.58
1:00	61345.0	40603.2	101948.2	0.60
2:00	66638.2	40603.2	107241.5	0.62
3:00	68632.2	40603.2	109235.5	0.63
4:00	70180.8	40603.2	110784.0	0.63
5:00	70448.1	40603.2	111051.3	0.63

Chapter Two

The max load occurs at 2:00 PM and its value equals:

TIME	TRSH (W)	TRLH (W)	TRTH (W)	RSHF
2:00	31834.1	7056.0	38890.1	0.82

TIME	Qven s (W)	Qvent_I (W)	Qvent_T (W)
2:00	34804.2	33547.2	68351.4

TIME	ERSH (W)	ERLH (W)	ERTH(W)	ERSHF
2:00	42299.7	17143.7	59443.3	0.71

TIME	GRSH(W)	GRLH(W)	GRTH(W)	GRSHF
2:00	66638.2	40603.2	107241.5	0.54

Time	GTH (KW)	GTH (HP)	GTH (TR)
2:00	107.24	143.70	30.64

For 2nd machine

TIME	TRSH	TRLH	TRTH	RSHF
8:00	37522.2	9129.0	46651.2	0.80
9:00	37122.1	9129.0	46251.1	0.80
10:00	35067.6	9129.0	44196.6	0.79
11:00	32091.4	9129.0	41220.4	0.78
12:00	30209.7	9129.0	39338.7	0.77
1:00	31100.6	9129.0	40229.6	0.77
2:00	32296.8	9129.0	41425.8	0.78
3:00	33048.5	9129.0	42177.5	0.78
4:00	32965.4	9129.0	42094.4	0.78
5:00	32338.2	9129.0	41467.2	0.78

TIME	Qvent_s	Qvent_I	Qvent_T
8:00	37097.2804	108667.752	145765
9:00	48124.4765	108667.752	156792.2
10:00	61001.3958	108667.752	169669.1
11:00	74803.1768	108667.752	183470.9
12:00	88604.9577	108667.752	197272.7
1:00	101481.877	108667.752	210149.6
2:00	112509.073	108667.752	221176.8
3:00	121046.257	108667.752	229714
4:00	126061.532	108667.752	234729.3
5:00	128160.577	108667.752	236828.3

TIME	GRSH	GRLH	GRTH	GRSHF
8:00	74619.5	117796.8	192416.3	0.39
9:00	85246.5	117796.8	203043.3	0.42
10:00	96069.0	117796.8	213865.7	0.45
11:00	106894.6	117796.8	224691.3	0.48
12:00	118814.7	117796.8	236611.5	0.50
1:00	132582.5	117796.8	250379.2	0.53
2:00	144805.9	117796.8	262602.6	0.55
3:00	154094.8	117796.8	271891.5	0.57
4:00	159027.0	117796.8	276823.7	0.57
5:00	160498.8	117796.8	278295.6	0.58

Chapter Two

The max load occurs at 5:00 PM and its value equals:

TIME	TRSH (W)	TRLH (W)	TRTH (W)	RSHF
5:00	32338.2	9129.0	41467.2	0.78

TIME	Qvent_s (W)	Qvent_l (W)	Qvent_T (W)
5:00	128160.577	108667.752	236828.3

TIME	ERSH (W)	ERLH (W)	ERTH(W)	ERSHF
5:00	54125.5	27602.5	81728.1	0.66

TIME	GRSH(W)	GRLH(W)	GRTH(W)	GRSHF
5:00	160498.8	117796.8	278295.6	0.58

Time	GTH (KW)	GTH (HP)	GTH (TR)
5:00	278.30	372.92	79.51

1st Floor calculations

Corridor 1-11

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
146.00	146.00	1050.00	0.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	87.14	0.00	466.09	1369.11	1283.14	146.00	1429.14
9:00	87.14	0.00	605.03	1369.11	1283.14	146.00	1429.14
10:00	87.14	0.00	767.26	1369.11	1283.14	146.00	1429.14
11:00	87.14	0.00	941.15	1369.11	1283.14	146.00	1429.14
12:00	87.14	0.00	1115.04	1369.11	1283.14	146.00	1429.14
13:00	87.14	0.00	1277.28	1369.11	1283.14	146.00	1429.14
14:00	87.14	0.00	1416.21	1369.11	1283.14	146.00	1429.14
15:00	87.14	0.00	1523.77	1369.11	1283.14	146.00	1429.14
16:00	87.14	0.00	1586.51	1369.11	1283.14	146.00	1429.14
17:00	87.14	0.00	1613.40	1369.11	1283.14	146.00	1429.14

Room 1-13

Variation of load with time

Qocc_s	Qlight_s	Qequip_s	Qequip_I
0	400	0	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	206.07	379.32	148.68	436.74	985.40	0.00	985.40
9:00	216.86	282.18	193.00	436.74	899.03	0.00	899.03
10:00	229.45	160.06	244.75	436.74	789.50	0.00	789.50
11:00	242.94	55.51	300.22	436.74	698.45	0.00	698.45
12:00	256.44	40.71	355.69	436.74	697.15	0.00	697.15
13:00	269.03	40.71	407.45	436.74	709.74	0.00	709.74
14:00	279.82	40.71	451.76	436.74	720.52	0.00	720.52
15:00	288.16	40.71	486.07	436.74	728.87	0.00	728.87
16:00	293.03	35.16	506.09	436.74	728.19	0.00	728.19
17:00	295.12	29.61	514.67	436.74	724.73	0.00	724.73

Chapter Two

Room 1-15

Variation Of load with time

Qocc_s	Qocc_l	Qlight_s	Qequip_s	Qequip_l
0.00	0.00	200.00	0.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	186.62	288.69	96.81	284.37	675.31	0.00	675.31
9:00	191.58	214.76	125.67	284.37	606.34	0.00	606.34
10:00	197.38	121.81	159.36	284.37	519.19	0.00	519.19
11:00	203.59	42.25	195.48	284.37	445.83	0.00	445.83
12:00	209.80	30.98	231.60	284.37	440.78	0.00	440.78
13:00	215.59	30.98	265.29	284.37	446.57	0.00	446.57
14:00	220.55	30.98	294.15	284.37	451.53	0.00	451.53
15:00	224.39	30.98	316.49	284.37	455.37	0.00	455.37
16:00	226.63	26.76	329.52	284.37	453.39	0.00	453.39
17:00	227.59	22.53	335.11	284.37	450.12	0.00	450.12

Room 1-41

Variation of load with time

Qocc_s	Qocc_i	Qligh_s	Qequ_s	Qequ_l
176	408	200	0	0

TIME	Qwal S	Qsun S	Qven S	Qvent	RSH	RLH	RTH
8:00	3.62	18.56	178.21	523.49	398.18	408.00	806.18
9:00	4.70	13.81	231.34	523.49	394.51	408.00	802.51
10:00	5.96	7.83	293.37	523.49	389.79	408.00	797.79
11:00	7.31	2.72	359.86	523.49	386.03	408.00	794.03
12:00	8.66	1.99	426.34	523.49	386.65	408.00	794.65
13:00	9.92	1.99	488.38	523.49	387.91	408.00	795.91
14:00	11.00	1.99	541.50	523.49	388.99	408.00	796.99
15:00	11.84	1.99	582.62	523.49	389.83	408.00	797.83
16:00	12.33	1.72	606.61	523.49	390.05	408.00	798.05
17:00	12.53	1.45	616.90	523.49	389.98	408.00	797.98

Room 1-42

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequ_s	Qequ_I
176	408	200	0	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	16.59	61.74	178.21	523.49	454.33	408.00	862.33
9:00	21.54	46.92	231.34	523.49	444.45	408.00	852.45
10:00	27.31	27.80	293.37	523.49	431.12	408.00	839.12
11:00	33.50	11.44	359.86	523.49	420.95	408.00	828.95
12:00	39.69	9.13	426.34	523.49	424.82	408.00	832.82
13:00	45.47	10.13	488.38	523.49	431.60	408.00	839.60
14:00	50.41	17.20	541.50	523.49	443.62	408.00	851.62
15:00	54.24	25.78	582.62	523.49	456.03	408.00	864.03
16:00	56.48	31.17	606.61	523.49	463.65	408.00	871.65
17:00	57.43	32.06	616.90	523.49	465.49	408.00	873.49

Room 1-49

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
432	384	200	0	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	52.05	0.00	534.64	1570.46	684.05	384.00	1068.05
9:00	67.57	0.00	694.01	1570.46	699.57	384.00	1083.57
10:00	85.68	0.00	880.10	1570.46	717.68	384.00	1101.68
11:00	105.10	0.00	1079.57	1570.46	737.10	384.00	1121.10
12:00	124.52	0.00	1279.03	1570.46	756.52	384.00	1140.52
13:00	142.64	0.00	1465.13	1570.46	774.64	384.00	1158.64
14:00	158.15	0.00	1624.49	1570.46	790.15	384.00	1174.15
15:00	170.17	0.00	1747.87	1570.46	802.17	384.00	1186.17
16:00	177.17	0.00	1819.84	1570.46	809.17	384.00	1193.17
17:00	180.18	0.00	1850.69	1570.46	812.18	384.00	1196.18

Chapter Two

Room 1-50

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
220	155	600	320	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	51.4995	61.8115	267.322	785.232	1253.3	155	1408.31
9:00	66.8503	71.5713	347.004	785.232	1278.4	155	1433.42
10:00	84.7761	71.5713	440.052	785.232	1296.3	155	1451.35
11:00	103.989	71.5713	539.784	785.232	1315.5	155	1470.56
12:00	123.203	73.1979	639.516	785.232	1336.4	155	1491.4
13:00	141.128	224.474	732.564	785.232	1505.6	155	1660.6
14:00	156.479	374.123	812.246	785.232	1670.6	155	1825.6
15:00	168.364	461.96	873.936	785.232	1770.3	155	1925.32
16:00	175.296	461.96	909.922	785.232	1777.2	155	1932.26
17:00	178.267	385.509	925.344	785.232	1703.7	155	1858.78

Room 1-55

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
225	165	100	110	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	39.81	56.70	267.32	785.23	531.52	165.00	696.52
9:00	51.68	65.66	347.00	785.23	552.34	165.00	717.34
10:00	65.54	65.66	440.05	785.23	566.19	165.00	731.19
11:00	80.39	65.66	539.78	785.23	581.05	165.00	746.05
12:00	95.24	67.15	639.52	785.23	597.39	165.00	762.39
13:00	109.10	205.92	732.56	785.23	750.02	165.00	915.02
14:00	120.97	343.20	812.25	785.23	899.17	165.00	1064.17
15:00	130.16	423.78	873.94	785.23	988.94	165.00	1153.94
16:00	135.52	423.78	909.92	785.23	994.30	165.00	1159.30
17:00	137.81	353.65	925.34	785.23	926.46	165.00	1091.46

Room 1-56

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequ_s	Qequ_I
220.00	155	300	596	0

TIME	Qwall S	Qsun S	Qvent S	Qvent_I	RSH	RLH	RTH
8:00	102.9479	52.81	267.32	921.06	1271.76	155.00	1426.76
9:00	111.9508	61.15	347.00	921.06	1289.10	155.00	1444.10
10:00	122.4639	61.15	440.05	921.06	1299.61	155.00	1454.61
11:00	133.7321	61.15	539.78	921.06	1310.88	155.00	1465.88
12:00	145.0003	75.05	639.52	921.06	1336.05	155.00	1491.05
13:00	155.5134	191.79	732.56	921.06	1463.30	155.00	1618.30
14:00	164.5163	319.65	812.25	921.06	1600.17	155.00	1755.17
15:00	171.4863	394.70	873.94	921.06	1682.19	155.00	1837.19
16:00	175.5521	394.70	909.92	921.06	1686.25	155.00	1841.25
17:00	177.2946	329.38	925.34	921.06	1622.67	155.00	1777.67

Room1-61

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
75	55	600	1319.8	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	105.29	108.22	179.87	528.35	2208.3	55.00	2263.31
9:00	125.88	125.30	233.48	528.35	2245.9	55.00	2300.98
10:00	149.92	125.30	296.09	528.35	2270.0	55.00	2325.03
11:00	175.69	125.30	363.20	528.35	2295.8	55.00	2350.80
12:00	201.46	128.15	430.30	528.35	2324.4	55.00	2379.41
13:00	225.51	392.99	492.91	528.35	2613.3	55.00	2668.30
14:00	246.10	654.99	546.53	528.35	2895.8	55.00	2950.89
15:00	262.04	808.77	588.03	528.35	3065.6	55.00	3120.61
16:00	271.34	808.77	612.25	528.35	3074.9	55.00	3129.90
17:00	275.32	674.92	622.62	528.35	2945.0	55.00	3000.04

Chapter Two

Room 1-62

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
750.00	550.00	1,200.00	2,416.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	243.41	558.43	891.07	2,617.44	5,167.8	550.00	5,717.8
9:00	279.85	583.70	1,156.68	2,617.44	5,229.5	550.00	5,779.5
10:00	322.40	507.94	1,466.84	2,617.44	5,196.3	550.00	5,746.3
11:00	368.01	380.27	1,799.28	2,617.44	5,114.2	550.00	5,664.2
12:00	413.62	265.23	2,131.72	2,617.44	5,044.8	550.00	5,594.8
13:00	456.17	642.77	2,441.88	2,617.44	5,464.9	550.00	6,014.9
14:00	492.61	1,030.1	2,707.49	2,617.44	5,888.7	550.00	6,438.7
15:00	520.82	1,257.49	2,913.12	2,617.44	6,144.3	550.00	6,694.3
16:00	537.28	1,249.0	3,033.07	2,617.44	6,152.3	550.00	6,702.3
17:00	544.33	1,042.7	3,084.48	2,617.44	5,953.1	550.00	6,503.1

Room 1-63

Variation of load with Time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
225.00	165.00	400.00	1234.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	216.51	1214.11	436.80	1283.07	3289.62	165.00	3454.62
9:00	239.18	915.52	567.00	1283.07	3013.70	165.00	3178.70
10:00	265.65	530.99	719.05	1283.07	2655.65	165.00	2820.65
11:00	294.03	194.21	882.01	1283.07	2347.24	165.00	2512.24
12:00	322.40	134.29	1044.97	1283.07	2315.69	165.00	2480.69
13:00	348.87	132.59	1197.01	1283.07	2340.46	165.00	2505.46
14:00	371.54	132.59	1327.21	1283.07	2363.13	165.00	2528.13
15:00	389.09	132.59	1428.01	1283.07	2380.68	165.00	2545.68
16:00	399.33	114.51	1486.81	1283.07	2372.84	165.00	2537.84
17:00	403.72	96.43	1512.01	1283.07	2359.15	165.00	2524.15

Room 1-64

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
300.00	220.00	500.00	730.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	53.07	1147.52	489.38	1437.50	2730.58	220.00	2950.58
9:00	68.89	853.64	635.25	1437.50	2452.53	220.00	2672.53
10:00	87.36	484.20	805.59	1437.50	2101.55	220.00	2321.55
11:00	107.16	167.93	988.16	1437.50	1805.08	220.00	2025.08
12:00	126.95	123.15	1170.74	1437.50	1780.10	220.00	2000.10
13:00	145.42	123.15	1341.08	1437.50	1798.57	220.00	2018.57
14:00	161.24	123.15	1486.95	1437.50	1814.39	220.00	2034.39
15:00	173.49	123.15	1599.89	1437.50	1826.64	220.00	2046.64
16:00	180.63	106.36	1665.76	1437.50	1816.99	220.00	2036.99
17:00	183.69	89.56	1694.00	1437.50	1803.26	220.00	2023.26

Room 1-65

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
0.00	0.00	300.00	110.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	19.07	228.50	121.95	358.22	657.57	0.00	657.57
9:00	24.75	222.97	158.30	358.22	657.73	0.00	657.73
10:00	31.39	176.68	200.75	358.22	618.08	0.00	618.08
11:00	38.51	104.44	246.24	358.22	552.94	0.00	552.94
12:00	45.62	41.66	291.74	358.22	497.28	0.00	497.28
13:00	52.26	34.37	334.19	358.22	496.63	0.00	496.63
14:00	57.94	34.37	370.54	358.22	502.32	0.00	502.32
15:00	62.34	34.37	398.68	358.22	506.72	0.00	506.72
16:00	64.91	29.69	415.10	358.22	504.60	0.00	504.60
17:00	66.01	25.00	422.13	358.22	501.01	0.00	501.01

Room 1-67 , 1-68 , 1-69

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
290.00	200.00	400.00	510.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	33.68	52.05	356.43	1046.98	1285.73	200.00	1485.73
9:00	43.72	60.27	462.67	1046.98	1303.99	200.00	1503.99
10:00	55.45	60.27	586.74	1046.98	1315.71	200.00	1515.71
11:00	68.01	60.27	719.71	1046.98	1328.28	200.00	1528.28
12:00	80.58	61.64	852.69	1046.98	1342.22	200.00	1542.22
13:00	92.30	189.02	976.75	1046.98	1481.32	200.00	1681.32
14:00	102.34	315.03	1083.00	1046.98	1617.38	200.00	1817.38
15:00	110.12	389.00	1165.25	1046.98	1699.11	200.00	1899.11
16:00	114.65	389.00	1213.23	1046.98	1703.65	200.00	1903.65
17:00	116.59	324.62	1233.79	1046.98	1641.22	200.00	1841.22

Room 1-70

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
936.00	780.00	800.00	0.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	71.69	106.00	1158.39	3402.67	1913.69	780.00	2693.69
9:00	93.06	122.74	1503.68	3402.67	1951.80	780.00	2731.80
10:00	118.01	122.74	1906.89	3402.67	1976.75	780.00	2756.75
11:00	144.76	122.74	2339.06	3402.67	2003.50	780.00	2783.50
12:00	171.50	125.53	2771.23	3402.67	2033.03	780.00	2813.03
13:00	196.45	384.96	3174.44	3402.67	2317.42	780.00	3097.42
14:00	217.82	641.60	3519.73	3402.67	2595.43	780.00	3375.43
15:00	234.37	792.24	3787.06	3402.67	2762.61	780.00	3542.61
16:00	244.02	792.24	3942.99	3402.67	2772.26	780.00	3552.26
17:00	248.15	661.13	4009.82	3402.67	2645.28	780.00	3425.28

Room 1- 71

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
290.00	200.00	400.00	510.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	66.35	969.99	2001.48	1046.98	2236.35	200.00	2436.35
9:00	86.13	824.82	2107.73	1046.98	2110.95	200.00	2310.95
10:00	109.23	565.67	2231.79	1046.98	1874.90	200.00	2074.90
11:00	133.98	280.26	2364.77	1046.98	1614.25	200.00	1814.25
12:00	158.74	137.49	2497.74	1046.98	1496.23	200.00	1696.23
13:00	181.84	123.29	2621.81	1046.98	1505.13	200.00	1705.13
14:00	201.61	123.29	2728.05	1046.98	1524.91	200.00	1724.91
15:00	216.93	123.29	2810.30	1046.98	1540.22	200.00	1740.22
16:00	225.86	106.48	2858.28	1046.98	1532.34	200.00	1732.34
17:00	229.69	89.67	2878.85	1046.98	1519.35	200.00	1719.35

Room 1-72 , 1-73

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
290.00	200.00	400.00	510.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	34.35	566.86	356.43	1046.98	1801.21	200.00	2001.21
9:00	44.59	421.69	462.67	1046.98	1666.28	200.00	1866.28
10:00	56.55	239.19	586.74	1046.98	1495.74	200.00	1695.74
11:00	69.36	82.96	719.71	1046.98	1352.32	200.00	1552.32
12:00	82.18	60.83	852.69	1046.98	1343.01	200.00	1543.01
13:00	94.14	60.83	976.75	1046.98	1354.97	200.00	1554.97
14:00	104.38	60.83	1083.00	1046.98	1365.21	200.00	1565.21
15:00	112.30	60.83	1165.25	1046.98	1373.14	200.00	1573.14
16:00	116.93	52.54	1213.23	1046.98	1369.47	200.00	1569.47
17:00	118.91	44.24	1233.79	1046.98	1363.15	200.00	1563.15

Chapter Two

Room 1-74

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
290.00	200.00	400.00	510.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	74.70	566.86	356.43	1046.98	1841.56	200.00	2041.56
9:00	85.13	421.69	462.67	1046.98	1706.82	200.00	1906.82
10:00	97.31	239.19	586.74	1046.98	1536.50	200.00	1736.50
11:00	110.37	82.96	719.71	1046.98	1393.32	200.00	1593.32
12:00	123.42	60.83	852.69	1046.98	1384.25	200.00	1584.25
13:00	135.60	60.83	976.75	1046.98	1396.43	200.00	1596.43
14:00	146.03	60.83	1083.00	1046.98	1406.86	200.00	1606.86
15:00	154.10	60.83	1165.25	1046.98	1414.94	200.00	1614.94
16:00	158.82	52.54	1213.23	1046.98	1411.35	200.00	1611.35
17:00	160.83	44.24	1233.79	1046.98	1405.08	200.00	1605.08

Room 1-75

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
0.00	0.00	0.00	500.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	101.79	0.00	68.49	162.37	601.79	0.00	601.79
9:00	124.05	0.00	88.90	162.37	624.05	0.00	624.05
10:00	148.58	0.00	112.74	162.37	648.58	0.00	648.58
11:00	174.23	0.00	138.29	162.37	674.23	0.00	674.23
12:00	199.89	0.00	163.84	162.37	699.89	0.00	699.89
13:00	224.42	0.00	187.68	162.37	724.42	0.00	724.42
14:00	246.67	0.00	208.09	162.37	746.67	0.00	746.67
15:00	265.88	0.00	223.89	162.37	765.88	0.00	765.88
16:00	280.71	0.00	233.11	162.37	780.71	0.00	780.71
17:00	292.06	0.00	237.06	162.37	792.06	0.00	792.06

Waiting Area 1-12 , 1-17 , 1-18 , 1-19

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
3922	1941	2100	760	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	254.40	482.76	5257.32	15442.90	7519.16	1941.00	9460.16
9:00	286.82	483.55	6824.41	15442.90	7552.38	1941.00	9493.38
10:00	324.68	392.72	8654.37	15442.90	7499.40	1941.00	9440.40
11:00	365.26	239.65	10615.75	15442.90	7386.91	1941.00	9327.91
12:00	405.84	98.00	12577.14	15442.90	7285.83	1941.00	9226.83
13:00	443.70	92.31	14407.09	15442.90	7318.01	1941.00	9259.01
14:00	476.12	104.51	15974.18	15442.90	7362.63	1941.00	9303.63
15:00	501.22	111.68	17187.41	15442.90	7394.89	1941.00	9335.89
16:00	515.86	101.58	17895.12	15442.90	7399.44	1941.00	9340.44
17:00	522.13	85.26	18198.43	15442.90	7389.39	1941.00	9330.39

Waiting Area 1-22 , 1- 54

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
6965	3395	4650	1110	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	189.206	0	9356.26	27483.12	12914.21	3395.00	16309.21
9:00	189.206	0	12145.14	27483.12	12914.21	3395.00	16309.21
10:00	189.206	0	15401.84	27483.12	12914.21	3395.00	16309.21
11:00	189.206	0	18892.44	27483.12	12914.21	3395.00	16309.21
12:00	189.206	0	22383.04	27483.12	12914.21	3395.00	16309.21
13:00	189.206	0	25639.74	27483.12	12914.21	3395.00	16309.21
14:00	189.206	0	28428.62	27483.12	12914.21	3395.00	16309.21
15:00	189.206	0	30587.76	27483.12	12914.21	3395.00	16309.21
16:00	189.206	0	31847.26	27483.12	12914.21	3395.00	16309.21
17:00	189.206	0	32387.04	27483.12	12914.21	3395.00	16309.21

Waiting Area 1-66 , 1-10 , 1-40

Variation Of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
219	177	1540	130	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	577.96	49.73	1364.03	4006.70	2516.69	177.00	2693.69
9:00	609.17	57.58	1770.61	4006.70	2555.74	177.00	2732.74
10:00	645.61	57.58	2245.40	4006.70	2592.18	177.00	2769.18
11:00	684.66	57.58	2754.29	4006.70	2631.24	177.00	2808.24
12:00	723.72	69.74	3263.17	4006.70	2682.45	177.00	2859.45
13:00	760.16	173.35	3737.96	4006.70	2822.51	177.00	2999.51
14:00	791.36	295.68	4144.55	4006.70	2976.04	177.00	3153.04
15:00	815.52	374.04	4459.32	4006.70	3078.56	177.00	3255.56
16:00	829.61	383.31	4642.94	4006.70	3101.92	177.00	3278.92
17:00	835.65	328.76	4721.63	4006.70	3053.41	177.00	3230.41

Room 1-44 ,1-43

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
441	390	900	1220	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
8:00	24.13	372.08	552.72	1904.40	2957.21	390.00	3347.2
9:00	31.32	276.79	717.47	1904.40	2869.11	390.00	3259.1
10:00	39.72	157.00	909.86	1904.40	2757.72	390.00	3147.7
11:00	48.72	54.45	1116.07	1904.40	2664.17	390.00	3054.1
12:00	57.72	39.93	1322.27	1904.40	2658.65	390.00	3048.6
13:00	66.12	39.93	1514.66	1904.40	2667.05	390.00	3057.0
14:00	73.31	39.93	1679.42	1904.40	2674.24	390.00	3064.2
15:00	78.88	39.93	1806.97	1904.40	2679.81	390.00	3069.8
16:00	82.13	157.00	1881.37	1904.40	2800.13	390.00	3190.1
17:00	83.52	29.04	1913.26	1904.40	2673.56	390.00	3063.5

Room 1-47 , 1-48

Variation of load with time

Qocc_s	Qocc_l	Qlight_s	Qequ s	Qequ l
441	390	900	1330	0

TIME	Qwall S	Qsun S	Qven S	Qvent l	RSH	RLH	RTH
8:00	164.29	468.19	534.64	1842.12	3303.4	390.00	3693.48
9:00	197.00	348.29	694.01	1842.12	3216.2	390.00	3606.29
10:00	235.20	197.55	880.10	1842.12	3103.7	390.00	3493.75
11:00	276.14	68.52	1079.5	1842.12	3015.6	390.00	3405.66
12:00	317.08	50.25	1279.0	1842.12	3038.3	390.00	3428.33
13:00	355.28	50.25	1465.1	1842.12	3076.5	390.00	3466.53
14:00	387.99	50.25	1624.4	1842.12	3109.2	390.00	3499.24
15:00	413.32	50.25	1747.8	1842.12	3134.5	390.00	3524.57
16:00	428.09	43.39	1819.8	1842.12	3142.4	390.00	3532.49
17:00	434.42	36.54	1850.6	1842.12	3141.9	390.00	3531.97

Room 1-53 ,1-52

Variation of load with time

Qocc_s	Qocc_l	Qlight_s	Qequip_s	Qequip_l
220	155	300	596	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_l	RSH	RLH	RTH
8:00	50.0676	59.3640	267.3216	921.06	1225.43	155	1380.4
9:00	64.9916	68.7373	347.004	921.06	1249.72	155	1404.
10:00	82.41897	68.7373	440.0525	921.06	1267.15	155	1422.1
11:00	101.098	68.73731	539.784	921.06	1285.83	155	1440.83
12:00	119.7771	70.29952	639.5155	921.06	1306.07	155	1461.07
13:00	137.204	215.585	732.564	921.06	1468.79	155	1623.79
14:00	152.128	359.308	812.2464	921.06	1627.43	155	1782.43
15:00	163.682	443.668	873.936	921.06	1723.35	155	1878.35
16:00	170.422	443.668	909.921	921.06	1730.09	155	1885.09
17:00	173.310	370.244	925.34	921.06	1659.55	155	1814.55

Chapter Two

1st floor Total Load calculations

TIME	TRSH	TRLH	TRTH	RSHF
8:00	67733.71	11539	79272.71	0.85
9:00	66750.09	11539	78289.09	0.85
10:00	65018.93	11539	76557.93	0.85
11:00	63400.21	11539	74939.21	0.85
12:00	63290.67	11539	74829.67	0.85
1:00	65696.75	11539	77235.75	0.85
2:00	68118.34	11539	79657.34	0.86
3:00	69631.51	11539	81170.51	0.86
4:00	69844.4	11539	81383.4	0.86
5:00	68681.64	11539	80220.64	0.86

TIME	Qvent_s	Qvent_l	Qvent_T
8:00	27247.43	76306.5	103553.9
9:00	34878.9	76306.5	111185.4
10:00	43790.5	76306.5	120097
11:00	53342.15	76306.5	129648.7
12:00	62893.8	76306.5	139200.3
1:00	71805.4	76306.5	148111.9
2:00	79436.87	76306.5	155743.4
3:00	85345.11	76306.5	161651.6
4:00	88791.58	76306.5	165098.1
5:00	90268.64	76306.5	166575.2

TIME	GRSH	GRLH	GRTH	GRSHF
8:00	94981.14	87845.5	182826.6	0.52
9:00	101629	87845.5	189474.5	0.54
10:00	108809.4	87845.5	196654.9	0.55
11:00	116742.4	87845.5	204587.9	0.57
12:00	126184.5	87845.5	214030	0.59
1:00	137502.1	87845.5	225347.7	0.61
2:00	147555.2	87845.5	235400.7	0.63
3:00	154976.6	87845.5	242822.1	0.64
4:00	158636	87845.5	246481.5	0.64
5:00	158950.3	87845.5	246795.8	0.64

The max load occurs at 5:00 PM and its value equals:

TIME	TRSH (W)	TRLH (W)	TRTH (W)	RSHF
5:00	68681.64	11539	80220.64	0.86

TIME	Qvent_s (W)	Qvent_I (W)	Qvent_T (W)
2:00	90268.64	76306.5	166575.2

TIME	ERSH (W)	ERLH (W)	ERTH(W)	ERSHF
2:00	94859.5	33667.9	128527.4	0.74

TIME	GRSH(W)	GRLH(W)	GRTH(W)	GRSHF
2:00	158950.3	87845.5	246795.8	0.64

Time	GTH (KW)	GTH (HP)	GTH (TR)
2:00	246.80	330.71	70.51

2nd floor calculation

Corridor 2-10

Variation of load with Time

Qocc-s	Qocc-l	Ql-s	Qeq-s	Qeq-l
942.00	521.00	2096.00	0.00	0.00

Time	Qw-s	Qsun-s	Qvent-s	Qvent-l	Qs tot	Ql tot
08:00	119.63	1923.39	2305.92	6773.41	5081.02	521
09:00	155.29	1923.39	2993.26	6773.41	5116.68	521
10:00	196.93	1557.67	3795.89	6773.41	4792.61	521
11:00	241.57	941.38	4656.18	6773.41	4220.94	521
12:00	285.28	365.71	5516.46	6773.41	3688.99	521
13:00	327.84	297.99	6319.10	6773.41	3663.83	521
14:00	363.50	297.99	7006.44	6773.41	3699.49	521
15:00	391.11	297.99	7538.57	6773.41	3727.10	521
16:00	408.13	257.35	7848.98	6773.41	3703.49	521
17:00	414.11	216.72	7982.02	6773.41	3668.83	521

Corridor 2-12

Variation of load with Time

Qocc-s	Qocc-l	Ql-s	Qeq-s	Qeq-l
144	120	1316	0	0

Time	Qw-s	Qsun-s	Qvent-s	Qvent-l	Qs tot	Ql tot (W)
08:00	171.10	2804.33	453.62	1332.46	4435.43	120
09:00	222.09	2086.15	588.83	1332.46	3768.24	120
10:00	281.65	1183.29	746.73	1332.46	2924.94	120
11:00	345.48	410.39	915.96	1332.46	2215.87	120
12:00	409.31	300.95	1085.20	1332.46	2170.26	120
13:00	468.87	300.95	1243.09	1332.46	2229.82	120
14:00	519.87	300.95	1378.30	1332.46	2280.82	120
15:00	559.35	300.95	1482.99	1332.46	2320.30	120
16:00	583.70	259.91	1544.05	1332.46	2303.61	120
17:00	592.25	218.87	1570.22	1332.46	2271.13	120

Room 2-13

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
66	31	300	0	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
08:00	0	0	260.31	764.63	366	31	397
09:00	0	0	337.90	764.63	366	31	397
10:00	0	0	428.51	764.63	366	31	397
11:00	0	0	525.62	764.63	366	31	397
12:00	0	0	622.74	764.63	366	31	397
13:00	0	0	713.34	764.63	366	31	397
14:00	0	0	790.93	764.63	366	31	397
15:00	0	0	851.01	764.63	366	31	397
16:00	0	0	886.05	764.63	366	31	397
17:00	0	0	901.06	764.63	366	31	397

Room 2-15

Variation of loads with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
66	31	300	0	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
08:00	0	0	260.31	764.63	366	31	397
09:00	0	0	337.90	764.63	366	31	397
10:00	0	0	428.51	764.63	366	31	397
11:00	0	0	525.62	764.63	366	31	397
12:00	0	0	622.74	764.63	366	31	397
13:00	0	0	713.34	764.63	366	31	397
14:00	0	0	790.93	764.63	366	31	397
15:00	0	0	851.01	764.63	366	31	397
16:00	0	0	886.05	764.63	366	31	397
17:00	0	0	901.06	764.63	366	31	397

Chapter Two

Room 2-18

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
144	120	200	0	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
08:00	0	0	178.2144	523.488	344	120	464
09:00	0	0	231.336	523.488	344	120	464
10:00	0	0	293.36832	523.488	344	120	464
11:00	0	0	359.856	523.488	344	120	464
12:00	0	0	426.34368	523.488	344	120	464
13:00	0	0	488.376	523.488	344	120	464
14:00	0	0	541.4976	523.488	344	120	464
15:00	0	0	582.624	523.488	344	120	464
16:00	0	0	606.6144	523.488	344	120	464
17:00	0	0	616.896	523.488	344	120	464

Room 2-20

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
144	120	300	0	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
08:00	0	0	223.74	657.21	444	120	564
09:00	0	0	290.43	657.21	444	120	564
10:00	0	0	368.31	657.21	444	120	564
11:00	0	0	451.78	657.21	444	120	564
12:00	0	0	535.25	657.21	444	120	564
13:00	0	0	613.13	657.21	444	120	564
14:00	0	0	679.82	657.21	444	120	564
15:00	0	0	731.45	657.21	444	120	564
16:00	0	0	761.57	657.21	444	120	564
17:00	0	0	774.48	657.21	444	120	564

Room 2-41

Variation of load with time

Qocc_I	Qlight_s	Qequip_s	Qequip_I
60	200	0	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	Qocc_s	QTOT_S	QTOT_I	QTOT
08:00	62.86	299.39	38.59	113.35	72.00	634.25	60.00	694.25
09:00	81.60	223.68	50.09	113.35	72.00	577.27	60.00	637.27
10:00	103.48	128.04	63.52	113.35	72.00	503.52	60.00	563.52
11:00	126.93	46.17	77.92	113.35	72.00	445.09	60.00	505.09
12:00	150.38	34.57	92.32	113.35	72.00	456.95	60.00	516.95
13:00	172.26	35.55	105.75	113.35	72.00	479.81	60.00	539.81
14:00	191.00	42.47	117.25	113.35	72.00	505.47	60.00	565.47
15:00	205.50	50.86	126.15	113.35	72.00	528.36	60.00	588.36
16:00	214.45	52.63	131.35	113.35	72.00	539.08	60.00	599.08
17:00	217.59	50.00	133.58	113.35	72.00	539.59	60.00	599.59

Room 2-42

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
72	60	200	0	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
08:00	0	0	76.377	224.352	272	60	332
09:00	0	0	99.144	224.352	272	60	332
10:00	0	0	125.729	224.352	272	60	332
11:00	0	0	154.224	224.352	272	60	332
12:00	0	0	182.718	224.352	272	60	332
13:00	0	0	209.304	224.352	272	60	332
14:00	0	0	232.070	224.352	272	60	332
15:00	0	0	249.696	224.352	272	60	332
16:00	0	0	259.977	224.352	272	60	332
17:00	0	0	264.384	224.352	272	60	332

Chapter Two

Room 2-43

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
216.00	180.00	800.00	0.00	0.00

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
8:00	0.00	0.00	304.80	895.31	1016.00	180.00	1196.00
9:00	0.00	0.00	395.65	895.31	1016.00	180.00	1196.00
10:00	0.00	0.00	501.74	895.31	1016.00	180.00	1196.00
11:00	0.00	0.00	615.45	895.31	1016.00	180.00	1196.00
12:00	0.00	0.00	729.17	895.31	1016.00	180.00	1196.00
13:00	0.00	0.00	835.26	895.31	1016.00	180.00	1196.00
14:00	0.00	0.00	926.11	895.31	1016.00	180.00	1196.00
15:00	0.00	0.00	996.45	895.31	1016.00	180.00	1196.00
16:00	0.00	0.00	1037.48	895.31	1016.00	180.00	1196.00
17:00	0.00	0.00	1055.06	895.31	1016.00	180.00	1196.00

Room 2-45

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
72.00	60.00	200.00	0.00	0.00

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
8:00	0.00	0.00	76.38	224.35	272.00	60.00	332.00
9:00	0.00	0.00	99.14	224.35	272.00	60.00	332.00
10:00	0.00	0.00	125.73	224.35	272.00	60.00	332.00
11:00	0.00	0.00	154.22	224.35	272.00	60.00	332.00
12:00	0.00	0.00	182.72	224.35	272.00	60.00	332.00
13:00	0.00	0.00	209.30	224.35	272.00	60.00	332.00
14:00	0.00	0.00	232.07	224.35	272.00	60.00	332.00
15:00	0.00	0.00	249.70	224.35	272.00	60.00	332.00
16:00	0.00	0.00	259.98	224.35	272.00	60.00	332.00
17:00	0.00	0.00	264.38	224.35	272.00	60.00	332.00

Room 2-46**Variation of load with time**

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
288.00	240.00	200.00	0.00	0.00

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
8:00	0.00	0.00	356.43	1046.98	488.00	240.00	728.00
9:00	0.00	0.00	462.67	1046.98	488.00	240.00	728.00
10:00	0.00	0.00	586.74	1046.98	488.00	240.00	728.00
11:00	0.00	0.00	719.71	1046.98	488.00	240.00	728.00
12:00	0.00	0.00	852.69	1046.98	488.00	240.00	728.00
13:00	0.00	0.00	976.75	1046.98	488.00	240.00	728.00
14:00	0.00	0.00	1083.00	1046.98	488.00	240.00	728.00
15:00	0.00	0.00	1165.25	1046.98	488.00	240.00	728.00
16:00	0.00	0.00	1213.23	1046.98	488.00	240.00	728.00
17:00	0.00	0.00	1233.79	1046.98	488.00	240.00	728.00

Room 2-47**Variation of load with time**

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
360.00	300.00	300.00	0.00	0.00

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
0.33	0.00	0.00	445.54	1308.72	660.00	300.00	960.00
0.38	0.00	0.00	578.34	1308.72	660.00	300.00	960.00
0.42	0.00	0.00	733.42	1308.72	660.00	300.00	960.00
0.46	0.00	0.00	899.64	1308.72	660.00	300.00	960.00
0.50	0.00	0.00	1065.86	1308.72	660.00	300.00	960.00
0.54	0.00	0.00	1220.94	1308.72	660.00	300.00	960.00
0.58	0.00	0.00	1353.74	1308.72	660.00	300.00	960.00
0.63	0.00	0.00	1456.56	1308.72	660.00	300.00	960.00
0.67	0.00	0.00	1516.54	1308.72	660.00	300.00	960.00
0.71	0.00	0.00	1542.24	1308.72	660.00	300.00	960.00

Chapter Two

Room 2-48

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
198	93	300	0	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
08:00	23.08	74.18	253.52	744.70	595.25	93.00	688.25
09:00	29.96	55.18	329.09	744.70	583.14	93.00	676.14
10:00	37.99	31.30	417.34	744.70	567.29	93.00	660.29
11:00	52.00	10.85	511.92	744.70	560.85	93.00	653.85
12:00	60.25	7.96	606.50	744.70	566.21	93.00	659.21
13:00	55.59	7.96	694.75	744.70	561.55	93.00	654.55
14:00	70.12	7.96	770.32	744.70	576.08	93.00	669.08
15:00	75.45	7.96	828.82	744.70	581.41	93.00	674.41
16:00	78.73	6.87	862.95	744.70	583.61	93.00	676.61
17:00	79.88	5.79	877.57	744.70	583.67	93.00	676.67

Room 2-49

Variation of load with Time

Qocc-s	Qocc-I	Ql-s	Qeq-s	Qeq-I
6168.00	4468.00	3000.00	56000.00	0.00

Time	Qw-s	Qsun-s	Qvent-s	Qvent-I	Qs tot	Ql tot	Q tot
08:00	257	343	7841	23033	65768	4468	70236
09:00	333	397	10179	23033	65899	4468	70367
10:00	422	397	12908	23033	65988	4468	70456
11:00	518	397	23033	23033	66084	4468	70552
12:00	612	488	18759	23033	66268	4468	70736
13:00	703	1246	21489	23033	67118	4468	71586
14:00	780	2077	23826	23033	68025	4468	72493
15:00	839	2565	25635	23033	68572	4468	73040
16:00	876	2565	26691	23033	68608	4468	73076
17:00	888	2140	27143	23033	68197	4468	72665

Room 2-50

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
210	151	300	55	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
08:00	0	0	296.41	870.67	565	151	716
09:00	0	0	384.76	870.67	565	151	716
10:00	0	0	487.93	870.67	565	151	716
11:00	0	0	598.51	870.67	565	151	716
12:00	0	0	709.09	870.67	565	151	716
13:00	0	0	812.27	870.67	565	151	716
14:00	0	0	900.62	870.67	565	151	716
15:00	0	0	969.02	870.67	565	151	716
16:00	0	0	1008.92	870.67	565	151	716
17:00	0	0	1026.02	870.67	565	151	716

Room 2-51

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
210	151	300	55	0

Time	Qwall_S	Qsun_S	Qvent_S	Qvent_I	QTOT_S	QTOT_I	QTOT
08:00	0	0	315.87	927.83	565	151	716
09:00	0	0	410.02	927.83	565	151	716
10:00	0	0	519.97	927.83	565	151	716
11:00	0	0	637.81	927.83	565	151	716
12:00	0	0	755.65	927.83	565	151	716
13:00	0	0	865.60	927.83	565	151	716
14:00	0	0	959.75	927.83	565	151	716
15:00	0	0	1032.64	927.83	565	151	716
16:00	0	0	1075.16	927.83	565	151	716
17:00	0	0	1093.39	927.83	565	151	716

Chapter Two

Room 2-52

Variation of load with Time

Qocc-s	Qocc-l	Ql-s	Qeq-s	Qeq-l
420	302	300	55	0

Time	Qw-s	Qsun-s	Qvent-s	Qvent-l	Qs tot	Ql tot (W)	Q tot
08:00	31.42	49.00	534.64	1570.46	855.43	302.00	1157.43
09:00	40.79	56.74	694.01	1570.46	872.53	302.00	1174.53
10:00	51.72	56.74	880.10	1570.46	883.47	302.00	1185.47
11:00	63.45	56.74	1079.57	1570.46	895.19	302.00	1197.19
12:00	74.93	69.64	1279.03	1570.46	919.56	302.00	1221.56
13:00	86.10	177.96	1465.13	1570.46	1039.07	302.00	1341.07
14:00	95.47	296.61	1624.49	1570.46	1167.08	302.00	1469.08
15:00	102.72	366.24	1747.87	1570.46	1243.97	302.00	1545.97
16:00	107.19	366.24	1819.84	1570.46	1248.44	302.00	1550.44
17:00	108.76	305.63	1850.69	1570.46	1189.40	302.00	1491.40

Room 2-53

Variation of load with Time

Qocc-s	Qocc-l	Ql-s	Qeq-s	Qeq-l
354.00	271.00	400.00	55.00	0.00

Time	Qw-s	Qsun-s	Qvent-s	Qvent-l	Qs tot	Ql tot
08:00	39.07	50.87	445.54	1308.72	898.93	271
09:00	51.09	59.06	578.34	1308.72	919.15	271
10:00	64.79	59.06	733.42	1308.72	932.85	271
11:00	79.47	59.06	899.64	1308.72	947.53	271
12:00	93.85	72.48	1065.86	1308.72	975.33	271
13:00	185.23	185.23	1220.94	1308.72	1179.46	271
14:00	118.70	307.88	1353.74	1308.72	1235.58	271
15:00	127.72	380.16	1456.56	1308.72	1316.88	271
16:00	133.28	380.16	1516.54	1308.72	1322.44	271
17:00	135.23	317.25	1542.24	1308.72	1261.48	271

Room 2-54

Variation of load with Time

Qocc-s	Qocc-l	Ql-s	Qeq-s	Qeq-l
288	240	300	0	0

Time	Qw-s	Qsun-s	Qvent-s	Qvent-l	Qs tot (W)	Ql tot (W)
08:00	92.84	480.27	305.51	897.41	1161.11	240
09:00	120.51	497.07	396.58	897.41	1205.58	240
10:00	152.83	425.97	502.92	897.41	1166.80	240
11:00	244.84	306.17	616.90	897.41	1139.01	240
12:00	221.39	222.25	730.87	897.41	1031.64	240
13:00	254.42	444.22	837.22	897.41	1286.64	240
14:00	282.09	701.75	502.92	897.41	1571.84	240
15:00	303.52	852.91	998.78	897.41	1744.42	240
16:00	316.73	845.01	1039.91	897.41	1749.73	240
17:00	321.37	705.54	1057.54	897.41	1614.91	240

Room 2-45a

Variation of load with Time

Qocc-s	Qocc-l	Ql-s	Qeq-s	Qeq-l
216	180	200	2000.00	0

Time	Qw-s	Qsun-s	Qven-s	Qvent-l	Qs tot	Ql tot
08:00	36.50	54.82	336.47	988.35	2507.31	180
09:00	47.37	63.47	436.76	988.35	2526.85	180
10:00	60.08	63.47	553.88	988.35	2539.55	180
11:00	73.69	63.47	679.41	988.35	2553.17	180
12:00	87.03	77.90	804.94	988.35	2580.93	180
13:00	100.01	199.08	922.05	988.35	2715.09	180
14:00	110.89	331.80	1022.35	988.35	2858.69	180
15:00	119.31	409.70	1099.99	988.35	2945.01	180
16:00	124.51	409.70	1145.29	988.35	2950.20	180
17:00	126.33	341.89	1164.70	988.35	2884.23	180

2nd floor Total load calculation

TIME	TRSH	TRLH	TRTH	RSHF
8:00	87898.0	8640.0	96538.0	0.91
9:00	86980.5	8640.0	95620.5	0.91
10:00	85581.5	8640.0	94221.5	0.91
11:00	84444.0	8640.0	93084.0	0.91
12:00	84534.9	8640.0	93174.9	0.91
1:00	86220.6	8640.0	94860.6	0.91
2:00	87871.4	8640.0	96511.4	0.91
3:00	88933.5	8640.0	97573.5	0.91
4:00	88977.7	8640.0	97617.7	0.91
5:00	88392.1	8640.0	101221.9	0.87

TIME	Qvent_s	Qvent_l	Qvent_T
8:00	19474.5	57204.5	76679.0
9:00	25279.4	57204.5	82483.9
10:00	32058.0	57204.5	89262.6
11:00	46523.3	57204.5	103727.8
12:00	46589.0	57204.5	103793.5
1:00	53367.6	57204.5	110572.2
2:00	53178.4	57204.5	110382.9
3:00	63666.6	57204.5	120871.2
4:00	66288.2	57204.5	123492.7
5:00	65939.5	55955.2	121894.6

TIME	GRSH	GRLH	GRTH	GRSHF
8:00	107372.5	65844.5	173217.0	0.54
9:00	113177.4	65844.5	179021.9	0.55
10:00	119956.0	65844.5	185800.5	0.56
11:00	134421.3	65844.5	200265.8	0.57
12:00	134487.0	65844.5	200331.5	0.58
1:00	141265.6	65844.5	207110.1	0.60
2:00	141076.4	65844.5	206920.9	0.62
3:00	151564.6	65844.5	217409.1	0.63
4:00	154186.2	65844.5	220030.7	0.63
5:00	153837.4	64595.2	218432.6	0.63

The max load occurs at 5:00 PM and its value equals:

TIME	TRSH (W)	TRLH (W)	TRTH (W)	RSHF
5:00	88392.1	8640.0	101221.9	0.87

TIME	Qvent_s (W)	Qvent l (W)	Qvent_T (W)
5:00	65939.5	55955.2	121894.6

TIME	ERSH (W)	ERLH (W)	ERTH(W)	ERSHF
5:00	107514.6	24867.0	132381.6	0.71

TIME	GRSH(W)	GRLH(W)	GRTH(W)	GRSHF
5:00	153837.4	64595.2	218432.6	0.63

Time	GTH (KW)	GTH (HP)	GTH (TR)
5:00	218.43	292.70	62.41

3rd floor calculation

Room 3-40

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
288	360	600	110	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
08:00	73.68	1243.73	302.89	889.72	2315.41	360.00	2675.41
09:00	95.64	1243.73	393.18	889.72	2337.37	360.00	2697.37
10:00	121.28	1007.25	498.61	889.72	2126.53	360.00	2486.53
11:00	148.77	608.73	611.61	889.72	1755.50	360.00	2115.50
12:00	175.69	236.48	722.28	889.72	1410.17	360.00	1770.17
13:00	201.90	192.69	830.04	889.72	1392.59	360.00	1752.59
14:00	223.86	192.69	920.33	889.72	1414.55	360.00	1774.55
15:00	240.86	192.69	990.22	889.72	1431.55	360.00	1791.55
16:00	251.35	166.41	1033.33	889.72	1415.76	360.00	1775.76
17:00	140.14	140.14	1048.47	889.72	1278.28	360.00	1638.28

Room 3-41

Variation of loads with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
216.00	270.00	150.00	110.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
08:00	0.00	0.00	190.94	560.88	476.00	270.00	746.00
09:00	0.00	0.00	247.86	560.88	476.00	270.00	746.00
10:00	0.00	0.00	314.32	560.88	476.00	270.00	746.00
11:00	0.00	0.00	385.56	560.88	476.00	270.00	746.00
12:00	0.00	0.00	455.33	560.88	476.00	270.00	746.00
13:00	0.00	0.00	523.26	560.88	476.00	270.00	746.00
14:00	0.00	0.00	580.18	560.88	476.00	270.00	746.00
15:00	0.00	0.00	624.24	560.88	476.00	270.00	746.00
16:00	0.00	0.00	651.41	560.88	476.00	270.00	746.00
17:00	0.00	0.00	660.96	560.88	476.00	270.00	746.00

Room 3-43

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
360	300	400	330	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
08:00	24.10	502.75	318.24	934.80	1616.85	300.00	1916.85
09:00	31.28	374.00	413.10	934.80	1495.28	300.00	1795.28
10:00	39.67	212.14	523.87	934.80	1341.81	300.00	1641.81
11:00	48.66	73.57	642.60	934.80	1212.23	300.00	1512.23
12:00	57.46	53.95	758.88	934.80	1201.42	300.00	1501.42
13:00	66.04	53.95	872.10	934.80	1209.99	300.00	1509.99
14:00	73.22	53.95	966.96	934.80	1217.17	300.00	1517.17
15:00	78.78	53.95	1040.40	934.80	1222.73	300.00	1522.73
16:00	82.21	46.60	1085.69	934.80	1218.81	300.00	1518.81
17:00	83.41	39.24	1101.60	934.80	1212.65	300.00	1512.65

Room 3-44

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
360.00	300.00	400.00	330.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
08:00	37.23	557.42	318.24	934.80	1684.65	300.00	1984.65
09:00	48.33	414.66	413.10	934.80	1552.99	300.00	1852.99
10:00	61.29	235.20	523.87	934.80	1386.49	300.00	1686.49
11:00	75.18	81.57	642.60	934.80	1246.75	300.00	1546.75
12:00	88.79	59.82	758.88	934.80	1238.61	300.00	1538.61
13:00	102.03	59.82	872.10	934.80	1251.85	300.00	1551.85
14:00	113.13	59.82	966.96	934.80	1262.95	300.00	1562.95
15:00	121.72	59.82	1040.40	934.80	1271.54	300.00	1571.54
16:00	127.02	51.66	1085.69	934.80	1268.68	300.00	1568.68
17:00	43.51	43.51	1101.60	934.80	1177.01	300.00	1477.01

Chapter Two

Room 3-45

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
144	120	200	1630	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
08:00	15.71	80.52	127.3	373.92	2070.23	120	2190.23
09:00	20.39	59.90	165.2	373.92	2054.3	120	2174.29
10:00	25.86	33.97	209.5	373.92	2033.84	120	2153.84
11:00	31.72	11.78	257	373.92	2017.51	120	2137.50
12:00	37.46	8.64	303.6	373.92	2020.11	120	2140.10
13:00	43.05	8.64	348.8	373.92	2025.7	120	2145.69
14:00	47.73	8.64	386.8	373.92	2030.38	120	2150.38
15:00	51.36	8.64	416.2	373.92	2034.01	120	2154.00
16:00	53.60	7.46	434.3	373.92	2035.06	120	2155.06
17:00	54.38	6.28	440.6	373.92	2034.67	120	2154.67

Room 3-46

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
360.00	300.00	400.00	330.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
08:00	24.10	502.75	318.24	934.80	1616.85	300.00	1916.85
09:00	31.28	374.00	413.10	934.80	1495.28	300.00	1795.28
10:00	39.67	212.14	523.87	934.80	1341.81	300.00	1641.81
11:00	48.66	73.57	642.60	934.80	1212.23	300.00	1512.23
12:00	57.46	53.95	758.88	934.80	1201.42	300.00	1501.42
13:00	66.04	53.95	872.10	934.80	1209.99	300.00	1509.99
14:00	73.22	53.95	966.96	934.80	1217.17	300.00	1517.17
15:00	78.78	53.95	1040.40	934.80	1222.73	300.00	1522.73
16:00	82.21	46.60	1085.69	934.80	1218.81	300.00	1518.81
17:00	83.41	39.24	1101.60	934.80	1212.65	300.00	1512.65

Room 3-47

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
360.00	300.00	400.00	330.00	0.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
08:00	41.27	593.03	318.24	934.80	1724.31	300.00	2024.31
09:00	53.58	441.16	413.10	934.80	1584.74	300.00	1884.74
10:00	67.94	250.23	523.87	934.80	1408.17	300.00	1708.17
11:00	83.34	86.79	642.60	934.80	1260.13	300.00	1560.13
12:00	98.42	63.64	758.88	934.80	1252.07	300.00	1552.07
13:00	113.11	63.64	872.10	934.80	1266.75	300.00	1566.75
14:00	125.41	63.64	966.96	934.80	1279.05	300.00	1579.05
15:00	134.94	63.64	1040.40	934.80	1288.58	300.00	1588.58
16:00	140.81	54.96	1085.69	934.80	1285.77	300.00	1585.77
17:00	142.87	46.29	1101.60	934.80	1279.16	300.00	1579.16

Room 3-51

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
7556.00	7300.00	1136.00	3731.00	207.00

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
08:00	375.33	2727.40	5473.73	16078.56	15525.73	7507.00	23032.73
09:00	487.21	2772.39	7105.32	16078.56	15682.60	7507.00	23189.60
10:00	617.85	2772.39	9010.60	16078.56	15813.24	7507.00	23320.24
11:00	757.87	1525.36	11052.72	16078.56	14706.24	7507.00	22213.24
12:00	895.01	869.32	13052.74	16078.56	14187.34	7507.00	21694.34
13:00	1028.54	1413.19	15000.12	16078.56	14864.73	7507.00	22371.73
14:00	1140.42	2103.04	16631.71	16078.56	15666.46	7507.00	23173.46
15:00	1227.03	2507.95	17894.88	16078.56	16157.98	7507.00	23664.98
16:00	1280.45	2456.35	18673.83	16078.56	16159.79	7507.00	23666.79
17:00	1299.21	2052.32	18947.52	16078.56	15774.54	7507.00	23281.54

Chapter Two

Room 3-54

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qegu_s	Qegu_I
5780.00	2975.00	2175.00	440.00	0.00

TIME	Qwall_S	Qsun_S	Qven_S	Qvent_I	RSH	RLH	RTH
08:00	270.67	4569.19	4723.51	13874.87	13234.86	2975.00	16209.86
09:00	351.35	4569.19	6131.48	13874.87	13315.54	2975.00	16290.54
10:00	445.56	3700.40	7775.63	13874.87	12540.96	2975.00	15515.96
11:00	546.54	2236.33	9537.86	13874.87	11177.87	2975.00	14152.87
12:00	645.44	868.79	11263.76	13874.87	9909.23	2975.00	12884.23
13:00	741.74	707.90	12944.24	13874.87	9844.64	2975.00	12819.64
14:00	822.42	707.90	14352.21	13874.87	9925.32	2975.00	12900.32
15:00	884.88	707.90	15442.25	13874.87	9987.78	2975.00	12962.78
16:00	923.40	611.37	16114.44	13874.87	9929.77	2975.00	12904.77
17:00	936.93	514.84	16350.62	13874.87	9846.77	2975.00	12821.77

Corridor 3-10

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
0.00	0.00	2105.	0	0

TIME	Qwall_S	Qsun_S	Qvent_S	Qvent_I	RSH	RLH	RTH
08:00	0.00	0.00	468.14	1375.13	2105	0	2105
09:00	0.00	0.00	607.69	1375.13	2105	0	2105
10:00	0.00	0.00	770.64	1375.13	2105	0	2105
11:00	0.00	0.00	945.29	2320.42	2105	0	2105
12:00	0.00	0.00	1116.34	2491.47	2105	0	2105
13:00	0.00	0.00	1282.89	2658.02	2105	0	2105
14:00	0.00	0.00	1422.44	2797.57	2105	0	2105
15:00	0.00	0.00	1530.47	2905.60	2105	0	2105
16:00	0.00	0.00	1597.09	2972.22	2105	0	2105
17:00	0.00	0.00	1620.50	2995.63	2105	0	2105

Room 3-53

Variation of load with time

Qocc_s	Qocc_I	Qlight_s	Qequip_s	Qequip_I
522	798	400	17240	8605

TIME	Qw_s	Qsun_s	Qvent_s	Qvent_I	RSH	RLH	RTH
08:00	0	0	235.008	664.101	18162	9403	27565
09:00	0	0	348.84	664.101	18162	9403	27565
10:00	0	0	481.7664	664.101	18162	9403	27565
11:00	0	0	624.24	664.101	18162	9403	27565
12:00	0	0	763.776	664.101	18162	9403	27565
01:00	0	0	899.64	664.101	18162	9403	27565
02:00	0	0	1013.472	664.101	18162	9403	27565
03:00	0	0	1101.6	664.101	18162	9403	27565
04:00	0	0	1155.946	664.101	18162	9403	27565
05:00	0	0	1175.04	664.101	18162	9403	27565

Total 3-53 (kitchen) load

TIME	RSH	RLH	RTH	R S H F
08:00	18162	9403	27565	0.66
09:00	18162	9403	27565	0.66
10:00	18162	9403	27565	0.66
11:00	18162	9403	27565	0.66
12:00	18162	9403	27565	0.66
13:00	18162	9403	27565	0.66
14:00	18162	9403	27565	0.66
15:00	18162	9403	27565	0.66
16:00	18162	9403	27565	0.66
17:00	18162	9403	27565	0.66

TIME	QASH	OALH	OATH
08:00	88.128	664.1016	752.2296
09:00	201.96	664.1016	866.0616
10:00	334.886	664.1016	998.988
11:00	477.36	664.1016	1141.462
12:00	616.896	664.1016	1280.998
13:00	752.76	664.1016	1416.862
14:00	866.592	664.1016	1530.694
15:00	954.72	664.1016	1618.822
16:00	1009.07	664.1016	1673.167
17:00	1028.16	664.1016	1692.262

Chapter Two

TIME	G S H	G L H	G T H	(K W)	T R	H P	GSHF
08:00	18250.13	10067.10	28317.23	28.32	8.09	37.76	0.64
09:00	18363.96	10067.10	28431.06	28.43	8.12	37.91	0.65
10:00	18496.89	10067.10	28563.99	28.56	8.16	38.09	0.65
11:00	18639.36	10067.10	28706.46	28.71	8.20	38.28	0.65
12:00	18778.90	10067.10	28846.00	28.85	8.24	38.46	0.65
13:00	18914.76	10067.10	28981.86	28.98	8.28	38.64	0.65
14:00	19028.59	10067.10	29095.69	29.10	8.31	38.79	0.65
15:00	19116.72	10067.10	29183.82	29.18	8.34	38.91	0.66
16:00	19171.07	10067.10	29238.17	29.24	8.35	38.98	0.66
17:00	19190.16	10067.10	29257.26	29.26	8.36	39.01	0.66

3rd floor Total load calculation

TIME	TRSH	TRLH	TRTH	RSHF
8:00	60531.89	21835.00	82366.89	0.73
9:00	60261.09	21835.00	82096.09	0.73
10:00	58735.85	21835.00	80570.85	0.73
11:00	55331.46	21835.00	77166.46	0.72
12:00	53163.36	21835.00	74998.36	0.71
1:00	53809.24	21835.00	75644.24	0.71
2:00	54756.06	21835.00	76591.06	0.71
3:00	55359.92	21835.00	77194.92	0.72
4:00	55275.46	21835.00	77110.46	0.72
5:00	54558.73	21835.00	76393.73	0.71

TIME	Qvent_s	Qvent_l	Qvent_T
8:00	12794.4828	37556.3749	50350.8577
9:00	16652.0044	37556.3749	54208.3793
10:00	21156.5942	37556.3749	58712.9691
11:00	25984.718	38501.6652	64486.3832
12:00	30713.2929	38672.7177	69386.0106
1:00	35317.4316	38839.2689	74156.7004
2:00	39174.9532	38978.8117	78153.7649
3:00	42161.4215	39086.8449	81248.2664
4:00	44003.077	39153.4654	83156.5424
5:00	44650.1451	39176.8726	83827.0177

TIME	GRSH	GRLH	GRTH	GRSHF
8:00	73326.37	59391.37	132717.74	0.55
9:00	76913.09	59391.37	136304.47	0.56
10:00	79892.44	59391.37	139283.82	0.57
11:00	81316.17	60336.66	141652.84	0.57
12:00	83876.64	60507.71	144384.36	0.58
1:00	89126.67	60674.26	149800.94	0.59
2:00	93931.01	60813.81	154744.82	0.60
3:00	97521.33	60921.84	158443.18	0.61
4:00	99278.53	60988.46	160267	0.61
5:00	99208.87	61011.87	160220.748	0.61

The max load occurs at 4:00 PM and its value equals:

TIME	TRSH (W)	TRLH (W)	TRTH (W)	RSHF
4:00	55275.46	21835	77110.46	0.72

TIME	Qvent_s (W)	Qvent_l (W)	Qvent_T (W)
4:00	44003.07	39153.46	83156.54


TIME	ERSH (W)	ERLH (W)	ERTH(W)	ERSHF
4:00	40074.37	47623.7369	87698.1069	0.690703

TIME	GRSH(W)	GRLH(W)	GRTH(W)	GRSHF
4:00	99278.53	60988.46	160267	0.61

Time	GTH (KW)	GTH (HP)	GTH (TR)
4:00	160.267	45.790	229.342

Chapter Three

Psychrometry



Chapter Three

Introduction

This chapter describes practical psychrometries as applied to apparatus selection. It is divided into three parts:

1. Description of terms, processes and factors – as encountered in normal air conditioning applications.
2. Air conditioning apparatus - factors affecting common processes and the effect of these factors on selection of air conditioning equipment.
3. Psychrometries of partial load control – the effect of partial load on equipment selection and on the common processes. To help recognize terms, factors and processes described in this chapter, a brief definition of psychrometries is offered at this point, along with an illustration and definition of terms appearing on a standard psychrometric chart (Fig. 3.1).




Fig 3.1 Skeleton psychrometric chart

Psychrometric terms:

Dry-bulb Temperature:

The temperature of air as registered by an ordinary thermometer.

Wet-bulb Temperature:

The temperature registered by a thermometer whose bulb is covered by a wetted wick and exposed to a current of rapidly moving air.

Dewpoint Temperature:

The temperature at which condensation of moisture begins when the air is cooled.

Relative Humidity:

Ratio of the actual water vapor pressure of the air to the saturated water vapor pressure of the air at the same temperature.

Specific Humidity or Moisture Content:

The weight of water vapor in grains or pounds of moisture per pound of dry air.

Enthalpy:

A thermal property indicating the quantity of heat in the air above an arbitrary datum, in Btu per pound of dry air. The datum for dry air is 0°F and, for the moisture content, 32 F water.

Specific Volume:

The cubic feet of the mixture per pound of dry air.

Sensible Heat Factor:

The ratio of sensible to total heat. Alignment Circle-Located at 24 C db and 50% RH and used in conjunction with the sensible heat factor to plot the various air conditioning process lines.

Hint:

The dry-bulb, Wet-bulb, and dew point temperatures and the relative humidity are so related that if two properties are known. All other properties shown may then be determined. When air is saturated, dry-bulb, wet-bulb and dew point temperatures are all equal.

Definition

Psychometrics is the science involving thermodynamic properties of moist air and the effect of atmospheric moisture on materials and human comfort. The chart is normally constructed for standard atmospheric pressure of 760mm.Hg or 1.01325 bar .corresponding to the pressure at the mean sea level.




Fig. 3.2 Typical air conditioning process tracked on a standard psychrometric chart

Chapter Three

Air conditioning processes

Fig. 3.2 shows a typical air conditioning process traced on a psychrometric chart. Outdoor air (2) is mixed with return air from the room (1) and enters the apparatus (3). Air flows through the conditioning apparatus (3 - 4) and is supplied to the space (4). The air supplied to the space moves along line (4 - 1) as it picks up the room loads, and the cycle is repeated. Normally most of the air supplied to the space by the air conditioning system is returned to the conditioning apparatus. There, it is mixed with outdoor air required for ventilation. The mixture then passes through the apparatus where heat and moisture are added or removed, as required, to maintain the desired conditions. The selection of proper equipment to accomplish this conditioning and to control the thermodynamic properties of the air depends upon a variety of elements. However, only those which affect the psychrometric properties of air will be discussed in this chapter. These elements are: room sensible heat factor (RSHF), grand sensible heat factor (GSHF), effective surface temperature (t_{es}) bypass factor (BF), and effective sensible heat factor (ESHF).

Description of terms, processes and factors

Sensible heat factor

The thermal properties of air can be separated into latent and sensible heat. The term sensible heat factor is the ratio of sensible to total heat, where total heat is the sum of sensible and latent heat. This ratio may be expressed as:

$$SHF = \frac{SH}{SH + LH} = \frac{SH}{TH} \quad \text{Eqn (3.1)}$$

Where:

- SHF = sensible heat factor
- SH = sensible heat
- LH = latent heat
- TH = total heat

Room sensible heat factor (RSHF):

The room sensible heat factor is the ratio of room sensible heat to the summation of room sensible and room latent heat. This ratio is expressed in the following formula:

$$RSHF = \frac{RSH}{RSH + RLH} = \frac{RSH}{RTH} \quad \text{Eqn (3.2)}$$

The supply air to a conditioned space must have the capacity to offset simultaneously both the room sensible and room latent heat loads.

Grand Sensible heat Factor (GSHF):

The grand sensible heat factor is the ratio of the total sensible heat to the grand total heat load that the conditioning apparatus must handle, including the outdoor air heat loads. This ratio is determined from the following equation:

$$GSHF = \frac{TSH}{TSH + TLH} = \frac{TSH}{GTH} \quad \text{Eqn (3.3)}$$

$$TSH = RSH + OASH \quad \& \quad TLH = RLH + OALH$$

Required Air Quantity:

The air quantity required to offset simultaneously the room sensible and latent loads and the air quantity required thru the apparatus to handle the total sensible and latent loads may be calculated, using the conditions on their respective RSHF and GSHF lines. For a particular application, when both the RSHF and GSHF ratio lines are plotted on the psychrometric chart, the intersection of the two lines (1) Fig(3-3), represents the condition of the supply air to the space. It is also the condition of the air leaving the apparatus.




Fig (3.3): RSHF and GSHF Lines Plotted On Skeleton Psychrometric Chart

This neglects fan and duct heat gain, duct leakage losses, etc. In actual practice, these heat gains and losses are taken into account in estimating the cooling load. The temperature of the air leaving the apparatus is not necessarily equal to the temperature of the air supplied to the space as indicated in Fig (3-3).

Fig (3-4) illustrates what actually happens when these supplementary loads are considered plotting the RSHF and GSHF lines. Point (1) is the condition of air leaving the apparatus and point (2) is the condition of supply air to the space. Line (1 -2) represents the temperature rise of the air stream resulting from fan horsepower and heat gain to the duct.




Fig (3.4): RSHF and GSHF Lines Plotted With Supplementary Load Line

Chapter Three

The air quantity required to satisfy the room load may be calculated from the following equation:

$$CMM_{sa} = \frac{RSH}{0.0204 (t_R - t_{sa})} \quad \text{Eqn (3.4)}$$

The air quantity required thru the conditioning apparatus to satisfy the total air conditioning load (including the supplementary loads) is calculated from the following equation:

$$CMM_{da} = \frac{TSH}{0.0204 (t_m - t_{ldb})} \quad \text{Eqn (3.5)}$$

The required air quantity supplied to the spaces equal to the air quantity required thru the apparatus, neglecting leakage losses. The above equation contains the term t_m which is the mixture condition of air entering the apparatus. With the exception of an all outdoor air application, the term t_m can only be determined by trial and error.

In a normal, well designed, tight system the difference in supply air temperature and the condition of the air leaving the apparatus ($t_{sa} - t_{db}$) is usually not more than a few degrees. To simplify the discussion on the interrelationship of RSHF and GSHF, the supplementary loads have been neglected in the various discussions, formulas and problems in the remainder of this chapter.

The RSHF ratio will be constant (at full load) under a specified set of conditions; however, the GSHF ratio may increase or decrease as the outdoor air quantity and mixture conditions are varied for design purposes. As the GSHF ratio changes, the supply air condition to the space varies along the RSHF line (Fig. (3-3)).

The difference in temperature between the room and the air supply to the room determines the air quantity required to satisfy the room sensible and room latent loads. As this temperature difference increases (supplying colder air, since the room conditions are fixed), the required air quantity to the space decreases.

Effective Surface Temperature (t_{es}) or (ADP):

The surface temperature of the conditioning equipment varies throughout the surface of the apparatus as the air comes in contact with it. However, the effective surface temperature can be considered to be the uniform surface temperature which would produce the same leaving air conditions as the no uniform surface temperature that actually occurs when the apparatus is in operation. This is more clearly understood by illustrating the heat transfer effect between the air and the cooling (or heating) medium. Fig. (3.5) illustrates this process and is applicable to a chilled water cooling medium with the supply air counter flow in relation to the chilled water.




Fig (3.5): Relationship of Effective Surface Temp to Supply Air and Chilled Water

For applications involving cooling and dehumidification, the effective surface temperature is at the point where the GSHF line crosses the saturation line on the psychrometric chart (Fig.(3.3)). As such, this effective surface temperature is considered to be the dew point of the apparatus, and hence the term apparatus dew point (ADP) has come into common usage for cooling and dehumidifying processes. The psychrometric of air can be applied equally well to other types of heat transfer applications such as sensible heating, evaporative cooling, sensible cooling, etc., but for these applications the effective surface temperature will not necessarily fall on the saturation line.

By Pass Factor (BF)

Bypass factor is a function of the physical and operating characteristics of the conditioning apparatus and, as such, represents that portion of the air which is considered to pass through the conditioning apparatus completely unaltered.


There is a psychrometric relationship of bypass factor to GSHF and RSHF. Under specified room outdoor design conditions and quantity of outdoor air, RSHF and GSHF are fixed. The position of RSHF is also fixed, but the relative position of GSHF may vary as the supply air quantity and supply air condition change. To properly maintain room design conditions, the air must be supplied to the space at some point along the RSHF line. Therefore, as the bypass factor varies the relative position of GSHF to RSHF changes, as shown by the dotted lines in Fig. (3.6). As the position of GSHF changes, the entering and leaving air conditions at the apparatus, the required air quantity, bypass factor and the apparatus dew point also change. The effect of varying the bypass factor on the conditioning equipment is as follows:

1. Smaller bypass factor

- a. higher ADP - DX equipment selected for higher refrigerant temperature and chilled water equipment would be selected for less or higher temperature chilled water. Possibly smaller refrigeration machine.
- b. Less air - smaller fan and fan motor.
- c. More heat transfer surface - more rows of coil or more coil surface available.
- d. Smaller piping if less chilled water is used.

2. Larger bypass factor

- a. Lower ADP - Lower refrigerant temperature to select DX equipment, and more water or lower temperature for chilled water equipment. Possibly Larger Refrigeration Machine.
- b. More air -larger fan and fan motor.
- c. Less heat transfer surface - less rows of coiler less coil surface available.
- d. Larger piping if more chilled water is used.



Chapter Three

Fig (3.6): RSHF and GSHF Lines Plotted On Skeleton Psychrometric Chart

It is, therefore, an economic balance of first cost and operating cost in selecting the proper bypass factor for a particular application. Table (3.2), its suggested bypass factors for various applications and is a guide for the engineer to proper bypass factor selection for use in load calculations.

Tables have also been prepared to illustrate the various configurations of heat transfer surfaces and the resulting bypass factor for different air velocities.

Table (3.1), lists bypass factors for various coil surfaces. Spray washer equipment is normally rated in terms of saturation efficiency which is the complement of bypass factor (1 - BF). Table (3.3), is a guide to representative saturation efficiencies for various spray arrangements.

As previously indicated the entering and leaving air conditions at the conditioning apparatus and the apparatus dew point are related psychrometrically to the bypass factor. Although it is recognized that bypass factor is not a true straight line function, it can be accurately evaluated mathematically from the following equations:

$$BF = \frac{t_{ldb} - t_{adp}}{t_{edb} - t_{adp}} = \frac{h_{la} - h_{adp}}{h_{ea} - h_{adp}} = \frac{W_{la} - W_{adp}}{W_{ea} - W_{adp}} \quad \text{Eqn (3.6)}$$

And

$$1 - BF = \frac{t_{edb} - t_{ldb}}{t_{edb} - t_{adp}} = \frac{h_{ea} - h_{la}}{h_{ea} - h_{adp}} = \frac{W_{ea} - W_{la}}{W_{ea} - W_{adp}} \quad \text{Eqn (3.7)}$$

NOTE: The quantity (1-BF) is frequently called contact factor and is considered to be that portion of the air leaving the apparatus at the ADP.

TABLE (3.1) - TYPICAL BYPASS FACTORS

(For Finned Coils)

DEPTH OF COILS	WITHOUT SPRAYS		WITH SPRAYS	
	8 fins/in.	14 fins/in.	8 fins/in.	14 fins/in.
	Velocity (fpm)			
	(rows)	300 - 700	300 - 700	300 - 600
2		.42 - .55	.22 - .38	
3		.27 - .40	.10 - .23	
4		.15 - .28	.05 - .14	.12 - .22
5		.10 - .22	.03 - .09	.08 - .16
6		.06 - .15	.01 - .05	.05 - .11
8		.02 - .08	.00 - .02	.02 - .06

TABLE (3.2) —TYPICAL BYPASS FACTORS
(For Various Applications)

COIL BYPASS FACTOR	TYPE OF APPLICATION	EXAMPLE
0.30 to 0.50	A <i>small</i> total load or a load that is somewhat larger with a low sensible heat factor (high latent load).	Residence
0.20 to 0.30	Typical comfort application with a <i>relatively small</i> total load or a low sensible heat factor with a somewhat larger load.	Residence, Small Retail Shop, Factory
0.10 to 0.20	Typical comfort application.	Dept. Store, Bank, Factory
0.05 to 0.10	Applications with high internal sensible loads or requiring a large amount of outdoor air for ventilation.	Dept. Store, Restaurant, Factory
0 to 0.10	All outdoor air applications.	Hospital Operating Room, Factory

TABLE (3.3) —TYPICAL SATURATION EFFICIENCY*
For Spray Chambers

NO. OF BANKS	DIREC- TION OF WATER SPRAY	1/4" NOZZLE (25 psig Nozzle Pressure 3 gpm/sq ft†)		1/8" NOZZLE (30 psig Nozzle Pressure 2.5 gpm/sq ft†)	
		Velocity‡ (fpm)			
		300	700	300	700
1	Parallel Counter	70%	50%	80%	60%
		75%	65%	82%	70%
2	Parallel Opposing Counter	90%	85%	92%	87%
		98%	92%	98%	93%
		99%	93%	99%	94%

Effective Sensible Heat Factor (ESHF)

To relate bypass factor and apparatus dew point to the load calculation, the effective sensible heat factor term was developed. ESHF is interwoven with BF and ADP, and thus greatly simplifies the calculation of air quantity and apparatus selection. The effective sensible heat factor is the ratio of effective room sensible heat to the effective room sensible and latent heats. Effective room sensible heat is composed of room sensible heat (plus that portion of the outdoor air sensible load which is considered as being bypassed, unaltered, thru the conditioning apparatus. The effective room latent heat is composed of the room

Chapter Three

latent heat plus that portion of the outdoor air latent heat load which is considered as being by-passed, unaltered, thru the conditioning apparatus. This ratio is expressed in the following formula:

$$ESHF = \frac{ERSH}{ERSH + ERLH} = \frac{ERSH}{ERTH} \quad \text{Eqn (3.8)}$$

Drawing a straight line between the ADP and room design conditions (1 -2), Fig. (3.7) represents the ESHF ratio. The interrelationship of RSHF and GSHF to BF, ADP and ESHF is graphically illustrated in Fig. (3.7).

Air Quantity Using ESHF, ADP and BPF

A simplified approach for determining the required air quantity is to use the psychrometric correlation of effective sensible heat factor, apparatus dew point and bypass factor. Previously in this chapter, the interrelationship of ESHF, BPF and ADP was shown with GSHF and RSHF. These two factors need not be calculated to determine the required air quantity, since the use of ESHF, BPF and ADP results in the same air quantity. The formula for calculating air quantity, using BPF and t_{adp} is:

$$CMMda = \frac{ERSH}{0.0204 (t_{rm} - t_{adp}) (1 - BF)} \quad \text{Eqn (3.5)}$$

(ESHF is used to determine t_{adp})

This air quantity simultaneously offsets the room sensible and room latent loads, and also handles the total sensible and latent loads for which the conditioning apparatus is designed, including the outdoor air loads and the supplementary loads.




Fig (3.7): RSHF and GSHF Lines Plotted On Skeleton Psychrometric Chart

Air Conditioning Apparatus

The following section describes the characteristic psychrometric performance of air conditioning equipment.

Coils, sprays and sorbent dehumidifiers are the three basic types of heat transfer equipment required for air conditioning applications. These components may be used singly or in combination to control the psychrometric properties of the air passing thru them.

The selection of this equipment is normally determined by the requirements of the specific application. The components must be selected and integrated to result in a practical system; that does, one having the most economical own and operating cost.

An economical system requires the optimum combination of air conditioning components. It also requires an air distribution system that provides good air distribution within the conditioned space, using a practical rise between supply air and room air temperatures.

Since the only known items are the load in the space and the conditions to be maintained within the space, the selection of the various components is based on these items. Normally, performance requirements are established and then equipment is selected to meet the requirements.

Psychrometrics of partial load control

The apparatus required to maintain proper space conditions is normally selected for peak load operation. Actually, peak load occurs but a few times each year and operation is predominantly at partial load conditions. Partial load may be caused by a reduction in sensible or latent loads in the space, or in the outdoor air load. It may also be caused by a reduction in these loads in any combination.

Partial load analysis

Since the system operates at partial load most of the time and must maintain conditions commensurate with job requirements, partial load analysis is at least as important as the selection of equipment. Partial load analysis should include a study of resultant room conditions at minimum total load. Usually this will be sufficient. Certain applications, however, should be evaluated at minimum latent load with design sensible load, or minimum sensible load and full latent load. Realistic minimum and maximum loads should be assumed for the particular application so that, psychrometrically; the resulting room conditions are properly analyzed. The six most common methods, used singly or in combination, of controlling space conditions for cooling applications at partial load are the following:

1. Reheat the supply air.
2. Bypass the heat transfer equipment.
3. Control the volume of the supply air.
4. Use on-off control of the air handling equipment.
5. Use on-off control of the refrigeration machine.
6. Control the refrigeration capacity.

The type of control selected for a specific application depends on the nature of the loads, the conditions to be maintained within the space, and available plant facilities.

1. Reheat control

Reheat control maintains the dry-bulb temperature within the space by replacing any decrease in the sensible loads by an artificial load. As the internal latent load and/or the outdoor latent load decreases, the space relative humidity decreases. If humidity is to be maintained, dehumidifying is required in addition to reheat.

Figure (3.8) illustrates the psychrometrics of reheat control. The solid lines represent the process at design load, and the broken lines indicate the resulting process at partial load. The RSHF value, plotted from room design conditions to point (2), must be calculated for the minimum practical room sensible load. The room thermostat then controls the temperature of the air leaving the reheat coil along line (1 -2). This type of control is applicable for any RSHF ratio that intersects line (1 -2). If the internal latent loads decrease, the resulting room conditions are at point (3), and the new RSHF process line is along line (2 -3). However, if humidity is to be maintained within the space, the reduced latent load is compensated by humidifying, thus returning to the design room conditions.





Fig. (3.8) Psychrometric of reheat control

2. Bypass control

Bypass control maintains the dry-bulb temperature within the space by modulating the amount of air to be cooled, thus varying the supply air temperature to the space. Fig.(3.9) illustrates one method of bypass control when bypassing return air only. Bypass control may also be accomplished by bypassing a mixture of outdoor and return air around the heat transfer equipment. This method of control is inferior to bypassing return air only since it introduces raw unconditioned air into the space, thus allowing an increase in room relative humidity. A reduction in room sensible load causes the bypass control to reduce the amount of air thru the dehumidifier. This reduced air quantity results in equipment operation at a lower apparatus dew point. Also, the air leaves the dehumidifier at a lower temperature so that there is a tendency to adjust for a decrease in sensible load that is proportionately greater than the decrease in latent load. Bypass control maintains the room dry-bulb temperature but does not prevent the relative humidity from rising above design. With bypass control, therefore, increased relative humidity occurs under conditions of decreasing room sensible load and relatively constant room latent load and outdoor air load.



Fig(3.9) Psychrometrics of bypass control with return air only

3. Volume control

Volume control of the supply air quantity provides essentially the same type of control that result from bypassing return air around the heat transfer equipment, Fig. 60. However, this type of control may produce problems in air distribution within the space and, therefore, the required air quantity at partial load should be evaluated for proper air distribution.




Fig. (3.10) schematic sketch of by pass control with bypass of return air only

4. On-off control of air handling equipment

On-off control of air handling equipment (fan-coil units) results in a fluctuating room temperature and space relative humidity. During the "off" operation the ventilation air supply is shut 'off', but chilled water continues to flow thru the coils. This method of control is not recommended for high latent load applications, as control of humidity may be lost at reduced room sensible loads

5. On-Off control of refrigeration equipment

On-off control of refrigeration equipment (large packaged equipment) results in a fluctuating room temperature and space relative humidity. During the "off" operation air is available for ventilation purposes but the coil does not provide cooling. Thus, any outdoor air in the system is introduced into the space unconditioned. Also the condensed moisture that remains on the cooling coil, when the refrigeration equipment is turned off, is re-evaporated in the warm air stream. This is known as re-evaporation. Both of these conditions increase the space latent load, and excessive humidity results. This method of control is not recommended for high latent load applications since control of humidity may be lost at decreased room sensible loads



6. Refrigeration capacity control

Refrigeration capacity control may be used on either chilled water or direct expansion refrigeration equipment. Partial load control is accomplished on chilled water equipment by bypassing the chilled water around the air side equipment (fan-coil units). Direct expansion refrigeration equipment is controlled either by unloading the compressor cylinders or by back pressure regulation in the refrigerant suction line. Refrigeration capacity controls is normally used in combination with bypass or reheat control. When used in combination, results are excellent. When used alone, results are not as effective. For example, temperature can be maintained reasonably well, but relative humidity will rise above design at partial load conditions, because the latent load may not reduce in proportion to the sensible load.

Chapter Three

Ground psychrometric calculations:

For 1st machine



$$\begin{aligned} \text{RSH} &= 30.82 \text{ kw} \\ \text{RLH} &= 7.06 \text{ kw} \\ \text{RTH} &= 37.87 \text{ kw} \\ \text{RSHF} &= 0.814 \end{aligned}$$

$$\begin{aligned} \text{OASH} &= 39.64 \text{ kw} \\ \text{OALH} &= 33.55 \text{ kw} \\ \text{OATH} &= 37.18 \text{ kw} \end{aligned}$$

$$\begin{aligned} \text{GSH} &= 70.448 \text{ kw} \\ \text{GLH} &= 40.61 \text{ kw} \\ \text{GTH} &= 111.051 \text{ kw} \\ \text{GTH} &= 31.7 \text{ TR} \\ \text{GSHF} &= 0.63 \end{aligned}$$

$$\text{CMM}_{v\text{-max}} = 108.1 \text{ m}^3/\text{min}$$

$$\begin{array}{llll} T_R &= 24 & ^\circ\text{C} & h_R = 47.9 \text{ kj/kg} \\ T_S &= 16 & ^\circ\text{C} \text{ “Assumed”} & h_S = 37.83 \text{ kj/hg} \\ T_M &= 34.47 & ^\circ\text{C} & \rho_S = 1.2 \text{ kg/m}^3 \end{array}$$

$$\begin{aligned} \text{Mixing Ratio} &= 0.58 \\ T_{\text{ADP}} &= 8.06 \text{ } ^\circ\text{C} \\ \text{BPF} &= 0.3 \end{aligned}$$

The air supplied to rooms

$$\begin{aligned} \text{RTH} &= \dot{m}_d * (h_R - h_S) \\ 37.87 &= \dot{m}_d * (48 - 37.84) \\ \dot{m}_d &= 3.73 \text{ kg/s} \\ q_d &= \dot{m}_d / \rho_S = 3.1 \text{ m}^3/\text{s} \end{aligned}$$



$$\text{CMM}_d = 3.1 * 60 = 188.1 \text{ m}^3/\text{min}$$

$$\begin{aligned} Q_{\text{coolingcoil}} &= \dot{m}_d * (h_m - h_s) \\ &= 3.73 * (67.9 - 37.84) \end{aligned}$$

$$Q_{\text{coolingcoil}} = 112.12 \text{ KW}$$

Chapter Three

For 2nd machine "All fresh air"



$$\begin{aligned} \text{RSH} &= 32.34 \text{ kw} \\ \text{RLH} &= 9.13 \text{ kw} \\ \text{RTH} &= 41.47 \text{ kw} \\ \text{RSHF} &= 0.78 \end{aligned}$$

$$\begin{aligned} \text{OASH} &= 128.16 \text{ kw} \\ \text{OALH} &= 108.67 \text{ kw} \\ \text{OATH} &= 236.83 \text{ kw} \end{aligned}$$

$$\begin{aligned} \text{GSH} &= 160.5 \text{ kw} \\ \text{GLH} &= 117.8 \text{ kw} \\ \text{GTH} &= 278.3 \text{ kw} \\ \text{GTH} &= 79.5 \text{ TR} \\ \text{GSHF} &= 0.58 \end{aligned}$$

$$\text{CMM}_{v\text{-max}} = 241.08 \text{ m}^3/\text{min}$$

$$\begin{array}{llll} T_R &= 24 & ^\circ\text{C} & h_R = 48 \text{ kj/kg} \\ T_{S1} &= 14.9 & ^\circ\text{C} & h_{S1} = 36.84 \text{ kj/hg} \\ T_{S2} &= 18.03 & ^\circ\text{C} & h_{S2} = 40.06 \text{ kj/hg} \\ T_M &= 42 & ^\circ\text{C} & \rho_{S2} = 1.2 \text{ kg/m}^3 \end{array}$$

$$\text{Mixing Ratio} = 0.00 \text{ } \underline{\text{“All fresh air”}}$$

$$T_{\text{ADP}} = 9 ^\circ\text{C}$$

$$\text{BPF} = 0.18$$

The air supplied to rooms

$$\text{RTH} = \dot{m}_d * (h_r - h_{S2})$$

$$41.47 = \dot{m}_d * (48 - 40.06)$$

$$\dot{m}_d = 5.22 \text{ kg/s}$$

$$q_d = \dot{m}_d / \rho_{S2} = 4.35 \text{ m}^3/\text{s}$$



$$\text{CMM}_d = 4.53 * 60 = 264.43 \text{ m}^3/\text{min}$$

$$\begin{aligned} Q_{\text{coolingcoil}} &= \dot{m}_d * (h_m - h_s) \\ &= 5.22 * (82.38 - 40.06) \end{aligned}$$

$$Q_{\text{coolingcoil}} = 220.91 \text{ KW}$$

Chapter Three

1st floor psychrometric calculations:



$$\begin{aligned} RSH &= 71.705 \text{ kw} \\ RLH &= 11.98 \text{ kw} \\ RTH &= 83.689 \text{ kw} \\ RSHF &= 0.857 \end{aligned}$$

$$\begin{aligned} OASH &= 99.144 \text{ kw} \\ OALH &= 84.24 \text{ kw} \\ OATH &= 183.38 \text{ kw} \end{aligned}$$

$$\begin{aligned} GSH &= 170.85 \text{ kw} \\ GLH &= 96.116 \text{ kw} \\ GTH &= 266.95 \text{ kw} \\ GTH &= 76.27 \text{ TR} \\ GSHF &= 0.64 \end{aligned}$$

$$CMM_{v-max} = 253.6 \text{ m}^3/\text{min}$$

$$\begin{array}{llll} T_R &= 24 & ^\circ\text{C} & h_R = 48 \text{ kj/kg} \\ T_S &= 16.45 & ^\circ\text{C} & \text{“Assumed” } h_S = 38.87 \text{ kj/hg} \\ T_M &= 34.85 & ^\circ\text{C} & \rho_S = 1.2 \text{ kg/m}^3 \end{array}$$

$$\begin{aligned} \text{Mixing Ratio} &= 0.59 \\ T_{ADP} &= 8.87^\circ\text{C} \\ BPF &= 0.29 \end{aligned}$$

The air supplied to rooms



$$\begin{aligned} RTH &= \dot{m}_d * (h_r - h_s) \\ 83.689 &= \dot{m}_d * (48 - 38.87) \\ \dot{m}_d &= 9.168 \text{ kg/s} \\ q_d &= \dot{m}_d / \rho_{S2} = 7.64 \text{ m}^3/\text{s} \end{aligned}$$

$$CMM_d = 7.64 * 60 = 458.345 \text{ m}^3/\text{min}$$

$$\begin{aligned} Q_{coolingcoil} &= \dot{m}_d * (h_m - h_s) \\ &= 9.168 * (68.59 - 38.87) \end{aligned}$$

$$Q_{coolingcoil} = 272.47 \text{ KW}$$

2nd Floor Psychrometric Calculations:



$$\begin{aligned} RSH &= 87.692 \text{ kw} \\ RLH &= 13.53 \text{ kw} \\ RTH &= 101.222 \text{ kw} \\ RSHF &= 0.87 \end{aligned}$$

$$\begin{aligned} OASH &= 65.94 \text{ kw} \\ OALH &= 55.955 \text{ kw} \\ OATH &= 121.89 \text{ kw} \end{aligned}$$

$$\begin{aligned} GSH &= 153.656 \text{ kw} \\ GLH &= 69.46 \text{ kw} \\ GTH &= 223.117 \text{ kw} \\ GTH &= 63.75 \text{ TR} \end{aligned}$$

$$GSHF = 0.69$$

$$CMM_{v-max} = 168.34 \text{ m}^3/\text{min}$$

$$\begin{array}{llll} T_R &= 24 & ^\circ\text{C} & \\ T_{S1} &= 16 & ^\circ\text{C} & \text{"Assumed"} \\ T_M &= 29.5 & ^\circ\text{C} & \\ h_R &= 48 & & \text{kJ/kg} \\ h_S &= 38.58 & & \text{kJ/hg} \\ \rho_S &= 1.2 & & \text{kg/m}^3 \end{array}$$

$$\begin{aligned} \text{Mixing Ratio} &= 0.31 \\ T_{ADP} &= 10.165 \text{ } ^\circ\text{C} \\ BPF &= 0.29 \end{aligned}$$

The air supplied to rooms

$$\begin{aligned} RTH &= \dot{m}_d * (h_r - h_s) \\ 101.222 &= \dot{m}_d * (48 - 38.58) \\ \dot{m}_d &= 10.86 \text{ kg/s} \\ q_d &= \dot{m}_d / \rho_{S2} = 9.05 \text{ m}^3/\text{s} \end{aligned}$$



$$CMM_d = 9.05 * 60 = 542.86 \text{ m}^3/\text{min}$$

$$\begin{aligned} Q_{coolingcoil} &= \dot{m}_d * (h_m - h_s) \\ &= 10.86 * (58.5 - 38.58) \end{aligned}$$

$$Q_{coolingcoil} = 216.33 \text{ KW}$$

Chapter Three

3rd Floor Psychrometric Calculations:



GTH = 160.267 kw
 GSH = 99.28 kw
 GLH = 60.988 kw
 GSHF = 0.619

RSH = 55.275 kw
 RLH = 21.835 kw
 RTH = 77.11 kw
 RSHF = 0.716

OASH = 44.003 kw
 OALH = 39.153 kw
 OATH = 83.156 kw

$CMM_{v-max} = 121.996 \text{ m}^3/\text{min}$

For All rooms (without room 3-53 "kitchen")

GTH = 130.882 kw
 GSH = 79.96 kw
 GLH = 50.921 kw
 GSHF = 0.61

RSH = 37.113 kw
 RLH = 12.432 kw
 RTH = 49.545 kw
 RSHF = 0.749

OASH = 42.847 kw
 OALH = 38.489 kw
 OATH = 81.336 kw

$CMM_{v-max} = 118.396 \text{ m}^3/\text{min}$

For Room (3-53)

GTH = 29.238 kw
 GSH = 19.171 kw
 GLH = 10.067 kw
 GSHF = 0.65568

RSH = 18.162 kw
 RLH = 9.403 kw
 RTH = 27.565 kw
 RSHF = 0.659

OASH = 1.009 kw
 OALH = 0.664 kw
 OATH = 1.673 kw
 $CMM_{v-max} = 3.6 \text{ m}^3/\text{min}$

Chapter Three

$T_{R1} = 24 \text{ }^{\circ}\text{C}$	$h_{R1} = 48 \text{ kJ/kg}$	“Assumed”
$T_{R2} = 26 \text{ }^{\circ}\text{C}$	$h_{R2} = 26 \text{ kJ/kg}$	
$T_{S1} = 12.6 \text{ }^{\circ}\text{C}$	$h_{S1} = 32.7 \text{ kJ/hg}$	
$T_{S2} = 15 \text{ }^{\circ}\text{C}$	$h_{S2} = 35.5 \text{ kJ/kg}$	
$T_M = 33.7 \text{ }^{\circ}\text{C}$	$\rho_{S2} = 1.2102 \text{ kg/m}^3$	

Mixing Ratio = 0.55

$T_{ADP} = 9 \text{ }^{\circ}\text{C}$

BPF = 0.145

The air supplied to rooms (without room 3-53 "kitchen")

$$\begin{aligned} RTH &= \dot{m}_d * (h_{r1} - h_{s2}) \\ 49.545 &= \dot{m}_d * (48 - 35.5) \\ \dot{m}_d &= 3.963 \text{ kg/s} \\ q_d &= \dot{m}_d / \rho_{S2} = 3.275 \text{ m}^3/\text{s} \\ CMM_D &= 3.275 * 60 = 196.511 \text{ m}^3/\text{min} \end{aligned}$$

For room (3-53 "kitchen")

$$\begin{aligned} RTH &= \dot{m}_d * (h_{r1} - h_{s2}) \\ 27.565 &= \dot{m}_d * (53 - 35.5) \\ \dot{m}_d &= 1.575 \text{ kg/s} \\ q_d &= \dot{m}_d / \rho_{S2} = 1.3 \text{ m}^3/\text{s} \\ CMM_d &= 1.3 * 60 = 78.093 \text{ m}^3/\text{min} \end{aligned}$$

$$\begin{aligned} CMM_{d-tot} &= CMM_{d-R1} + CMM_{d-R2} \\ CMM_{d-tot} &= 196.511 + 78.093 = 274.604 \text{ m}^3/\text{min} \\ CMM_{v-max} &= 121.996 \text{ m}^3/\text{min} \\ CMM_{v-max} / CMM_{d-tot} &= 121.996 / 274.604 = 0.444 \end{aligned} \quad \text{"old mixing ratio"}$$

“Assume new mixing ratio = 55%”

$$\begin{aligned} CMM_o &= 0.55 * CMM_{d-tot} \\ CMM_o &= 0.55 * 274.604 = 151.0326 \text{ m}^3/\text{min} \end{aligned}$$

For outside air

$$\begin{aligned} OASH &= .0204 * CMM_d (T_o - T_r) \\ OASH &= .0204 * 151.03 (41.47 - 24) \\ OASH &= 54.65 \text{ KW} \end{aligned}$$

$$\begin{aligned} OALH &= 50 * CMM_o * (W_o - W_r) \\ OALH &= 50 * 151.03 * (6.23 * 10^{-3}) \\ OALH &= 47.06 \text{ KW} \end{aligned}$$

$$\begin{aligned} OATH &= OASH + OALH \\ OATH &= 101.68 \text{ KW} \end{aligned}$$

$$\begin{aligned} GSH &= RSH + OASH \\ GSH &= 55.25 + 54.65 \\ GSH &= 109.91 \text{ KW} \end{aligned}$$

$$\begin{aligned} GTH &= RTH + OATH \\ GTH &= 77.11 + 101.68 \\ GTH &= 178.79 \text{ KW} \end{aligned}$$

$$GTH = 51.08 \text{ TR}$$

$$\begin{aligned} GSHF &= GSH / GTH \\ GSHF &= 0.61 \end{aligned}$$

$$\begin{aligned} \text{Reheat} &= m_{td} * (h_{s2} - h_{s1}) \\ \text{Reheat} &= 3.96 * (35.5 - 32.7) \\ \text{Reheat} &= 11.1 \text{ Kw} \end{aligned}$$

$$\begin{aligned} ERSR &= RSH + BPF * OASH \\ ERSR &= 55.27 + 0.145 * 39.15 \\ ERSR &= 61.69 \text{ KW} \end{aligned}$$

$$\begin{aligned} ERLH &= RLH + BPF * OALH \\ ERLH &= 21.83 + 0.145 * 39.15 \\ ERLH &= 27.54 \text{ KW} \end{aligned}$$

$$\begin{aligned} ERSHF &= (RSH + \text{Reheat}) / (RSH + RLH + \text{Reheat}) \\ ERSHF &= 0.725 \end{aligned}$$

$$\begin{aligned} Q_{\text{coolingcoil}} &= m_d * (h_m - h_{s1}) \\ &= 5.538 * (66.69 - 32.7) \end{aligned}$$

$$Q_{\text{coolingcoil}} = 188.24 \text{ KW}$$

Chapter Four

Air Distribution



Chapter Four

4.1 Introduction

The object of good air distribution in HVAC systems is to create the proper combination of temperature, humidity and air motion, in the occupied zone of the conditioned room from the floor to 2m above floor level. To obtain comfort conditions within this zone, standard limits have been established as acceptable *effective draft temperature*. This term includes air temperature, air motion, relative humidity, and their physiological effects on the human body. Any variation from accepted standards of one of these elements causes discomfort to occupants. Lack of uniform conditions within the space or excessive fluctuation of conditions in the same part of the space may produce similar effects.

4.2 Air Diffusion Performance Index (ADPI):

ADPI is a measure of cooling mode conditions. If many measurements of air velocity and air temperature were made throughout the occupied zone of an office, the ADPI would be defined as the percentage of locations where measurements were taken that meet the specifications on effective draft temperature and air velocity - the *effective draft temperature* (-1.7°C and + 1.1°C) and air velocity is less than (0.35m/s) - If the ADPI is maximum (approaching 100 percent), the most desirable conditions are achieved.

The following cooling zone design criteria for the various air diffusion devices maximize the ADPI and comfort. These criteria also account for airflow rate, outlet size, manufacturer's design qualities, and dimensions of the room for which the system is designed.

4.3 Definitions

A. Throw

The *throw* of a jet is the distance from the outlet device to a point in the airstream where the maximum velocity in the stream cross section has been reduced to a selected terminal velocity. For all devices, the terminal velocity, V_t was selected as 0.25 except in the case of ceiling slot diffusers, where the terminal velocity was selected as 0.5 m/s.

B. Throw Distance

The *throw distance* of a jet is denoted by the symbol T_v , where the subscript indicates the terminal velocity for which the throw is given.

C. Characteristic Room Length

The *characteristic room length* (L) is the distance from the outlet device to the nearest boundary wall in the principal horizontal direction of the airflow. However, where air injected into the room does not impinge on a wall surface but mixes with air from a neighboring outlet, the characteristic length (L) is one-half the distance between outlets, plus the distance the mixed jets must travel downward to reach the occupied zone. Table 1 summarizes definitions of characteristic length for various devices.

Diffuser Type	Characteristic Length, L
High Sidewall Grille	Distance to wall perpendicular to jet
Circular Ceiling Diffuser	Distance to closest wall or intersecting air jet
Sill Grille	Length of room in the direction of the jet flow
Ceiling Slot Diffuser	Distance to wall or midplane between outlets
Light Troffer Diffusers	Distance to midplane between outlets, plus distance from ceiling to top of occupied zone
Perforated, Louvered Ceiling Diffusers	Distance to wall or midplane between outlets

Table 1: characteristic room length for diffusers

4.4 Design Conditions

The quantity of air must be known from other design specifications. If it is not known, the solution must be obtained by a trial and error technique. The devices for which data were obtained are:

- (1) High sidewall grille,
- (2) Sill grille,
- (3) Two and four-slot ceiling diffusers,
- (4) Cone type circular ceiling diffusers,
- (5) Light troffer diffusers, and
- (6) Square-faced perforated and louvered ceiling diffusers.

Table 2 summarizes the results of the recommendations on values of Tv/L by giving the value of Tv/L where the ADPI is a maximum for various loads, as well as a range of values Tv/L where ADPI is above a minimum specified value.

4.5 Outlet Type Selection

No criteria have been established for choosing among the six types of outlets to obtain an optimum ADPI. All outlets tested, when used according to these recommendations, can have ADPI values that are satisfactory [greater than 90 percent for loads less than 126 W/m²].

4.6 Design Procedure

- a) Determine the air volume requirements and room size.
- b) Select the tentative outlet type and location within room.
- c) Determine the room's characteristic length (L) (Table 1).
- d) Select the recommended Tv/L ratio from Table 2.
- e) Calculate the throw distance (Tv) by multiplying the recommended Tv/L ratio from Table 2 by the room length (L).
- f) Locate the appropriate outlet size from manufacturer's catalog.
- g) Ensure that this outlet meets other imposed specifications, such as noise and static pressure.

Chapter Four

Terminal Device	Room Load W/m ²	$T_{0.25}/L$ for Max. ADPI	Maximum ADPI	For ADPI Greater Than	Range of $T_{0.25}/L$
High Sidewall Grilles	250 190 125 65	1.8 1.8 1.6 1.5	68 72 78 85	— 70 70 80	— 1.5-2.2 1.2-2.3 1.0-1.9
Circular Ceiling Diffusers	250 190 125 65	0.8 0.8 0.8 0.8	76 83 88 93	70 80 80 90	0.7-1.3 0.7-1.2 0.5-1.5 0.7-1.3
Sill Grille Straight blades	250 190 125 65	1.7 1.7 1.3 0.9	61 72 86 95	60 70 80 90	1.5-1.7 1.4-1.7 1.2-1.8 0.8-1.3
Sill Grille Spread blades	250 190 125 65	0.7 0.7 0.7 0.7	94 94 94 94	90 80 — —	0.8-1.5 0.6-1.7 — —
Ceiling Slot Diffusers (for T_{100}/L)	250 190 125 65	0.3* 0.3* 0.3* 0.3*	85 88 91 92	80 80 80 80	0.3-0.7 0.3-0.8 0.3-1.1 0.3-1.5
Light Troffer Diffusers	190 125 65	2.5 1.0 1.0	86 92 95	80 90 90	<3.8 <3.0 <4.5
Perforated and Louvered Ceiling Diffusers	35-160 —	2.0 —	96 —	90 80	1.4-2.7 1.0-3.4

Table 2: ADPI Selection guide

4.7 Outlet Location


The building's use, size and construction type must be considered in designing the air distribution system, and in selecting the type and location of the supply outlets. Location and selection of the supply outlets is further influenced by the interior design of the building, local sources of heat gain or loss, and outlet performance and design. Local sources of heat gain or loss promote convection currents or cause stratification and may, therefore, determine both the type and location of the supply outlets. Outlets should be

located to neutralize any undesirable convection currents set up by a concentrated load. If a concentrated heat source is located at the occupancy level of the room, the heating effect can be counteracted by directing cool air toward the heat source or by locating an exhaust or return grille adjacent to the heat source. The second method is more economical, rather than dissipated into the conditioned space. Where lighting loads are heavy [54 W/m²] and ceilings relatively high [above 4.6m], the outlets should be located below the lighting load, and the stratified warm air should be removed by an exhaust or return fan. An exhaust fan is recommended if the wet-bulb temperature of the air is above that of the outdoors; a return fan is recommended if it is below this temperature.

These methods reduce the requirements for supply air. Enclosed lights produce more savings than exposed lights, since a considerable portion of the energy is radiant.

Type of Outlet	Floor Space	Approximate Maximum Air Changes/Hour For (3 m) Ceiling Height
	l/s per Sq. Metre	
Grilles & Registers	3 to 6	7
Slot Diffusers	4 to 10	12
Perforated Panel	5 to 15	18
Ceiling Diffuser	5 to 25	30
Perforated Ceiling	5 to 50	60

Table 3: guide for selection of supply outlets



4.8 Selection Procedures

The following procedure is generally used in selecting outlet locations and types:

- Determine the amount of air to be supplied to each room.
- Select the type and quantity of outlets for each room, considering such factors as air quantity required, distance available for throw or radius of diffusion, structural characteristics, and architectural concepts. Table 3 is based on experience and typical ratings of various outlets. It may be used as a guide to the outlets applicable for use with various room air loadings. Special conditions, such as ceiling heights greater than the normal 2.4 to 3.6 m and exposed duct mounting, as well as product modifications and unusual conditions of room occupancy, can modify this table. Manufacturers' rating data should be consulted for final determination of the suitability of the outlets used.
- Locate outlets in the room to distribute the air as uniformly as possible. Outlets may be sized and located to distribute air in proportion to the heat gain or loss in various portions of the room.

Chapter Four

- d) Select proper outlet size from manufacturers' ratings according to air quantities, discharge velocities, distribution patterns, and sound levels. Note manufacturers' recommendations with regard to use. In an open space configuration, the interaction of airstreams from multiple diffuser sources may alter single diffuser throw data or single diffuser air temperature air velocity data, and it may not be sufficient to predict particular levels of air motion in a space. Also, obstructions to the primary air distribution pattern require special consideration.

Return & Exhaust Inlets

To summarize the procedure for inlet location and selection:

- a) Determine room return and an exhaust air quantity from design load calculations.
- b) Select type and quantity of inlets for each room evaluating:
 - 1) Inlet airflow
 - 2) Inlet velocity
 - 3) Architectural requirements
- c) Locate inlets to enhance room air circulation and to remove undesirable air (considering air temperature and contamination).
- d) Select proper inlet size from manufacturer's catalog data considering:
 - 1) Inlet airflow
 - 2) Inlet velocity
 - 3) Pressure loss
 - 4) Sound level

Ground Floor

Supply Diffusers Selection

Square Louver Face Ceiling Diffuser
From Air Diffusion catalogs

For First machine

Room	L/S	No_	act. Th	L/S/diff	Catalogue				
					diffuser	Th	L/S	dB	ΔP (Pa)
0-13	63.31575	1	3.6	63.31575	150*150	3.4	69	23	19
0-15	60.1875	1	2.9	60.1875	200*200	2.4	61	<15	6
0-23	369.7577	6	3	61.62629	150*150	3.4	69	23	19
0-41	120.0239	2	2.5	60.01196	200*200	2.4	61	<15	6
0-42	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-43	124.9683	2	2.5	62.48416	150*150	3.4	69	23	19
0-44	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-45	124.9683	2	2.5	62.48416	150*150	3.4	69	23	19
0-46	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-47	56.87568	1	2.1	56.87568	150*150	3	57	17	14
0-48	60.59744	1	2.9	60.59744	200*200	2.4	61	<15	6
0-49	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-50	124.9683	2	2.5	62.48416	150*150	3.4	69	23	19
0-51	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-52	124.9683	2	2.5	62.48416	150*150	3.4	69	23	19
0-53	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-54	124.564	2	2.5	62.28201	150*150	3.4	69	23	19
0-55	75.0072	1	2.8	75.0072	200*200	3	81	<15	10
0-59	190.8456	2	1.8	95.42279	200*200	3.7	102	21	16
0-60	121.8485	2	1.8	60.92426	200*200	2.4	61	<15	6
0-61	141.0012	2	1.8	70.5006	250*250	2.7	95	<15	7
0-62	173.7462	2	1.9	86.8731	200*200	3.7	102	21	16
0-63	283.7302	2	3.1	141.8651	250*250	4.3	159	24	17
0-66	25.96661	1	1	25.96661	150*150	2.1	34	<15	5
0-67	44.56576	1	1	44.56576	150*150	2.7	46	<15	9

For second machine

0-17	2271.177	16	3.5	141.9486	250*250	4.3	159	24	17
0-20	1873.076	10	6	187.3076	250*250	4.6	191	31	23

Chapter Four

Return Diffusers Selection

For First machine


					Catalogue				
Room	L/S	No_	act. Th	L/S/diff	diffuser	Th	L/S	dB	ΔP (Pa)
0-13	63.31575	1	3.6	63.31575	150*150	3.4	69	23	19
0-15	60.1875	1	2.9	60.1875	200*200	2.4	61	<15	6
0-23	369.7577	6	3	61.62629	150*150	3.4	69	23	19
0-41	120.0239	2	2.5	60.01196	200*200	2.4	61	<15	6
0-42	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-43	124.9683	2	2.5	62.48416	150*150	3.4	69	23	19
0-44	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-45	124.9683	2	2.5	62.48416	150*150	3.4	69	23	19
0-46	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-47	56.87568	1	2.1	56.87568	150*150	3	57	17	14
0-48	60.59744	1	2.9	60.59744	200*200	2.4	61	<15	6
0-49	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-50	124.9683	2	2.5	62.48416	150*150	3.4	69	23	19
0-51	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-52	124.9683	2	2.5	62.48416	150*150	3.4	69	23	19
0-53	120.5279	2	2.5	60.26396	200*200	2.4	61	<15	6
0-54	124.564	2	2.5	62.28201	150*150	3.4	69	23	19
0-55	75.0072	1	2.8	75.0072	200*200	3	81	<15	10
0-59	190.8456	2	1.8	95.42279	200*200	3.7	102	21	16
0-60	121.8485	2	1.8	60.92426	200*200	2.4	61	<15	6
0-61	141.0012	2	1.8	70.5006	250*250	2.7	95	<15	7
0-62	173.7462	2	1.9	86.8731	200*200	3.7	102	21	16
0-63	283.7302	2	3.1	141.8651	250*250	4.3	159	24	17
0-66	25.96661	1	1	25.96661	150*150	2.1	34	<15	5
0-67	44.56576	1	1	44.56576	150*150	2.7	46	<15	9

For second machine

0-17	2271.177	16	3.5	141.9486	250*250	4.3	159	24	17
0-20	1873.076	10	6	187.3076	250*250	4.6	191	31	23

Air quantity for ventilated rooms

Room	Room no.	A (m ²)	H (m)	ζ (time/hr)	CMM	CMM tot
stairs	0_9	12.10	3.90	2.00	1.57	30.52
stairs	0_6	12.96	3.90	2.00	1.68	
stairs	0_7	11.80	3.90	2.00	1.53	
Outside stair case	0_8	14.42	3.9	2.00	1.87	
main stairs	0_5	26.47	3.90	2.00	3.44	
Staff toilet F	0_14	10.00	2.60	5.00	2.17	
Staff toilet M	0_16	7.55	2.60	5.00	1.64	
toilet (F)	0_19	17.95	2.60	5.00	3.81	
toilet (M)	0_21	10.30	2.60	5.00	2.23	
toilet (F)	0_18	11.70	2.60	5.00	2.54	
toilet (M)	0_26	14.34	2.60	5.00	3.11	
toilet (M)	0_22	14.34	2.60	5.00	3.10	
toilet (F)	0_25	8.39	2.60	5.00	1.82	



Ground floor supply and return ducts layout

1st Floor

Supply Diffusers Selection

Square Louvre Face Ceiling Diffuser

From Air Diffusion catalogs

					Catalogue				
Room	L/S	No_	act. Th	L/S/diff	diffuser	Th	L/S	dB	ΔP (Pa)
13	65.26	1	4.4	65.26	150*150	3.4	69	23	19
15	40.54	1	2.3	40.54	150*150	2.7	46	<15	9
41	71.86	1	2.1	71.86	200*200	3	81	<15	10
42	78.66	1	2.1	78.66	200*200	3	81	<15	10
44+43	279.95	4	3	69.99	200*200	3	81	<15	10
45+46	275.88	4	3	68.97	200*200	3	81	<15	10
47+48	318.06	4	2.7	79.52	200*200	3	81	<15	10
49	107.72	1	2.8	107.72	250*250	3.7	127	17	11
50	167.39	2	2.6	83.69	250*250	2.7	95	<15	7
51	212.25	2	2.5	106.12	250*250	3.7	127	17	11
52+53	163.41	2	3.1	81.70	250*250	2.7	95	<15	7
55	98.29	1	2	98.29	200*200	3.7	102	21	16
56	160.09	2	3.2	80.04	200*200	3	81	<15	10
61	270.16	2	3.2	135.08	300*300	3	137	<15	8
62	585.62	5	2.7	117.12	250*250	3.7	127	17	11
63	227.31	2	3	113.65	250*250	3.7	127	17	11
64	182.20	2	3.4	91.10	200*200	3.7	102	21	16
65	45.12	1	2.3	45.12	150*150	2.7	46	<15	9
67	165.81	2	2.31	82.90	250*250	2.7	95	<15	7
68	165.81	2	2.31	82.90	250*250	2.7	95	<15	7
69	165.81	2	2.31	82.90	250*250	2.7	95	<15	7
70	308.46	2	4.16	154.23	200*200	4.6	163	36	39
71	154.83	2	2.41	77.42	200*200	3	81	<15	10
72	140.77	2	2.41	70.38	200*200	3	81	<15	10
73	140.77	2	2.41	70.38	200*200	3	81	<15	10
74	144.54	2	2.41	72.27	200*200	3	81	<15	10
75	71.33	1	2.5	71.33	200*200	3	81	<15	10
11	128.70	3	2	42.90	150*150	2.7	46	<15	9
12+17+18+19	840.23	6	3.6	140.04	250*250	4.3	159	24	17
22+54	1468.69	7	5.1	209.81	250*250	4.9	222	35	33
66+10+40	290.91	3	3	96.97	200*200	3.7	102	21	16


Chapter Four

Return Diffusers Selection

				Cataloge				
Room	L/S	No_	L/S/diff	diffuser	L/S	dB	ΔP (mm _{water})	ΔP
15	13.27	1	13.27	150*150	35	<15	1.524	15.0
44+43	305.29	2	152.65	450*225	159	17	1.524	15.0
45+46	300.89	2	150.45	450*225	159	17	1.524	15.0
47+48	347.29	2	173.65	375*300	177	17	1.524	15.0
50	183.70	2	91.85	300*225	106	15	1.524	15.0
51	233.20	2	116.60	375*150	118	23	2.626	25.8
52+53	176.59	1	176.59	375*300	177	17	1.524	15.0
55	98.29	1	98.29	450*150	106	15	1.524	15.0
56	173.29	1	173.29	375*300	177	17	1.524	15.0
61	270.16	1	270.16	600*300	283	21	1.524	15.0
62	585.62	3	195.21	600*225	212	19	1.524	15.0
63	227.31	1	227.31	375*300	236	27	2.794	27.4
64	182.20	1	182.20	525*225	186	18	1.524	15.0
65	49.50	1	49.50	225*150	53	<15	1.524	15.0
67	165.81	1	165.81	375*300	177	17	1.524	15.0
68	165.81	1	165.81	375*300	177	17	1.524	15.0
69	165.81	1	165.81	375*300	177	17	1.524	15.0
70	308.46	1	308.46	525*375	310	21	1.524	15.0
71	154.83	1	154.83	450*225	159	17	1.524	15.0
72	140.77	1	140.77	300*300	142	16	1.524	15.0
73	140.77	1	140.77	300*300	142	16	1.524	15.0
74	144.54	2	72.27	450*225	159	17	1.524	15.0
11	124.19	3	41.40	150*150	47	17	2.032	19.9
12+17+18+19	706.19	3	235.40	375*300	236	27	2.794	27.4
22+54	1199.14	6	199.86	600*225	212	19	1.524	15.0
66+10+40	207.22	3	69.07	300*150	71	<15	1.524	15.0

Air quantity for ventilated rooms

ROOM	ROOM NO	A (m2)	H (m)	ζ (time/hr)	CMM	CMM tot
main stairs case	1_5	26.47	3.90	2.00	3.44	28.33
stairs case	1_6	12.96	3.90	2.00	1.68	
stairs case	1_7	11.80	3.90	2.00	1.53	
outside stairs case	1_8	12.60	3.90	5.00	4.10	
Staff toilet F	1_14	10.00	2.60	5.00	2.17	
Staff toilet M	1_16	7.55	2.60	5.00	1.64	
toilet (F)	1_20	5.00	2.60	5.00	1.08	
toilet (M)	1_21	13.22	2.60	5.00	2.86	
toilet (F)	1_23	10.30	2.60	5.00	2.23	
toilet (M)	1_24	14.33	2.60	5.00	3.10	
toilet (F)	1_25	5.36	2.60	5.00	1.16	
Room toilet	1_43	1.50	2.60	5.00	0.33	
Room toilet	1_45	1.50	2.60	5.00	0.33	
Room toilet	1_56	1.50	2.60	5.00	0.33	
Room toilet	1_53	1.50	2.60	5.00	0.33	
toilet (M)	1_26	9.34	2.60	5.00	2.02	



1st floor supply and return ducts layout

2nd Floor

Supply Diffusers Selection

Square Louver Face Ceiling Diffuser

From Air Diffusion catalogs

Room	L/S	No_	Thr _{act}	L/S/diff	From Catalogue				
					Size	Thr	L/S	dB	ΔP (Pa)
2_10	374.5	5	3.2	74.90	200*200	3	81	<15	10
2_12	213.7	7	2	30.53	150*150	2.1	34	<15	5
2_13	44.2	1	2.4	44.16	150*150	2.7	46	<15	9
2_15	44.2	1	2.4	44.16	150*150	2.7	46	<15	9
2_18	41.5	1	2.8	41.47	150*150	2.7	46	<15	9
2_20	50.4	1	2.5	50.41	200*200	2.4	61	<15	6
2_41	65.4	1	1.6	65.39	150*150	3.4	69	23	19
2_42	41.5	1	2.6	41.47	150*150	2.7	46	<15	9
2_43	106.9	2	3.4	53.45	150*150	3	57	17	14
2_45	29.7	1	1.8	29.68	150*150	2.1	34	<15	5
2_46	65.1	1	2.4	65.07	150*150	3.4	69	23	19
2_47	85.8	1	2.8	85.81	250*250	2.7	95	<15	7
2_48	60.5	1	2.4	60.48	200*200	2.4	61	<15	6
2_49	6495.1	27	3.4	240.56	375*375	4.2	286	21	13
2_50	64.0	1	2.4	64.00	150*150	3.4	69	23	19
2_51	64.0	1	3.4	64.00	150*150	3.4	69	23	19
2_52	133.3	2	2.7	66.65	150*150	3.4	69	23	19
2_53	137.0	1	2.4	136.98	300*300	3	137	<15	8
2_54	165.8	2	3.4	82.90	150*150	3.7	91	33	35
2_54a	273.9	2	2.6	136.95	300*300	3	137	<15	8
2_55	246.7	2	3	123.34	250*250	3.7	127	17	11
2_56	102.8	1	3	102.82	250*250	3.7	127	17	11
2_57	100.4	1	3	100.42	200*200	3.7	102	21	16
2_58	48.4	1	2.8	48.42	150*150	2.7	46	<15	9


Chapter Four

Return Diffusers Selection

				From Catalogue			
Room	L/S	No_	L/S/diff	Size	L/S	dB	ΔP (Pa)
2_10	555.04	3	185.0133	525*225	186	18	1.524
2_12	256.66	5	51.332	225*150	34	<15	1.524
2_18	36	1	36	150*150	35	<15	1.27
2_20	44.9	1	44.9	150*150	47	17	2.032
2_41	71.94	1	71.94	300*150	71	<15	1.524
2_43	106.9	1	106.9	300*225	106	15	1.524
2_44	71.5	1	71.5	225*225	79	<15	1.524
2_47	85.8	1	85.81	375*150	88	<15	1.524
2_49	6410.8	10	641.08	600*525	661	2.794	34
2_50	64.9	1	64.9	300*150	71	<15	1.524
2_51	64.35	1	64.35	300*150	71	<15	1.524
2_52	127.8	1	127.8	372*225	133	16	1.524
2_53	123.3	1	123.3	525*150	124	16	1.524
2_54	149.22	1	149.22	450*225	159	17	1.524
2_54a	246.51	1	246.51	525*300	137	20	1.524
2_55	246.7	1	246.7	525*300	248	20	1.524
2_57	100.4		100.42	200*200	102	21	16

Air quantity for ventilated rooms

ROOM	ROOM NO	A (m2)	H (m)	ζ (time/hr)	CMM	CMM tot
main stairs	2_5	36.80	3.93	2.00	4.82	17.16
staircase	2_6	12.96	3.90	2.00	1.68	
Staff toilet F	2_14	1.5	2.6	5.00	0.33	
Staff toilet F	2_16	1.5	2.6	5.00	0.33	
toilet (F)	2_19	1.50	2.60	5.00	0.33	
toilet (M)	2_21	1.50	2.60	5.00	0.33	
staff toilet (F)	2_22	11.38	2.60	5.00	2.47	
staff toilet (M)	2_23	9.47	2.60	5.00	2.05	
Kitchenette	2_44	8.90	2.60	10.00	3.86	
Room toilet	2_50	1.5	2.6	5.00	0.33	
Room toilet	2_51	1.5	2.6	5.00	0.33	
Room toilet	2_52	1.5	2.6	5.00	0.33	



2nd floor supply and return ducts layout

Chapter Four

3rd floor

Supply Diffusers Selection

Square Louvre Face Ceiling Diffuser

From Air Diffusion catalogs


Room	L/S	No_	Thr _{act}	L/S/diff	From Catalogue				
					Size	Th	L/S	dB	ΔP (Pa)
3_10	139.2	5	2	27.83	150*150	2.1	34	<15	5
3_40	117.4	2	2.5	58.693	200*200	2.4	61	<15	6
3_41	49.31	1	2.4	49.314	200*200	2.4	61	<15	6
3_43	100.4	1	2.7	100.4	200*200	3.7	102	21	16
3_44	103.7	1	2.7	103.7	250*250	3.7	127	17	11
3_45	142.5	1	2.1	142.46	250*250	4.3	159	24	17
3_46	100.4	1	2.7	100.4	200*200	3.7	102	21	16
3_47	104.8	2	2.7	52.414	200*200	2.4	61	<15	6
3_51	1564	6	4	260.75	375*375	4.2	286	21	13
3_53	1302	2	1.5	650.78	535*535	6.1	726	38	23
3_54	853.1	6	3.7	142.18	250*250	4.3	159	24	17

Return Diffusers Selection

Room	L/S	No_	L/S/diff	From Catalogue			
				Size	L/S	dB	ΔP (Pa)
3_10	0	0	0	0	0	0	0
3_40	86.302	1	86.30	375*150	88	<15	1.524
3_41	49.3142	1	49.31	225*150	53	<15	1.524
3_43	73.3829	1	100.40	300*225	106	15	1.524
3_44	76.6801	1	103.70	250*250	106	15	1.524
3_45	113.872	1	142.46	300*300	142	16	1.524
3_46	73.3829	1	100.40	300*225	106	15	1.524
3_47	50.7924	2	25.40	225*150	53	<15	1.524
3_51	1064.49	4	266.12	525*525	433	23	1.524
3_53	1801.56	1	1801.56	600*600	1321	53	8.382
3_54	853.067	4	213.27	375*375	212	19	1.524

Air quantity for ventilated rooms


ROOM	NO of ROOM	A (m2)	H (m)	ζ (time/hr)	CMM	CMM tot
elevator	3_01	6.84	2.30	3.00	1.057977	19.99
elevator	3_02	6.84	2.30	3.00	1.057977	
main stairs	3_05	36.80	3.93	2.00	6.483976	
staircase	3_06	18.15	3.93	2.00	3.197939	
staff toilet (F)	3_11	9.16	2.60	5.00	2.669377	
staff toilet (M)	3_12	10.44	2.60	5.00	3.04239	
sanitary facility	3_42	6.40	2.60	5.00	1.865067	
cleaners store	3_48	5.98	2.30	2.00	0.616638	



3rd floor supply and return ducts layout

Chapter five

Duct Design



Duct design fundamentals

5.1 Duct system air flow

A more complicated system may include a fan, ductwork, air control dampers, cooling coils, heating coils, filters, diffusers, sound attenuation, turning vanes, etc. The fan is the component or "air pump" in the system which provides energy to the airstream to overcome the resistance to flow of the other components.

5.2 Design methods

There is no design method that will automatically provide the most economical duct system for all conditions. Duct systems have been designed using one or more of the following methods or their variations (some of which are obsolete):

- * Equal friction.
- * Static regain.
- * Extended plenum or semi-extended plenum (modification of equal friction or other design methods.)
- * T-Method.
- * Velocity reduction.
- * Total pressure.
- * Constant velocity.
- * Residential system design method.

5.3 Equal Friction Method (commonly used)

The equal friction method of duct sizing (where the pressure loss per meter of duct is the same for the entire system) is probably the most universally used means of sizing lower pressure supply air, return air and exhaust air duct systems. It normally is not used for higher pressure systems. With supply air duct systems, this design method "automatically" reduces air velocities in the direction of the airflow, thus reducing the possibility of generating noise (against the air flow in return or exhaust duct systems). The major disadvantage of the equal friction method is that there is no provision for equalizing pressure drops in duct branches (except in symmetrical layouts)

5.4 System Pressures

It is important to distinguish between static pressure and total pressure. *Static pressure* is commonly used as the basic pressure for duct system design, but *total pressure* determines the actual amount of energy that must be supplied to the system to maintain airflow. Total pressure always decreases in the direction of airflow. But static pressure may decrease, then increase in direction of airflow (as it does in Figure 5-1), and may go through several more increases and decreases in the course of the system. It can become negative (below atmospheric) on the discharge side of the fan, as demonstrated by Points G and H (in Figure 5-1). The distinction must be made between static pressure loss (sections BC or FG) and static pressure change as a result of conversion of velocity pressure (section C or G).




Figure 5-1 PRESSURE CHANGES DURING FLOW IN DUCTS

5.5 Straight Duct Losses

5.5.1. Duct Friction Losses

Pressure drop in a straight duct section is caused by surface friction, and varies with the velocity, the duct size and length, and the interior surface roughness. Friction loss is most readily determined from Air Duct Friction Charts.

5.5.2. Circular Equivalents

HVAC duct systems usually are sized first as round ducts. Then, if rectangular ducts are desired, duct sizes are selected to provide flow rates equivalent to those of the round ducts originally selected.

5.6 Dynamic Losses

Wherever turbulent flow is present, brought about by sudden changes in the direction or magnitude of the velocity of the air flowing, a greater loss in total pressure takes place than would occur in a steady flow through a similar length of straight duct having a uniform cross-section

5.6.1. Duct Fitting Loss Coefficients

The dynamic loss coefficient "C" is dimensionless and represents the number of velocity heads lost at the duct transition or bend (in terms of velocity pressure). Values of the dynamic loss coefficient for elbows and other duct elements have been determined by laboratory testing, and can be found in the tables.

5.6.2. Pressure Losses in Elbows

Dynamic-loss coefficients for elbows are nearly independent of the air velocity and are affected by the roughness of the duct walls only in the case of the bends.

A. Splitter vanes

Smooth radius rectangular duct elbows (with radius throat and heel) have a reasonably low loss coefficient when the R/W ratio is equal to 1.0 or higher.

B. Turning vanes

B.1. Single vs. Double Thickness

Turning vanes still indicates that using double thickness turning vanes instead of single thickness vanes increases the pressure loss of elbows.

B.2. Trailing Edges

Actually have a *higher loss* than vanes without them. And when the vanes are accidentally installed with the airflow reversed, much higher losses develop.

5.6.3. Pressure Losses in Divided-Flow Fittings

A. Straight-through sections

Whenever air is diverted to a branch, there will be a velocity reduction in the straight-through section immediately following the branch. If no friction or dynamic losses occurred at the junction, there would be no loss in total pressure and the change in velocity pressure would be completely converted into a regain (rise) in static pressure.

B. Diverted flow sections

The loss in a diverted flow section (tee or wye) depends on the ratio of the velocity of the diverted flow to the total flow, the areas of the inlets and exits and the takeoff geometry. The total pressure loss coefficients for a variety of branch configurations for round and rectangular ductwork are shown in tables.

5.6.4. Losses Due to Area Changes

Experimental investigations of pressure changes and of pressure losses at changes of the area in duct cross sections indicate that the excess pressure loss over the normal friction loss is a dynamic one, due to a faster stream expanding into a slower stream, as determined by the actual areas occupied by the flow, rather than by the areas of the duct.

5.7 Design Objectives

1. Design the duct system to convey the design airflow from the fan to the terminal devices in the most efficient manner as allowed by the building structure.
2. Consider energy conservation in the fan selection, duct configuration, duct wall heat gain or loss, etc.
3. Special consideration should be given to the need for sound attenuation and breakout noise.
4. Testing, adjusting and balancing equipment and dampers should be shown on the drawings.
5. Locations of all life safety devices such as fire dampers, smoke dampers, etc. should be shown on the drawings.
6. The designer should consider the pressure losses that occur from tie rods and other duct obstructions.
7. If the ductwork is well designed and constructed, at least 75 to 90 percent of the original velocity pressure can be regained.
8. Round ducts generally are preferred for higher pressure systems.
9. Branch takeoffs and fittings with low loss coefficients should be used. Both **90°** and **45°** duct takeoffs can be used. However, the use of conical tees or angular takeoffs can reduce pressure losses.
10. Use of the Duct Design Calculators would aid the duct design process, especially when making changes in the field

Chapter Five

5.8 Fan Sizing

With the various elements of the HVAC duct system selected, the duct system laid out, and the sizing finalized, the designer now must calculate the total pressure of the systems which the fan(s) must overcome. These, in combination with the pressure loss data for duct system components and apparatus, enable the designer to sum up the total pressure requirements for the fan(s). Estimated system air leakage must be added to the system airflow at this time.




Figure 5-2 INTERACTION OF SYSTEM CURVES AND FAN CURVE (1)

► Fan total pressure estimations *FTP* :










$$FTP = (\Delta P / L) \cdot (L + L_{\text{equivalent}}) + 0.5 \rho V^2 + \Delta P_{\text{equipments}} \quad \text{Eqn (5-1)}$$

Where:

- FTP:** is the fan total pressure .
- $L_{\text{equivalent}}$:** is the equivalent length for each fitting in the duct.
- $0.5 \rho V^2$:** is the dynamic head at the exit of the selected duct.
- $\Delta P_{\text{equipments}}$:** is the total pressure drop over the machine equipments.
- $L_{\text{equivalent}}$:** is the equivalent length for the fittings installed in system duct and indicated

$$\text{Fan power} = FTP * Q \text{ (m}^3\text{/s)} \quad \text{Eqn (5-2)}$$

Table (5-1): Elements Used In Duct Network

Element Shape	Name	Symbol	L_{eq} (m)
	Duct	D	L
	Contraction	C	2.5
	Expansion	E	6
	Tee 45°	Tt	Main: 3
			Branch: 18
	Volume control Damper	D	15
	Elbow	e	5
	Flexible Connection	flex	5.7
	Tee	Ty	22
	Cross connection	Tx	Main: 3
			Branch: 18
	Transition rectangular to round	Conv C	1.5
	Transition round to rectangular	Conv E	6




Fig.(3-5)Friction Chart for Round Duct ($\rho = 1.20 \text{ kg/m}^3$ and $\epsilon = 0.09 \text{ mm}$)

Ground floor duct design

By equal friction method (and $p_f/m = .95 \text{ Pa/m}$ constant through the duct network)

"For Machine 1"

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	$\Delta P(\text{Pa})$
D0	Rec	3195	8.14	2019	-	650	650	1.92
D1	Rec	3195	8.14	1375	-	650	650	1.31
D2	Rec	3195	8.14	855	-	650	650	0.81
D _{riser}	Rec	3195	8.14	9942	-	650	650	9.44
D3	Rec	3195	8.14	3643	-	650	650	3.46
D4	Rec	3195	8.14	4786	-	650	650	4.55
D5	Rec	122	3.66	1127	-	200	175	1.07
D6	Rec	122	3.66	2517	-	200	175	2.39
D7	Rec	122	3.66	150	-	200	175	0.14
D8	Rec	122	3.66	424	-	200	175	0.40
D9	Rec	61	3.07	316	-	150	140	0.30
D10	Rec	61	3.07	608	-	150	140	0.58
D11	Rec	1550	6.85	3480	-	500	475	3.31
D12	Rec	126	3.69	880	-	200	200	0.84
D13	Rec	126	3.69	2043	-	200	200	1.94
D14	Rec	126	3.69	337	-	200	200	0.32
D15	Rec	126	3.69	1003	-	200	200	0.95
D16	Rec	63						
D17	Rec	63						
D18	Rec	1424	6.71	2878	-	475	475	2.73
D19	Rec	122	3.66	795	-	200	175	0.76
D20	Rec	122	3.66	2379	-	200	175	2.26
D21	Rec	122	3.66	280	-	200	175	0.27
D22	Rec	122	3.66	940	-	200	175	0.89
D23	Rec	61	3.07	90	-	150	140	0.09
D24	Rec	61	3.07	225	-	150	140	0.21
D25	Rec	1302	6.57	2980	-	475	450	2.83
D26	Rec	126	3.69	875	-	200	200	0.83
D27	Rec	126	3.69	2171	-	200	200	2.06
D28	Rec	126	3.69	280	-	200	200	0.27
D29	Rec	126	3.69	940	-	200	200	0.89
D30	Rec	63						
D31	Rec	63	3.09	170	-	150	150	0.16
D32	Rec	1176	6.41	2980	-	450	425	2.83
D33	Rec	122	3.66	1160	-	200	175	1.10
D34	Rec	122	3.66	2275	-	200	200	2.16
D35	Rec	122	3.66	220	-	200	175	0.21
D36	Rec	122	3.66	915	-	200	175	0.87
D37	Rec	61	3.07	350	-	150	140	0.33
D38	Rec	61						
D39	Rec	61	3.07	2015	-	150	140	1.91
D40	Rec	61	3.07	1210	-	150	140	1.15
D41	Rec	61	3.07	2235	-	150	140	2.12

Chapter Five

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	ΔP (Pa)
D42	Rec	61	3.07	675	-	150	140	0.64
D43	Rec	1487	6.78	2377	-	475	475	2.26
D44	Rec	126	3.6	820	-	200	200	0.78
D45	Rec	126	3.6	2384	-	200	200	2.26
D46	Rec	126	3.6	950	-	200	200	0.90
D47	Rec	63						
D48	Rec	63	3	188	-	150	150	0.18
D49	Rec	1361	6.6	5727	-	475	450	5.44
D50	Rec	75	3.2	435	-	175	150	0.41
D51	Rec	75	3.2	335	-	175	150	0.32
D52	Rec	75	3.2	426	-	175	150	0.40
D53	Rec	75	3.2	204	-	175	150	0.19
D54	Rec	1286	6.5	783	-	450	450	0.74
D55	Rec	372	4.8	2426	-	300	275	2.30
D56	Rec	372	4.8	1192	-	300	275	1.13
D57	Rec	372	4.8	1235	-	300	275	1.17
D58	Rec	372	4.8	1659	-	300	275	1.58
D59	Rec	372	4.8	815	-	300	275	0.77
D60	Rec	62	3	562	-	150	140	0.53
D61	Rec	62	3	432	-	150	140	0.41
D62	Rec	248	4.3	2008	-	250	250	1.91
D63	Rec	124	3.6	1762	-	200	200	1.67
D64	Rec	62	3	527	-	150	140	0.50
D65	Rec	62	3	486	-	150	140	0.46
D66	Rec	124	3.6	4522	-	200	200	4.30
D67	Rec	62	3	516	-	150	140	0.49
D68	Rec	62	3	2838	-	150	140	2.70
D69	Rec	62	3	5200	-	150	140	4.94
D70	Rec	914	6	2412	-	400	400	2.29
D71	Rec	914	6	3070	-	400	400	2.92
D72	Rec	914	6	6041	-	400	400	5.74
D73	Rec	192	4.1	211	-	225	225	0.20
D74	Rec	192	4.1	241	-	225	225	0.23
D75	Rec	192	4.1	434	-	225	225	0.41
D76	Rec	192	4.1	1022	-	225	225	0.97
D77	Rec	96	3.4	80	-	175	175	0.08
D78	Rec	96						
D79	Rec	722	5.6	1363	-	375	350	1.29
D80	Rec	122	3.6	443	-	200	175	0.42
D81	Rec	122	3.6	373	-	200	175	0.35
D82	Rec	122	3.6	714	-	200	175	0.68
D83	Rec	122	3.6	327	-	200	175	0.31
D84	Rec	61						
D85	Rec	61						
D86	Rec	600	5.4	3900	-	350	325	3.71
D87	Rec	142	3.7	423	-	200	200	0.40
D88	Rec	142	3.7	456	-	200	200	0.43

Duct Design

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	ΔP (Pa)
D89	Rec	142	3.7	454	-	200	200	0.43
D90	Rec	71	3.1	90	-	175	150	0.09
D91	Rec	71						
D92	Rec	284	4.5	2000	-	275	250	1.90
D93	Rec	284	4.5	320	-	275	250	0.30
D94	Rec	284	4.5	1035	-	275	250	0.98
D95	Rec	284	4.5	405	-	275	250	0.38
D96	Rec	142	3.7	629	-	200	200	0.60
D97	Rec	142	3.7	810	-	200	200	0.77
D98	Rec	174	3.9	2577	-	225	225	2.45
D99	Rec	174	3.9	182	-	225	225	0.17
D100	Rec	174	3.9	182	-	225	225	0.17
D101	Rec	174	3.9	470	-	225	225	0.45
D102	Rec	174	3.9	590	-	225	225	0.56
D102a	Rec	87						
D102b	Rec	87						
D103	Rec	993	6.1	9490	-	425	400	9.02
D104	Rec	179	4	678	-	225	225	0.64
D105	Rec	122	3.6	505	-	200	175	0.48
D106	Rec	122	3.6	1110	-	200	175	1.05
D107	Rec	122	3.6	915	-	200	175	0.87
D108	Rec	61	3	446	-	150	140	0.42
D109	Rec	61						
D110	Rec	57	3	2244	-	150	140	2.13
D111	Rec	57	3	745	-	150	140	0.71
D112	Rec	57	3	810	-	150	140	0.77
D113	Rec	57	3	97	-	140	140	0.09
D114	Rec	814	5.8	3085	-	400	375	2.93
D115	Rec	126	3.6	1700	-	200	175	1.62
D116	Rec	126	3.6	1050	-	200	175	1.00
D117	Rec	126	3.6	778	-	200	175	0.74
D118	Rec	63						
D119	Rec	63	3	430	-	150	150	0.41
D120	Rec	688	5.6	3194	-	375	350	3.03
D121	Rec	122	3.6	1581	-	200	175	1.50
D122	Rec	122	3.6	1200	-	200	175	1.14
D123	Rec	122	3.6	640	-	200	175	0.61
D124	Rec	61						
D125	Rec	61	3	555	-	150	140	0.53
D126	Rec	566	5.3	2840	-	350	325	2.70
D127	Rec	126	3.6	1624	-	200	175	1.54
D128	Rec	126	3.6	760	-	200	175	0.72
D129	Rec	126	3.6	867	-	200	200	0.82
D130	Rec	63						
D131	Rec	63	3	364	-	150	150	0.35
D132	Rec	440	5	3152	-	325	300	2.99
D133	Rec	122	3.6	1692	-	200	175	1.61

Chapter Five

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	ΔP (Pa)
D134	Rec	122	3.6	925	-	200	175	0.88
D135	Rec	122	3.6	795	-	200	175	0.76
D136	Rec	61						
D137	Rec	61	3	260	-	150	140	0.25
D138	Rec	318	4.6	2742	-	275	275	2.60
D139	Rec	122	3.6	1777	-	200	175	1.69
D140	Rec	122	3.6	795	-	200	175	0.76
D141	Rec	122	3.6	1160	-	200	175	1.10
D142	Rec	61						
D143	Rec	61	3	240	-	150	150	0.23
D144	Rec	196	4.1	3063	-	225	225	2.91
D145	Rec	196	4.1	10147	-	225	225	9.64
D146	Rec	45	2.8	400	-	140	125	0.38
D147	Rec	45	2.8	450	-	140	125	0.43
D148	Rec	45	2.8	462	-	140	125	0.44
D149	Rec	151	3.8	1675	-	225	200	1.59
D150	Rec	26	2.4	470	-	110	100	0.45
D151	Rec	26	2.4	325	-	110	100	0.31
D152	Rec	26	2.4	732	-	110	100	0.70
D153	Rec	125	3.6	3032	-	200	200	2.88
D154	Rec	64	3.1	612	-	150	150	0.58
D155	Rec	64	3.1	268	-	150	150	0.25
D156	Rec	64	3.1	782	-	150	150	0.74
D157	Rec	61	3	6661	-	150	140	6.33
D158	Rec	61	3	612	-	150	140	0.58
D159	Rec	61	3	300	-	150	140	0.29
D160	Rec	61	3	1524	-	150	140	1.45

single element "Machine 1"

Element	Symbol	Q(L/s)	Input Dim		Output Dim		L(mm)	L _{eq} (m)	ΔP (Pa)
			W (mm)	H (mm)	W (mm)	H(mm)			
Contraction	c1	1550	500	650	500	475	51	2.5	2.42
	c2	1424	500	475	475	475	70	2.5	2.44
	c3	1302	475	475	475	450	50	2.5	2.42
	c4	1176	475	450	450	425	70	2.5	2.44
	c5	993	425	425	425	400	51	2.5	2.42
	c6	814	425	400	400	375	134	2.5	2.50
	c7	688	400	375	375	350	70	2.5	2.44
	c8	566	375	350	350	325	70	2.5	2.44
	c9	440	350	325	325	300	70	2.5	2.44
	c10	318	325	300	275	275	100	2.5	2.47
	c11	196	275	275	225	225	100	2.5	2.47
	c12	151	225	225	225	200	50	2.5	2.42
	c13	125	225	200	200	200	70	2.5	2.44
	c14	61	200	200	150	140	100	2.5	2.47
	c15	3195	800	800	650	650	211	2.5	2.58

Duct Design

Element	Symbol	Q(L/s)	Input Dim		Output Dim		L(mm)	L _{eq} (m)	ΔP (Pa)
			W (mm)	H (mm)	W (mm)	H(mm)			
Expansion	E1	61	150	140	250	200	160	6	5.85
Conv-Cont	conv-c1	61	150	140	D=160		240	1.5	1.65
Conv-Expn	conv-E1	61	D=125		150	140	190	6	5.88
Rec-elbow	e1	3195	650	650	650	650	1555	5	6.23
	e2	196	225	225	225	225	534	5	5.26
	e3	61	150	140	150	140	353	5	5.09
	e4	61	150	140	150	140	341	5	5.07
	e5	3195	650	650	650	650	1650	5	6.32
	e6	3195	650	650	650	650	2187	5	6.83
	e7	3195	650	650	650	650	1675	5	6.34
	e8	3195	650	650	650	650	1385	5	6.07
	e9	3195	650	650	650	650	1359	5	6.04
	e10	3195	650	650	650	650	1261	5	6.95
	e11	3195	650	650	650	650	2264	5	6.90
	e12	3195	650	650	650	650	2127	5	6.77

Double elements "Machine 1"

Element	Symbol	Type	Input specifications			Output specifications			L (mm)	L _{eq} (mm)	ΔP (Pa)
			Q (L/s)	W (mm)	H (mm)	Q (L/s)	W (mm)	H (mm)			
Branch Tee 90°	Tt1	main	1550	500	475	1424	500	475	600	3	3.42
	Tt2	main	1424	475	475	1302	475	475	575	3	3.40
	Tt3	main	1302	475	450	1176	475	450	575	3	3.40
	Tt4	br-D114	993	425	400	814	425	400	525	18	17.60
	Tt5	main	814	400	375	688	400	375	500	3	3.33
	Tt6	main	688	375	350	566	375	350	475	3	3.30
	Tt7	main	566	350	325	440	350	325	450	3	3.28
	Tt8	main	440	325	300	318	325	300	425	3	3.25
Cross connection	X1	br-D111	3195	650	650	1550	500	650	700	18	17.77
	X2	br-D103	1176	450	425	993	425	425	475	18	17.55

Chapter Five

Devices

Name	ΔP
VAV	25
Flex connection	5.7
Filter	70
Coil	80
Mix Damper	25
Damper,c,v	15
diffuser	9

For longest path *For Machine 1* $\Delta P = 537.81 \text{ Pa}$

For "Machine 2"

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	$\Delta P(\text{Pa})$
D1	Rec	4152	8.7	3600	-	700	700	3.42
D2	Rec	4152	8.7	9942	-	700	700	9.44
D3	Rec	2272	7.5	6627	-	600	550	6.30
D4	Rec	2272	7.5	3041	-	600	550	2.89
D5	Rec	2272	7.5	2032	-	600	550	1.93
D6	Rec	2272	7.5	4175	-	600	550	3.97
D7	Rec	2272	7.5	2630	-	600	550	2.50
D8	Rec	2272	7.5	3707	-	600	550	3.52
D9	Rec	1136	6.3	5763	-	450	425	5.47
D10	Rec	1136	6.3	260	-	450	425	0.25
D11	Rec	142	3.8	435	-	200	200	0.41
D12	Rec	142	3.8	147	-	200	200	0.14
D13	Rec	852	5.9	3836	-	400	375	3.64
D14	Rec	142	3.8	436	-	200	200	0.41
D15	Rec	142	3.8	419	-	200	200	0.40
D16	Rec	568	5.4	3886	-	350	325	3.69
D17	Rec	142	3.8	309	-	200	200	0.29
D18	Rec	142	3.8	270	-	200	200	0.26
D19	Rec	284	4.5	3893	-	275	250	3.70
D20	Rec	142	3.8	427	-	200	200	0.41
D21	Rec	142	3.8	612	-	200	200	0.58
D22	Rec	1136	6.3	368	-	450	425	0.35
D23	Rec	142	3.8	145	-	200	200	0.14
D24	Rec	142	3.8	228	-	200	200	0.22
D25	Rec	852	5.9	3836	-	400	375	3.64
D26	Rec	142	3.8	179	-	200	200	0.17

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	ΔP (Pa)
D27	Rec	142	3.8	313	-	200	200	0.30
D28	Rec	568	5.4	3886	-	350	325	3.69
D29	Rec	142	3.8	265	-	200	200	0.25
D30	Rec	142	3.8	527	-	200	200	0.50
D31	Rec	284	4.5	3339	-	275	250	3.17
D32	Rec	142	3.8	368	-	200	200	0.35
D33	Rec	142	3.8	539	-	200	200	0.51
D34	Rec	1880	7.2	998	-	550	500	0.95
D35	Rec	1880	7.2	1706	-	550	500	1.62
D36	Rec	1880	7.2	668	-	550	500	0.63
D37	Rec	1880	7.2	2479	-	550	500	2.36
D38	Rec	1880	7.2	2262	-	550	500	2.15
D39	Rec	376	4.8	1756	-	300	275	1.67
D40	Rec	188	4.1	1094	-	225	225	1.04
D41	Rec	188	4.1	1335	-	225	225	1.27
D42	Rec	376	4.8	6332	-	300	275	6.02
D43	Rec	188	4.1	2588	-	225	225	2.46
D44	Rec	188	4.1	4874	-	225	225	4.63
D45	Rec	1128	6.3	1448	-	450	425	1.38
D46	Rec	188	4.1	2219	-	225	225	2.11
D47	Rec	188	4.1	537	-	225	225	0.51
D48	Rec	188	4.1	1988	-	225	225	1.89
D49	Rec	188	4.1	775	-	225	225	0.74
D50	Rec	752	5.7	2309	-	375	375	2.19
D51	Rec	752	5.7	12418	-	375	375	11.80
D52	Rec	376	4.8	3537	-	300	275	3.36
D53	Rec	188	4.1	4873	-	225	225	4.63
D54	Rec	188	4.1	826	-	225	225	0.78
D55	Rec	376	4.8	1730	-	300	275	1.64
D56	Rec	188	4.1	697	-	225	225	0.66
D57	Rec	188	4.1	4296	-	225	225	4.08
D58	Rec	188	4.1	2151	-	225	225	2.04

single element "Machine 2"

Element	Symbol	Q(L/s)	Input Dim		Output Dim		L(mm)	L _{eq} (m)	ΔP (Pa)
			W (mm)	H(mm)	W(mm)	H(mm)			
Contraction	c1	1128	550	500	450	425	160	2.5	2.53
	c2	752	450	425	375	375	130	2.5	2.50
	c3	376	375	375	300	275	130	2.5	2.50
	c4	188	300	275	225	225	130	2.5	2.50
	c5	1880	700	700	550	500	221	2.5	2.58
	c6	4152	800	800	700	700	161	2.5	2.53
Expansion	E1	1880	500	550	850	500	460	6	6.14
Conv-Cont	conv-c1	188	225	225	D=225		337	1.5	1.75
Conv-Expn	conv-E1	1880	D=400		550	500	600	6	6.27

Chapter Five

Rec-elbow	e1								
	e2								
	e3	1880	550	500	550	500	1304	5	5.99
	e4	1880	550	500	550	500	1296	5	5.98
	e5	752	375	375	375	375	880	5	5.59
	e6	376	300	275	300	275	652	5	5.37
	e7	376	300	275	300	275	652	5	5.37
	e8	376	300	275	300	275	652	5	5.37
	e9	376	300	275	300	275	652	5	5.37
	e10	4152	700	700	700	700	1833	5	6.49
	e11	4152	700	700	700	700	1833	5	6.49
	e12	4152	700	700	700	700	1942	5	6.59
	e13	4152	700	700	700	700	1926	5	6.58
	e14	4152	700	700	700	700	1362	5	6.04
	e15	4152	700	700	700	700	1910	5	6.56
	e16	4152	700	700	700	700	1950	5	6.60

Double elements "Machine 2"

Element	Symbol	Type	Input specifications			Output specifications			L(mm)	L eq (mm)	ΔP (Pa)
			Q (L/s)	W (mm)	H (mm)	Q (L/s)	W (mm)	H (mm)			
Wye Tee	Ty1	br-D53	376	300	275	188	300	275	400	22	21.28
	Ty2	Br-D35	4152	700	700	1880	550	500	800	22	21.66
Branch Tee 90°	Tt1	br-D52	752	375	375	376	375	375	475	18	17.55
Cross connection	X1	br-D45	1880	550	500	1128	550	500	600	18	17.67
	X2	main	1128	550	500	752	450	425	500	3	3.33

Devices

Name	ΔP
VAV	25
Flex connection	5.7
Filter	70
Coil	80
Mix Damper	25
Damper,c,v	15
diffuser	23

For longest path *For Machine 2* $\Delta P = 703.5$ Pa

1st Floor Supply duct design

By equal friction method (and pf/m = .95 Pa/m constant through the duct network)

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	ΔP (Pa)
D0	Rec	7571	10.03	5270	-	900	900	5.01
D1	Rec	7571	10.03	3492	-	900	900	3.32
D2	Rec	7571	10.03	1479	-	900	900	1.41
D3	Rec	3906	8.56	2076	-	700	700	1.97
D4	Rec	3906	8.56	1126	-	700	700	1.07
D5	Rec	1470	6.76	1224	-	475	475	1.16
D6	Rec	210	4.19	5291	-	250	225	5.03
D7	Rec	1260	6.51	743	-	450	450	0.71
D8	Rec	210	4.19	445	-	250	225	0.42
D9	Rec	210	4.19	2222	-	250	225	2.11
D10	Rec	840	5.9	4745	-	400	375	4.51
D11	Rec	210	4.19	588	-	250	225	0.56
D12	Rec	210	4.19	2333	-	250	225	2.22
D13	Rec	420	4.98	4683	-	300	300	4.45
D14	Rec	210	4.19	72	-	250	225	0.07
D15	Rec	210	4.19	2309	-	250	225	2.19
D16	Rec	2436	7.64	1047	-	600	550	0.99
D17	Rec	2436	7.64	1260	-	600	550	1.20
D18	Rec	587	5.4	2169	-	350	325	2.06
D19	Rec	129	3.71	1035	-	200	200	0.98
D20	Rec	129	3.71	491	-	200	200	0.47
D21	Rec	43	2.8	281	-	140	125	0.27
D22	Rec	43	2.8	1501	-	140	125	1.43
D23	Rec	86	3.35	1316	-	175	175	1.25
D24	Rec	86	3.35	6008	-	175	175	5.71
D25	Rec	43	2.8	945	-	140	125	0.90
D26	Rec	43	2.8	4484	-	140	125	4.26
D27	Rec	458	5.08	7464	-	325	300	7.09
D28	Rec	46						
D29	Rec	412	4.95	5097	-	300	300	4.84
D30	Rec	184	4.05	463	-	225	225	0.44
D31	Rec	184	4.05	558	-	225	225	0.53
D32	Rec	92	3.41	293	-	175	175	0.28
D33	Rec	92	3.41	341	-	175	175	0.32
D34	Rec	228	4.28	3203	-	250	225	3.04
D35	Rec	114	3.59	379	-	200	175	0.36
D36	Rec	114	3.59	3171	-	200	175	3.01
D37	Rec	1849	7.15	4167	-	550	500	3.96
D38	Rec	825	5.88	2428	-	400	375	2.31
D39	Rec	99	3.47	892	-	175	175	0.85
D40	Rec	726	5.69	5178	-	375	350	4.92
D41	Rec	164	3.94	609	-	225	200	0.58
D42	Rec	164	3.94	275	-	225	200	0.26

Chapter Five

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	ΔP (Pa)
D43	Rec	82	3.31	161	-	175	150	0.15
D44	Rec	82	3.31	60	-	225	200	0.06
D45	Rec	562	5.35	5096	-	350	325	4.84
D46	Rec	214	4.21	438	-	250	225	0.42
D47	Rec	214	4.21	529	-	250	225	0.50
D48	Rec	107						
D49	Rec	107						
D50	Rec	348	4.75	4639	-	275	275	4.41
D51	Rec	168	3.96	449	-	225	200	0.43
D52	Rec	168	3.96	670	-	225	200	0.64
D53	Rec	84						
D54	Rec	84						
D55	Rec	180	4.03	3786	-	225	225	3.60
D56	Rec	108						
D57	Rec	72	3.2	5032	-	175	150	4.78
D58	Rec	1024	6.19	1883	-	425	400	1.79
D59	Rec	162	3.93	309	-	425	400	0.29
D60	Rec	162	3.93	348	-	225	200	0.33
D61	Rec	81	3.29	541	-	175	150	0.51
D62	Rec	81	3.29	263	-	175	150	0.25
D63	Rec	862	5.94	9261	-	400	375	8.80
D64	Rec	272	4.47	1144	-	275	250	1.09
D65	Rec	272	4.47	927	-	275	250	0.88
D66	Rec	136	3.76	512	-	200	200	0.49
D67	Rec	136	3.76	775	-	200	200	0.74
D68	Rec	560	5.34	5826	-	350	325	5.53
D69	Rec	560	5.34	898	-	350	325	0.85
D70	Rec	560	5.34	929	-	350	325	0.88
D71	Rec	118						
D72	Rec	118						
D73	Rec	354	4.77	4827	-	300	275	4.59
D74	Rec	118						0.00
D75	Rec	236	4.31	129	-	250	225	0.12
D76	Rec	118						
D77	Rec	118						
D78	Rec	3665	8.43	3434	-	700	650	3.26
D79	Rec	291	4.54	241	-	275	250	0.23
D80	Rec	291	4.54	1057	-	270	250	1.00
D81	Rec	97						
D82	Rec	194	4.11	1500	-	225	225	1.43
D83	Rec	97	3.45	1500	-	175	175	1.43
D84	Rec	97	3.45	3690	-	175	175	3.51
D85	Rec	97	3.45	87	-	175	175	0.08
D86	Rec	3374	8.27	2917	-	650	650	2.77
D87	Rec	2498	7.69	3793	-	600	575	3.60
D88	Rec	79						
D89	Rec	2419	7.63	1477	-	570	570	1.40

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	ΔP (Pa)
D90	Rec	72						0.00
D91	Rec	2347	7.57	2641	-	575	575	2.51
D92	Rec	66						
D93	Rec	2281	7.52	5954	-	575	550	5.66
D94	Rec	41	2.77	526	-	125	125	0.50
D95	Rec	2240	7.49	1457	-	575	550	1.38
D96	Rec	846	5.91	1002	-	400	375	0.95
D97	Rec	846	5.91	1135	-	400	375	1.08
D98	Rec	145						
D99	Rec	705	5.65	1761	-	375	350	1.67
D100	Rec	144	3.81	467	-	375	350	0.44
D101	Rec	564	5.35	3302	-	350	325	3.14
D102	Rec	143						
D103	Rec	423	4.98	2745	-	300	300	2.61
D104	Rec	142						
D105	Rec	282	4.51	3235	-	275	250	3.07
D106	Rec	141						
D107	Rec	141	3.79	2624	-	200	200	2.49
D108	Rec	808	5.85	1619	-	400	375	1.54
D109	Rec	808	5.85	2900	-	400	375	2.76
D110	Rec	332	4.69	2488	-	375	375	2.36
D111	Rec	166	3.96	402	-	225	200	0.38
D112	Rec	166	3.96	820	-	225	200	0.78
D113	Rec	83						
D114	Rec	83						
D115	Rec	166	3.96	430	-	225	200	0.41
D116	Rec	166	3.96	490	-	225	200	0.47
D117	Rec	83						
D118	Rec	83						
D119	Rec	476	5.13	3120	-	325	300	2.96
D120	Rec	166	3.95	2621	-	225	200	2.49
D121	Rec	166	3.95	272	-	225	200	0.26
D122	Rec	166	3.95	450	-	225	200	0.43
D123	Rec	83						
D124	Rec	83						
D125	Rec	310	4.62	6808	-	275	275	6.47
D126	Rec	310	4.62	1393	-	275	275	1.32
D127	Rec	310	4.62	711	-	275	275	0.68
D128	Rec	155	3.88	267	-	225	200	0.25
D129	Rec	155	3.88	740	-	225	200	0.70
D130	Rec	586	5.4	770	-	350	325	0.73
D131	Rec	586	5.4	10297	-	350	325	9.78
D132	Rec	288	4.53	1444	-	275	250	1.37
D133	Rec	146	3.83	683	-	200	200	0.65
D134	Rec	146	3.83	675	-	200	200	0.64
D135	Rec	73	3.21	141	-	175	150	0.13
D136	Rec	73						

Chapter Five

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	ΔP (Pa)
D137	Rec	142	3.8	240	-	200	200	0.23
D138	Rec	142	3.8	258	-	200	200	0.25
D139	Rec	71	3.19	177	-	175	150	0.17
D140	Rec	71						
D141	Rec	298	4.57	6468	-	275	250	6.14
D142	Rec	298	4.57	1540	-	275	250	1.46
D143	Rec	142	3.8	732	-	200	200	0.70
D144	Rec	142	3.8	660	-	200	200	0.63
D145	Rec	71						
D146	Rec	71						
D147	Rec	156	3.89	240	-	225	200	0.23
D148	Rec	156	3.89	310	-	225	200	0.29
D149	Rec	78						
D150	Rec	78						
D151	Rec	876	5.96	3863	-	400	400	3.67
D152	Rec	280	4.5	777	-	275	250	0.74
D153	Rec	280	4.5	620	-	275	250	0.59
D154	Rec	140	3.79	1730	-	200	200	1.64
D155	Rec	70	3.18	205	-	175	150	0.19
D156	Rec	70	3.18	460	-	175	150	0.44
D157	Rec	140	3.79	1520	-	200	200	1.44
D158	Rec	70	3.18	205	-	175	150	0.19
D159	Rec	70	3.18	460	-	175	150	0.44
D160	Rec	596	5.43	7067	-	350	325	6.71
D161	Rec	276	4.49	777	-	275	250	0.74
D162	Rec	276	4.49	705	-	275	250	0.67
D163	Rec	138	3.77	1145	-	200	200	1.09
D164	Rec	69	3.17	204	-	175	150	0.19
D165	Rec	69	3.17	460	-	175	150	0.44
D166	Rec	138	3.77	1692	-	200	200	1.61
D167	Rec	69	3.17	204	-	175	150	0.19
D168	Rec	69	3.17	460	-	175	150	0.44
D169	Rec	320	4.65	7538	-	275	275	7.16
D170	Rec	320	4.65	777	-	275	275	0.74
D171	Rec	320	4.65	648	-	275	275	0.62
D172	Rec	160	3.91	2034	-	225	200	1.93
D173	Rec	80	3.29	161	-	175	150	0.15
D174	Rec	80	3.29	400	-	175	150	0.38
D175	Rec	160	3.91	2247	-	225	200	2.13
D176	Rec	80	3.29	32	-	175	150	0.03
D177	Rec	80	3.29	288	-	175	150	0.27

single element for longest path

Element	Symbol	Q(L/s)	Input Dim		Output Dim		L(mm)	L _{eq} (m)	ΔP (Pa)
			W (mm)	H(mm)	W (mm)	H(mm)			
Contraction	c1	3906	1050	750	700	700	462	2.5	2.81
	c2	2436	700	700	600	550	419	2.5	2.77
	c3	1849	600	550	550	500	230	2.5	2.59
	c4	1024	550	500	425	400	191	2.5	2.56
	c5	862	425	400	400	375	147	2.5	2.51
	c6	560	400	375	350	325	100	2.5	2.47
	c7	354	350	325	300	275	100	2.5	2.44
	c8	236	300	275	250	225	100	2.5	2.47
	c9	560	325	350	350	325	70	6	5.77
Expansion	E1	560	325	350	350	325	70	6	5.77
	E2	7571	800	800	900	900	161	6	5.85
conv-cont	conv-c1	118	250	225	D=210		315	1.5	1.72
Rec-elbow	e1	3906	700	700	700	700	1649	5	6.32
	e2	2436	600	550	600	550	1413	5	6.09
	e3	560	350	325	350	325	824	5	5.53
	e4	7571	900	900	900	900	2132	5	6.78
	e5	7571	900	900	900	900	2125	5	6.77
	e6	7571	900	900	900	900	2162	5	6.80
	e7	7571	900	900	900	900	2121	5	6.76

Double elements for longest path

Element	Symbol	Type	Input specsefications			Output specsefications			L(mm)	L _{eq} (m)	ΔP(Pa)
			Q (L/s)	W (mm)	H (mm)	Q (L/s)	W (mm)	H (mm)			
Wye Tee	Ty1									22	20.90
		br-D3	7571	1050	750	3906	1050	750	1150	22	21.99
	Ty2									22	20.90
		br-D58	1849	550	500	1024	550	500	615	22	21.62
	Ty3									22	20.90
		br-D75	354	300	275	236	300	275	345	22	21.23
	Ty4									22	20.90
		br-D77	236	250	225	118	250	225	300	22	21.19
Branch Tee 90°	Tt1									3	2.85
		br-D16	3906	700	700	2436	700	700	753	18	17.82
	Tt2									3	2.85
		br-D37	2436	600	550	1849	600	550	700	18	17.77
	Tt3	main	1024	425	400	862	425	400	525	3	3.35
										18	17.10
	Tt4	main	862	400	375	560	400	375	500	3	3.33
										18	17.10
	Tt5									3	2.85
		br-D73	560	350	325	354	350	350	325	18	17.41

Chapter Five

Devices

Name	ΔP
Heater	25
Flex connection	5.7
Filter	70
Coil	80
Mix Dumper	25
diffuser	11

For longest path $\Delta P = 614.92 \text{ Pa}$

2nd Floor supply duct design

By equal friction method (and $p_f/m = .95 \text{ Pa/m}$ constant through the duct network)

Duct Name	Type	Q L/s	V (m/s)	L(mm)	D (mm)	W (mm)	H (mm)	ΔP (Pa)
D0	Rec	9080	10.47	1306	-	1200	750	1.24
D1	Rec	1755	7.05	1653	-	550	500	1.57
D2	Rec	1755	7.05	876	-	525	500	0.83
D3	Rec	1163	6.38	11870	-	450	425	11.28
D4	Rec	1163	6.38	4844	-	450	425	4.60
D5	Rec	134	3.74	610	-	200	200	0.58
D6	Rec	134	3.74	297	-	200	200	0.28
D7	Round	67	3.14	353	180	-	-	0.34
D8	Round	67	3.14	715	180	-	-	0.68
D9	Rec	1029	6.2	3639	-	425	425	3.46
D10	Rec	137	3.765	677	-	200	200	0.64
D11	Round	137	3.77	1359	224	-	-	1.29
D12	Rec	101	3.486	266	-	175	175	0.25
D12a	Round	101	3.49	1042	200	-	-	0.99
D13	Rec	791	5.8	2264	-	375	375	2.15
D14	Rec	274	4.47	617	-	250	250	0.59
D14a	Round	137	3.765	151	250	-	-	0.14
D14b	Round	137	3.77	211	250	-	-	0.20
D15	Rec	103	3.5	870	-	200	200	0.83
D16	Round	103	3.5	698	224	-	-	0.66
D17	Rec	414	4.95	2588	-	300	300	2.46
D18	Rec	166	3.95	522	-	225	225	0.50
D19	Rec	166	3.95	1394	-	225	225	1.32
D20	Round	83	3.317	1095	200	-	-	1.04
D21	Round	83	3.32	1133	200	-	-	1.08
D22	Rec	248	4.367	3232	-	250	250	3.07
D23	Rec	248	4.37	669	-	250	250	0.64
D24	Rec	248	4.37	1261	-	250	250	1.20
D25	Round	124	3.67	1167	200	-	-	1.11
D26	Round	124	3.67	786	200	-	-	0.75
D27	Round	103	3.5	691	224	-	-	0.66
D28	Rec	375	4.839	461	-	350	325	0.44
D29	Round	75	3.2	1058	180	-	-	1.01
D30	Rec	300	4.579	1815	-	275	250	1.72
D31	Round	75	3.2	1083	180	-	-	1.03
D32	Rec	225	4.26	2352	-	250	250	2.23
D33	Rec	150	3.85	1848	-	200	200	1.76
D34	Rec	150	3.85	537	-	200	200	0.51
D35	Round	75	3.2	290	180	-	-	0.28
D36	Round	75	3.2	830	180	-	-	0.79
D37	Round	75	3.2	4914	180	-	-	4.67
D38	Round	75	3.2	5629	180	-	-	5.35

Chapter Five

Duct Name	Type	Q L/s	V (m/s)	L(mm)	D (mm)	W (mm)	H (mm)	ΔP (Pa)
D39	Rec	217	4.22	1488	-	250	225	1.41
D40	Rec	217	4.22	2090	-	250	225	1.99
D41	Rec	186	4.065	700	-	225	225	0.67
D42	Rec	186	4.07	3214	-	225	225	3.05
D44	Rec	186	4.07	2155	-	225	225	2.05
D45	Rec	155	3.88	4179	-	225	225	3.97
D46	Rec	124	3.67	4216	-	225	200	4.01
D47	Rec	93	3.41	4241	-	200	175	4.03
D48	Rec	62	3.08	4291	-	175	150	4.08
D49	Round	31	2.57	1519	125	-	-	1.44
D50	Round	31	2.57	294	125	-	-	0.28
D51	Round	31	2.57	352	125	-	-	0.33
D52	Round	31	2.57	4921	125	-	-	4.67
D53	Rec	6600	9.7	135	-	850	850	0.13
D54	Rec	51	2.93	868	-	140	140	0.82
D55	Rec	6549	9.688	2046	-	850	850	1.94
D56	Rec	42	2.787	807	-	125	125	0.77
D56a	Round	42	2.79	1029	150	-	-	0.98
D57	Round	6507	9.67	77	925	-	-	0.07
D58	Rec	1446	6.736	604	-	475	475	0.57
D59	Rec	964	6.102	1996	-	425	400	1.90
D61	Rec	482	5.148	2895	-	325	300	2.75
D63	Rec	5061	9.109	2795	-	775	775	2.66
D64	Rec	1446	6.736	741	-	475	475	0.70
D65	Round	241	4.336	1028	280	-	-	0.98
D66	Round	241	4.34	836	280	-	-	0.79
D67	Rec	964	6.102	1346	-	425	400	1.28
D68	Rec	482	5.148	2895	-	325	300	2.75
D69	Rec	241	4.34	453	280	-	-	0.43
D70	Rec	241	4.34	426	280	-	-	0.40
D71	Rec	3615	8.403	2707	-	750	700	2.57
D72	Rec	482	5.148	3735.5	-	350	350	3.55
D73	Rec	241	1.967	3735.5	-	350	350	3.55
D74	Rec	3133	8.12	1487	-	700	700	1.41
D75	Rec	1446	6.736	566	-	475	475	0.54
D76	Rec	241	4.34	734	-	475	475	0.70
D77	Round	241	4.34	700	300	-	-	0.67
D78	Rec	964	6.102	1596	-	425	400	1.52
D79	Round	241	4.34	291	300	-	-	0.28
D80	Round	241	4.34	391	300	-	-	0.37
D81	Rec	482	5.148	2895	-	325	300	2.75
D82	Round	241	4.34	265	300	-	-	0.25
D83	Round	241	4.34	400	300	-	-	0.38
D84	Rec	1687	6.992	5691	-	525	500	5.41
D85	Rec	1205	6.444	1921	-	450	450	1.82
D87	Round	241	4.34	123	280	-	-	0.12
D88	Round	241	4.34	160	300	-	-	0.15

Duct Name	Type	Q L/s	V (m/s)	L(mm)	D (mm)	W (mm)	H (mm)	ΔP (Pa)
D89	Rec	723	5.688	847	-	375	350	0.80
D90	Round	241	4.34	3192	280	-	-	3.03
D91	Round	241	4.34	696	280	-	-	0.66
D92	Rec	482	5.148	722	-	325	300	0.69
D93	Round	241	4.34	134	280	-	-	0.13
D94	Round	241	4.34	192	280	-	-	0.18
D95	Rec	725	5.692	991	-	375	350	0.94
D96	Rec	683	5.609	3225	-	375	375	3.06
D97	Rec	66	3.129	132	-	150	150	0.13
D98	Rec	66	3.129	692	-	150	150	0.66
D99	Rec	617	5.47	4400	-	350	350	4.18
D100	Rec	64	3.1	7743	-	150	150	7.36
D101	Rec	553	5.326	1270	-	350	325	1.21
D102	Rec	108	3.546	633	-	175	175	0.60
D103	Round	54	2.97	2800	150	-	-	2.66
D104	Round	54	2.97	435	150	-	-	0.41
D105	Rec	445	5.048	2625	-	325	300	2.49
D106	Rec	152	3.864	5499	-	250	225	5.22
D107	Round	66	3.129	378	180	-	-	0.36
D108	Rec	86	3.347	2326	-	200	200	2.21
D109	Rec	86	3.347	387	-	175	150	0.37
D110	Round	86	3.347	538	180	-	-	0.51
D111	Rec	293	4.55	3035	-	250	225	2.88
D112	Rec	30	2.55	829	-	125	100	0.79
D113	Rec	263	4.43	1952	-	225	225	1.85
D114	Rec	45	2.83	1657	-	125	100	1.57
D115	Round	45	2.83	590	150	-	-	0.56
D116	Rec	218	4.22	1740	-	200	200	1.65
D117	Rec	45	2.83	1915	-	150	125	1.82
D118	Round	45	2.83	417	150	-	-	0.40
D119	Rec	173	3.99	1258	-	175	175	1.20
D120	Rec	112	3.578	8643	-	150	125	8.21
D121	Rec	64	3.105	432	-	175	150	0.41
D122	Rec	64	3.105	237	-	175	150	0.23
D123	Rec	48	2.88	2468	-	150	140	2.34
D124	Rec	48	2.88	2229	-	150	125	2.12
D125	Rec	48	2.88	230	-	150	125	0.22
D126	Round	48	2.88	490	160	-	-	0.47
D127	Rec	61	3.06	1564	-	150	150	1.49
D128	Rec	61	3.06	972	160	-	-	0.92
D129	Rec	61	3.06	236	160	-	-	0.22
D130	Rec	61	3.06	167	160	-	-	0.16
D131	Rec	9080	10.47	11372	-	950	950	10.80
D132	Rec	9080	10.47	2142	-	950	950	2.03

Chapter Five

Single element for longest path

Element	Symbol	Q	Input Dim		Output Dim		L(mm)	L _{eq} (m)	ΔP (Pa)
			W (mm)	H (mm)	W (mm)	H (mm)			
Contraction	c1	617	375	350	350	350	70	2.5	2.44
	c2	553	350	350	350	325	337	2.5	2.70
	c3	445	350	325	325	300	325	2.5	2.68
	c4	392	325	300	250	225	275	2.5	2.64
	c5	263	250	225	225	225	237	2.5	2.60
	c6	218	225	225	200	200	212	2.5	2.58
	c7	173	200	200	175	175	187	2.5	2.55
	c8	112	175	175	150	125	150	2.5	2.52
	c9	48	200	200	150	140	100	2.5	2.47
	c10	9080	975	950	1200	750	311	2.5	2.67
	c11	725	375	950	375	350	362	2.5	2.72
Expansion	E1	112	150	125	200	200	100	6	5.80
	E2	48	150	125	250	200	187	6	5.88
	E3	9080	800	800	950	950	221	6	5.91
Rec-elbow	e1	48	150	140	150	140	353	5	5.09
	e2	48	150	125	150	125	863	5	5.57
	e3	9080	950	950	950	950	2862	5	7.47
	e4	9080	950	950	950	950	2086	5	6.73
	e5	9080	950	950	950	950	2513	5	7.14
	e6	9080	950	950	950	950	2238	5	6.88

Double and triple element for longest path

Element	Symbol	Type	Input specs			Output specs			L(mm)	L _{eq} (mm)	ΔP (Pa)
			Q (L/s)	W (mm)	H (mm)	Q(L/s)	W(mm)	H(mm)			
Branch Tee 90°	Tt1	main	725	375	350	683	375	375	475	3	3.30
	Tt2	br-D99	683	375	375	617	350	350	475	18	17.55
	Tt3	main	617	350	350	553	350	325	450	3	3.28
	Tt4	main	553	350	325	445	325	300	450	3	3.28
	Tt5	main	445	325	300	293	250	225	425	3	3.25
	Tt6	main	293	250	225	263	225	225	350	3	3.18
	Tt7	main	263	225	225	218	200	200	325	3	3.16
	Tt8	br-D117	218	200	200	45	150	125	300	18	17.39
	Tt9	br-D120	173	175	175	112	150	125	275	18	17.36
	Tt10	main	112	200	200	48	200	200	300	3	3.14
Cross connection	X1	br-D95	9080	1200	750	725	375	950	1022	18	18.07

Devices for longest path

Name	ΔP
V.A.V.	25
Flex connection	5.7
Filter	70
Coil	80
Mix Dumper	25
diffuser	9

For longest path $\Delta P = 432.43 \text{ Pa}$

Chapter Five

3rd floor Supply duct design

By equal friction method (and $pf/m = .95 \text{ Pa/m}$ constant through the duct network)

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	$\Delta P(\text{Pa})$
D00	Rec	4598	8.9	2457	-	750	725	2.33
D1	Rec	4598	8.9	1992	-	750	725	1.89
D2	Rec	1566	6.867	600	-	500	490	0.57
D3	Rec	1566	6.87	2116	-	500	490	2.01
D4	Round	261	4.42	1114	280	-	-	1.06
D5	Round	261	4.42	1664	280	-	-	1.58
D6	Rec	1044	6.22	2539	-	425	425	2.41
D7	Round	261	4.42	1164	280	-	-	1.11
D8	Round	261	4.42	3419	280	-	-	3.25
D9	Rec	522	5.25	2824	-	325	325	2.68
D10	Round	261	4.42	1038	273	-	-	0.99
D11	Round	261	4.42	3037	280	-	-	2.89
D12	Round	261	4.42	1364	280	-	-	1.30
D13	Rec	3023	8.05	5214	-	630	625	4.95
D14	Rec	1302	6.56	1600	-	460	450	1.52
D15	Round	651	5.54	1432	400	-	-	1.36
D16	Rec	1721	7.02	1805	-	510	500	1.71
D17	Rec	976	6.12	1137	-	425	410	1.08
D18	Rec	858	5.93	519	-	400	395	0.49
D19	Rec	286	4.52	581	-	265	250	0.55
D20	Round	143	3.8	1064	224	-	-	1.01
D21	Round	143	3.8	1257	224	-	-	1.19
D22	Rec	572	5.37	1530	-	350	335	1.45
D23	Round	143	3.8	600	224	-	-	0.57
D24	Round	143	3.8	1089	224	-	-	1.03
D25	Rec	286	4.52	3024	-	265	250	2.87
D26	Round	143	3.8	1135	224	-	-	1.08
D27	Round	143	3.8	1135	224	-	-	1.08
D28	Rec	118	3.62	1442	-	185	175	1.37
D29	Rec	118	3.62	4206	-	185	175	4.00
D30	Rec	118	3.62	443	-	185	175	0.42
D31	Rec	118	3.62	1029	-	185	175	0.98
D32	Round	59	3.04	222	160	-	-	0.21
D33	Round	59	3.04	1012	160	-	-	0.96
D34	Rec	745	5.73	805	-	375	375	0.76
D35	Rec	745	5.73	1017	-	375	375	0.97
D36	Rec	140	3.78	3351	-	200	200	3.18
D37	Rec	140	3.78	4919	-	200	200	4.67
D38	Rec	28	2.5	508	-	110	100	0.48
D39	Rec	112	3.57	1590	-	180	175	1.51
D40	Rec	56	3	5942	-	145	125	5.64
D41	Round	28	2.5	2392	200	-	-	2.27

Duct Name	Type	Q (L/s)	V (m/s)	L (mm)	D (mm)	W (mm)	H(mm)	ΔP (Pa)
D42	Round	28	2.5	2082	200	-	-	1.98
D43	Round	28	2.5	4559	200	-	-	4.33
D44	Rec	56	3	1248	-	145	125	1.19
D45	Round	28	2.5	1996	200	-	-	1.90
D46	Round	28	2.5	701	200	-	-	0.67
D47	Rec	605	5.44	1598	-	350	340	1.52
D48	Rec	311	4.62	3113	-	300	300	2.96
D49	Rec	207	4.17	2945	-	250	250	2.80
D50	Rec	106	3.52	3524	-	200	200	3.35
D51	Round	53	2.95	854	200	-	-	0.81
D52	Round	53	2.95	555	200	-	-	0.53
D53	Round	101	3.48	656	200	-	-	0.62
D54	Round	104	3.51	744	200	-	-	0.71
D55	Round	101	3.48	727	200	-	-	0.69
D56	Round	143	3.8	459	200	-	-	0.44
D57	Rec	193	4.1	1868	-	250	250	1.77
D58	Rec	50	2.91	6277	-	150	150	5.96
D59	Rec	50	2.91	3752	-	150	150	3.56
D60	Rec	50	2.91	3194	-	150	150	3.03
D61	Round	50	2.91	1780	200	-	-	1.69

Single element longest three paths

Element	Symbol	Q	Input Dim		Output Dim		L(mm)	L _{eq} (m)	ΔP (Pa)
			W (mm)	H(mm)	W(mm)	H(mm)			
Contraction	c0	4598			750	725	700	2.5	3.04
	c4	3023	750	725	630	625	687	2.5	3.0277
	c6	1721	630	625	510	500	565	2.5	2.9118
	c7	976	510	500	425	410	460	2.5	2.812
	c12	118	425	410	185	125	300	2.5	2.66
	c13	745	510	500	375	375	442	2.5	2.7949
	c14	140	375	375	200	200	287.5	2.5	2.6481
	c16	112	200	200	180	175	187.5	2.5	2.5531
	c18	56	180	175	145	125	165	2.5	2.5318
	c19	605	375	375	350	340	357.5	2.5	2.7146
	c29	193	350	340	250	250	275	2.5	2.6363
	c31	50	250	250	150	150	171.5	2.5	2.5379
Expansion	c32	50	D=400		D=200		200	2.5	2.565
	E7	118	185	175	850	500	512	6	6.1864
	E8	140	200	200	850	500	525	6	6.1988
	E15	50	150	150	850	500	500	6	6.175
conv-cont	E16	56	145	125	200	200	175	6	5.8663
	conv-c14	118	D=400		185	175	600	1.5	1.995
	conv-c16	59	D=160		185	175	240	1.5	1.653
	conv-c17	140	D=400		200	200	600	1.5	1.995
conv-cont	conv-c19	28	D=200		200	200	300	1.5	1.71
	conv-c21	28	D=200		200	200	300	1.5	1.71

Chapter Five

Rec-elbow	e0	4598	750	725	750	725	1255	5	5.9423
	e00	4598	750	725	750	725	1255	5	5.9423
	e2	118	185	175	185	175	864	5	5.5708
	e3	118	185	175	185	175	864	5	5.5708
	e4	118	185	175	185	175	864	5	5.5708
	e9	50	150	150	150	150	864	5	5.5708
	e10	50	150	150	150	150	864	5	5.5708
	e11	50	150	150	150	150	864	5	5.5708
	e12	745	375	375	375	375	2000	5	6.65
	e13	745	375	375	375	375	2000	5	6.65
	e14	28	D=200		D=200		314	3	3.1483
	e15	28	D=200		D=200		314	3	3.1483
	e16	28	D=200		D=200		314	3	3.1483
	e17	28	D=200		D=200		314	3	3.1483

Double elements longest three paths

Element	Symbol	Type	Input specifications			Output specifications			L(mm)	L _{eq} (m)	ΔP(Pa)
			Q(L/s)	W(mm)	H(mm)	Q(L/s)	W(mm)	H(mm)			
Wye Tee	Ty4	br-D33	118	185	175	28	185	175	285	22	21.17
		br-D32	118	185	175	112	185	175	285	22	21.17
	Ty5	br-D38	140	200	200	28	200	200	300	22	21.19
		br-D39	140	200	200	112	200	200	300	22	21.19
Branch Tee 90°	Tt1	main	4598	750	725	1566	750	725	850	3	3.66
		br-D13	4598	750	725	261	750	725	850	18	17.91
	Tt3	main	3023	630	625	1721	630	625	730	3	3.54
		br-D14	3023	630	625	1302	630	625	730	18	17.79
	Tt5	main	1721	510	500	745	510	500	630	3	3.45
		br-D17	1721	510	500	976	510	500	630	18	17.70
	Tt6	main	976	425	410	858	425	410	525	3	3.35
		br-D28	976	425	410	118	425	410	525	18	17.60
	Tt7	main	745	375	375	605	375	375	475	3	3.30
		br-D36	745	375	375	140	375	375	475	18	17.55
	Tt8	main	112	180	175	56	180	175	280	3	3.12
		br-D40	112	180	175	56	180	175	280	18	17.37
	Tt9	main	56	200	200	28	200	200	300	3	3.14
		br-cc22	56	200	200	28	200	200	300	18	17.39
Cross connection	X4	main	193	250	250	50	250	250	350	3	3.18
		br-c29	193	250	250	143	250	250	350	18	17.43
		main	605	350	340	101	200	340	350	3	3.18
		br-D48	605	350	340	311	300	340	350	18	17.43
		br-D57	605	350	340	193	300	340	350	18	17.43

Devices for longest path

Name	ΔP
V.A.V.	25
Flex connection	5.7
Filter	70
Coil	80
Mix Dumper	25
diffuser	9

For longest path $\Delta P = 407 \text{ Pa}$

Chapter Six

Units Selection




Chapter Six

6.1 Air Handling Units Selection:

From Carrier Catalogs

Floor No	Air Handling Unit Data					
	Model	Q (l/s)	V (m/s)	L (mm)	H (mm)	W (mm)
Ground 1	39FD350	3135	3.15	3830	995	1625
Ground 2	39FD450	4144	3.15	3830	1310	1625
1st floor	39FD480	7536	3.15	2255	1310	2570
2nd floor	39FD670	9054	3.15	3200	1940	2255
3rd floor	39FD450	4576	3.15	3830	1310	1625



6.2 Cooling Coils Selection :

Floor No	Cooling Coil Data									
	Q (l/s)	V (m/s)	Face Area (m ²)	Fins Pitch (mm)	PBF	ADP (°C)	Cooling Capacity (KW)	No Of Rows	Water Temp.Rise (°C)	Water Press. Drop (KPa)
G -1	3135	3.15	1.44	3	0.3		160.6	4	7	24.7
G -2	4144	3.15	1.68	3	0.18		229.5	6	7	33.2
1st	7536	3.15	3.3	3	0.29		372	4	8	31
2nd	9054	3.15	3.59	3	0.29		460.4	6	10	22.5
3rd	4576	3.15	2.07	3	0.16		272.8	6	8	34.2




Fig (6-1): Cooling Coil

6.2 Filters Selection :




Fig (6-2): Filter Rating and Performance for Panel and Bag Filter

AHU	Filter Data "Panel Filter"						
	V (m/s)	Press. Drop (Pa)	Cell Quantity	Filter Size		Frame Size	
				H(mm)	W(mm)	H(mm)	W(mm)
G -1	3.15	50	2	390	493	410	510
G -2	3.15	50	2	493	595	510	510
1st	3.15	50	2	595	595	605	605
2nd	3.15	50	2	493	493	510	605
3rd	3.15	50	2	493	493	510	605

Panel filter Bag filter





Fig (6-3): Panel and Bag Filter


6.3 Mixing damper selection :

A H U	Mixing Damper Data		
	H(mm)	W(mm)	Weight(kg)
G-1	578	1625	44.8
G-2	578	1625	44.8
1st	893	2386	80.6
2st	893	2255	83.5
3st	735	1625	48.3




Fig(6-4) Fresh and mixing and exhaust damper

6.4 Fans Selection :




Supply fan (Backward Blade Fane)

AHD	Backward Blade Fane							
	Q (L/S)	Q (m3/s)	P.D (pa)	V (m/s)	D (mm)	RPM	η	Motor power(kw)
G-1	3135	3.135	537.8	4	710	800	74	2.2
G-2	4144	4.144	703.5	3.15	1000	700	58	7
1st	7536	7.536	614.9	4.8	1000	630	75	6
2nd	9054	9.054	432.4	5.5	1000	550	79	5
3rd	4576	4.576	407	3.15	1000	500	65	2.5




(Fig 6-5) Performance curve for backward blade fan with diameter 710 mm



(Fig. 6.6) Performance curve for backward blade fan with diameter 1000mm

Chapter Seven

Chilled Water System



Chapter Seven

1. Chilled water systems description

A chilled water system is a means by which heat, generated in a space or by a process, is conveyed from that space and ultimately released to the outside.

System functions:

Basically, a chilled water system circulates the chilled water through a loop piping system. Pumps force the water from the water chiller through the heat transfer components and back to the chiller via the piping system. Heat is transferred to the chilled water as it circulates through the heat transfer device that causes the temperature of the chilled water to increase. The portion of the system that supplies the water from the chiller to the heat transfer equipment is typically designated the chilled water supply system. Once the water is through this heat transfer equipment, the piping system delivering it back to the chiller is termed the chilled water

2. Chilled water systems major components

Chilled water systems are generally comprised of the following major system components:

- a. *Chillers.* The most common chilled water air-conditioning system is a single compressor and refrigerant circuit using a water-cooled condenser. It is relatively simple and compact. Compression type refrigeration liquid chilling equipment ranges in size from quite small to those with capacities in the thousands of tons (1 ton equals 12,000 BTU per hour of cooling). The three categories of chillers are those which use reciprocating compressors, centrifugal compressors, and rotary screw type compressors. Control of water chillers is typically based on the return water temperature. The return water temperature indicates the cooling load in the facility at any given time. The warmer the chilled water return temperature, the larger the facility cooling loads.
- b. *Pumps.* The type of pump used to distribute chilled water through the chilled water system varies with the system design. There are two basic types of pumps: positive displacement and centrifugal.
- c. *Expansion tanks.* Expansion tanks are used in chilled water systems to allow for thermal expansion of the chilled water that, if not for the expansion tank, could damage the piping system.
- d. *Control valves.* Control valves are used in chilled water systems to control the flow of chilled water through the piping system. The control system positions the valve through a valve operator or actuator that is directly attached to the valve stem. The valve operator or actuator uses electricity, compressed air, or hydraulic fluid to move the valve stem through its operating range.
- e. *Strainers.* Strainers are defined as closed vessels with cleanable screen elements designed to remove and retain foreign particles down to 0.001 inch diameter from various flow fluids. A strainer differs from a filter in that strainers trap particles that are typically visible to the naked eye. Strainers are typically installed in chilled water systems on the inlet (suction) side of the distribution pumps.
- f. *Air separators.* All chilled water systems use air separators to remove air (gas) bubbles that have become entrained in the water.
- g. *Valves.* Valves installed in the chilled water system are used to control water flow and to isolate equipment for ease of maintenance. Most valves in a chilled water system are manually operated with a handwheel or lever operator.

- Valves are typically installed at the following:

(a) On the inlet and outlet connection of each piece of equipment, including chillers pumps, reducing valves, control valves, tanks, coils, and other equipment that requires periodic maintenance.

(b) On the supply and return branch lines at the point of connection to the main supply and return piping headers.

(c) Drain valves are installed at low points in the water distribution system to facilitate draining of the system.

(d) Vent valves should be installed at all high points in the chilled water piping system for manual venting of air from the system and to help in the draining of the piping.

The most common types of valves utilized in chilled water systems include gate, ball, butterfly, globe, check, and pressure regulating valves. The general characteristics of these valves are described below. Illustrations of these valves are located on figures 7-1 and 7-2.

(a) Gate valves are identified by a wedge-shaped disk that is raised to open or lowered to close the valve. Gate valves are intended to operate fully open or fully closed, and have very low resistance to flow in the open position, since the disk rises out of the flow path. The gate valve should not be operated in the partially open position, as this may cause vibration and premature wear on the disk. The gate valve may be used for shutoff service where a slow closure is acceptable and where an absolute bubble tight closure is not a critical consideration.

(b) Ball valves use a ball as the opening/closing mechanism to control fluid flow. The ball is rotated 90 degrees from full open to full closed; therefore, it is well-suited for applications which require quick or frequent opening and closing.

(c) Butterfly valves in the chilled water system are most common in the larger sizes due to the ease of operation, low cost, and superior shutoff characteristics. Like the ball valve, a 90-degree rotation of the operating mechanism results in valve travel from closed to full open. The butterfly valve is well-suited for both on/off service or throttling service.

(d) Globe valves are primarily used for throttling service and are not well-suited for full flow applications due to the high resistance to flow designed into the valve. The standard valve consists of a round disk or tapered plug that seat against a round opening. Unlike the gate and ball valves, globe valves must be installed in the proper direction of flow. Flow should enter through the disk seat and push up against the valve disk. Reverse installation will result in valve chatter, vibration, and premature valve failure.

(e) Check valves are used in the chilled water system to prevent reversal of flow at pumps and equipment.

(f) Water pressure regulating valves are used in the chilled water system to limit the water supply pressure to equipment within acceptable levels. The two common types of water pressure regulating valves include the direct-acting type and the pilot-operated type.

Chapter Seven




Figure 7.1. Typical valves used in water service




Figure 7.2. Typical valves used in water service

Water piping design:

There is a friction loss in pipe through which water is flowing.
These losses depends the following factors:

- 1- Water velocity
- 2- Water length and diameter
- 3- Interior surface roughness

To properly design a water piping system, the engineer must evaluate not only the pipe friction loss but also through valves, fitting

Water Velocity and Pressure Drop

The velocity should not exceed 2.4 (m/s) in order to avoid noise and corrosion
The pressure drop should not exceed 500 (pa/L).

Corrosion results in an increase in the friction factor and a in the effective diameter.

Design procedure:

Using Darcy formula in Hardy-Cross method using Excel as follows:

$$h_l = KQ^n \quad \text{Eqn (7.1)}$$

Where:

$n=2$

$$K = \frac{8*f*L}{g*\Pi^2*D^5} \quad \text{Eqn (7.2)}$$

$$f = \frac{0.3086}{\left[\log\left(\frac{6.9}{Re} + \left(\frac{\epsilon}{3.7D}\right)^{1.11}\right)\right]^2} \quad \text{Eqn (7.3)}$$

$$Re = \frac{V*D}{\nu} \quad \text{Eqn (7.3)}$$

$$\frac{dh_l}{dQ} = n * K * |Q^{n-1}| \quad \text{Eqn (7.4)}$$

$$\Delta Q = \frac{-\sum h_l}{\sum dh_l/dQ} \quad \text{Eqn (7.5)}$$

$$\sum h_l = 0.0 \quad \text{Eqn (7.6)}$$




Fig. (7.3) Simple diagram of water system

Chapter Seven

Assume H_p and iterate Gives the solution as following:

Table (7.1): Standard Diameter of Pipes:

pipe	Qw (m ³ /s)	d (m)	d (in)	standard d (in)	nominal size	d (m)	v (m/s)
1	0.005602	0.054531	2.146902	2.469	2.5	0.062713	1.814652
2	0.008109	0.126587	4.983753	5.047	5	0.128194	0.628602
3	0.008109	0.065607	2.582947	3.068	3	0.077927	1.701107
4	0.008109	0.126587	4.983753	5.047	5	0.128194	0.628602
5	0.003814	0.044991	1.771306	2.067	2	0.052502	1.762454
6	0.013712	0.126587	4.983753	5.047	5	0.128194	1.062881
7	0.013712	0.126587	4.983753	5.047	5	0.128194	1.062881
8	0.005151	0.052287	2.058541	2.067	2	0.052502	2.380397
9	0.017525	0.126587	4.983753	5.047	5	0.128194	1.3585
10	0.017525	0.126587	4.983753	5.047	5	0.128194	1.3585
11	0.007514	0.063153	2.486336	3.068	3	0.077927	1.576232
12	0.022676	0.126587	4.983753	5.047	5	0.128194	1.757767
13	0.022676	0.126587	4.983753	5.047	5	0.128194	1.757767
14	0.03019	0.126587	4.983753	5.047	5	0.128194	2.340225

Table (7.2): Elements Loss Coefficient:

element	C
90° elbow	0.75
Tee main	0.4
Tee branch	1
gate valve open	0.17
globe valve	6.4
coupling	0.04
flex connection	0.05

$$\varepsilon = 4.5E-5 \text{ mm}$$

$$v = 1E-6 \text{ m}^2/\text{s}$$

$$H_{\text{pump}} = 10 \text{ m} \quad \text{"Initial guess"}$$

$$H_{\text{pump-actual}} = 7.7 \text{ m}$$

$$\begin{aligned} \text{Pump Power} &= \gamma \cdot Q \cdot H / \eta = 2.28 \text{ KW} \\ &= 3 \text{ hp} \end{aligned}$$


Chilled Water System

loop	pipe	common	D	L	Qo	V	E/D	Re	F	K	hlf	hld	hlp	dhf/dQ	dhld/dQ	dQ	Qnew
1	1	2	0.0627	4.75	0.0056	1.8147	0.0007	113802	0.0207	8365.9	0.2626	0.6504		93.738	232.2		0.0053
	2		0.1282	3	-0.0081	0.6286	0.0004	80583	0.0201	143.84	-0.0095	-0.0128		2.3329	3.1587		-0.008
	3		0.0779	3.59	-0.0081	1.7011	0.0006	132562	0.0188	2041.1	-0.1342	-0.7766		33.104	191.53	9E-05	-0.008
	4		0.1282	4	-0.0081	0.6286	0.0004	80583	0.0201	191.79	-0.0126	-0.0196		3.1105	4.8434		-0.008
	sum										-0.052307035			564.0212396			
2	1	1	0.0627	4.75	-0.0056	1.8139	0.0007	113753	0.0207	8366.3	-0.2624	-0.6499		93.702	232.1		-0.0053
	5	3	0.0779	13.5	0.00381	0.8	0.0006	62341	0.0217	8440.7	0.1228	0.6067		64.379	318.17	0.0004	0.0052
	6		0.1282	5	-0.01371	1.0629	0.0004	136255	0.0186	222.41	-0.0418	0		6.0992	0		-0.0133
	7		0.1282	4.15	-0.01371	1.0629	0.0004	136255	0.0186	184.6	-0.0347	-0.0195		5.0624	2.8485		-0.0133
	sum										-0.278856505			722.366889			
3	5	2	0.0779	13.5	-0.0038	0.7992	0.0006	62283	0.0217	8441.9	-0.1225	-0.6055		64.327	317.87		-0.0051
	8	4	0.0625	3.76	0.00515	2.3804	0.0009	124975	0.021	16390	0.4348	1.474		168.84	572.36	-0.001	0.0026
	9		0.1282	2.2	-0.01753	1.3585	0.0004	174151	0.0181	95.021	-0.0292	0		3.3305	0		-0.0185
	10		0.1282	3	-0.01753	1.3585	0.0004	174151	0.0181	129.57	-0.0398	-0.0319		4.5416	3.6408		-0.0185
	sum										1.079871776			1134.90751			
4	8	3	0.0525	3.76	-0.0052	2.3801	0.0009	124958	0.021	16390	-0.4347	-1.4736		168.82	572.28		-0.0026
	11	5	0.0779	5.4	0.00751	1.5762	0.0006	122831	0.0199	3094.8	0.1747	0.6668		46.509	177.47	0.0016	0.0169
	12		0.1282	6.8	-0.02268	1.7578	0.0004	225335	0.0176	285.84	-0.147	-0.1001		12.963	8.8328		-0.0211
	13		0.1282	6.881	-0.02268	1.7578	0.0004	225335	0.0176	289.25	-0.1487	-0.1536		13.118	13.544		-0.0211
	sum										-1.61624341			1013.533594			
5	14		0.1282	69	-0.0302	2.3402	0.0004	300004	0.0171	2826.7	-2.5764	-2.3215	10	170.68	153.79	-0.0078	-0.038
	11	4	0.0779	5.4	-0.0075	1.5754	0.0006	122767	0.0199	3095	-0.1746	-0.6661		46.487	177.38		-0.0169
	sum										4.261495107			548.3366812			

loop	pipe	common	D	L	Qo	V	E/D	Re	F	K	hlf	hld	hlp	dhlf/dq	dhl/dq	dq	Qnew
1	1	2	0.06271	4.75	0.00579	1.87384	0.00072	117513	0.02059	8339.38	0.2791	0.69357		96.4886	239.776		0.00579
	2		0.12819	3	-0.0081	0.6311	0.00035	80903.7	0.02006	143.753	-0.0095	-0.0129		2.34073	3.17132		-0.0081
	3		0.07793	3.59	-0.0081	1.70788	0.00058	133090	0.01975	2040.27	-0.1352	-0.7828		33.2218	192.295	0.00000	-0.0081
	4		0.12819	4	-0.0081	0.6311	0.00035	80903.7	0.02006	191.67	-0.0127	-0.0198		3.12097	4.86289		-0.0081
	sum										-0.000294894			575.2766667			
2	1	1	0.06271	4.75	-0.0058	1.87307	0.00072	117465	0.02059	8339.71	-0.2789	-0.693		96.4528	239.677		-0.0058
	5	3	0.07793	13.5	0.004633	0.97195	0.00058	75741.5	0.02112	8207.87	0.1762	0.89553		76.0595	386.562	0.00000	0.00463
	6		0.12819	5	-0.01393	1.07955	0.00035	138391	0.01858	221.973	-0.0431	0		6.18268	0		-0.0139
	7		0.12819	4.15	-0.01393	1.07955	0.00035	138391	0.01858	184.238	-0.0357	-0.0201		5.13162	2.89321		-0.0139
	sum										0.000931161			812.9591895			
3	5	2	0.07793	13.5	-0.0046	0.9712	0.00058	75682.6	0.02113	8208.75	-0.1759	-0.8941		76.0085	386.261		-0.0046
	8	4	0.0525	3.76	0.004043	1.86825	0.00086	98086.5	0.0215	16759.1	0.27388	0.90798		135.498	449.213	0.00000	0.00404
	9		0.12819	2.2	-0.01856	1.43871	0.00035	184434	0.01796	94.4177	-0.0325	0		3.50478	0		-0.0186
	10		0.12819	3	-0.01856	1.43871	0.00035	184434	0.01796	128.751	-0.0444	-0.0358		4.77924	3.85577		-0.0186
	sum										-0.000890625			1059.120697			
4	8	3	0.0525	3.76	-0.004	1.86792	0.00086	98069.2	0.0215	16759.4	-0.2738	-0.9077		135.477	449.133		-0.004
	11	5	0.07793	5.4	0.010808	2.26714	0.00058	176672	0.01923	2988.3	0.34904	1.37938		64.5922	255.283	0.00000	0.01081
	12		0.12819	6.8	-0.0226	1.75207	0.00035	224605	0.0176	285.932	-0.1461	-0.0995		12.9256	8.80423		-0.0226
	13		0.12819	6.881	-0.0226	1.75207	0.00035	224605	0.0176	289.338	-0.1478	-0.1526		13.0795	13.4998		-0.0226
	sum										0.0010253			952.774734			
5	14		0.12819	69	-0.0334	2.58985	0.00035	332003	0.01701	2803.98	-3.1299	-2.8432	7.7	187.363	170.199	0.00000	-0.0334
	11	4	0.07793	5.4	-0.0108	2.26631	0.00058	176607	0.01923	2988.39	-0.3488	-1.3784		64.5707	255.17		-0.0108
	sum										-0.000264068			677.3023559			

Chapter Eight

Operation Control By Building Management System (BMS)



8.1 Introduction

The objective of a BMS is to centralize and simplify the monitoring, operation, and management of buildings. This is done to achieve more efficient building operation at reduced labor and energy costs and provide a safe and more comfortable working environment for building occupants. In the process of meeting these objectives, the BMS has evolved from simple supervisory control to totally integrated computerized control. Some of the advantages of a BMS are as follows:

- Simpler operation with routine and repetitive functions programmed for automatic operation
- Reduced operator training time through on-screen instructions and supporting graphic displays
- Faster and better responsiveness to occupant needs and trouble conditions
- Reduced energy cost through centralized management of control and energy management programs
- Better management of the facility through historical records, maintenance management programs, and automatic alarm reporting
- Flexibility of programming for facility needs, size, organization, and expansion requirements
- Improved operating-cost record keeping for allocating to cost centers and/or charging individual occupants
- Improved operation through software and hardware integration of multiple subsystems such as direct digital control (DDC), fire alarm, security, access control, or lighting control

8.2 Definitions

- **Building Control System (BCS):** A system that controls the comfort and safety of a buildings assets and environment.
- **Building Management System (BMS):** A system which centralizes the monitoring, operations, and management of a building to achieve more efficient operations.
- **Building Management and Control System (BMCS):** An integrated BMS and BCS
- **Building Automation and Control Network (BACnet) Protocol:** A BMCS communications protocol developed by the American Society of Heating, Refrigerating, and Air Conditioning Engineers (ASHRAE).
- **Dynamic Display Data:** Data displayed on a BMCS work station which periodically updates, such as temperature or ON/OFF status. The data updates automatically at a rate appropriate for the point or it may be updated manually.

Chapter Eight

- **Energy Management System (EMS):** A system that optimizes the operation, temperatures, and processes of an HVAC system within a building. Except for some early versions, a BCS or BMCS includes all EMS functions.
- **Hierarchical configuration:** A system in which the processors and controllers are arranged in levels or tiers, with each tier having a definite rank or order in accessing and processing data. A typical arrangement includes, in descending order, management-level processors, operations-level processors, system-level controllers, and zone-level controllers.
- **Management-level processor:** A PC or minicomputer used by management personnel to collect, store, and process data for reports on energy use, operating costs, and alarm activity. This processor can access points or data in all the lower level processors and controllers. (In most cases a separate, management-level processor is not used. Many of the functions of the management-level processor can be combined into the operations-level processor.)
- **Operations-level processor:** A PC or other device used primarily by building operation personnel for everyday building operations. This processor can access points or data in all the lower level controllers.
- **System-level controller:** A microprocessor-based controller that controls centrally located HVAC equipment such as VAV supply units, built-up air handlers, and central chiller and boiler plants. These controllers typically have an input/output (I/O) device capability, a library of control programs, and may control more than one mechanical system from a single controller. In a BMS, these controllers provide processing of point data for higher level processors and typically include energy management programs.

8.3 System configuration

A BMS includes the hardware configuration and communication systems needed to access data throughout a building or from remote buildings using leased telephone lines.

8.4 Hardware configuration

Microprocessor-based controllers have led to a hierarchical configuration in the BMS. Figure 8.1 shows several levels, or tiers, of processors.

- Management-level processors
- Operations-level processors
- System-level controllers
- Zone-level controllers

The actual levels used in a given system depend on the specific needs of the building or complex of buildings.




Fig.8.1 Hierarchical BMS Configuration

8.4.1 Zone-level controllers

Zone-level controllers are microprocessor-based controllers that provide direct digital control of zone-level equipment, including items such as VAV boxes, heat pumps, single-zone air handlers, and perimeter radiation. At the zone level, sensors and actuators interface directly with the controlled equipment. A communications bus provides networking of zone-level controllers so that point information can be shared between zone-level controllers and with processors at the system and operation level. Zone-level controllers typically have a port or communications channel for use of a portable terminal during initial setup and subsequent adjustments.

8.4.2 System-level controllers

Microprocessor-based system-level controllers have greater capacity than zone-level controllers in terms of number of points, DDC loops, and control programs. System-level controllers are usually applied to major pieces of mechanical equipment such as large built-up air handlers, central VAV systems, and central chiller plants. These controllers can also perform lighting control functions. Controllers at this level interface with controlled equipment directly through sensors and actuators or indirectly through communications links with zone-level controllers. System-level controllers typically have a port for connecting portable operating and programming terminals during initial setup and subsequent adjustments.

8.4.3 Operations-level processors

Operations-level processors interface primarily with BMCS operating personnel. The processor at this level is in most cases a PC with color operator terminal displays and plug-in function boards to accommodate additional operator terminals, printers, memory expansion, and communications links. An operations-level processor generally includes application software for:

- **System security:** Limits access and operation to authorized personnel.
- **System penetration:** Permits authorized personnel to select and retrieve system data via PC keyboard or other selection mechanism.
- **Data formatting:** Assembles random system points into logical group format for display and printout.
- **Graphics:** Builds custom graphic displays incorporating dynamic system data. Bar chart and curve plot software may be included.




Fig.8.2 Top Level Graphic Display of a Two Building Facility.

- **Standard reports:** Provides automatic, scheduled, and by-request reports of alarm and operator activity. Also provides a broad range of system and category (points- in alarm, disabled points, etc.) summary reports.
- **Custom reports:** Provides spread sheet, word processing, and a data base management capability.
- **Maintenance management:** Automatically schedules and generates work orders for equipment maintenance based either on history of equipment run time or on a calendar schedule.

8.4.4 Management-level processors

Management-level processors, at the top of the BMCS system hierarchy, exercise control and management over the connected subsystems. An operator at this level can request data from and issue commands to points anywhere in the system (as with most operations-level processors). Day-to-day operation is normally a function of the operations-level processor; however, complete control can be transferred to the management-level processor during emergencies or unattended periods. The management-level processor primarily collects, stores, and processes historical data such as energy use, operating costs.

Operation

Operator access to the system is usually positioning the cursor (via a mouse) on a graphic display of a system.




Fig.8.3 Graphic sketch for Sequence of Operation

8.5 Air handling system control applications


Introduction

This section describes control applications for air handling systems commonly found in commercial buildings. The basic processes such as heating, cooling, humidification, dehumidification, and ventilation are presented individually then combined into typical air handling systems.

Abbreviations:


AHU	—Air Handling Unit	N.C	—Normally Closed
BCMS	—Building Control Management System	N.O	—Normally Open
CFM	—Cubic feet per minute	OA	—Outdoor Air
DB	—Dry Bulb	OAT	—Outdoor Air Temperature
DDC	—Direct Digital Control	P	—Proportional
DP	—Dew Point	PI	—Proportional-Integral
EA	—Exhaust Air	PID	—Proportional-Integral-Derivative
EPID	—Enhanced PID	RA	—Return Air
F	—Fahrenheit	RAT	—Return Air Temperature
IAQ	—Indoor Air Quality	RH	—Relative Humidity
MA	—Mixed Air	SA	—Supply Air
MAT	—Mixed Air Temperature	VAV	—Variable Air Volume
WB	—Wet Bulb		

Symbols:



8.5.1 Ventilation control processes

Fan system start-stop control




Item	No.	Function
	1	Supply fan starts and enables return fan start and system controls.
	2	SA smoke detector stops supply fan when smoke detected.
	3	RA smoke detector stops supply fan when smoke detected.
	4	Controller stops fan when low temperature detected.
	5	SA high static pressure control stops fan when unsafe pressure exists.
	6	Automatic fan system control subject to commendable ON-OFF-AUTO software point.
	7	Control program turns supply, return, and exhaust fan on and off dependent upon optimized time schedule, unoccupied space temperatures, and occupant override requests.
	8	Occupant override switch provides after hours operation when pressed.
	9	Duration of operation for override request.
	10	Space temperature (perimeter zone) inputs to optimum start-stop, unoccupied purge, and low limit programs.
	11	Set point at which unoccupied low-limit program executes.
	12	OA temperature input to optimum start-stop program.
	13	Return fan operation enables exhaust fan control program.
	14	Exhaust fan status (operator information).
	15	Warm-up mode status (operator information).
	16	Supply fan load (VAV type systems-operator information).
	17	Return fan load (VAV type systems-operator information).

Features

- Smoke, low temperature and high static pressure safety shutdown (hard-wired).
- optimized start-stop control of supply, return and exhaust fans.
- Proof of operation interlocking and alarming on supply and return fans.
- Software on-off-auto system command.
- Zero ventilation/exhaust during preoccupancy operational periods.
- May be modified for night purge and prepurge operation.
- After-hours operation function; duration is operator adjustable.
- Positions valves and dampers properly during off modes.
- Night low temperature operation.

Chapter Eight


8.5.2 Mixed air control



Item No. Function

- 1-3 Control system energizes when fan is turned on (See FAN SYSTEM START-STOP CONTROL).
- 4 MA temperature maintained by modulating mixing dampers.
- 5, 6 OA and EA dampers close and RA damper opens when fan is off, and modulate for temperature control when fan is on.
- 7 Set point for MA temperature control.
- 8 Damper control and set point for minimum ventilation damper position.
- 9 OA temperature, operator information.

8.5.3 Heating control processes




Item No. Function

- 1-2 Control system energizes when fan is turned on (See FAN SYSTEM START-STOP CONTROL).
- 3,5 SA temperature maintained by modulating the hot water valve.
- 4 Set point for SA temperature control.
- 6 Control program coordinates temperature control and fan interlock.

Features

- 1. Air is discharged at a minimum temperature.
- 2. Valve opens upon loss of motive force (electricity or compressed air) and closes upon fan shutdown.

8.5.4 Preheat control processes 'with face and bypass dampers'




Item No.	Function
1-2	Control system energizes when fan is turned on (See FAN SYSTEM START STOP CONTROL).
3	OA damper opens on fan startup, closes upon fan shutdown (in some cases the OA damper may be part of a mixed air system).
4	OA temperature determines valve position.
5	Valve controls heating medium flow to coil.
6	Control program coordinates fan interlock and valve control.
7	Valve position determined by OA temperature.
8-10	Face-and-bypass dampers controlled to maintain face-and-bypass leaving air temperature set point.
11	Control program coordinates fan interlock and face-and-bypass damper control.

Features

1. Preheat coil conditions large quantities of low temperature OA before it enters the system.
2. Bypass damper controls temperature of air leaving the face-and-bypass section without endangering the preheat coil which operates in full valve open mode during freezing conditions.
3. Upon fan shutdown, valve controls at 100°F leaving air temperature in freezing weather and positions closed upon fan shutdown in non-freezing weather.

8.5.5 Cooling control processes

Control of chilled water coil three-way valve



Item No.	Function
1	Control system energizes when fan is turned on (See FAN SYSTEM START-STOP CONTROL).
2, 3	Space temperature PID control loop modulates the three-way valve to maintain space temperature set point.
4	Chilled water valve directs flow through or around coil as needed to furnish proper amount of cooling.
5	Control program coordinates temperature control and fan status.

Features

1. Chilled water is supplied to the coil at a constant temperature and varying volume.
2. A reasonably constant flow is maintained through the entire piping system.

8.6 Building Airflow System Control Applications

8.6.1 Introduction

There are several types of airflow control that relate directly to the control of airflow in a central air handling system. These types of airflow control include space pressurization, zone pressurization, and exhaust air control. Space or zone pressurization is used when an enclosed area within a building (e.g., a clean room, hospital space, laboratory, fire and smoke control area) must be kept at a positive or negative pressure so contaminated air does not migrate to unwanted areas. Basic types of space pressure control are static pressure, airflow tracking, and constant airflow. Exhaust air control regulates the amount of air exhausted to keep it at the minimum safe level. Space pressure control is generally required with exhaust air control, and control of airflow in a central air handling system is generally required with space pressure control and/or exhaust air control.

8.6.2 Definitions

Constant Air Volume (CAV) system:

A central fan system in which airflow in the duct is maintained at a constant volume.

Differential:

The difference between supply and return airflows necessary to maintain a positive or a negative pressure in an area.

Variable Air Volume (VAV) system:

A central fan system in which airflow in the duct varies depending on the instantaneous load requirements of the connected VAV terminal units.

8.6.3 Air flow control applications

8.6.3.1 Supply fan control for VAV systems

The supply fan control system provides adequate duct static pressure to all air terminal units. This duct static pressure at the air terminal unit is used to overcome pressure drops between the air terminal unit inlet and the controlled space. Inadequate static limits maximum airflow to less than required, while excessive duct static increases sound levels and wastes energy. The location of the duct static pressure sensor is critical for proper control of the supply fan.




Fig 8.4: Locating Duct Static Pressure Sensor for Supply Fan Control.

If the supply duct is one simple run with short takeoffs to the air terminal units (Fig. 8.4-A), the duct static pressure sensor is located at the air terminal unit furthest from the supply fan. Typically, the supply duct is complex with multiple runs or branches. This duct layout requires a compromise in duct static pressure sensor location that is usually about 75 percent of the distance between the fan and the furthest air terminal unit (Fig. 8.4-B). In complex duct runs where multiple branches split close to the fan, sensors should be located in each end of the branch (Fig. 8.4-C). Each sensed point should have its own set point in the control loop. This avoids the assumption that branches and multi sensor locations have identical requirements. The sensed point having the lowest duct pressure relative to its own set point should control the supply fan.

Chapter Eight

8.6.3.2 Return fan control for VAV systems

There are four techniques to control the return fan: open loop, direct building static, airflow tracking, and duct static.

8.6.3.3 Open Loop Control

This type of control presumes a fixed relationship between the supply and return fans, controls the return fan in tandem with the supply fan, and changes the output of the return fan without measuring the result. Open loop control requires similar supply and return fan operating characteristics.




Fig.8.5 Open Loop Control

8.6.3.4 Direct Building Static Control

In direct building static control, the return fan responds directly to the building space static pressure referenced to the static pressure outside of the building (Fig.8.6). The location of the building space static pressure sensor should be away from doors opening to the outside, elevator lobbies, and some confined areas.




Fig.8.6 Direct Building Static Control

8.6.3.6 Duct Static Control

Individual space returns are damper controlled; return fan control must use this technique. Duct static control is relatively simple, but individual space return controls make the entire system complex.




Fig.8.8. Duct Static Control

8.6.3.7 Return damper control for VAV systems

In systems having a return fan, when the mixed air control cycle is not operating, the outdoor air (or maximum outdoor air) and relief dampers are closed and the return damper remains fully open. When the mixed air control cycle is operating, the return damper modulates closed and outdoor air (or maximum outdoor air) and relief dampers modulate open. The return damper should be sized for twice the pressure drop of the outdoor air (or maximum outdoor air) and relief dampers.




Fig.8.9. Return Air Damper Mixed Air Control Cycle.

8.7 Smoke Management Fundamentals

8.7.1 Introduction


This section describes objectives, design considerations, design principles, control applications, and acceptance testing for smoke management systems. A smoke management system modifies the movement of smoke in ways to provide safety for the occupants of a building, aid firefighters, and reduce property damage. References are at the end of this section which include smoke control codes

Early smoke management systems used the concept of passive control to limit the spread of fire and smoke. This method evolved from early fire containment methods used in high rise buildings. With passive control, HVAC fans were shut down and dampers were used to prevent smoke from spreading through ductwork. This application required very-low-leakage dampers. Fire walls or barriers, used to prevent the spread of fire, were enhanced to prevent the spread of smoke.

8.7.2 Definitions

Fire damper:

A damper that meets the requirements of Standards for Fire Dampers, and resists the passage of air or fire.



Chapter Eight

Smoke Control System:

A system that modifies the movement of smoke in ways to provide safety for the occupants of a building, aid firefighters, and reduce property damage.

Smoke Management System, Active:

A system that uses fans to produce airflows and pressure differences across smoke barriers to limit and direct smoke movement.

Smoke Management System, Passive:

A system that shuts down fans and closes dampers to limit the spread of fire and smoke.

Smoke Control Zone:

An indoor space enclosed by smoke barriers, including the top and bottom, that is part of a zoned smoke control system

8.7.3 Design Principals

8.7.3.1 Cause of Smoke movement

The movement or flow of smoke in a building is caused by a combination of stack effect, buoyancy, expansion, wind velocity, and the HVAC system. See Figure 1. These items basically cause pressure differences resulting in movement of the air and smoke in a building.




Fig.8.10. Factors Affecting the Movement of Smoke

Before controls can be applied, it is necessary to first understand the overall movement of smoke.

8.7.4 Control of smoke

Smoke control uses barriers within the building along with airflow produced by mechanical fans to contain the smoke. The control system results by using pressurization and airflow methods

8.7.4.1 Pressurization

Pressurization of nonsmoke areas can be used to contain smoke in a fire or smoke zone. Barriers are required between the nonsmoke areas and the area(s) containing the smoke and fire. For the barrier to perform correctly in a smoke control system, a static pressure difference is required across any penetrations or cracks to prevent the movement of smoke. Figure 8.11

illustrates such an arrangement with a door in a wall. The high pressure side can act as a refuge or an escape route, the low pressure side as a containment area. The high pressure prevents any of the smoke from infiltrating into the high pressure area.




Fig.8.11. Pressurization Used to Prevent Smoke Infiltration

8.7.4.2 Airflow

Airflow is most commonly used to stop smoke movement through open doorways and corridors. Figure 4 illustrates a system with relatively high velocity to prevent backflow of smoke through an open doorway. Figure 8.12 illustrates a system with relatively low velocity which allows backflow of smoke. The magnitude of the velocity of the airflow required to prevent backflow depends on the energy release rate of the fire.




Fig.8.12. High Air Velocity Preventing Backflow of Smoke through an Open Doorway




Fig.8.13. Low Air Velocity Allowing Backflow of Smoke through an Open Doorway

8.7.5 Control Application

Figure 8.14 illustrates a smoke control system with detectors, an initiating panel, and a communications bus to an alarm processor and remote control panels in appropriate areas of the building. A configuration similar to this will meet the requirements of UL 864, Standard for Control Units for Fire- Protective Signalling Systems, and comply with NFPA 92A recommended practice for smoke control systems. The remote control panels position dampers and operate fans to contain or




Fig.8.14. Typical Smoke Control System Meeting the Requirements of UL Standard 864 and NFPA92A

8.8 Individual Room Control Applications

8.8.1 Air Terminal Unit Control ATU

Air terminal units (ATUs) regulate the quantity and/or temperature of conditioned air delivered to satisfy the temperature

ATU controls can be as basic as a room sensor controlling a damper or as complex as a room sensor and an airflow sensor operating a damper and a reheat coil valve. requirements of a room or space.




Fig.8.15. Basic Individual Room Control

Variable Air Volume ATU

A variable air volume (VAV) ATU controls the cooling of a space by varying the amount of conditioned air supplied rather than changing the temperature of the conditioned air. Most VAV systems provide energy savings by reducing the load on the central fan when cooling loads are less than design and avoid reheating cooled air.

Single-Duct VAV ATU

System Configuration

1. Flow control damper.
2. Damper actuator, usually electric, bidirectional.
3. A digital controller.
4. A low voltage control transformer.
5. A line voltage power source.
6. A digital communications bus for control and BMS functions.
7. An optional bus connection to the space wall module for easy access from a portable control terminal
8. A wall module.




Fig.8.16 Single-Duct VAV ATU

Throttling VAV ATU

The throttling VAV ATU (Fig.8.17) is the simplest and least expensive ATU. A room controller controls the operation of the damper actuator using PI control. The throttling VAV ATU usually has software minimum and/or maximum damper position limits for limiting air volume. Because the unit is pressure dependent, volume at any given damper position varies with the inlet duct static pressure.

The space temperature set point is the value set by the occupant on the wall module. With this option, the BMS operator may assign software limits to the set value.

Chapter Eight





Fig.8.17 Throttling VAV Air Terminal Unit

Figure 8.18 shows a reheat coil added to a throttling VAV ATU. In this application, the temperature controller sequences the operation of the damper actuator and the control valve or reheat coil. The coil can be replaced by single or multiple stages of electric resistance heat. The damper modulates under PI control at the cooling set point and the hot water valve modulates under a separate PI control at the heating set point, with a dead band between heating and cooling.



Variable Air Volume ATU

The variable air volume ATU (Fig.8.19) is a pressure- independent unit which delivers the required air volume to the space regardless of the supply static pressure. The amount of air delivered is derived from a space temperature PI loop. A flow sensor in the supply airflow modulates the damper actuator to control air volume. The room sensor resets the airflow set point as the space thermal load changes.




Fig.8.19. Variable Air Volume Single-Duct Air Terminal Unit

Variable Air Volume ATU with Electric Reheat

The VAV ATU with electric reheat in Figure 8.20 adds reheat to Figure 5. Figure 6 also shows four boxes on one display. The cooling PID varies the box airflow from maximum to minimum as the cooling load drops to maintain set point. If the cooling load drops further, the space temperature drops through a dead band until the heating set point is reached, at which point the heating unit is controlled to maintain the heating set point.




Fig.8.20 Variable Air Volume Single-Duct with Reheat Air Terminal Unit

References

1. Carrier Air conditioning Co., Air conditioning system design
2. Air conditioning C.P Arora
3. Egyptian code of Air conditioning
4. Air conditioning Dr. Ramadan Mahmoud
5. Air conditioning principles, applications book'' Dr Ramadan Mahmoud
6. ASHRAE 2009 Modern Air Conditioning Practice
7. ASHRAE hospitals 1997
8. ASHRAE- Fundamentals 2005
9. ASHRAE HVAC Systems & Equipment 2008
10. SMACNA HVAC Systems Duct Design 1990 2nd Ed.
11. Wang, S - Handbook of Air Conditioning and Refrigeration 3rd Ed.
12. TRANE HVAC System Control
13. TRANE VAV systems
14. Automatic control for commercial building