

microza

Membrane Bioreactor (MBR)



AsahiKASEI
GROUP

Asahi Kasei Chemicals Corporation
Microza & Water Processing Division
Technical Marketing Department


Basic concept of MBR

Advantages of MBR process


MBR system can

- dispenses sedimentation tank by using MF membranes
- diminishes aeration tank by higher MLSS concentration
- discharges treated water without SS and colon bacillus and recycle water
- dissolves bulking problem

MBR



Conventional
process




Calculation example -Required tank capacity-


microza

Influent Water : BOD 200mg/l, Treatment capacity 1,000m³/day

Activated sludge
MLSS:3000
F/M ratio: 0.15
(BOD·SS loading)



MBR
MLSS:10000
F/M ratio: 0.07




MBR system can perform space saving at WWT facilities.

Activated sludge

microza



Aeration tank



Flocculant of
microorganism
(Flock)

Treated Water

Photomicrograph of Activated sludge (*100)

Activated sludge is mixed liquor of microorganism and treated water.

<Reaction formula>

BOD component of Waste water + O_2 (Aeration)

—————>

$CO_2 + H_2O + \Delta E + \text{Cell growth of microorganism}$

Microorganism

(Excess sludge)

Bulking problem at sedimentation tank



Normal condition




Carry over of activated sludge

Treated water quality of MBR system (Sewage wastewater)

microza

Water quality of MBR and CAS



	Influent	(mg/l)	
		MBR	Typical CAS
BOD	160	0.7	5-10
COD-Mn	90	4.5	7-13
SS	180	<0.4	3-5
T-N	35	5.5	10-15
T-P	4	0.2	0.4-0.7
E.coil	2.3×10^5	<0.3	3-5
(Number /ml)			

*Commercial application of Asahi-kasei
MBR Module*

Microza Reference for MBR

No.	Raw Water	Capacity	Year Installed	Location
		(m3/day)		
1	Food plant wastewater	600	2004	Japan
2	Food plant wastewater	300	2005	Japan
3	Petrochemical wastewater	25,000	2006	China
4	Sewage	260	2006	Korea
5	Domestic Sewage (Black Water)	1,500	2006	China
6	Petrochemical wastewater	10,800	2006	China
7	Sewage	35,000	2007	China
8	Petrochemical wastewater	6,000	2007	China
9	Food plant wastewater	720	2007	Netherlands
10	Sewage	200	2007	Korea
11	Sewage	1,000	2007	Korea
12	LCD wastewater	4,200	2007	Korea
13	Sewage	1,375	2007	Japan
14	Sewage (River water)	100,000	2007	China

This list excludes less than 200m3/day plants.


MBR projects for Petrochemical waster water

(China 10,800 m³/d, 25,000 m³/d)



MBR project in China

	Hainan	Daya Bay
Type of waste water	Oily waste water	Oily waste water
Capacity (m ³ /day)	10,800	25,000
Module Number	864	2000
Flux (m ³ /m ² /day)	0.5	0.5
Star of system operation	2006.8	2007.1



Hainan project (10,800m³/day)



Daya Bay project (25,000m³/day)

microza



Installed example

Sewage water treatment (1500m³/d) in China



Flux: 0.5m/d Number of module: 120


Reconstruction of conventional SBR system

Installed date 2006.4

Sewage plant under construction in China (35,000 and 100,000m³/day)



Sewage treatment plant
(35,000m³/day)
Start schedule : '07.8



River water treatment plant
by MBR (100,000m³/day)
Start schedule : '07.10

Technical Meeting with Chinese customer



Small scaled MBR system in Australia

microza




<u>Place</u>	<u>Scale</u>	<u>Module number</u>
Amity point Stradbroke Island	14m ³ /day	MUNC-620A
Moor Park Bundaberg	25m ³ /day	MUNC-620A * 2
Caravan Park	40m ³ /day	MUNC-
620A * 3		

Small scaled MBR system in Australia



Small scaled MBR system in Australia

microza



Installed example

Apelbaum villa in Giheung Korea (260m³/d)



Outlook of Apelbaum villa



WWT plant at Apelbaum constructed underground

Installed example

Fuel chemistry plant in Netherlands (720m³/d)



Vegetable debris (Raw material)



Methane fermentation tank



A/O treatment for Residue



MBR tank

Introduction Asahi-kasei MBR module for Food factory (900m3/d)

microza



Food factory aspect



Aeration tank



Asahi-kasei MBR rack



Soaking Asahi-kasei MBR rack in aeration tank


Appearance of module




Specification of ASAHI-KASEI MBR

Specification of MBR module (MUNC-620A)

microza




Cross-section of Hollow fiber



Surface of Hollow fiber

Type of Module	Submerged module
	MUNC-620A
Membrane materia	PVDF
Pore size	0.1 μ m
Membrane area	25m2
Figure	6inch dia $\times$ 2mL
Weight (WET)	14kg



Aspect of MBR module

The dependence of crystallinity on Ozone resistance





Fig. Ozone resistance of PVDF hollow fiber

SEM images of Microza PVDF H.F. (High Crystalline)



Only ASAHI membrane has ozone resistant.

Specification of MBR module (MUNC-640A,600A)

microza



MUNC-620A (25m²)

Membrane length: 2.0m

Total length: 2.2m Weight: 14kg

XMUNC-640A (17.5m²)

Membrane length: 1.4m

Total length: 1.6m weight: 11kg

XMUNC-600A (12.5m²)

Membrane length: 1.0m


Total length: 1.2m Weight: 9kg

XMUNC-640A

(Membrane length:
1.4m)

Hollow fiber alignment of Asahi-kasei MBR module

microza



Dividing **multiple bundles** of hollow fibers to make path to outside of module

Upper part of module

Middle and lower part of module

Uniform dispersion of hollow fibers for not to dissipate aeration and to swing hollow fibers effectively



PCT/JP2004/112944

Parts name of MBR module (Munc-620A)

Header



Multiple bundles of hollow fibers



Skirt



Aeration holes

Low hardness resin



Accessories of MBR units



Reducer





Gasket



Crump

Parts of MBR units

Reducer, Crump, Gasket



Asahi-kasei MBR rack unit (100m² type)

microza



Specific design


- Unit size 0.52*0.46*H2.7m
- Total membrane area 100m²
- Weight (wet) 185kg

Advantage of Asahi-kasei MBR rack system

- Less aeration volume for membrane
(60-70% aeration volume of conventional MBR system)
- Space saving
(about 50% space of conventional MBR system)


From Design manual of Japan Sewage Works Agency

Aeration tank and MBR unit for 1000m³/d sewage system - tank depth 4m-




Asahi-kasei
(Foot print 5.8m²)

Aeration volume
625Nm³/hr



M company
(Foot print 11.5m²)

Aeration volume
958Nm³/hr




K company
(Foot print 12.5m²)

Aeration volume
792Nm³/hr

MBR Rack unit (24 Module type)

microza


Aeration line




Permeate line

MBR Rack unit (24 Module type)

microza



Guide Part of rack



Guide Pipe at membrane tank

MBR Rack unit

microza



Installation and setting of MBR modules



Leak check




Submerging

Installation


*Operation Mode and considerations
of MBR Module*

Comparison of MBR and CAS in sewage process

MBR



CAS (Conventional Activated Sludge)




MBR operating condition

1. Flux 0.4 - 0.7 m³/m²/d (Municipal water)
 0.2 - 0.6 m³/m²/d (Industrial water)
2. Filtration / Reverse filtration time
 F : 9 min. RF : 1min. (Standard condition)
3. Aeration flow rate
 For Module : 5 m³/hr/Mo
 For Aeration Tank : to keep DO level 1 –2 mg/l
4. EFM
 Case1 : When TMP reaches 30(or 40)KPa
 Case2 : Frequency 1-2 month
 0.3% NaClO sol. 2L/m²(membrane) 90min
5. CIP
 Case : When effect of In Line Cleaning become smaller
 Soak modules in chemical solution tank
 0.3% NaClO sol. , 8hr< (Standard condition)
 0.5-1% Oxalic acid , 1hr< (Additional condition)

Filtration


9min.



Operation mode 2

Filtration $\Leftrightarrow$ RF

9min.- 1min.



9min.- 1min.

0.3% NaClO sol.
50L/module

Pump

every 12 months

Pump

NaClO Tank

Sludge Tank


CIP Tank

Pump

Permeate Tank


Operation mode 4

microza



Operation mode 1

microza



Operating and maintenance considerations

Design

/ Elimination of foreign substances by Grid tank and Screen

/ Appropriate BOD loading ($< 1 \text{ BOD-kg/m}^3/\text{day}$)

/ MLSS ($8000 - 12000 \text{mg/l}$)

/ Feed water considerations

Oil content (Fat oil $< 50 \text{mg/l}$, Mineral oil $< 3 \text{mg/l}$)

Antifoam agent (Silicone based antifoam agents are not recommended)

Inorganic material deposition (pretreatment or PH control)

Toxic substance for microorganism (heavy metal, insecticide etc.)

Operating and maintenance considerations

Operations

/ Do not filter with clogging membrane under high vacuum pressure

Appropriate cleaning membrane is required for stable filtration.

/ Do not dry membrane during operation

/ Do not filter without aeration

It is recommended that filtration be stopped when aeration for membrane is not provided.

/ Do not freeze membrane during storage

Operating and maintenance considerations

Maintenance

/ Daily checking by check list

Filtration pressure, Flow rate, Water temp., MLSS, DO, PH

It is recommended to make up time series graph

/ Periodical maintenance by maintenance contractor

Discussion about condition by using daily check list

Do not leave situation when any conditions are abnormal

COD removal ratio at various waste water field




	Influent COD (mg/l)	Effluent COD (mg/l)	Removal ratio (%)	Remarks
Municipal	330	8.4	97.5	COD _{Cr}
Petrochemical factory	679	99.7	85.3	COD _{Cr}
LCD factory	450	3.6	99.2	COD _{Cr}
Chemical factory	194	40.9	78.9	COD _{Mn}
Coolant factory	512	56.8	88.9	COD _{Mn}
Chemical factory (including PEG)	654	33.2	94.9	COD _{Mn}
Food factory (sea food)	324	6.8	97.9	COD _{Mn}
Food factory (Japanese pickle)	3490	51.4	98.5	COD _{Mn}
Food factory (soybeans)	368	10.9	97.0	COD _{Mn}
Food factory (sugar)	778	33	95.8	COD _{Mn}
Food factory (tofu)	629	3.4	99.5	COD _{Mn}

COD removal ratio of treated water depends on raw water quality.

Sewage and food factory wastewater are mostly easy to reduce.

Chemical waste water show various removal ratio.

Repairing of hollow fiber breakage (detecting leaked module)




1. Detection of leakage by turbidity or IT test
2. Find leaking unit
3. Find leaking module

Leaking module

Repairing of hollow fiber breakage




pressed air air leak from
 broken hollow



sealed bagage

Detecting of leaked
hollow fiber

driving a nail
into a hollow



making knot



Repairing

Field test result

- Title 22 test result at USA, CA-

What is Title22 ?

- Qualification test by California state in USA for membrane but it affects not only CA but also whole of USA.
- Permeate turbidity (less than 0.1NTU) and Virus removal are examined.
- Some public tender need Title 22 in order to distinguish from unknown membrane.
- Many MBR membrane supplier had passed

First period : ZENON, Kubota, USFilter, Mitsubishi rayon

Second period : Koch, Kruger, Huber, Dynalift, Asahi-kasei

Test site location: Point Loma WWTP, San Diego, CA, USA

Test period : 2006.9 – 2007.2




Aspect of Sewage plant



Test rig.

Existing process (San Diego city WWTP)

Sewage $\Rightarrow$ Dozing FeCl_3 $\Rightarrow$ Sedimentation $\Rightarrow$ Discharge to Ocean (clear upper portion)



MBR raw water

<Test condition>

Treatment capacity : 15m³/day (normal), 30m³/day (2Q test)

Flux : 0.6m³/m²/d (normal), 1.2m³/m²/day (2Q test)

Treatment system : Anoxic(1.9m³), Aerobic(1.9m³), Membrane tank(1m³)

Analytical item : permeate turbidity, rejection ratio of virus (2Q*6days test)




Fig. Flow diagram



Before use



After 40 days

After 4months use

microza




Flashing by 0.1% NaClO
from B.K. side



Average Water quality of Influent and Treated water (06.9~07.1)


		Influent	Treated water
BOD	mg/l	141	<2
SS	mg/l	128	—
TOC	mg/l	60	5
T-N	mg/l	21	5.2
Total Coliforms	CFU/ 100mL	6.40E+07	<10
Fecal Coliforms	CFU/ 100mL	5.10E+06	<10

Peak Flow test



Test result of permeate turbidity


MUNC-620A passed Title 22.




Permeate Turbidity during Peaking Study

Virus removal (Challenge test)

1.5log, it is good as MF membrane.



MS-2 Phage Concentration in the Reactor and Permeate of Asahi MBR during Virus Seeding Experiments



Log Removal of MS-2 Phage by Asahi MBR during Virus Seeding Experiments

No criteria for Virus removal, but membrane with less than 1log is evaluated 'insufficient filtration ability'.

Kubota and Mitsubishi membranes are about 0.5log.



State of California—Health and Human Services Agency
Department of Health Services



ARNOLD SCHWARZENEGGER
Governor

May 8, 2007

Asahi-Kasei Chemicals Corporation
Microza Sales & Marketing Department 1
Microza & Water Processing Division
Hibiya-Mitsui Bldg., 1-2, Yurakucho 1 - chome,
Chiyoda-Ku, Tokyo 100-8440, Japan

Attn. Mr. Atsuo Kubota
Deputy General Manager

Subject: Use of the Asahi-Microza™ Membrane Bioreactor to
comply with California Water Recycling Criteria

Gentlemen:

By transmittal e-mail dated March 20, 2007, Montgomery Watson Harza, Consulting Engineers, requested Departmental acceptance of the Asahi-Microza™ Membrane Bioreactor (MBR) treatment unit as an acceptable filtration technology for compliance with the State of California Water Recycling Criteria (Title 22). Accompanying this request was a report prepared by Montgomery Watson Harza entitled "Assessing the Ability of the Microza™ Membrane Bioreactor to Meet Existing Water Reuse Criteria", dated March 2007. The report was prepared under a grant from the U.S. Bureau of Reclamation and outlines findings from a study conducted in the City of San Diego, California. The Department has reviewed this report and offers the following comments.

Division of Drinking Water and Environmental Management
Technical Programs Branch, Recycled Water Unit
1180 Eugenia Place, Suite 200, Carpinteria, CA 93013-2000
(805) 566-1326; (805) 745-8196 fax
Internet Address: jstone1@dhs.ca.gov

The Asahi-Microza™ MBR treatment system evaluated utilizes hollow fiber PVDF ultrafiltration membranes with a nominal pore size of 0.1 micron. The membrane piloted during this study is identified as the Microza™ MUNC-620A membrane module. The Asahi-Microza™ MBR configuration consists of an anoxic tank, aerobic tank and the submerged membrane tank. The membranes are operated under vacuum (-11.6 psi max.) with a maximum transmembrane pressure differential ranging 6.0 psi and an average design flux of 14.6 gallons per square foot per day (gfd).

The California Water Recycling Criteria recognize membrane filtration as an acceptable filtration technology provided prescribed performance requirements (i.e. turbidity) are reliably met. The turbidity performance criteria require that the filtered wastewater not exceed any of the following:

1. 0.2 NTU more than 5 percent of the time within a 24-hour period; and
2. 0.5 NTU at any time.

The demonstration studies conducted using the Asahi-Microza™ MBR treatment system which utilizes the PVDF hollow fiber membrane with a nominal pore size of 0.1 micron have sufficiently demonstrated the ability to produce an oxidized wastewater and the membranes ability to comply with the above stated turbidity performance requirements. In addition, virus seeding experiments demonstrated the processes ability to achieve 1.5-log removal of inherent Total Coliphage at the 50th percentile level. Therefore, the Department of Health Services accepts the use of this membrane, identified as the Asahi-Microza™ MBR filtration treatment system utilizing a hollow fiber membrane with a nominal pore size of 0.1 micron (identified as the Microza™ MUNC-620A) as a filtration technology for use in compliance with the Water Recycling Criteria.

The acceptance of this technology is specific to the Asahi-Microza™ MBR filtration treatment system utilizing MUNC 620A hollow fiber membrane. Any proposed changes made in the physical attributes or character of this membrane shall be reviewed in advance by the Department to determine whether the modifications will require additional testing.

The Department will continue to review all proposed projects on a case-by-case basis to determine full compliance with all applicable treatment and reliability features required by the

Water Recycling Criteria. This will include the collective review of all treatment unit processes, operational controls (e.g. loading rates, TMP, type and frequency of integrity tests), 'O&M' procedures, etc.

If you have any questions concerning this letter, please contact the undersigned at (805) 566-9767.

Sincerely,

A handwritten signature in black ink, appearing to read "Jeffrey L. Stone". The signature is fluid and cursive, with the last name "Stone" being more prominent.

Jeffrey L. Stone, Chief
Recycled Water Unit
Division of Drinking Water

cc: Montgomery Watson - James DeCarolis
City of San Diego - Larry Wasserman
Recycled Water Committee

techlist/KrugerNeosepapprltr.doc

Point Loma Tilte22 Test Summary (1)

microza

	Asahi Kasei	GE/Zenon*	Siemens/ Memcor	Kubota*	Mitsubishi Rayon
Membrane Type	HF	HF	HF	FS	HF
Membrane Material	PVDF	PVDF/R	PVDF	PE	PE
Nominal pore size	0.1um	0.04um	0.04um	0.4um	0.4um
Membrane area/module (ft2)	269	340	409 (B30R)	8.6	269 (SADF2590A)
Module Type	Submerged	Submerged	Submerged	Submerged	Submerged
Flux (gfd) Q	15 – 24	(22)*		(15)*	
Peak Flux (gfd)	30 – 39				
Average Flux (gfd)	20 – 27		14 – 24		12 – 15
Operation Cycle	9.5min F→ 0.5min BW	10min F→ 0.5min RL	12min F→ 0.75 min RL→ 0.25 min BW	9 min F→ 1 min RL	12 min F→ 2 min RL
Cleaning cycle (Hr) (CIP)	N/A	1,350	1,608	0	1,176
EFM cycle (Hr)	336	56	None	None	None
Required Air Flow (SCFM/ft2)	0.013	0.028 (10/10)	0.021	0.033	0.049
Membrane damage during test period	None so far	No. Info.	No. Info.	No. Info.	No. Info.
Rack foot print (Membrane area/rack area)	430 (Latest design)	341 (500d)		166 (EK400)	223 (SADF2590A)
Comments		10/30 air cycle now			SADF2590A is PVDF
* Feed water of Zenon & Kubota test was after coagulation and sedimentation					
(These two suppliers already had tested on raw waste water at different site (San Pasqual))					

Point Loma Tilte22 Test Summary (2)

microza

	Asahi Kasei	Koch/Puron	Kruger/Toray	Huber	Dynalift/ Norit/X- Flow
Membrane Type	HF	HF	FS	FS	Tubular
Membrane Material	PVDF	PES/R	PVDF	PES	PVDF/R
Nominal pore size	0.1um	0.04um	0.08um	0.038 um	0.03um
Membrane area/module (ft2)	269	323	15	8.1	312
Module Type	Submerged	Submerged	Submerged	Submerged	Side stream
Flux (gfd) Q	15 – 24	11	18	15	30
Peak Flux (gfd)	34 – 39	35	35	33	45
Average Flux (gfd)	20 – 27	14	21	18	32
Operation Cycle	9.5min F→ 0.5min BW				
Cleaning cycle (Hr) (CIP)	N/A	?	920	?	?
EFM cycle (Hr)	336	191	None	207	332
Required Air Flow (SCFM/ft2)	0.013	0.019	0.04	0.026	0.019
Membrane damage during test period	None so far	After 500 hrs	After 2200 hrs	None	None
Comments					

Test result of permeate turbidity




Figure 3 – Particulate Removal by Newly Developed MBR Systems

Test result of Total coliform concentration




Figure 5 – Microbial Contaminants Removal by Newly Developed MBR Systems

Field test result
Sewage research with JSWA
2002-2004

Asahi-kasei MBR system development (No.1)

Municipal wastewater treatment

(Co-operation with Japan Sewage Works Agency at Mooka pilot plant)

- Operation Flux : $0.8\text{m}^3/\text{m}^2/\text{d}$ (19.7GFD)
(average Flux : $0.72\text{m}^3/\text{m}^2/\text{d}$, 17.7GFD) : TMP stable
- Ratio of aeration volume / permeate water volume
reduce to 13.3 (conventional MBR 20)
- The water quality, BOD,T-N,T-P,SS are less than the
criteria of permeate water.
- T-P of permeate water is reduced without adding
coagulants by biological elimination.
- RO test starting for MBR treated water from '04.8.

Photograph of Asahi-kasei MBR Pilot Plant


(a) Cooperative influent tank



(b) Asahi-kasei MBR Pilot Plant



Flow diagram of Asahi-kasei MBR Pilot Plant



Treatment water capacity : 36m³/day


Tank volume : 9m³ Water level : 4.5m

HRT : 6hr (anaerobic 3hr, aerobic 3hr)

TMP data

(Long period demonstration)


F:9.5min(Q),RF:0.5min(2Q)




★ 3000 or 5000 mg/l NaClO * 90min (EFM)

● 5000mg/l NaClO+ 1% NaOH * 5hr → 2% HNO₃ *1hr

Water quality of Influent water




Water quality of treated water



Performance and specification of MBR (Municipal Waste Water)

	Asahi-kasei	Mitsubishi Rayon		Kubota	Zenon
Membrane Specification	Hollow Fiber	Hollow Fiber		Sheet	Hollow Fiber
Membrane Pore Size	0.1µm	0.4µm		0.4µm	0.1µm
Membrane Material	PVDF	Hydrophlic PE	PVDF +Reinforceme	Chlorinated PE	PVDF+Brade
O/I diameter (mm)	1.2/0.7	0.54/0.36	2.8/1.1		2.0/1.5
Module Structure	Cylinder	Cage & Shroud		Box	Cage & Shroud
Membrane Area (m2/Element)	25	15	25	0.8	46
Total membrane area / Module foot	1243	274	667	272	669
Total membrane area / Unit rack	465	377	243	180	343
Average Flux (m/d)	0.72	0.4	0.8	0.7	0.73
Ratio of Aeration/Treated water	13.3	20	13-15	19.3	15
for Module	6.7	20	13-15	15.4	9.5
for Tank	6.7	0	0	3.8	5.5

RO combination test





RO : FILMTEC
BW30-404FR


RO operating date and water conductivity

microza

Operation Pressure : 1MPa



Water quality of MBR water and RO water



Other date of RO water

BOD	< 0.1mg/l	Coliform bacteria count	< 0.02 MPN
T-P	0.01	Standard plate count bacteria	ave. 277 (Min.2 Max.507) cfu
T-N	< 0.1	Turbidity	< 0.1
		Chroma	< 0.1
		Total dissolved solid (TDS)	6.9 mg/l

Asahi-kasei MF modules

microza

Asahi-kasei Chemicals manufactures MF membrane 1,500,000 m²/year for drinking water at MF plant. MBR modules are also applied MF membranes manufactured this plant.



Microza MF plant
(Fuji city, Shizuoka, Japan)



Thank you for your kind attention.

