

DESIGN OF PIPELINE DISTRIBUTION NETWORK

7th May 2020

Presenter : Simeshwaran Pillai, L&T
(Mobile No. : 9884717775)



WATER RESOURCES DEPARTMENT
MAHARASHTRA KRISHNA VALLEY DEVELOPMENT CORPORATION
GOVERNMENT OF MAHARASHTRA

AGENDA


- **Pipeline Distribution Network**
- **Pipeline Hydraulics design & concepts**
- **Modelling pipeline network in Water Gems Software**
- **Pipe thickness calculation as per AWWA M11**
- **Automation in pipeline irrigation**
- **Surge analysis concepts and modelling in SAP**
- **Pipeline Alignment LS details**

CANAL & PIPED MAJOR IRRIGATION SYSTEM

- **CANAL IRRIGATION** – Irrigation main canals & sub canals by Gravity flow – **FLOODED IRRIGATION SYSTEM**
- **PIPED IRRIGATION** – Pressurized pipeline system by Pumping / Gravity flow with sufficient pressure – **EQUITABLE PRESSURIZED IRRIGATION SYSTEM**



CHAK PLANNING & PIPE ROUTING

- 
- ROR data, Digitized ROR map and village boundaries are collected and superimposed.
 - CCA in each plot is identified and grouped together to form a chak of required size.
 - From survey inputs, highest elevation in each chak is identified.
 - Pipe routing is carried out in AutoCAD connecting all the chak outlets

CHAK PLANNING - TYPICAL


- ROR data, Digitized ROR map and village boundaries are collected
- Sample ROR data is shown below

Village Tag	20 Ha Chak Tag	20 Ha Tag	PLOT NO	Village Name	NAME OF OWNER	CCA (Ha)	GCA (Ha)	TYPE OF LAND	LAND DESCRIPTION
V3	C3	V3-C3	38	KONDHAVALA KH	शासकीय औद्योगिक प्रशिक्षण संस्था वेल्हे	1.391	2.782	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	46	KONDHAVALA KH	दत्तात्रय यशवंत देशपांडे	0.400	0.400	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	45	KONDHAVALA KH	रमा गिरीष देशपांडे (72) सुशिला मधुकर देशपांडे	0.400	0.400	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	75	KONDHAVALA KH	निवृत्ती नबाजी खोपडे	1.628	1.721	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	93	KONDHAVALA KH	दत्तु भागु सरफले (204) नथू भागु सरफले	0.121	0.121	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	34	KONDHAVALA KH	राजु नामदेव चोर (226) सागर सुरेश मळेकर	0.100	0.106	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	57	KONDHAVALA KH	बाळकृष्ण अर्जुन दारवटकर	0.430	0.430	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	60	KONDHAVALA KH	निवृत्ती हरिभाऊ सुतार	0.060	0.060	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	29	KONDHAVALA KH	दत्तु नानु सणस	0.195	0.203	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	39	KONDHAVALA KH	दत्तात्रय यशवंत देशपांडे	0.225	0.225	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	56	KONDHAVALA KH	जयराम लक्ष्मण खोपडे	0.070	0.070	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	72	KONDHAVALA KH	भिमाजी राघु खोपडे	0.290	0.290	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	89	KONDHAVALA KH	पांडुरंग बाळा धायगावे	0.139	0.139	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	71	KONDHAVALA KH	विशाल बाबासाहेब कुटे (352) विक्रम बाबासाहेब कुटे	0.270	0.270	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	90	KONDHAVALA KH	दत्तु भागु सरफले (204) नथू भागु सरफले	0.100	0.100	PRIVATE CULTIVABLE	Cultivable
V3	C3	V3-C3	63	KONDHAVALA KH	हनुवती खंडु धायगावे	0.035	0.035	PRIVATE CULTIVABLE	Cultivable

ROR - TYPICAL



Village boundary of
Kondhavale KH – Village V3



Detailed view of chak V3-C3 with plot
numbers as per the digitized ROR map

CHAK PLANNING - TYPICAL

‘Khedi’ Village boundary-CCA–95.8 Ha
30 Ha Chaks – 3 Nos.

Yellow – Village Boundary

Brown – 30 Ha Boundary


Green – 5 Ha Boundary

Blue – 1 Ha Boundary

Blue Pipe – From main pipe line upto
30 Ha Chak

Cyan Pipe – From 30Ha upto 5 Ha
Chak

Pink Pipe – From 5Ha upto 1 Ha Chak



HYDRAULIC DESIGN - CRITERIA

Flow Discharge

Desired @ Demand Point

Pressure Head

Desired @ Demand Point

Head Losses

Intermediate/cumulative

Flow Velocity

Optimum Range (0.6 – 2.1 m/s)

Pipe Size

Cost Effective

Hydraulic Gradient Line (HGL)

Feasibility check w.r.t Ground level

PIPE DIAMETER SELECTION

$$\text{Flow Rate} = \frac{1}{4} \cdot \pi \cdot (\text{pipe diameter})^2 \cdot \text{velocity}$$

- Discharge in m³/s
 - Calculated from water requirement / total water intake
- Velocity of flow in m/s
 - MS pipe Upto 3,0 m/s as per CWC Guidelines
 - MS pipe lined – upto 2.1 m/s as per CPHEEO

SIZING OF PIPES

Factors governing sizing of pipes:

- Velocity criteria
- Power Consumption for pressurised distribution network
- Pressure Head availability for gravity distribution network
- Total operational cost based on economic pipe sizing

Factors governing selection of pipe material:


- Contract Conditions
- Durability and Longevity
- Work feasibility at site
- Capital Cost

		Diameter(mm)		Velocity(m/s)	
3.	HDPE and PVC	20	100	0.3	1.8
4.	CI/DI (for water with positive Langelier's index)	100	1000	0.3	1.8
5.	CI/DI (For waters with negative Langelier's index)	100	1000	0.3	1.8
6.	Metallic pipes lined with cement mortar or epoxy (for water with negative Langelier's index)	100	2000	0.3	2.1

LOSSES IN PIPELINE

The total head, or pressure, affecting flow may be divided into four parts:

- velocity head loss
- entrance head loss
- loss of head through friction
- Minor losses (fittings losses)



PUMP HEAD

**Total Pump Head = Static Head
+ Pipe friction loss
+ Fitting losses (10% of frictional loss)
+ pumping Station loss (1 m)**

- **Static Head = Full supply level at DC / Max. peak point – Lifting water level in Pump House**
- **Friction loss is calculated from Hazen Williams / Modified Hazen Williams Formula**

FRICTION LOSS IN PIPELINE

Head Loss may be calculated From Below Hazen Williams Formula

Where
$$h_L = \frac{4.72 Q^{1.852} L}{C^{1.852} D^{4.87}}$$

h_L = frictional head loss in pipe length L, m

Q = flow (discharge), m³/sec

L = length of pipe, m

D = inside diameter of pipe, m

C = 140 for MS & HDPE pipe

HAZEN WILLIAM'S CONSTANT

As per CPHEEO manual table 6.1, the recommended C-value of MS, DI & HDPE pipes are tabulated below.

Sl. No.	Material	Diameter (mm)	C-value (Design purpose)
1	MS (Lined metallic)	<1200	140
2	MS (Lined metallic)	>1200	145
3	DI (Lined metallic)	<1200	140
4	Plastic pipes (HDPE)	All Dia	145

FRICTION LOSS IN PIPELINE

Modified Hazen-Williams coefficient C

Head Loss may be calculated From Below Modified Hazen Williams Formula

Where :

$$H_f = \frac{L \times Q^{1.81}}{994.62 \times C_R^{1.81} \times D_{in}^{4.81}}$$

H_f = frictional he

Q = flow (discharge), m³/sec

L = length of pipe, m

D = inside diameter of pipe, m

C_R = Modified Hazen William's constant = 1

HYDRAULIC DESIGN - OUTCOMES

Pumping station - Parameters

Total Discharge

Each Pump Flow & Head

Power consumption

Pipe line network- Parameters

Optimum Pipe Size & Rating

Valve Ratings

Control & Automation (if any)

HGL GRAPH OF A LIFT IRRIGATION PROJECT (NORMAL OPERATION)




Fig.: Minimum and Maximum Piezometric Heads


Hydraulics in Bentley WaterGEMS - Preprocessing

Pipe routing

After chak planning is carried out, the **pipe routing** is done in AutoCAD and saved as a dwg file.


File Import

The **pipe routing** in dwg format is **imported** into the Bentley WaterGEMS software.



Hydraulics in Bentley WaterGEMS

**DWG file is now
imported into the
software in true
coordinates**



Hydraulics in Bentley WaterGEMS

Pipeline validation

The uploaded pipe route is checked for its correctness using the validation option available.

The screenshot displays the Bentley WaterGEMS CONNECT Edition software interface. The main window shows a hydraulic network diagram with a complex pipe layout. A dialog box titled "Engine Error Message" is open, displaying a yellow warning icon and the text "Problems were found during the validation." with an "OK" button.

The software interface includes a ribbon menu with tabs: File, Home, Layout, Analysis, Components, Review, View, Tools, Report, and Bentley Cloud Services. The "Analysis" tab is active, showing options for Validation, Notifications, Alerts, and Summary. The "Validation" group includes buttons for Compute, Summary, and Alerts. The "Notifications" group includes buttons for Alerts and Alerts.

The "Element Symbology" panel on the left lists various hydraulic elements with checkboxes for selection. The "Background Layers" panel on the right shows a list of layers including Network, Network Review, Network Trace, Input, and Results.

The "User Notifications" panel at the bottom displays a table of notifications:


Message Id	Scenario	Element Type	Element Id	Label	Time (hours)	Message
41595	OCT-I	Junction	2822	J-1	0.000	Node is not connected to,

The status bar at the bottom indicates the current location (X: 3,76,351.76 m, Y: 20,22,733.23 m) and the zoom level (0.4 %).

Hydraulics in Bentley WaterGEMS

Uploading Contour
From survey points
a contour is
generated using the
Civil 3D software
and saved as a dwg
file


The **contour file** in
dwg is imported
using Trex option &
the junctions are
automatically
assigned **elevations**



Hydraulics in Bentley WaterGEMS

Each Pipe and Junction is assigned a name by the software & analysis (friction loss) is carried out for each pipe.

**Output is derived for
each junction
(pressure head at
entry and exit).**




Hydraulics in Bentley WaterGEMS

All the chak outlet points are called demand points.

The **demand points** are identified as **end nodes**.

A selection set is created consisting of all end nodes.




Hydraulics in Bentley WaterGEMS

Demand Inputs

The reservoir pumphouse in case of rising main (LWL) & delivery chamber (FSL) in case of a gravity main is assigned with a **water level**.

Demand points are identified and **demand** for each point in the earlier created selection set is assigned a flow as per the duty point and chak size for the project.




Hydraulics in Bentley WaterGEMS

Analysis

After all the inputs are assigned, the analysis is carried out in the software.

The friction loss is calculated using the Hazen Williams formula

All the pipes are annotated with the required details.




Hydraulics in Bentley WaterGEMS

Analysis

After all the inputs are assigned, the analysis is carried out in the software.

The friction loss is calculated using the Hazen Williams formula

All the pipes are annotated with the required details.



Hydraulics in Bentley WaterGEMS

Analysis

The pipe diameters are assigned using the pipe flex table in the software.

The velocity criteria is considered and the minimum pipe diameters are assigned.

The analysis is re-run and post processing results are taken.

The screenshot displays the Bentley WaterGEMS CONNECT Edition Update 1 interface. The main window shows a hydraulic network diagram with various pipes and junctions. The 'FlexTable: Pipe Table' window is open, displaying a table of pipe data. The table includes columns for ID, Pipe Name, Start Node, End Node, Length (m), Diameter (mm), Hazen-Williams C, Pipe Material, Flow (L/s), Velocity (m/s), Hydraulic Grade (Start/End) (m), and Pressure (Start/End) (m H2O). The table lists 1342 elements, with the first 13 rows visible.

	ID	Pipe Name	Start Node	End Node	Length (m)	Diameter (mm)	Hazen-Williams C	Pipe Material	Flow (L/s)	Velocity (m/s)	Hydraulic Grade (Start) (m)	Pressure (Start) (m H2O)	Headloss (Hazen-Williams) (m)	Hydraulic Grade (End) (m)	Pressure (End) (m H2O)
2544: P-1	2544	P-1	Gunjawan...	J-2	853	2,400.0	137.0	MS	6,631.60	1.47	727.20	0.00	0.47	726.73	43.27
1978: P-1341	1978	P-1341	J-2	V1-C1	33	98.6	137.0	HDPE	3.93	0.51	726.73	43.27	0.11	726.62	43.49
2576: P-2	2576	P-2	J-2	J-3	680	2,200.0	137.0	MS	6,627.67	1.74	726.73	43.27	0.57	726.16	42.68
1989: P-1340	1989	P-1340	J-3	V2-C1	10	98.6	137.0	HDPE	3.48	0.46	726.16	42.68	0.03	726.13	43.33
2543: P-3	2543	P-3	J-3	J-4	702	2,200.0	137.0	MS	6,624.19	1.74	726.16	42.68	0.59	725.57	41.78
1498: P-4	1498	P-4	J-4	J-5	273	2,200.0	137.0	MS	6,618.73	1.74	725.57	41.78	0.23	725.34	41.10
1988: P-1339	1988	P-1339	J-4	V2/V3-C1	185	98.6	137.0	HDPE	5.46	0.72	725.57	41.78	1.12	724.45	46.79
2351: P-5	2351	P-5	J-5	J-6	58	2,200.0	137.0	MS	6,618.73	1.74	725.34	41.10	0.05	725.29	42.60
2263: P-6	2263	P-6	J-6	J-7	374	2,200.0	137.0	MS	6,618.73	1.74	725.29	42.60	0.31	724.98	44.18
1806: P-1337	1806	P-1337	J-7	V3/V4-C1	26	98.6	137.0	HDPE	5.70	0.75	724.98	44.18	0.17	724.81	40.76
1830: P-1338	1830	P-1338	J-7	V3-C3	134	98.6	137.0	HDPE	6.15	0.81	724.98	44.18	1.01	723.97	44.95


1342 of 1342 elements displayed

Output After Analysis

All the demand points are checked for the required pressure

Wherever the required pressure is not achieved, the same is highlighted.


The pipe diameters are increased and required residual pressure is achieved.



Hydraulics in Bentley WaterGEMS

Hydraulic Gradient Line is generated by the software.

It is checked for the correctness or possibilities of optimization in the system.



Hydraulics in Bentley WaterGEMS

Results

The results are exported from the Pipe Flex table into an excel for further processing.

WaterGEMS CONNECT Edition Update 1 [24 fortnight 19.02.20.wtg]

File Home Layout Analysis Components Review View Tools Report Bentley Cloud Services

Search Ribbon (F3) CONNECT Advisor

Alternatives Options Scenarios Compute Validation Times Alerts Summary Calculation

Layout Select By Polygon By Element By Attribute Drawing

Patterns Pump Definitions Demand Center Controls Common Components

Graphs FlexTables Properties Refresh Common Views

Active Topology ModelBuilder Common Tools

Element Symbology <default> Pipe Label Diameter Length Pressure (Stop) Velocity Lateral Junction

24 fortnight 19.02.20.wtg OCT-1

Background Layers Background Layers LBC OKM TO END L-section with Chainage

Selection Sets Label

Properties: (select a sin... V16A-C1 100%

FlexTable: Pipe Table (Current Time: 0.000 hours) (24 fortnight 19.02.20.wtg)

	ID	Pipe Name	Start Node	End Node	Length (m)	Diameter (mm)	Hazen-Williams C	Pipe Material	Flow (L/s)	Velocity (m/s)	Hydraulic Grade (Start) (m)	Pressure (Start) (m H2O)	Headloss (Hazen-Williams) (m)	Hydraulic Grade (End) (m)	Pressure (End) (m H2O)
2544: P-1	2544	P-1	Gunjawan...	J-2	853	2,400.0	137.0	MS	6,631.60	1.47	727.20	0.00	0.47	726.73	43.27
1978: P-1341	1978	P-1341	J-2	V1-C1	33	98.6	137.0	HDPE	3.93	0.51	726.73	43.27	0.11	726.62	43.49
2576: P-2	2576	P-2	J-2	J-3	680	2,200.0	137.0	MS	6,627.67	1.74	726.73	43.27	0.57	726.16	42.68
1989: P-1340	1989	P-1340	J-3	V2-C1	10	98.6	137.0	HDPE	3.48	0.46	726.16	42.68	0.03	726.13	43.33
2543: P-3	2543	P-3	J-3	J-4	702	2,200.0	137.0	MS	6,624.19	1.74	726.16	42.68	0.59	725.57	41.78
1498: P-4	1498	P-4	J-4	J-5	273	2,200.0	137.0	MS	6,618.73	1.74	725.57	41.78	0.23	725.34	41.10
1988: P-1339	1988	P-1339	J-4	V2/V3-C1	185	98.6	137.0	HDPE	5.46	0.72	725.57	41.78	1.12	724.45	46.79
2351: P-5	2351	P-5	J-5	J-6	58	2,200.0	137.0	MS	6,618.73	1.74	725.34	41.10	0.05	725.29	42.60
2263: P-6	2263	P-6	J-6	J-7	374	2,200.0	137.0	MS	6,618.73	1.74	725.29	42.60	0.31	724.98	44.18
1806: P-1337	1806	P-1337	J-7	V3/V4-C1	26	98.6	137.0	HDPE	5.70	0.75	724.98	44.18	0.17	724.81	40.76
1830: P-1338	1830	P-1338	J-7	V3-C3	134	98.6	137.0	HDPE	6.15	0.81	724.98	44.18	1.01	723.97	44.95

1342 of 1342 elements displayed SORTED

X: 3,84,050.43 m, Y: 20,16,488.01 m Zoom Level: 3.2 % Sign in

PIPE THICKNESS SELECTION

The pipe thickness is selected based on the following criteria as per various codal provisions.

- Minimum thk based on hoop stress as per IS 5822
- Minimum thk considering collapse pressure as per AWWA M11
- Minimum thickness for handling as per AWWA M11
- Minimum thk considering buckling pressure as per AWWA M11
- Minimum thk considering deflection as per AWWA M11

INTRODUCTION TO PIPE THICKNESS CALCULATION

$$t = \frac{pd}{2s} \quad (4-1)$$

Where:

t = minimum pipe wall thickness for the specified internal design pressure,
in. (mm)

p = internal design pressure, psi (kPa)

d = outside diameter of pipe steel cylinder (not including coatings), in. (mm)

s = allowable design stress, psi (kPa)

PIPE THICKNESS SELECTION

MINIMUM THICKNESS FOR WORK AND TEST PRESSURE CONSIDERATION AS PER IS 5822

MS Pipe Thickness calculation as per IS 5822 & Checking as per AWWA M11 (Size:1100mm)				
A) : Pipe Thickness Calculation as per IS 5822 - 1994				
	Minimum Thickness to sustain Internal Pressure	$t = \frac{P D}{(2 a f_y e + P)}$		
	Selected thickness	t	=	7
	Internal Design Pressure (Max pressure head)	Pd (mwc)	=	125
		Pd	=	1.23
	Internal Diameter	Di	=	1000
	Outer Diameter	Do	=	1014
	Velocity in the pipeline (max. considered)	V	=	1.800
	Test pressure = 1.5 times of Internal Design pressure or Surge pressure whichever is higher		=	1.84
				N/mm ²

PIPE THICKNESS SELECTION

MINIMUM THICKNESS FOR WORK AND TEST PRESSURE CONSIDERATION AS PER IS 5822 (Continued....)

Joint efficiency (As Per IS 5822 Cl. B 9.2)				
Shop Weld	e	=	0.9	
Field Weld	e	=	0.8	
Design Factor (As per IS: 5822, Cl. B 9.2)				
For Work Pressure	a	=	0.6	
For Test Pressure	a	=	0.9	
Minimum Yield Strength as per IS 2062 E250 Gr Br	Fy	=	250	Mpa
Minimum Tensile Strength as per IS 2062 E250 Gr Br	Ft	=	410	Mpa
Permissible Stress				
For Work Pressure	a*Fy	=	150	N/mm ²
For Test Pressure	a*Fy	=	225	N/mm ²
Calculated Thickness				
For Work Pressure		=	5.15	mm
For Test Pressure		=	5.15	mm
Min. Thickness required	tmin	=	5.15	mm
Hence the selected pipe thickness	t	=	7	mm

PIPE THICKNESS SELECTION

MINIMUM THICKNESS CONSIDERING COLLAPSE PRESSURE

B).Calculation of Collapse (Negative) Pressure			
P_c	$= \frac{(2 \times E_s) / (1 - [\theta_s]^2) \times (t/D_0)^3 + (2 \times E_c) / (1 - [\theta_c]^2) \times (t_L/D_I)^3 + (2 \times E_c) / (1 - [\theta_c]^2) \times (t_C/D_C)^3}{}$		(AWWA M11-FIFTH EDITION - Equ- 4-6)
P_c	= Collapse(Negative) Pressure in psi		
t	= Pipe steel thickness	=	0.276 In
t_L	= Cement mortar lining thickness in inch	=	0 In
t_C	= Cement mortar coating thickness	=	1.182 In
D_0	= Outside Diameter of steel cylinder	=	39.922 In
D_I	= inside diameter of steel cylinder (cement-mortar lining outside diameter)	=	39.371 In
D_C	= Outside Diameter of cement mortar coating	=	42.286 In
v_s	= Poisson's ratio for steel (taken as 0.3)	=	0.3
v_c	= Poisson's ratio for cement mortar (taken as 0.25)	=	0.25
E_s	= Modulus of elasticity for steel	=	30000000 psi
E_c	= Modulus of elasticity for cement mortar	=	4000000 psi
P_c	= -208.2 psi = -146.45 mWC	=	-14.16437078 atm
Calculated collapse pressure is more than 1/3 of atmospheric pressure, hence the pipeline is safe			

PIPE THICKNESS SELECTION

MINIMUM THICKNESS REQUIRED FOR HANDLING

C) Calculation of minimum pipe thickness for handling	
$t_{min} = (D) / 288$	(AWWA M11-FIFTH EDITION - Equ- 4-3)
t_{min} = Minimum pipe thickness required	
D= Pipe Inside Diameter in inch	
$t_{min} =$	0.14 inch (required)
$t_{min} =$	3.47 mm (required)
Since the required thickness for handling is less than the selected thickness, hence the pipe is safe	

PIPE THICKNESS SELECTION

MINIMUM THICKNESS CONSIDERING BUCKLING PRESSURE

D) Allowable buckling pressure calculation

E_s	=	Modulus of elasticity for MS pipe	=	30000000 psi
E_c	=	Modulus of elasticity for Guniting Layer	=	4000000 psi
t_s	=	Steel Pipe wall thickness	=	0.275590551 in
t_L	=	Lining Layer wall thickness	=	0 in
t_c	=	Coating Layer wall thickness	=	1.182 in
I_s	=	Moment of Inertia for MS pipe = $t_s^3/12$	=	0.001744262 in ³
I_L	=	Moment of Inertia for Lining Layer = $t_L^3/12$	=	0 in ³
I_c	=	Moment of Inertia for Coating Layer = $t_c^3/12$	=	0.137616714 in ³
EI	=	Pipe wall stiffness = $E_s*I_s + E_L*I_L + E_c*I_c$	=	602794.7166 Lb-In

PIPE THICKNESS SELECTION

MINIMUM THICKNESS CONSIDERING BUCKLING PRESSURE continued....

C_n	=	Scalar calibration factor	=	0.55	
Φ_s	=	factor to account for variability of stiffness of compacted soil	=	0.9	
ν_s	=	Poisson's Ratio of Soil	=	0.3	
k_v	=	Modulus correction factor for poisson's ratio, of the soil			
	=	$(1+\nu_s) \cdot (1-2 \cdot \nu_s) / (1-\nu_s)$	=	0.742857143	
r	=	mean radius of the pipe = $(D_o - t) / 2$	=	19.82283465	In
H_c	=	Height of ground surface above top of Pipe	=	47.24409449	In
R_H	=	correction factor for depth of fill			
	=	$11.4 / (11 + (2 \cdot r / H_c))$	=	0.96290561	
E'	=	modulus of soil reaction considering compaction 85% for soil category SC1 from Table 5-3 of AWWA M11 Edition 2017 Pg. 63	=	700	psi
FS	=	factor of safety	=	2	
r_o	=	Outside radius of steel cylinder	=	19.96062992	In
q_a	=	Allowable buckling pressure			
	=	$(1.2 \times C_n \times [(EI)]^{0.33} \times [(\Phi_s \times E' \times k_v)]^{0.67} \times$		79.14874808	psi
					(AWWA M11-FIFTH EDITION - Equ- 5-7) (Pg. No. 67)
			=	55.68484123	mWC

PIPE THICKNESS SELECTION

MINIMUM THICKNESS CONSIDERING BUCKLING PRESSURE continued....

H_c	=	Height of ground surface above top of Pipe	=	47.24409449	In
D_o	=	Outer Diameter of pipe with coating	=	39.92125984	In
H_w	=	Height of water above top of Pipe	=	47.24409449	In
γ_w	=	Unit weight of water	=	62.4	lb/ft ³
P_v	=	Internal vacuum pressure (atmospheric pressure less absolute pressure inside pipe)	=	0.3 atm	= 4.4087964 psi
R_w	=	Water buoyancy factor = $1 - 0.33 \cdot (H_w/H_c)$	=	0.67	for $0 \leq H_w \leq H_c$
W_L	=	Live load considering Highway load for 3 ft soil cover above pipe top from Table No. 5-1 Pg. 59 of AWWA M11- Fifth edition 2017	=	600	lb/ft ²
w	=	unit weight of fill	=	2000 Kg/m ³	= 124.854628 lb/ft ³
D_c	=	Outside diameter of coated pipe	=	39.922	In
H_c	=	Height of ground surface above top of Pipe	=	3.937007874	ft
W_c	=	prism load = dead load on the conduit	=		
	=	$W_c = (w \times H_c \times D_c)$	=	1635.31708	lb/lin ft of pipe (AWWA M11-FIFTH EDITION - Equ- 5-3) (Pg. No. 58)

PIPE THICKNESS SELECTION

MINIMUM THICKNESS CONSIDERING BUCKLING PRESSURE continued....

Load Combination - 1 : Buckling Pressure due to Earth Pressure +		
Vacuum Pressure + External Water Pressure =		
=	$\gamma_w/1728 \times H_w + R_w \times W_c / (12 \times D_o) + P_v$	8.401965465 psi (AWWA M11-FIFTH EDITION - Equ- 5-8) No. 67)

since buckling pressure due to load combination-1 is less than/equal to allowable buckling pressure so pipe thickness is OK.

Load Combination - 2 : Earth pressure + Pressure due to Live load +		
External Water Pressure =		
	$\gamma_w/1728 \times H_w + R_w \times W_c / (12 \times D_o) + W_L / (144 \times D_o)$	4.097541189 psi (AWWA M11-FIFTH EDITION - Equ- 5-9) No. 67)

since buckling pressure due to load combination-2 is less than/equal to allowable buckling pressure so pipe thickness is OK.

PIPE THICKNESS SELECTION

MINIMUM THICKNESS CONSIDERING DEFLECTION

E) Pipe Deflection Calculation

Δx	=	predicted horizontal deflection of pipe	=	
D_I	=	Deflection lag factor	=	1
K	=	Bedding constant	=	0.1
D_C	=	Outside diameter of coated pipe	=	39.922 In
W_C	=	prism load = dead load on the conduit	=	1635.31708 lb/lin ft of pipe
W_L	=	Live load per linear foot of coated pipe	=	600 lb/ft ²
W	=	load per unit of pipe length	$= W_C/12 + (W_L \times D_C)/12$	302.61809 Lb/lin In
				(AWWA M11-FIFTH EDITION - Equ- 5-4) No. 62)



PIPE THICKNESS SELECTION

MINIMUM THICKNESS CONSIDERING DEFLECTION

t	=	Pipe cylinder wall thickness	=	0.275590551 In	
t_L	=	Lining Layer wall thickness	=	0 In	
t_C	=	Coating Layer wall thickness	=	1.182 In	
r	=	mean radius of the pipe = $(D_C - t - t_L - t_C)/2$	=	19.23220472 In	
E'	=	modulus of soil reaction considering	=	700 psi	
EI	=	Pipe wall stiffness = $E_s * I_s + E_L * I_L + E_C * I_C$	=	602794.7166 Lb-In	
Δx	=	$D_L \times (K \times W \times r^3) / (E \times I + 0.061$	=	0.237461537 In	(AWWA M11-FIFTH EDITION - Equ- 5-4) (Pg No. 61)
			=	6.1 mm	
$\Delta x \%$	=	$(\Delta x / D_C) * 100$	=	0.59 %	
Δx allowable %	=	Allowable Deflection as per AWWA M11	=	2 %	(AWWA M11-FIFTH EDITION) (Pg. No. 62)
			=	0.799 In	
			=	20 mm	

since actual deflection of the coated pipe is less than allowable deflection so pipe thickness is OK.

HENCE SELECTED THICKNESS IS OK


TYPICAL ALIGNMENT PLAN

Road Crossing

Air Valve Location


Pipe Alignment

Elevation Contour



LONGITUDINAL SECTION

A vertical sectional drawing is usually scaled for better readability. The below section is scaled 100 times vertically and 2000 times horizontally.



FOR CONT. REFER DRG. NO. LE100335-M/MLS-2004 (SH 06 OF 97)

LONGITUDINAL SECTION

CHAINAGE (M)	GROUND (M)	PIPE TOP (M)	PIPE BOTTOM (M)	HGL (M)	WORKING PRESSURE (M)	COVER DEPTH	TURNING POINT & VALVE DETAILS	DISCHARGE (LPS)	PIPE SPECIFICATION
68000.00	595.200	593.808	593.276	657.927	64.119	1.392			
68020.00	595.618	594.268	593.736	657.890	63.622	1.350			
68040.00	594.834	593.414	592.882	657.853	64.439	1.420			
68060.00	598.985	597.494	596.962	657.817	60.323	1.491			
68080.00	598.200	596.849	596.317	657.780	60.931	1.351			
68100.00	596.700	595.500	594.968	657.743	62.243	1.200			
68120.00	596.783	595.438	594.906	657.710	62.272	1.345			
68139.00	596.380	594.907	594.375	657.700	63.325	1.473	J-158		
68140.00	596.345	594.872	594.340	657.670	62.798	1.473			
68160.00	596.379	594.905	594.373	657.633	62.728	1.474			
68180.00	596.492	595.077	594.545	657.597	62.520	1.415			
68200.00	596.538	595.227	594.695	657.561	62.334	1.311			
68220.00	596.186	594.896	594.364	657.524	62.628	1.290			
68240.00	595.756	594.524	593.992	657.488	62.964	1.232			
68260.00	595.417	594.151	593.619	657.451	63.300	1.266			
68280.00	594.960	593.615	593.083	657.415	63.800	1.345			
68300.00	594.300	593.031	592.499	657.378	64.347	1.269	AV-120		
68320.00	593.578	592.347	591.815	657.342	64.995	1.231			
68340.00	593.257	591.923	591.391	657.305	65.382	1.334			
68360.00	592.695	591.354	590.822	657.269	65.915	1.341			
68380.00	592.519	591.229	590.697	657.232	66.003	1.290			
68400.00	588.400	587.106	586.574	657.196	70.090	1.294			
68420.00	588.160	586.858	586.326	657.160	70.302	1.302			
68440.00	587.920	586.601	586.069	657.123	70.522	1.319			
68460.00	587.680	586.397	585.865	657.087	70.690	1.283			
68480.00	587.440	586.193	585.661	657.050	70.857	1.247			
68500.00	587.200	585.989	585.457	657.014	71.025	1.211			
68520.00	587.090	585.887	585.355	656.977	71.090	1.203			
68540.00	586.980	585.719	585.187	656.941	71.222	1.261			
68560.00	586.870	585.520	584.988	656.904	71.384	1.350			

204.48

204.48

DI PIPE DIA 500 & K9 CLASS

A vertical sectional drawing is usually scaled for better readability.
The below section is scaled 100 time vertically and 2000 times horizontally.


PIPE CROSS-SECTIONAL DRAWING

Typical Cross-Sectional drawing


The slopes are maintained as per site conditions

Trenches are backfilled using the excavated soil.

Trenches in rocky terrain are much more steeper than in normal soil conditions



TYPICAL CROSS SECTION OF TRENCH IN SOIL TERRAIN



TYPICAL CROSS SECTION OF TRENCH IN ROCKY TERRAIN

LONGITUDINAL SECTION DRAWING

A typical Longitudinal-Section drawing will contain all the below details

In addition, it contains following details as well.


- Running chainage
- Pipe dia
- Cover depth
- Ground level
- MOC of Pipe
- Pipe Dia
- Coordinates of turning points
- Crossings details
- Valve details (Air, Scour and butterfly valves)

SR. NO.	DESCRIPTION	SYMBOL	SR. NO.	DESCRIPTION	SYMBOL
1	H.G.L		14	VILLAGE AREA	
2	R.L. OF PIPE		15	SURVEY BOUNDARY	
3	GROUND LEVEL		16	SURVEY NUMBER	42
4	ROAD		17	BORE WELL / WELL	
5	CART TRACK/FOOT PATH		18	MS – PIPE	
6	THRUST/ANCHOR BLOCK		19	DI – PIPE	
7	BUTTERFLY VALVE		20	HDPE – PIPE	
8	AIR VALVE		21	DISNET NOMENCLATURE	BR1
9	SCOUR VALVE		22	IRRIGATION WATER OUTLET	
10	NATURAL DRAIN/STREAMS		23	TEMPLE	
11	VILLAGE BOUNDARY		24	OUTLET NUMBER	V2-C2
12	TANK / POND		25	JUNCTION NUMBER	J12
13	HT LINE				

AUTOMATION IN PIPELINE DISTRIBUTION

- Avoid the Draining of the Network
- Uniform Distribution of Water to the Chak
- Isolation of System from Remote as and when required
- Record, Monitor and Control of the flow Delivered to the Chak as per water demand
- No Need of External Electric Energy
- Wireless Communication
- Protective Enclosure capable of giving Vandalism Alert

OUTLET MANAGEMENT SYSTEM



SURGES IN PIPELINE

A Simple formula for Surge

(Recommended by CPHEEO)


$$\Delta H = \frac{a V}{g}$$

a = pressure wave velocity

V = Flow Velocity

ΔH = Surge Pressure

g = Acceleration due to gravity



Pressure increase
is up surge &
pressure
decrease is down
surge

**The equation focuses only on UPSURGE
(& not on down surge)**

SURGE ANALYSIS PROGRAM - SAP

Waterhammer or surge or hydraulic transients is a phenomenon occurring in closed conduit or pipe flows, associated with rapid changes in discharge in the pipe.

CASES CONSIDERED

- Surge Phenomenon Following Single Pump Failure
- Surge Phenomenon Following Multiple Pump Failure
- Surge Phenomenon Following Power Failure




Commonly used softwares

SAP – developed by IISc

Water Hammer – Bentley



SURGE ANALYSIS PROGRAM - SAP

The pipeline system is modelled as a line diagram and fed as input to the software



SURGE ANALYSIS PROGRAM - SAP

All pipe and junction details are provided as inputs



SAP

File View Run Help

Pipe Data




Enter the Pipe Data

Sl. No.	Pipe No.	U/S Node No.	D/S Node No.	Discharge (cum/sec)	Diameter (mm)	Length (m)	Starting Chainage (m)
1	1	1	6	1.798	1000	10	0
2	2	2	6	1.798	1000	10	0
3	3	3	6	1.798	1000	10	0
4	4	4	6	1.798	1000	10	0
5	5	5	6	1.798	1000	10	0
6	6	6	7	8.99	2400	13700	10

Cancel OK

SURGE ANALYSIS PROGRAM - SAP


The HGL at all junctions and delivery reservoir is provided



SURGE ANALYSIS PROGRAM - S

All details required for analysis is obtained from the performance curve.

Details regarding GD2 values of motor and pump is obtained from the Pump Datasheet & GA provided by the pump vendor.



SURGE ANALYSIS PROGRAM - SAP

Pump details are obtained from the pump vendor and provided as input to the software.

Pump Details

Enter the Pump Details

Sl. No.	Node No.	No. of Pumps	Discharge (cum/sec)	Head (m)	Speed (rpm)	Sump Water Level (RL)	Type of NRV	Machinery Finalised ?
1	1	1	1.798	82.5	750	486	6	YES
2	2	1	1.798	82.5	750	486	6	YES

Pump Characteristics

Sl. No.	Discharge (cum/sec)	Head (m)	Efficiency (%)
1	0.45	120	42
2	0.9	112	70
3	1.35	100	85
4	1.798	82.5	90.1
5	2.34	50	83

OK

SAP

File View Run Help

Pump Characteristics and Other Data

GD-Square Value of the Pump (kgf - sqm) 446

GD-Square Value of the Motor (kgf - sqm) 540

Rated Discharge of the Pump (cum/sec) 1.798

Rated Head of the Pump (m) 82.5

Rated Efficiency of the Pump (%) 90.1

Shut-off Head of Pump (m) 124

Non-Reverse Rotation Ratchet Provided ? NO

Discharge, Head and Efficiency Data

Enter Get From File

Cancel OK

of	Machinery Finalised ?
6	YES
6	YES
6	YES
6	YES

SURGE ANALYSIS PROGRAM - SAP

Pipe details such as MOC of pipe and thickness of lining and coating is provided as input.

Trip code (Running/Failure) for each pump is also assigned.

Data for Steel Pipe

Wall Thickness of the Pipe (mm)

Cement Mortar Lining Provided ?

Thickness of the Lining (mm)

Cement Mortar Guniting Provided ?

Thickness of the Guniting (mm)

SAP

File View Run Help

Wave Velocity and Trip Code

Type of Pipe

Trip Code for Each Pump

Trip Code for Each Booster

Valve Closing at Delivery Reservoir to be Considered ?

Wave Velocity

Sl. No.	Pipe No.	Material Type
1	1	STEEL
2	2	STEEL
3	3	STEEL
4	4	STEEL
5	5	STEEL
6	6	STEEL

SURGE ANALYSIS PROGRAM - SAP

Pump working condition

The HGL graph is generated for the pump working condition to check for the correctness of inputs




Fig.:Minimum and Maximum Piezometric Heads

SURGE ANALYSIS PROGRAM - SAP

Single Pump Failure




Fig.:Minimum and Maximum Piezometric Heads

Two Pump Failure




Fig.:Minimum and Maximum Piezometric Heads



SURGE ANALYSIS PROGRAM - SAP

Power Failure

Worst Case scenario is when all pumps fail at a time during the power failure condition.





Fig.: Minimum and Maximum Piezometric Heads

SURGE ANALYSIS PROGRAM - SAP

Following are the protection devices available in the software.



SURGE ANALYSIS PROGRAM - SAP

Data for ACV

Number of Air Cushion Valves

Enter the Data for ACV

ACV No.	Pipe No.	Size (mm)	Chainage (m)	Pipe Invert Level (RL, m)
1	6	300	70	495.604
2	6	200	870	502.797
3	6	300	1280	508.822

OK




Fig.:Minimum and Maximum Piezometric Heads

Data for Stand Pipes

Number of Stand Pipes

Enter the Data for Stand Pipes

Stand Pipe No.	Pipe No.	Chainage (m)	Diameter (mm)	Pipe Invert Level (RL, m)	Top Level (RL, m)
1	6	12350	500	539.794	553

OK

HGL GRAPH OF A LIFT IRRIGATION PROJECT (NORMAL OPERATION)




Fig.: Minimum and Maximum Piezometric Heads

HGL GRAPH OF A LIFT IRRIGATION PROJECT (RESULT OF SURGE CAUSED BY POWER FAILURE & PROPOSED PROTECTION SCHEME)




Fig.: Minimum and Maximum Piezometric Heads

HGL GRAPH OF A LIFT IRRIGATION PROJECT (MODIFIED RESULT DUE TO PROPOSED SURGE PROTECTION SCHEME)




Fig.:Minimum and Maximum Piezometric Heads

PIPE FAILURE DUE TO SURGE




TYPES OF VALVES

1. Manually Operated Butterfly Valve
2. Hydraulically Operated Butterfly Valve
3. Electrically Operated Butterfly Valve
4. Sluice Valve
5. Kinetic Air Valve
6. Air Cushion Valve
7. Zero Velocity Valve
8. Swing Check Valve (Multi Door Type)

TYPES OF VALVES COMMONLY USED IN LIFT IRRIGATION SYSTEM


1. Manually Operated Butterfly Valve

The valve may also be opened incrementally to throttle flow. Butterfly valves are generally favored because they cost less than other valve designs, and are lighter weight so they need less support.




2. Hydraulically Operated Butterfly Valve

These are Normal Butterfly Valves coupled with Hydraulic Actuators for quick and precise reaction as per situational requirement.






3. Electrically Operated Butterfly Valve

These are Normal Butterfly Valves coupled with Electric Motor and Gear Box for isolation purpose remote handling capability.




4. Sluice Valve (Non Rising Spindle)

These are Normally used as on / off valves, however, they can also be used for throttling purpose.




5. Kinetic Air Valve

Kinetic Air Valves are commonly used in air venting / air admission services in water pipelines. Designed to operate with the floats inside.






6. Air Cushion Valve

These Valves are commonly used for surge protection. Allowing suction of large volumes of air venting in the system through its inlet port and controlled expulsion of air from the system to dampen the effect of surge.



7. Zero Velocity Valve


These Valves are self acting valve which prevents reverse flow by closing the path before zero velocity is attained through spring action. It is used for surge protection.



BY PASS ARRANGEMENT

7. Swing Check Valve (Multi Door Type)

Multi-Door Non Return Valves are used in pipelines to reduce water hammer and to prevent back flow of water to the pump from rising mains. These valves are suitable for clear water having turbidity up to 5000 ppm and temperature upto 45 Deg.C



Thank
you