



FUTURE WAY

الباب الثالث الاحمال الحرارية اليدوية



#### المحتويات

۲	٣- ١ - مقدمة
٣	٢-٢- الحمل الحراريload estimation
٣	٣-٢-١- مصادر الحمل الحراري.
٥	cooling load estimation ــــــــــــــــــــــــــــــــــــ
	٣-٣- الملخص



#### ٣-١- مقدمة

ان مهمة جهاز التكييف هي الوصول لراحة الانسان عن طريق ضبط درجة الحرارة والرطوبة .

- ولتعيين قدرة جهاز التكييف يلزم معرفة ما هي الاحمال الحرارية التي يجب حسابها على جهاز التكييف لإزالتها وللوصول لدرجة الحرارة والرطوبة المطلوبة.
- وقبل البدء في التعريف بالأحمال الداخلية والخارجية يجب معرفة بعض المعلومات عن المبني او المكان المراد تكييفه مثل الاتي :
  - ١ موقع المبنى (مكانه الجغرافي) وكذلك اتجاه الشمال .
  - ٢-استخدام المبني هل هو مستشفى ام مبنى اداري ام سكنى ام مصنع ....الخ.
    - ٣- ابعاد المبني (طول + عرض).
    - ٤- اماكن الاعمدة والكمر في المبني.
  - ٥- ارتفاع السقف وكذلك المسافة بين السقف الحقيقي والسقف الساقط ان وجد .
  - ٦- مكونات الحوائط والسطح (الحوائط عامة عبارة عن طوب + محارة + دهان او سيراميك) اما السطح فهو عبارة عن
     (خرسانة ورمل واسمنت وبلاط).
    - ٧- الشبابيك وابعادها ونوع الزجاج.
      - ٨-الإضاءة.
    - ١ الاجهزة الموجودة داخل المكان وحملها بالواط.
    - ١١- كمية الهواء لكل شخص وتحدد حسب الاشخاص ونشاطهم داخل الغرف.



- وبهذه المعلومات سنري انها تفيدنا في حساب الاحمال الحرارية للمبني وهناك معلومات اضافية تهمنا كمهندس تصميم لتكييف فعليا مثل:
  - ١- الاماكن المسموح بوضع الاجهزة عليها (غرف الماكينات).
  - ٢- اماكن الحوائط المضادة للحريق وذلك بوضع ال Smoke fire damper.
    - ٣- مكان مصدر المياه.
    - ٤- مصدر بخار الماء.
  - ٥- الشكل النهائي للسقف الساقط لمعرفة نوعية الجريلات وابعادها ومخارج الهواء عموما .
    - ٦- اماكن الصرف لتوصيل صرف كل وحدة.

## الحمل الحراري load estimation

تعريف الحمل الحراري هو الحرارة المطلوب منزعها او اضافتها من المكان لتحقيق درجة الحرارة المطلوبة.

## ٣-٢-١- مصادر الحمل الحراري.

وتتلخص المصادر في مصد<mark>رين</mark> رئيسيين:

١- الحرارة المكتسبة المحسوسة sensible heat gain

#### و هي:

- 1- الحرارة التي تنتقل بالتوصيل conduction من خلال الحوائط والاسقف والابواب والشبابيك.
  - ٢- الحرارة التي تمتصها الحوائط والاسقف والشبابيك من الشمس.
- ٣- الحرارة المنتقلة من الحوائط التي تجاور غرف اخري بالمبني ليست مكيفة اوتختلف في درجات الحرارة وتسمي partitions.
  - ٤- الحرارة المكتسبة من الاضاءة والمواتير والعمليات الصناعية والبشر المتواجدون حسب نشاطهم.
  - ٥- الحرارة المكتسبة بالحمل convection نتيجة الهواء المتسرب من الشروخ بالابواب والشبابيك infiltration.
  - ٦- الحرارة المكتسبة في ممرات الهواء المكيف duct heat gained وذلك نتيجة مرورة في اماكن مختلفة درجة الحرارة.

### ١- الحرارة المكتسبة الكامنة latent heat gain



#### وهي:

- ١- الناتجة عن نسبة الرطوبة بالهواء المتسرب infiltration.
  - ٢- الناتجة عن عمليات صناعية مثل الطهور
    - ٣- الناتجة عن البشر المتواجدين بالمكان.
  - ٤- المنتقلة من الاماكن المجاورة الاعلى ضغطا.

والحمل الحراري المطلوب للجهاز او لملف التبريد هو مجموع الحمل المحسوس والكامن. ملحوظة:

تختلف البلدان دوائر العرض وهذا الاختلاف يغير في قيم كلا من:

- درجات الحرارة الخارجية ambient air temperature.
  - .Global solar radiation -
    - .Relative humidity -
      - .Wind velocity -



## cooling load estimation حساب الاحمال الحرارية ٢-٢-٣

١- الحرارة المكتسبة الشمسية الشبابيك- Window solar heat gain

Q=A\*sc\*q

الحرارة الناتجة عن الاشعاع (Q)

BTU/HR

- مساحة الشباك بالقدم المربع (A)
- المعامل الكلي للحرارة المكتسبة خلال الزجاج (shaded or not) (sc) ويعتبر ايضا معامل تصحيح حسب نوعية الزجاج المستخدمة.
- كمية الحرارة الناتجة عن الاشعاع لكل قدم مربع من مساحة الشباك (ordinary glass)



# - اولا: يتم تحديد ال sc من الجدول رقم ١٦، ص٢٥ من كتاب carrier ch1 load estimation وهو الجدول الاتي (وذلك طبقا لنوع الزجاج والتظليل shading):

#### TABLE 16-OVER-ALL FACTORS FOR SOLAR HEAT GAIN THRU GLASS

WITH AND WITHOUT SHADING DEVICES\*

Apply Factors to Table 15

Outdoor wind velocity, 5 mph-Angle of incidence, 30 - Shading devices fully covering window

	GLASS FACTOR NO	45° h	INSIDE IETIAL BL noriz. or ve OLLER SH	ertical	VENETI	TSIDE AN BLIND oriz, slats	OUTSI SHADII SCREE 17° horiz.	NG N†	AW	ITSIDE NING‡ ides & top
	SHADE	Light Color	Medium Color	Dark Color	Light Color	Light on Outside Dark on Inside	Medium** Color	Dark§ Color	Light Color	Med. or Dark Color
ORDINARY GLASS	1.00	.56	.65	.75	.15	.13	.22	.15	.20	.25
REGULAR PLATE (1/4 inch)	.94	.56	.65	.74	.14	.12	.21	.14	.19	.24
HEAT ABSORBING GLASS†† 40 to 48% Absorbing 48 to 56% Absorbing 56 to 70% Absorbing	.80 .73 .62	.56 .53	.62 .59 .54	.72 .62 .56	.12 .11 .10	.11 .10 .10	.18 .16 .14	.12 .11 .10	.16 .15	.20 .18 .16
DOUBLE PANE Ordinary Glass Regular Plate 48 to 56% Absorbing outside; Ordinary Glass inside.	.90 .80 .52	.54 .52 .36	.61 .59 .39	.67 .65 .43	.14 .12 .10	.12 .11 .10	.20 .18 .11	.14 .12 .10	.18 .16 .10	.22 .20 .13
48 to 56% Absorbing outside; Regular Plate inside.	.50	.36	.39	.43	.10	.10	.11	.10	.10	.12
TRIPLE PANE Ordinary Glass Regular Plate	.83 .69	.48 .47	.56 .52	.64 .57	.12 .10	.11 .10	.18 .15	.12 .10	.16 .14	.20 .17
PAINTED GLASS Light Color Medium Color Dark Color	.28 .39 .50									
STAINED GLASS‡‡ Amber Color Dark Red Dark Blue Dark Green Greyed Green Light Opalescent Dark Opalescent	.70 .56 .60 .32 .46 .43									

Footnotes for Table 16 appear on next page.



- ثانيا: يتم تحديد قيمة q وذلك من الجدول q ، من كتاب carrier ch1 load estimation وذلك بحسب دوائر العرض والجدول التالي هو الجزء من جدول q الذي يخص دائرة عرض مصر q:

TABLE 15-SOLAR HEAT GAIN THRU ORDINARY GLASS (Contd)

30°

Btu/(hr) (sq ft sash area)

30°

30° NORI	H LATITUDE		AM				Sυ	N TI	ME				РМ		30° SOUTH	LATITUDE
Time of Year	Exposure	6	7	8	9	10	11	Noon	1	2	3	4	5	6	Exposure	Time of Yes
	North	33	29	18	14	14	14	14	14	14	14	18	29	33	South	
	Northeast	105	139	130	97	55	19	14	14	14	14	12	10	5	Southeast	1
	East	108	156	161	143	98	44	14	14	14	14	12	10	5	East	_
	Southeast	42	75	90	90	73	44	17	14	14	14	12	10	5	Northeast	250 00
JUNE 21	South	5	10	12	14	15	19	21	19	15	14	12	10	5	North	DEC 22
	Southwest	5	10	12	14	14	14	17	44	73	90	90	75	42	Northwest West	⊣
	West	5	10	12	14	14	14	14	19	98	97	161	156	108	Southwest	1
	Northwest	19	10	12	14	14	240	250	240	217	180	130	61	19	Horizontal	1
	Horizontal		61	131	180	217					_					+
	North	22	20	14	13	14	14	14	14	14	13	14	20	22	South	1
	Northeast	93	131	123	89	46 99	16	14	14	14	13	12	9	4	Southeast East	JAN 21
JULY 23	East	100	155	164	145	83	53	22	14	14	13	12	9	4	Northeast	- 3019 21
	Southeast South	42	82	12	14	20	27	30	27	20	14	12	9	4	North	
•	Southwest	4	9	12	13	14	14	14	53	83	100	100	82	42	Northwest	_
MAY 21	West	4	9	12	13	14	14	14	44	99	145	164	155	100	West	NOV 21
MAIZI	Northwest	4	9	12	13	14	14	14	16	46	89	123	131	93	Southwest	1
	Horizontal	15	66	123	176	214	236	246	236	214	176	123	66	15	Horizontal	
	North	6	8	11	13	13	14	14	14	13	13	11	8	6	South	
- 0	Northeast	55	108	100	66	27	14	14	14	13	13	11	8	2	Southeast	
AUG 24	East	66	147	165	148	102	46	14	14	13	13	ii	8	2	East	FEB 20
700 24	Southeast	37	98	127	129	112	82	39	15	13	13	ii	8	2	Northeast	1 1 1 1 1 1 1
&	South	2	8	13	27	47	58	63	58	47	27	13	8	2	North	
	Southwest	2	8	11	13	13	15	39	82	112	129	127	98	37	Northwest	
APR 20	West	2	8	11	13	13	14	14	46	102	148	165	147	66	West	OCT 23
	Northwest	2	8	11	13	13	14	14	14	27	66	100	108	55	Southwest	
	Horizontal	6	47	107	161	200	225	235	225	200	161	107	47	6	Horizontal	
	North	0	5	10	12	13	14	14	14	13	12	10	5	0	South	
1	Northeast	ő	74	90	40	15	14	14	14	13	12	10	5	0	Southeast	
SEPT 22	East	0	124	158	144	103	48	14	14	13	12	10	5	0	East	MAR 22
	Southeast	0	98	131	152	141	113	67	25	13	12	10	5	0	Northeast	7
&	South	0	9	18	60	82	98	105	98	82	60	18	9	0	North	&
( <del>100</del> 1)	Southwest	0	5	10	12	13	25	67	113	141	152	131	98	0	Northwest	
MAR 22	West	0	5	10	12	13	14	14	48	103	144	158	124	0	West	SEPT 22
	Northwest	0	5	10	12	13	14	14	14	15	40	90	74	0	Southwest	
	Horizontal	0	25	81	135	179	202	212	202	179	135	81	25	0	Horizontal	
	North	0	3	8	-11	12	13	14	13	12	11	8	3	0	South	
- 1	Northeast	0	33	39	18	12	13	14	13	12	11	8	3	0	Southeast	1022 00
OCT 23	East	0	79	135	132	94	43	14	13	12	11	8	3	0	East	APR 20
25	Southeast	0	73	142	163	159	136	92	47	15	11	-8	3	0	Northeast	
&	South	0	18	57	92	121	139	145	139	121	92	57	18	0	North	
	Southwest	0	3	8	11	15	47	92	136	159	163	142	73	0	Northwest West	AUG 24
FEB 20	West	0	3	8 8	11	12	13	14	43	94	132	135	33	0	Southwest	700 24
	Northwest	0	3	49	100	143	171	179	171	143	100	49	6	0	Horizontal	
	Horizontal	_	6		-	_	_		_		_	_	_	0	South	+
	North	0		6	9	!!	12	12	12	!!	9	6		0	Southeast	1
	Northeast	0	8 27	109	Sec. 1977.2	83	12 35	12	12	11	9	6		0	East	MAY 21
NOV 21	East	0	28	127	116	162	143	104	64	23	9	6	+	0	Northeast	- M^1 21
Ł	Southeast South	0	10	68	109	137	154	159	154	137	109	68	10	0	North	
α	Southwest	0	1 10	6	9	23	64	104	143	162	161	127	28	ŏ	Northwest	1 -
JAN 21	West	Ö	1	6	9	11	12	12	35	83	116	109	27	ŏ	West	JULY 23
3014 21	Northwest	0	i	6	9	Lii	12	12	12	11	9	16	8	0	Southwest	
	Horizontal	۱ŏ	2	27	71	109	136	145	136	109	71	27	2	l ŏ	Horizontal	1
	North	0	0	4	9	11	12	12	12	11	9	4	0	0	South	1
	Northeast	ő	0	10	9	ii	12	12	12	iii	9	4	Ö	ŏ	Southeast	1
	East	ő	ő	92	105	80	32	12	12	ii	9	4	ő	ő	East	
- 1	Southeast	ŏ	ŏ	114	157	162	143	108	72	28	9	4	Ö	ŏ	Northeast	
DEC 22	South	ŏ	0	64	113	142	159		159	142	113	64	ő	ő	North	JUNE 21
200 11	Southwest	ő	ŏ	4	9	28	72	108	143	162	157	114	ő	ŏ	Northwest	1211/02/2017
t	West	Ō	0	4	9	II	12	12	32	80	105	92	0	ő	West	7
	Northwest	0	ō	4	9	11	12	12	12	11	9	10	0	0	Southwest	
	Horizontal	0	0	19	60	97	122		122	97	60	19	0	0	Horizontal	1
	10 (XXX-11)	1			-				-		(A)		-			
Solar Gain	Steel Sash, or	-1	н	aze			Altit	ude	- 1		Dewpo				ewpoint	South Lat
Correction	No Sash					margae a			_	Decre					se From 67 F	Dec. or Jan
POLLACTION	X 1/.85 or 1.17	- 1	-15%	Ma	x.)	+0.7	1% DE	er 1000	Ft I	+ 1	7% pe	er 10 F		- 7	% per 10 F	+ 7%

Bold Face Values — Monthly Maximums

Boxed Values — Yearly maximums



## ملحوظة: اسفل الجدول السابق معاملات تصحيح تؤخذ في الاعتبار وهي:

- أ- مساحة الزجاج من اجمال مساحة التركيب (العرض الخشبي او المعدني) هي ٠,٨٥ ولذلك يجب القسمة علي ذلك الرقم لحساب مساحة الزجاج فقط.
  - ب- Haze و هو يعبر عن الضباب فاذا كان هناك ضباب بالبلد موقع الحساب وجب العمل به (يطرح من ال ١).
  - ت- Altitude و هو الخاص بالارتفاع حيث الارتفاع بالجدول ١٥ هو مستوي سطح البحر (يضاف الي ال١).
  - ث- Dew point الحسابات بالجدول عند wbt ٦٦,٨ وعند الاختلاف وجب اخذ المعامل في الاعتبار (يضاف او يطرح من ال ١).
    - ج- Atitude ويضاف عند وجود اختلاف بين دائرة عرض الجدول والخاصة بالمكان الي ال ١.

### ليكون الناتج النهائي من الجدول السابق كالاتي:

= قيمة جدول \*أ\*(١-ب)\*(١+٢)\*(١ (+r-) ث)\*(١+ج)

#### ملحوظة:

يوجد مايسمي بال glass block وهي كتل زجاجية بدون اي براويز تذكر ولها الجدول رقم ١٧ بcarrier.



## Solar & الحرارة المكتسبة من الشمس والمنتقلة الي الغرفة عن طريق الحوائط والاسقف Transmitted heat gain thru walls and roofs

 $Q_2=A*U*\Delta T$  (equivalent)

- الحرارة الناتجة عن التوصيل من خلال الحائط (Q)
- مساحة كل حائط على حدة مع اخذ الاتجاه في الاعتبار وهنا يتم طرح مساحة الشباك من مساحة الحائط (A)
- معامل انتقال الحرارة للحوائط وهنا يجب تكون معرفة نوع الحائط (U)
- $(\Delta T_{(equivalent)})$  درجة الحرارة المكافأة

و هو مصطلح يعبر عن فرق الحرارة اللحظية القادمة من الشمس الي الحائط او السقف والحرارة الصادرة عن الحائط مباشرتا و هما مختلفتان بسبب ان الحائط يختزن جزء من حرارة الشمس الواردة اليه.

- يتم تحديد قيمة U للحوائط وذلك من الجدول ٢١-٣٣، ص٦٦-٤٧ من كتاب carrier ch1 load estimation وذلك من الجدول التالي:

ملحوظة: الجدول القادم مثال من تلك الجداول ويلاحظ به ارقام بين الاقواس وهي وزن الحائط او السقف او ال partition (وسنتحدث عنه بعد الجدول) ورقم بدون اقواس وهو معامل انتقال الحرارة وكل ذلك حسب مكونات الحائط او السقف.



#### TABLE 21-TRANSMISSION COEFFICIENT U-MASONRY WALLS\*

#### FOR SUMMER AND WINTER

Btu/(hr) (sq ft) (deg F temp diff)

All numbers in parentheses indicate weight per sq ft. Total weight per sq ft is sum of wall and finishes.

							INTERIO	R FINISH				
		THICK- NESS (Inches) and	None	%" Gypsum Board (Plaster Board)	Pla	ś″ ster Wall	Plas	etal ath stered urring	Gyps Wood Plas	i" um or d Lath tered urring	Bo Plai Plas	ating ard in or tored urring
EXTERIOR	rimism	(ib per sq ft)		(2)	Sand Aga (6)	Lt Wt Agg (3)	3/4" Sand Plaster(7)	1/4" Lt Wt Plaster(3)	1/2" Sand Plaster(7)	1/2" Lt Wt Plaster(2)	1/2" Board (2)	1" Board (4)
SOLID BRICK	Face & Common	8 (87) 12 (123) 16 (173)	.48 .35 .27	.41 .31 .25	.45 .33 .26	.41 .30 .25	.31 .25 .21	.28 .23 .19	.29 .23 .20	.27 .22 .19	.22 .19 .16	.16 .14 .13
	Common	8 (80) 12 (120) 16 (160)	.41 .31 .25	.36 .28 .23	.39 .30 .24	.35 .27 .23	.28 .23 .19	.26 .22 .18	.26 .22 .18	.25 .21 .18	.21 .18 .16	.15 .14 .12
STONE		8 (100) 12 (150) 16 (200) 24 (300)	.67 .55 .47 .36	.55 .47 .41 .32	.63 .52 .45 .35	.53 .46 .40 .32	.39 .34 .31 .26	.34 .31 .28 .24	.35 .31 .28 .24	.32 .29 .27 .23	.26 .24 .22 .19	.18 .17 .16 .15
ADOBE-BLOCKS OR BRICK		8 (26) 12 (40)	.34 .25	.30 .23	.32	.30 .23	.25	.23 .18	.23 .18	.22 .18	18	.12
POURED CONCRETE	140 lb/cu ft	6 (70) 8 (93) 10 (117) 12 (140)	.75 .67 .61 .55	.55 .49 .44 .40	.69 .63 .57	.58 .53 .49 .45	.41 .39 .36 .34	.36 .34 .32	.37 .35 .33	.34 .32 .31 .29	.27 .26 .25 .24	.18 .17 .17
	80 lb/cu ft	6 (40) 8 (53) 10 (66) 12 (80)	.31 .25 .21	.28 .23 .19	.30 .24 .20	.27 .23 .19	.23 .19 .17 .15	.21 .18 .16	.22 .18 .15	.21 .18 .14	.18 .16 .14 .12	.14 .12 .11
	30 lb/cu ft	6 (15) 8 (20) 10 (25) 12 (30)	.13 .10 .08 .07	.13 .10 .08 .07	.13 .10 .08 .07	.13 .10 .08 .07	.12 .09 .08 .07	.11 .09 .07	.11 .09 .08 .06	.11 .09 .07	.13 .10 .08 .07	.09 .07 .06 .06
HOLLOW CONCRETE BLOCKS	Sand & Gravel Agg	8 (43) 12 (63)	.52 .47	.44 .41	.48 .45	.43 .40	.33 .31	.29 .28	.30 .28	.28 .27	.23 .22	.17 .16
	Cinder Agg	8 (37) 12 (53)	.39 .36	.35 .33	.37 .35	.34 .32	.27 .26	.25 .24	.25 .23	.24 .23	.20 .19	.15 .15
	Li Wi Agg	8 (32) 12 (43)	.35 .32	.32 .29	.34 .31	.31 .28	.26 .24	.23 .22	.24 .22	.22 .21	.19 .18	.15 .14
STUCCO ON HOLLOW CLAY 1	TILE	8 (39) 10 (44) 12 (49)	.36 .32 .29	.32 .29 .27	.34 .31 .28	.32 .28 .26	.26 .23 .22	.24 .22 .20	.24 .22 .21	.23 .21 .20	.19 .18 .17	.15 .14 .13

1958 ASHAE Guide

Equations: Heat Gain, Btu/hr = (Area, sq ft) × (U value) × (equivalent temp diff, Table 19)
Heat Loss, Btu/hr = (Area, sq ft) × (U value) × (outdoor temp — inside temp)

## للحصول علي باقي الجداول يكون ذلك من مرجعنا carrier load estimation.

وزن الحوائط او الاسقف مهم بسبب انه يدخل في معامل تخزين الحوائط للحرارة ويكفي ان نعرف الان ان بالحصول علي ذلك الوزن من الجدول السابق لكل حائط مع ضرب كل قيمة من تلك في مساحة الحائط الخاص بها نحصل علي وزن الحائط

<sup>\*</sup>For addition of insulation and air spaces to above walls, refer to Table 31, page 75.



ويقسم الاجمالي للحوائط والسقف والارضية علي المساحة السطحية لارض الغرفة للحصول علي وزن المنشأة او building وهو ماسيتم استخدامه في الجداول القادمة.

carrier ch1 load يتم تحديد قيمة  $\Delta T_{(equivalent)}$  للحوائط وذلك من الجدول ١٩، ص ٢٦ من كتاب  $\Delta t_{(equivalent)}$  estimation

#### TABLE 19-EQUIVALENT TEMPERATURE DIFFERENCE (DEG F)

FOR DARK COLORED †, SUNLIT AND SHADED WALLS\*

Based on Dark Colored Walls; 95 F db Outdoor Design Temp; Constant 80F db Room Temp;

20 deg F Daily Range; 24-hour Operation; July and 40 N. Lat. †

	WEIGHTS		SUN TIME																						
EXPOSURE	OF WALL ‡	Н	_	_	АМ	_	_		Г	_	_		OIV		M	_	_	_	_		Г	_	ΑN	Л	
EXI COOKE	(lb/sq ft)	6	7	8		10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5
	20	_	45	-	23	24	19	_	40	-	13	14	14	_	10	_	8	6	4	-	0	- 2	_	- 4	-2
Northeast	60	5	15 - 2	22 - 2		24			13 15	12 10	11	12	13	14 14		10	_	10	8	2	4	2	- 3	0	- 1
Northeast	100	- 1			_	- 1													l -	8	٠.	6		-	
	140	5	3 5	4	4	4 6		6	15 10							12		10	10	10	7	9	8	5 7	5 7
	20	0	_	30		_	6 35		_	14	16	14	12	10	10		10	10	4	2	0	9	_	- 3	- 3
East	60	1	17			36 30			20	12	13	14	14	14	12		8	6 10	8	5	4	3	- 2	- 3	0
EdSt	100	- 1	- 1	0					19 25			12				12			11		4	8		7	6
	140	11	5	6	8							18			14						-	13	12	1 1	
		11	10	10	9	8	9	10	15	18	19	18	17	16	14	12	13	14	14	14	_	13	12	_	12
Courthogast	20 60	10	6	13	19	26	27	28	26	24	19	16	15	14	12	10	8	6	4	2	0	- 1	- 1	- 2	-2
Southeast	100	1	1	0		20			26		21	18				12		10	8	6	5	9	3	3	2
	140	7	1 1	6	6	6			17		19	18				12			10			ľ	8 10	8 10	7
		9	8	8	8	8	7	6	11	14	15	16	18	_	15	-	13	12	_	12	11	11	_	-	_
South	20 60	- 1	- 2	- 4	1	4	14		27	30	28	26	20		12		7	6	3	2	1		0	0	- 1
South	100	- 1	-		- 3	_			20										6	4	2	1	1	0	- 1
	140	4	4	2	2	2	3	4	8	12			18				11	10	9	8	8	7	6	6	5
		7		6	5	4	4	4	4	4	7	10	13		15		16	_	12	_	10	9	_	8	7
Cauthunant	20	- 2	- 4	- 4	- 2	0	4	6	19	26	34	40	41		30		12	6	4	2	1	1.	0	- 1	- 1
Southwest	60	2	1	0	0	0	1	2	8	12						34		10		6	5	4	4	3	3
	100 140	7	- 1	6	5	4	5	6	7	8	12	14				24			15				- 1	8	7
		8		8	8	8	7	6	6	6	7	8	9	_	_	18		20	_	8	8	8	8	8	8
Mont	20	- 2		- 4	- 2	0	3	6	14	20						22		8	5	2	1	0	0	- 1	- 1
West	60	2		0	0	0	2	4	7	10						36				6	5	4	3	3	2
	100 140	7	1	7 6 6 6 6 6 7 8 10 12 17 20 25 28 27 26 19 14 12 11 10 9 8																					
		12		10	9	8	8	8	9	10	10	10	11	12	14	16	21	22	23	22	20	18	16	-	13
Nanthurant	20	- 3		- 4	- 2	0	3	6	10	12	19	24	33			34	18	6	4	2	0	- 1	- 1	- 2	- 2
Northwest	60	- 2		- 4	- 3	- 2	0	2	6	8	10		21	30		32		12	8	6	4	3	1	0	- 1
	100	5							5																
	140	8		6	6	6	6	6	6	6	6	6	7	8	9	10	14	_	_	_	_	_	-	-	9
N	20	- 3	1		- 3	- 2	1	4	8	10	12	14	13		10		6	4	2	0	0	13		- 2	- 2
North	60	- 3	- 3		_	-2	-1	0	3	6	8	10				12		8	6	4	2	- 1	0		- 2
(Shade)	100	1	1	0	0	0	0	0	1	2	3	4	5	5	5	8	7	6	5	4	3	1	2	2	1
	140	_1	1	0	0	0	0	0	0	0	1	2	3	4	5	6	7	8	7	6	4	3	2	2	1
		6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5
		AM PM AM																							
		SUN TIME																							

Equation: Heat Gain Thru Walls, Btu/hr = (Area, sq ft) X (equivalent temp diff) X (transmission coefficient U, Tables 21 thru 25)

For wall constructions less than 20 lb/sq ft, use listed values of 20 lb/sq ft.

<sup>\*</sup>All values are for the both insulated and uninsulated walls.

For other conditions, refer to corrections on page 64.

<sup>#&</sup>quot;Weight per sq ft" values for common types of construction are listed in Tables 21 thru 25.



## carrier ch1 load يتم تحديد قيمة $\Delta T_{(equivalent)}$ للاسقف وذلك من الجدول $\Delta T_{(equivalent)}$ وذلك من الجدول التالى:

#### TABLE 20-EQUIVALENT TEMPERATURE DIFFERENCE (DEG F)

FOR DARK COLORED<sup>†</sup>, SUNLIT AND SHADED ROOFS\*

Based on 95 F db Outdoor Design Temp; Constant 80 F db Room Temp; 20 deg F Daily Range; 24-hour Operation: July and 40 N. Lat.†

			110		·			_		_						÷									
	WEIGHTS								_			S	UN	TII	ИE						_				
CONDI-	OF ROOF‡				АМ									Ρ	M								A١	Л	
TION	(lb/sq ft)	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5
	10	- 4	- 6	- 7	- 5	- 1	7	15	24	32	38	43	46	45	41	35	28	22	16	10	7	3	1	- 1	- 3
Exposed	20	0	- 1	- 2	- 1	2	9	16	23	30	36	41	43	43	40	35	30	25	20	15	12	8	6	4	2
to	40	4	3	2	3	6	10	16	23	28	33	38	40	41	39	35	32	28	24	20	17	13	11	9	6
Sun	60	9	8	6	7	8	11	16	22	27	31	35	38	39	38	36	34	31	28	25	22	18	16	13	11
	80	13	12	11	11	12	13	16	22	26	28	32	35	37	37	35	34	34	32	30	27	23	20	18	14
Covered	20	- 5	- 2	0	2	4	10	16	19	22	20	18	16	14	12	10	6	2	1	1	- 1	- 2	- 3	- 4	- 5
with	40	- 3	- 2	- 1	- 1	0	5	10	13	15	15	16	15	15	14	12	10	7	5	3	1	- 1	- 2	- 3	- 3
Water	60	- 1	- 2	- 2	- 2	- 2	2	5	7	10	12	14	15	16	15	14	12	10	8	6	4	3	2	1	0
	20	- 4	- 2	0	2	4	8	12	15	18	17	16	15	14	12	10	6	2	1	0	- 1	- 2	- 2	- 3	- 3
Sprayed	40	- 2	- 2	- 1	- 1	0	2	5	9	13	14	14	14	14	13	12	9	7	5	3	1	0	0	- 1	- 1
	60	- 1	- 2	- 2	- 2	- 2	0	2	5	8	10	12	13	14	13	12	11	10	8	6	4	2	1	0	- 1
	20	- 5	- 5	- 4	- 2	0	2	6	9	12	13	14	13	12	10	8	5	2	1	0	- 1	- 3	- 4	- 5	- 5
Shaded	40	- 5	- 5	- 4	- 3	- 2	0	2	5	8	10	12	13	12	11	10	8	6	4	2	0	- 1	- 3	- 4	- 5
	60	- 3	- 3	- 2	- 2	- 2	- 1	0	2	4	6	8	9	10	10	10	9	8	6	4	2	1	0	- 1	- 2
		6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5
					ΑN									Р	M								A۱	Λ	
												S	UN	TI	МE										

Equation: Heat Gain Thru Roofs, Btu/hr = (Area, sq ft) × (equivalent temp diff) × (transmission coefficient U, *Tables 27 or 28*)
\*With attic ventilated and ceiling insulated roofs, reduce equivalent temp diff 25%

For peaked roofs, use the roof area projected on a horizontal plane.

†For other conditions, refer to corrections on page 64.

‡"Weight per sq ft" values for common types of construction are listed in Tables 27 or 28.

ملحوظة: الجدولين السابقين تمت بناءا علي ماهو مذكور اعلهم واذا حدث اختلاف يتم عمل معامل التصحيح من الجدول carrier ch1 load estimation وهو التالى:

TABLE 20A-CORRECTIONS TO EQUIVALENT TEMPERATURES (DEG F)

OUTDOOR																	
DESIGN																	
FOR MONTH																	
AT 3 P.M.							D	AILY F	RANGE	(deg	F)						
MINUS																	
ROOM TEMP																	
(deg F)	8	10	12	14	16	18	20	22	24	26	28	30	32	34	36	38	40
-30	-39	-40	-41	-42	-43	-44	-45	-46	-47	-48	-49	-50	-51	-52	-53	-54	-55
-20	-29	-30	-31	-32	-33	-34	-35	-36	-37	-38	-39	-40	-41	-42	-43	-44	-45
-10	-19	-20	-21	-22	-23	-24	-25	-26	-27	-28	-29	-30	-31	-32	-33	-34	-35
0	- 9	-10	-11	-12	-13	-14	-15	-16	-17	-18	-19	-20	-21	-22	-23	-24	-25
5	- 4	- 5	- 6	- 7	- 8	- 9	-10	-11	-12	-13	-14	-15	-16	-17	-18	-19	-20
10	1	0	- 1	- 2	- 3	- 4	- 5	- 6	- 7	- 8	- 9	-10	-11	-12	-13	-14	-15
15	6	5	4	3	2	1	0	- 1	- 2	- 3	- 4	- 5	- 6	- 7	- 8	- 9	-10
20	11	10	9	8	7	6	5	4	3	2	1	0	- 1	- 2	- 3	- 4	- 5
25	16	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
30	21	20	19	18	17	16	15	14	13	12	11	10	9	8	7	6	5
35	26	25	24	23	22	21	20	19	18	17	16	15	14	13	12	11	10
40	31	30	29	28	27	26	25	24	23	22	21	20	19	18	17	16	15



# Transmitted heat gain thru - الحرارة المنتقلة عبر الزجاج او الابواب او الاسقف الزجاجية doors and skylights and windows

$$\mathbf{Q}_1 = \mathbf{A} \cdot \mathbf{U} \cdot \Delta \mathbf{T}$$

- الحرارة الناتجة عن التوصيل من خلال الشباك (Q)
- مساحة الشبابيك كلها و (لا يلزم الاتجاه) (A)
- معامل انتقال الحرارة بالتوصيل للزجاج (U)
- الفرق بين درجة حرارة الغرفة ودرجة الحرارة الخارجية ( $\Delta T$ )
  - اذا كان هناك زجاج بالسقف او skylight او حوائط زجاجية او شبابيك او عزل يتم تحديد قيمة ال U من الجدول carrier ch1 load estimation من كتاب من كتاب

## TABLE 32-TRANSMISSION COEFFICIENT U-FLAT ROOFS WITH ROOF-DECK INSULATION SUMMER AND WINTER

Btu/(hr) (sq ft) (deg F temp diff)

	Dtu/(III	/ (SQ IL) (I	aeg r tei	np am,		
U VALUE OF ROOF		Addi	tion of Roof	f-Deck Insu	lation	
BEFORE ADDING			Thickn	ess (in.)		
ROOF DECK						
INSULATION	1/2	1	11/2	2	2 <sup>1</sup> /2	3
.60	.33	.22	.17	.14	.12	.10
.50	.29	.21	.16	.14	.12	.10
.40	.26	.19	.15	.13	.11	.09
.35	.24	.18	.14	.12	.10	.09
.30	.21	.16	.13	.12	.10	.09
.25	.19	.15	.12	.11	.09	.08
.20	.16	.13	.11	.10	.09	.08
.15	.12	.11	.09	.08	.08	.07
.10	.09	.08	.07	.07	.06	.05



## TABLE 33-TRANSMISSION COEFFICIENT U-WINDOWS, SKYLIGHTS, DOORS & GLASS BLOCK WALLS

Btu/(hr) (sq ft) (deg F temp diff)

Btar(iii) (eq it) (aeg i terrip aiii)													
	GLASS												
			Ver	tical Gla	ass				Horizon	tal Glass			
	Single	Single Double Triple Single Double (1/4")									(1/4")		
Air Space Thickness (in.)		1/4	1/4 1/2 3/4 -4			1/2   3/4 -4		Summer	Winter	Summer	Winter		
Without Storm Windows	1.13	0.61 0.55 0.53			0.41 0.36 0.3		0.34	0.86	1.40	0.50	0.70		
With Storm Windows	0.54 0.43 0.64												

	DOORS	
Nominal Thickness	U	U
of Wood (inches)	Exposed Door	With Storm Door
1, ,	0.69	0.35
11/4	0.59	0.32
11/2	0.52	0.30
13/4	0.51	0.30
2	0.46	0.28
21/2	0.38	0.25
3	0.33	0.23
Glass (3/4" Herculite)	1.05	0.43

HOLLOW GLASS BLOCK WALL	S
Description*	U
5 <sup>3</sup> / <sub>4</sub> ×5 <sup>3</sup> / <sub>4</sub> ×37/8" Thick—Nominal Size 6×6×4 (14)	0.60
7 <sup>3</sup> / <sub>4</sub> ×7 <sup>3</sup> / <sub>4</sub> ×37/8" ThickNominal Size 8×8×4 (14)	0.56
11 <sup>3</sup> / <sub>4</sub> ×11 <sup>3</sup> / <sub>4</sub> ×37/8" Thick—Nominal Size 12×12×4 (16)	0.52
$7\sqrt[3]{4}\times7\sqrt[3]{4}\times37/8$ " Thick with glass fiber screen dividing the cavity (14)	0.48
113/4×113/4×37/8" Thick with glass fiber screen dividing the cavity (16)	0.44

Equation: Heat Gain or Loss, Btu/hr = (Area, sq ft) × (U value) × (outdoor temp – inside temp)

ملحوظة: تم العمل بالحرارة المكافئة والتي بداخلها تعبير عن الحرارة المخزنة في جداول وحسابات الحوائط والاسقف اما الزجاج في اي مكان فتم الحساب فقط علي الفرق بين درجة الحرارة داخليا وخارجيا وذلك لان باخر جزء سيتم حساب الحرارة المخزنة عن طريق الشبابيك.

٤- الحرارة المنتقلة خلال البدرومات

وتنقسم الي حوائط وارضيات

Heat loss thru = area\*heat transfer coefficient  $U*(T_{basement}-T_{ground})$ 

- تحدد القيم المختلفة من الجداول ٣٥-٣٦-٣٧، ص ٨٠-٨١ من كتاب carrier ch1 load estimation وهي التاليه.

#### TABLE 35-TRANSMISSION COEFFICIENT U-MASONRY FLOORS AND WALLS IN GROUND

(Use only in conjunction with Table 36)

	Transmission
Floor or Wall	Coefficient U
	Btu/(hr) (sq ft) (deg f)
*Basement Floor	.05
Portion of Wall	
exceeding 8 feet	.08
below ground level	

<sup>\*</sup>Italicized numbers in parentheses indicate weight in lb per sq ft.



# TABLE 36-PERIMETER FACTORS FOR ESTIMATING HEAT LOSS THROUGH BASEMENT WALLS AND OUTSIDE STRIP OF BASEMENT FLOOR

(Use only in conjunction with Table 35)

	· · · · · · · · · · · · · · · · · · ·
Distance of Floor	Perimeter Factor
From Ground Level	(q)
2 Feet above	.90
At ground level	.60
2 Feet below	.75
4 Feet below	.90
6 Feet below	1.05
8 Feet below	1.20

#### Equations:

Heat loss about perimeter, Btu/hr = (perimeter of wall, ft) × (perimeter factor) × (basement-outdoor temp).

#### TABLE 37-GROUND TEMPERATURES

FOR ESTIMATING HEAT LOSS THROUGH BASEMENT FLOORS

Outdoor Design Temp (F)	-30	-20	-10	0	+10	+20
Ground Temp (F)	40	45	50	55	60	65





#### ٥- التسريب infiltration

يتم تحديد قيمة التسريب من الجدول ٢٤١، ص٨٩-٩٠ من كتاب carrier ch1 load estimation وذلك هو الجدول التالى:

#### TABLE 41-INFILTRATION THRU WINDOWS AND DOORS-SUMMER\* 7.5 mph Wind Velocity†


TABLE 41a-DOUBLE HUNG WINDOWS‡

	CFM PER SQ FT SASH AREA								
DESCRIPTION		Small-30 <b>X</b> "72	"	Large-54"X96"					
	No W-Strip	W-Strip	Storm Sash	No W-Strip	W-Strip	Storm Sash			
Average Wood Sash	.43	.26	.22	.27	.17	.14			
Poorly Fitted Wood Sash	1.20	.37	.60	.76	.24	.38			
Metal Sash	.80	.35	.40	.51	.22	.25			

TABLE 41b-CASEMENT TYPE WINDOWS ‡

				CFM F	ER SQ F	T SASH	AREA			
DESCRIPTION	Percent Openable Area									
	0%	25%	33%	40%	45%	50%	60%	66%	75%	100%
Rolled Section-Steel Sash										
Industrial Pivoted	.33	.72	-	.99	-	-	-	1.45	-	2.6
Architectural Projected	-	.39	-	-	-	.55	.74	-	-	-
Residential	-	-	.28	-	-	.49	-	-	-	6.3
Heavy Projected	-	-	-	-	.23	-	-	.32	.39	-
Hollow Metal-Vertically	.27	.58	-	.82	-	-	-	1.2	-	2.2
Pivoted										









REPRESENTATIVE TYPES OF WINDOWS (VIEWED FROM OUTSIDE)





#### TABLE 41-INFILTRATION THRU WINDOWS AND DOORS-SUMMER\* (Contd)

7.5 mph Wind Velocity†

#### Table 41c-DOORS ON ONE OR ADJACENT WALLS, CORNER ENTRANCES

	CFM PE	R SQ FT AREA**	CFM			
DESCRIPTION	No Use	Average Use	Standir	ng Open		
			No Vestibute	Vestibule		
Revolving Doors-Normal Operation	.8	5.2	-	-		
Panels Open	-	-	1,200	900		
Glass Door-3/4" Crack	4.5	10.0	700	500		
Wood Door (3"X7")	1.0	6.5	700	500		
Small Factory Door	.75	6.5	-	-		
Garage & Shipping Room Door	2.0	4.5	-	-		
Ramp Garage Door	2.0	6.75	-	-		

TABLE 41d-SWINGING DOORS ON OPPOSITE WALLS


% Time	CFM PER PAIR OF DOORS							
2 <sup>nd</sup> Door	% Time 1st Door is Open							
is Open	10	10 25 50 75						
10	100	250	500	750	1,000			
25	250	625	1250	1875	2,500			
50	500	1250	2500	3750	5,000			
75	750	1875	3750	5625	7,500			
100	1000	2500	5000	7500	10,000			

TABLE 41e-DOORS

	CFM PER	CFM PER PERSON IN ROOM PER DOOR					
APPLICATION		36" Swingi	ing Door				
	72" Revolving Door	No Vestibule	Vestibule				
Bank	6.5	8.0	6.0				
Barber Shop	4.0	5.0	3.8				
Candy and Soda	5.5	7.0	5.3				
Cigar Store	20.0	30.0	22.5				
Department Store (Small)	6.5	8.0	6.0				
Dress Shop	2.0	2.5	1.9				
Drug Store	5.5	7.0	5.3				
Hospital Room	-	3.5	2.6				
Lunch Room	4.0	5.0	3.8				
Men's Shop	2.7	3.7	2.8				
Restaurant	2.0	2.5	1.9				
Shoe Store	2.7	3.5	2.6				

<sup>\*</sup>All values in *Table 41* are based on the wind blowing directly at the window or door. When the wind direction is oblique to the window or door, multiply the above values by 0.60 and use the total window and door area on the windward side(s).

<sup>\*\*</sup> Vestibules may decrease the infiltration as much as 30% when the door usage is light. When door usage is heavy, the vestibule is of little value for reducing infiltration.



لاكثر من ذلك يرجي الرجوع الي المرجع.

<sup>†</sup>Based on a wind velocity of 7.5 mph. For design wind velocities different from the base, multiply the above values by the ratio of velocities. ‡Includes frame leakage where applicable.



### ventilation load حمل التهوية

نحصل عليه من جدول ٥٤، ص٩٦ و هو التالي:

#### **TABLE 45-VENTILATION STANDARDS**

APPLICATION	SMOKING	CFM PER	CFM PER SQ FT OF FLOOR	
711 2.67 (110.11	omorano	Recommended	Minimum*	Minimum*
Average	Some	20	15	-
Apartment De Luxe	Some	30	25	.33
Banking Space	Occasional	10	71/2	-
Barber Shops	Considerable	15	10	-
Beauty Parlors	Occasional	10	71/2	-
Broker's Board Rooms	Very Heavy	50	30	-
Cocktail Bars	Heavy	30	25	-
Corridors (Supply or Exhaust)	-	-	-	.25
Department Stores	None	71/2	5	.05
Directors Rooms	Extreme	50	30	-
Drug Stores†	Considerable	10	71/2	-
Factories‡§	None	10	71/2	.10
Five and Ten Cent Stores	None	7 <sup>1</sup> /2	5	-
Funeral Parlors	None	10	71/2	-
Garage‡	-	-	-	1.0
Operating Rooms‡**	None	-	-	2.0
Hospitals → Private Rooms	None	30	25	.33
Wards	None	20	15	-
Hotel Roms	Heavy	30	25	.33
Restaurant†	-	-	-	4.0
Kitchen Residence	-	-	-	2.0
Laboratories†	Some	20	15	-
Meeting Rooms	Very Heavy	50	30	1.25
General	Some	15	10	-
Office	None	25	15	.25
Private	Considerable	30	25	.25
Cafeteria†	Considerable	12	10	-
Restaurant \(\mathbb{L}\) Dining Room \(\dagger\)	Considerable	15	12	-
School Rooms‡	None	-		-
Shop Retail	None	10	71/2	-
Theater‡	None	71/2	5	-
Theater	Some	15	10	-
Toilets‡ (Exhaust)	-	-	-	2.0

 $<sup>^{\</sup>star}$ When minimum is used, use the larger.

§Use these values unless governed by other sources of contamination or by local codes.

\*\*All outdoor air is recommended to overcome explosion hazard of anesthetics.

 $H_S = 1.08 \times CFM \times \Delta T$ 

وتحدد قيمة الحرارة المفقودة لكل من التهوية والتسريب من العلاقة التالية:

<sup>‡</sup>See local codes which may govern.

<sup>†</sup>May be governed by exhaust..



## ۱nternal heat gain الاحمال الداخلية ٧-

- الناس people:

جدول ٤٨، ص ١٠٠

#### TABLE 48-HEAT GAIN FROM PEOPLE

			17	(DLL 40-	IILA I	JAIN FRO	JIVI FE	OFLE					
DEGREE OF	TYPICAL	Met-	Aver- age Ad- justed				ROOM	DRY-BULE	RTEMPE	RATURE			
ACTIVITY	APPLICATION	Rate (Adult	Met- abolic	82		80	F	78	F	75		70	
		Male) Btu/hr	Rate* Btu/hr	Btu/ Sensible	hr Latent	Btu/ Sensible	hr Latent	Btu. Sensible	/hr Latent	But Sensible	/hr Latent	Btu. Sensible	/hr Latent
Seated at rest	Theater, Grade School	390	350	175	175	195	155	210	140	230	120	260	90
Seated, very light work	High School	450	400	180	220	195	205	215	185	240	160	275	125
Office worker	Offices, Hotels, Apts., College	475											
Standing, walking slowly	Dept., Retail, or Variety Store	550	450	180	270	200	250	215	235	245	205	285	165
Walking, seated	Drug Store	550	500	180	320	200	300	220	280	255	245	290	210
Standing, walking slowly	Bank	550											
Sedentary work	Restaurant†	500	550	190	360	220	330	240	310	280	270	320	230
Light bench work	Factory, light work	800	750	190	560	220	530	245	505	295	455	365	385
Moderate dancing	Dance Hall	900	850	220	630	245	605	275	575	325	525	400	450
Walking, 3 mph	Factory, fairly heavy work	1000	1000	270	730	300	700	330	670	380	620	460	540
Heavy work	Bowling Alley‡ Factory	1500	1450	450	1000	465	985	485	965	525	925	605	845

<sup>\*</sup>Adjusted Metabolic Rate is the metabolic rate to be applied to a mixed group of people with a typical percent composition based on the following factors:

Metabolic rate, adult female=Metabolic rate, adult male×0.85
Metabolic rate, children =Metabolic rate, adult male×0.75

الإضاءة lights

جدول ٤٩، ص ١٠٠

TABLE 49 - HEAT GAIN FROM LIGHT

TYPE	HEAT GAIN* Btu/hr
Fluorescent	Total Light Watts×1.25 +×3.4
Incandescent	Total Light Watts×3.4

<sup>†</sup>Restaurant-Values for this application include 60 Bu per hr for food per Individual (30 Btu sensible and 30 Btu latent heat per hr).

<sup>‡</sup>Bowling-Assume one person per alley actually bowling and all others sitting, metabolic rate 400 Btu per hr; or standing, 550 Btu per hr.



## - الاجهزة appliances

جداول ٥٠-٥١-٥٢، ص ١٠٠-١٠١-١٠١

#### TABLE 50-HEAT GAIN FROM RESTAURANT APPLIANCES

NOT HOODED\*-ELECTRIC

	OVERALL	TYPE		MFR	MAIN- TAIN-		OM HEAT G	
APPLIANCE	DIMENSIONS	OF		MAX	ING	Sensible	Latent	Total
ALLIANOE	Less Legs and	CON-	MISCELLANEOUS	RATING	RATE	Heat	Heat	Heat
	Handles (In.)	TROL	DATA	Btu/hr	Btu/hr	Btu/hr	Btu/hr	Btu/hr
Coffee Brewer-1/2 gal	Tidifalos (III)	Man.	D/ (I/ (	2240	306	900	220	1120
Warmer-1/2 gal		Man.		306	306	230	90	320
4 Coffee Brewing Units		1110111	Water heater—2000					
with 41/2 gal Tank	20×30×26 H	Auto.	watts	16900		4800	1200	6000
9			Brewers-2960 watts					
Coffee Urn3 gal	15 DiaX34H	Man.	Black finish	11900	3000	2600	1700	4300
3 gal	12X23 oval X21H	Auto.	Nickel plated	15300	2600	2200	1500	3700
5 gal	18 Dia X37H	Auto.	Nickel plated	17000	3600	3400	2300	5700
Doughnut Machine	22×22×57H	Auto.	Exhaust system to					
			outdoors-1/2 hp motor	16000		5000		5000
Egg Boiler	10×13×25H	Man.	Med. ht550 watts					
			Low ht-275 watts	3740		1200	800	2000
Food Warmer with Plate			Insulated, separate					
Warmer, per sq ft top		Auto.	heating unit for each	1350	500	350	350	700
surface			pot. Plate warmer in					
			base					
Food Warmer without								
Plate Warmer, per sq ft		Auto.	Ditto, without plate	1020	400	200	350	550
top surface			warmer					
Fry Kettle111/2 lb fat	12 DiaX14H	Auto.		8840	1100	1600	2400	4000
Fry Kettle—25 lb fal	16×18×12H	Auto.	Frying area 12"X14"	23800	2000	3800	5700	9500
Griddle, Frying	18×18×8H	Auto.	Frying top 18"X14"	8000	2800	3100	1700	4800
Grille, Meat	14X14X10H	Auto.	Cooking area 10"X12"	10200	1900	3900	2100	6000
Grille, Sandwich	13×14×10H	Auto.	Grill area 12"X12"	5600	1900	2700	700	3400
Roll Warmer	26×17×13H	Auto.	One drawer	1500	400	1100	100	1200
Toaster, Continuous	15×15×28H	Auto.	2 Slices wide					
			360 slices/hr	7500	5000	5100	1300	6400
Toaster, Continuous	20×15×28H	Auto.	4 Slices wide					
			720 slices/hr	10200	6000	6100	2600	8700
Toaster, Pop-Up	6×11×9H	Auto.	2 Slices	4150	1000	2450	450	2900
Waffle Iron	12X13X10H	Auto.	One waffle 7" dia	2480	600	1100	750	1850
Waffle Iron for Ice Cream	14×13×10H	Auto.	12 Cakes,					
Sandwich			each 2 1/2"X3 3/4"	7500	1500	3100	2100	5200

<sup>\*</sup>If properly designed positive exhaust hood is used, multiply recommended value by .50.





## TABLE 51-HEAT GAIN FROM RESTAURANT APPLIANCES NOT HOODED\*--GAS BURNING AND STEAM HEATED

					MAIN-	REC	OM HEAT G	SAIN
	OVERALL	TYPE		MFR	TAIN-	F	OR AVG US	E
APPLIANCE	DIMENSIONS	OF		MAX	ING	Sensible	Latent	Total
	Less Legs and	CON-	MISCELLANEOUS	RATING	RATE	Heat	Heat	Heat
	Handles (In.)	TROL	DATA	Btu/hr	Btu/hr	Btu/hr	Btu/hr	Btu/hr
GAS BURNING								
Coffee Brewer-1/2 gal		Man.	Combination brewer	3400		1350	350	1700
Warmer-1/2 gal		Man.	and warmer	500	500	400	100	500
Coffee Brewing Units			4 Brewers and 41/2					
with Tank	19×30×26 H		gal tank			7200	1800	9000
Coffee Urn-3 gal	15" DiaX34H	Auto.	Black finish	3200	3900	2900	2900	5800
Coffee Urn3 gal	12X23 oval X21H	Auto.	Nickel plated		3400	2500	2500	5000
Coffee Urn5 gal	18 Dia X37H	Auto.	Nickel plated		4700	3900	3900	7800
Food Warmer, Values per								
sq ft top surface		Man.	Water bath type	2000	900	850	450	1300
Fry Kettle—15 lb fat	12X20X18H	Auto.	Frying area 10X10	14250	3000	4200	2800	7000
Fry Kettle—28 lb fal	15×35×11H		Frying area 11X16	24000	4500	7200	4800	12000
Grill—Broil-O-Grill	22X14X17H		Insulated					
Top Burner	(1.4 sq ft)	Man.	22,000 Btu/hr	37000		14400	3600	18000
Bottom Burner	grill surface)		15,000 Btu/hr					
Stoves, Short Order		Man.	Ring type burners	14000		4200	4200	8400
Open Top. Values			12000 to 22000					
per sq ft top surface			Btu/ea					
Stoves, Short Order		Man.	Ring type burners	11000		3300	3300	6600
Closed Top. Values			10000 to 12000					
per sq ft top surface			Btu/ea					
Toaster, Continuous	15×15×28H	Auto.	2 Slices wide	40000	40000	7700	0000	44000
			360 slices/hr	12000	10000	7700	3300	11000
			STEAM HEATED					
Coffee Urn3 gal	15 DiaX34H	Auto.	Black finish			2900	1900	4800
3 gal	12X23 ovalX21H	Auto.	Nickel plated			2400	1600	4000
5 gal	18 DiaX37H	Auto.	Nickel plated			3400	2300	5700
Coffee Urn3 gal	15 DiaX34H	Man.	Black finish			3100	3100	6200
3 gal	12X23 ovalX21H	Man.	Nickel plated			2600	2600	5200
5 gal	18 DiaX37H	Man.	Nickel plated			3700	3700	7400
Food Warmer, per sq ft								
top surface		Auto.				400	500	900
Food Warmer, per sq ft						455	4455	4500
top surface		Man.				450	1150	1500

<sup>\*</sup>If properly designed positive exhaust hood is used, multiply recommended value by. 50.





## TABLE 52-HEAT GAIN FROM MISCELLANEOUS APPLIANCES NOT HOODED\*

	TYPE		MFR	RECOM H	EAT GAIN FOR	R AVG USE
APPLIANCE	OF CONTROL	MISCELLANEOUS DATA	MAX RATING Btu/hr	Sensible Heat Btu/hr	Latent Heat Btu/hr	Total Heat Btu/hr
		GAS BURNING				
Hair Dryer, Blower Type		Fan 165 watts,				
15 amps, 115 volts AC	Man.	(low 915 watts, high 1580 watts)	5,370	2,300	400	2,700
Hair Dryer, helmet type,		Fan 80 watts,				
6.5 amps, 115 volts AC	Man.	(low 300 watts, high 710 watts)	2,400	1,870	330	2,200
Permanent Wave Machine		60 heaters at 25 watts each,				
	Man.	36 in normal use	5,100	850	150	1,000
Pressurized Instrument		44104441040011		40.000	00.400	05.400
Washer and Sterilizer		11"X11"X22"		12,000	23,460	35,460
Neon Sign, per		1/2" outside dia 3/8" outside dia		30		30
Linear ft tube		18"×30"×72"		1,200	2.000	4,200
Solution and/or Blanket Warmer		18"X24"X72"		1,200	3,000 2,400	3,450
Sterilizer	Auto.	16"X24"		9,600	8,700	18,300
Dressing	Auto.	20"X36"		23,300	24,000	47,300
Sterilizer, Rectangular Bulk	Auto.	24"X24"X36"		34,800	21,000	55.800
Sterilizer, Rectarigular Bulk	Auto.	24"X24"X48"		41,700	27,000	68,700
	Auto.	24"×36"×48"		56,200	36,000	92,200
	Auto.	24"×36"×60"		68,500	45,000	113,500
	Auto.	36"×42"×84"		161,700	97,500	259,200
	Auto.	42"×48"×96"		184,000	140,000	324,000
	Auto.	48"×54"×96"		210,000	180,000	390,000
Sterilizer, Water	Auto.	10 gallon		4,100	16,500	20,600
	Auto.	15 gallon		6,100	24,600	30,700
Sterilizer, Instrument	Auto.	6"X8"X17"		2,700	2,400	5,100
	Auto.	9"×10"×20"		5,100	3,900	9,000
	Auto.	10"×12"×22"		8,100	5,900	14,000
	Auto.	10"X12"X36"		10,200	9,400	19,600
	Auto.	12"X16"X24"		9,200	8,600	17,800
Sterilizer, Utensil	Auto.	16"X16"X24"		10,600	20,400	31,000
	Auto.	20"×20"×24"		12,300	25,600	37,900
Sterilizer, Hot Air	Auto.	Model 120 Amer Sterilizer Co		2,000	4,200	6,200
	Auto.	Model 100 Amer Sterilizer Co		1,200	2,100	3,300
Water Still		5 gal/hour		1,700	2,700	4,400
X-ray Machines, for		Physicians and Dentists office		None	None	None
making pictures						
X-ray Machines,		Heat load may be appreciable				
for therapy		write mfg for data				
		GAS BURNING				
Burner, Laboratory		7/16 dia barrel with				
small bunsen	Man.	manufactured gas	1,800	960	240	1,200
small bunsen	Man.	7/16 dia with nat gas	3,000	1,680	420	2,100
fishtail burner	Man.	7/16 dia with not gas	3,500	1,960	490	2,450
fishtail burner	Man.	7/16 dia bar with not gas	5,500	3,080	770	3,850
large bunsen	Man.	1 ½ dia mouth, adj orifice	6,000	3,350	850	4,200
Cigar Lighter	Man.	Continuous flame type	2,500	900	100	1,000
Hair Dryer System		Consists of heater & fan which				
5 helmets	Auto.	blows hot air thru duct system to	33,000	15,000	4,000	19,000
10 helmets	Auto.	helmets		21,000	6,000	27,000

<sup>\*</sup>If properly designed positive exhaust hood is used, multiply recommended value by. 50.



### - المواتير الكهربية

جدول ۵۳، ص ۱۰۶

## TABLE 53-HEAT GAIN FROM ELECTRIC MOTORS CONTINUOUS OPERATION\*

	CONTINUOUS OPERATION								
		LOCATION OF EQUIPMENT WITH RESPECT TO							
			IONED SPACE OR AIR						
NAMEPLATE†	FULL LOAD	Motor In-	Motor Out-	Motor In-					
OR	MOTOR	Driven Machine in	Driven Machine in	Driven Machine out					
BRAKE	EFFICIENCY	HPX2545	HPX2545	HPX2545 (1-% Eff)					
HORSEPOWER	PERCENT	% Eff		% Eff					
			Btu per Hour						
1/20	40	320	130	190					
1/12	49	430	210	220					
1/8	55	580	320	260					
1/6	60	710	430	280					
1/4	64	1,000	640	360					
1/3	66	1,290	850	440					
1/3	70	1,820	1,280	540					
3/4	72	2,680	1,930	750					
1	79	3,220	2,540	680					
1 1/2	80	4,770	3,820	950					
2	80	6,380	5,100	1,280					
3	81	9,450	7,650	1,800					
5 7 <sup>1</sup> / <sub>2</sub>	82	15,600	12,800	2,800					
7 1/2	85	22,500	19,100	3,400					
10	85	30,000	25,500	4,500					
15	86	44,500	38,200	6,300					
20	87	58,500	51,000	7,500					
25	88	72,400	63,600	8,800					
30	89	85,800	76,400	9,400					
40	89	115,000	102,000	13,000					
50	89	143,000	127,000	16,000					
60	89	172,000	153,000	19,000					
75	90	212,000	191,000	21,000					
100	90	284,000	255,000	29,000					
125	90	354,000	318,000	36,000					
150	91	420,000	382,000	38,000					
200	91	560,000	510,000	50,000					
250	91	700,000	636,000	64,000					
AF 1.1 111 1									

<sup>\*</sup>For intermittent operation, an appropriate usage factor should be used, preferably measured.

#### Maximum Service Factors

Horsepower	/20 - /8	/6 - /3	/2 - 3/4	1	1 /2 - 2	3 - 250
AC Open Type	1.4	1.35	1.25	1.25	1.20	1.15
DC Open Type				1.15	1.15	1.15

<sup>†</sup>If motors are overloaded and amount of overloading is unknown, multiply the above heat gain factors by the following maximum service factors:





### - الممرات الهوائية duct heat gain

خریطة ۳، ص ۱۰۹

#### CHART 3- HEAT GAIN TO SUPPLY DUCT

Percent of Room Sensible Heat





### MULTIPLYING FACTORS FOR OTHER ROOM TEMPERATURES

Room Temp	<b>Multiplying Factor</b>
75	1.10
76	1.06
77	1.00
78	0.97
79	0.94
80	0.92

Q = UPI × 
$$\frac{2.165 \times AV}{(2.165 \times AV) + UPI}$$
  $(t_3-t_1)$ 

where:

Q = duct heat gain (Btu/hr)

U = duct heat transmission factor (Btu/hr-sq ft-F)

P = rectangular duct perimeter (ft)

1 = duct length (ft)

A = duct area (sq ft)

V = duct velocity (fpm)

t<sub>1</sub> = temperature of supply air entering duct (F)

t3 = temperature of surrounding air (F)

Based on formulas in ASHRAE Guide 1963, p. 184, 185.



#### ٨- الحرارة المخزنة

الحرارة الساقطة من الشمس علي المبني هي حرارة لحظية instantaneous ولكن الحمل الفعلي لجهاز التكييف المطلوب نزعة من الغرفة يكون الفرق بين تلك الحرارة اللحظية والحرارة المخزنة storage في جدران ومكونات المبني او الغرفة، ويعتمد ذلك علي ما يسمي بالسعة الحرارية للمبني وهي تساوي وزن المبني مقسوما علي الحرارة النوعية للمبني تكون غالبا (btu/hr.f •, ۲) وسبق ان اشرنا الي كيفية الحصول علي وزن كل مكون من مكونات الغرفة بالرجوع لجدول ٢١-٣٣، وكما ذكر ايضا بنفس البند يستخدم مصطلح وزن المبني للدخول الي الجداول المختلفة لتعيين القيم المطلوبة وهنا نستخدم ذلك العنصر للدخول الي جداول الي جداول الي جداول ٧-١٢، ص ٣١ والتالي مثال عليه:

# TABLE 7-STORAGE LOAD FACTORS, SOLAR HEAT GAIN THRU GLASS WITH INTERNAL SHADE\* 24 Hour Operation, Constant Space Temperature†

EVECULE	WEIGHT§											S	UN	TII	ИE											
(North Lat)	(lb per sq				ΑМ									Ρ	М								A۱	Λ		EXPOSURE
(NOTH Lat)	ft of floor area)	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5	(South Lat)
	150 & over	.47	.58	.54	.42	.27	.21	.20	.19	.18	.17	.16	.14	.12	.09	.08	.07	.06	.06	.05	.05	.04	.04	.04	.03	
Northeast	100	.48	.60	.57	.46	.30	.24	.20	.19	.17	.16	.15	.13	.11	.08	.07	.06	.05	.05	.04	.04	.03	.03	.02	.02	Southeast
	30	.55	.76	.73	.58	.36	.24	.19	.17	.15	.13	.12	.11	.07	.04	.02	.02	.01	.01	0	0	0	0	0	0	
	150 & over	.39	.56	.62	.59	.49	.33	.23	.21	.20	.18	.17	.15	.12	.10	.09	.08	.08	.07	.06	.05	.05	.05	.04	.04	
East	100	.40	.58	.65	.63	.52	.35	.24	.22	.20	.18	.16	.14	.12	.09	.08	.07	.06	.05	.05	.04	.04	.03	.03	.02	East
	30	.46	.70	.80	.79	.64	.42	.25	.19	.16	.14	.11	.09	.07	.04	.02	.02	.01	.01	0	0	0	0	0	0	
	150 & over	.04	.28	.47	.59	.64	.62	.53	.41	.27	.24	.21	.19	.16	.14	.12	.11	.10	.09	.08	.07	.06	.06	.05	.05	
Southeast	100	.03	.28	.47	.61	.67	.65	.57	.44	.29	.24	.21	.18	.15	.12	.10	.09	.08	.07	.06	.05	.05	.04	.04	.03	Northeast
	30	0	.30	.57	.75	.84	.81	.69	.50	.30	.20	.17	.13	.09	.05	.04	.03	.02	.01	0	0	0	0	0	0	
	150 & over	.06	.06	.23	.38	.51	.60	.66	.67	.64	.59	.42	.24	.22	.19	.17	.15	.13	.12	.11	.10	.09	.08	.07	.07	
South	100	.04	.04	.22	.38	.52	.63	.70	.71	.69	.59	.45	.26	.22	.18	.16	.13	.12	.10	.09	.08	.07	.06	.06	.05	North
	30	.10	.21	.43	.63	.77	.86	.88	.82	.56	.50	.24	.16	.11	.08	.05	.04	.02	.02	.01	.01	0	0	0	0	
	150 & over	.08	.08	.09	.10	.11	.24	.39	.53	.63	.66	.61	.47	.23	.19	.18	.16	.14	.13	.11	.10	.09	.08	.08	.07	
Southwest	100	.07	.08	.08	.08	.10	.24	.40	.55	.66	.70	.64	.50	.26	.20	.17	.15	.13	.11	.10	.09	.08	.07	.06	.05	Northwest
	30	.03	.04	.06	.07	.09	.23	.47	.67	.81	.86	.79	.60	.26	.17	.12	.08	.05	.04	.03	.02	.01	.01	0	0	
	150 & over	.08	.09	.09	.10	.10	.10	.10	.18	.36	.52	.63	.65	.55	.22	.19	.17	.15	.14	.12	.11	.10	.09	.08	.07	
West	100	.07	.08	.08	.09	.09	.09	.09	.18	.36	.54	.66	.68	.60	.25	.20	.17	.15	.13	.11	.10	.08	.07	.06	.05	West
	30	.03	.04	.06	.07	.08	.08	.08	.19	.42	.65	.81	.85	.74	.30	.19	.13	.09	.06	.05	.03	.02	.02	.01	0	
	150 & over	.08	.09	.10	.10	.10	.10	.10	.10	.16	.33	.49	.61	.60	.19	.17	.15	.13	.12	.10	.09	.08	.08	.07	.06	
Northwest	100	.07	.08	.09	.09	.10	.10	.10	.10	.16	.34	.52	.65	.64	.23	.18	.15	.12	.11	.09	.08	.07	.06	.06	.05	Southwest
	30	.03	.05	.07	.08	.09	.09	.10	.10	.17	.39	.63	.80	.79	.28	.18	.12	.09	.06	.04	.03	.02	.02	.01	0	
North	150 & over	.08	.37	.67	.71	.74	.76	.79	.81	.83	.84	.86	.87	.88	.29	.26	.23	.20	.19	.17	15	.14	.12	.11	.10	South
and	100	.06	.31	.67	.72	.76	.79	.81	.83	.85	.87	.88	.90	.91	.30	.26	.22	.19	.16	.15	.13	.12	.10	.09	.08	and
Shade	30	0	.25	.74	.83	.88	.91	.94	.96	.96	.98	.98	.99	.99	.26	.17	.12	.08	.05	.04	.03	.02	.01	.01	.01	Shade

Equation: Cooling Load, Btu/hr = [Peak solar heat gain, Btu/(hr) (sq ft), (Table 6)]

- X [Window area, sq ft]
- X [Shade factor, Haze factor, etc., (Chapter 4)]
- X [Storage factor, (above Table at desired time)]



### يوضح الشكل التالى منحنى الحرارة اللحظية ومنحنى الحرارة الحقيقية




FIG. 3-ACTUAL COOLING LOAD, SOLAR HEAT GAIN, WEST EXPOSURE, AVERAGE CONSTRUCTION

#### ملاحظات هامة:

- يستخدم العامل السابق بان يضرب في الحمل الحراري الشمسي الواقع على الشبابيك او الحمل الحراري الخاص بالناس او الاجهزة او الإضاءة وذلك كما موضح بالمرجع وذلك لنحصل على القيمة الحقيقية الفعلية للحمل المطلوب نزعه.
- عند الحصول علي القيمة الخاصة لوزن ال partition نقسم علي ٢ لانها ليست معرضه لاشعة الشمس كالحوائط الخارجية.
  - للحوائط الداخلية partitions

 $T_o$  -  $T_{in}$  – 5 = الحرارة درجات الحرارة

 $T_o$  -  $T_{in}$  + 15 to 25= الغلايات المطابخ او الغلايات

المرجع ص٦٩.



# ٣-٣ الملخص الجدول التالي يوضح جدول لحسابات الاحمال الحرارية اليدوية بالصورة التقليدية:

CHAP REF	TABLE	REFERENCES	CHAP REF		TA	BLE REFE	ERENCES		
	ITEM AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF. FACTOR		ESTIMATE FOR		LOCAL TIME	PEAK LOA	ID	LOCAL TIME SUN TIME
3 & 4	GLASS WITH SO GLASS STORAGE SO GLASS WITHOUT	GAIN GLASS   FT X   Tels 687.8   X   Tels 16.17   FT X   PP 29.34   X   PP 52.54   FT X   Tels 15 CORR	2	CONDITIONS OUTDOOR (OA) ROOM (RM) DIFFERENCE	Tecs 1-3	-	% RH 23 X X X	DP X X X	GR/LB
5	SKYLIGHT   SC	FT X         PP 44-49         X         PP 44-49           GAIN—WALLS         F ROOF           FT X         X         TBLS 21-22           FT X         X         23.24 oR 25           FT X         P 62         X         PP 66-69           FT X         TBL 20         X         TBLS 27-28           FT X         P 63         X         71.72	6	OPEN	ng Doors	PEOPLE :	CFM VENTIL	H/PERSON :	=
6	ALL GLASS         SC           PARTITION         SC           CEILING         SC           FLOOR         SC	Total   Tota		ESHF EFFEC SENS I FACT THE 6		PPARATUS  EFFE SYCH CHART	DEWPOII COTIVE ROOM FIG 33 P 11	NT SEHS. HE TOTAL HE	AT =





				P 121 DEHUMIDIFIED AIR QUANTITY
3	PEOPLE PEOPLE X 77 38.100		TEMP. RISE	(1BF) × (T <sub>AB</sub> F - T <sub>Abp</sub> F) =F
8	POWER HP on KW X Tal 53 p 105		DEHUM.	EFFECTIVE ROOM SENS. HEATCFM.DA
7	LIGHTS WATTS X 3.4 X PP 35.38 101		· · ·	1.08 × F TEMP. RISE
1 ′ 1	APPLIANCES, ETC. TBLS 50-52 PP 101-103 X TBLS 50-52		QUTLET TEMP.	ROOM SEMS. HEAT = F(SH-OUTLET AIR)*
-	ADDITIONAL HEAT GAINS TBLS 54-57 PP 107-109 X	8	Dirr.	1.08 × CFH AA
2	TEMP SWING SUB TOTAL			SUPPLY AIR QUANTITY
8 3	STORAGE SQ FT X TEL 14 P 38 X (- Tel 13)		SUPPLY	Danie Cana Mana
- 3	SUB TOTAL		SUPPLY	1.08 × F DESIRED BATE
	SAFETY FACTOR F 113 %		BYPASS	ALIMO AND
7	ROOM SENSIBLE HEAT		CFM	Сги заСги за =Сги за
	SUPPLY CHART 3 SUPPLY P 110 FAX TOL 59 DUCT P 110 DUCT P 110 FAX P 111 HEAT GAIR 96 + LEAR LOSS 96 + N.P. %			RESULTING ENT & LYG CONDITIONS AT APPARATUS
8	OUTDOOR AIR NOTE 3 CFM X NOTE 1F X P 121 BF X 1.08		EDB	T <sub>BH</sub> F + F125 CFMT × (T <sub>OA</sub> F - T <sub>BH</sub> F) = T <sub>EOB</sub> F
$\vdash$	EFFECTIVE ROOM SENSIBLE HEAT		LDB	TADPF +
6	INFILTRATION NOTE 4 CFM × Nutt 2 Ga/La × 0.68			FROM PSYCH. CHART: TemaF, TimeF
3	PEOPLE PEOPLE X TRUS 14.48; PP 38.100	_		
1 1	STEAM P 107 Le/He X 1030		l	HOTES
&	APPLIANCES, ETC. TOLS 50-52 PT 101-103 X CORR BELOW TELS			
7	ADDITIONAL HEAT GAINS TEL 58 P 109		1. Use	DRY-BULB (DB) TEMPERATURE DIFFERENCE FROM TOP OF ESTIMATE
5_	VAPOR TRANS. Se FT X 1/100 X North 2 Ge/Le X TSL 40 P 84		2. Use	MOISTURE CONTENT (GR. LB) DIFFERENCE FROM TOP OF ESTIMATE
7	SAFETY FACTOR P 113 %		3. Nos	RMALLY, USE "CFM VENTILATION" FOR "CFM OUTDOOR AIR." HOW- R WHEN INSTITUTED IS TO BE OFFSET, REFER TO PAGE 92 TO ERMINE "CFM OUTDOOR AIR."
'	ROOM LATENT HEAT		4. WH	EN INTILITATION IS NOT TO BE OFFSET, AND "CFR VENTILATION" LESS THAN "CFR INFILTRATION" THEN THE EXCESS INFILTRATION
$\vdash$	SUPPLY DUCT LEAKAGE LOSS PIIO %		iš A	LESS THAN "CIM INFILTRATION." THEN THE EXCESS INFILTRATION
1 1	OUTDOOR AIR NOTE 3 CFH X NOTE 2 COPLE X P 121 OF X 0.48		l	
1 1	EFFECTIVE ROOM LATENT HEAT		l	
8				- Maria
1 1	OUTDOOR AIR HEAT  SENSIBLE: Note 3 CFN x Note 1 F x (1 - # 1218F) x 1.08			
	LATENT: NOTE 3 CFM X NOTE 2Garle X (1 - F 121BF) Y 0.68		l	
$\vdash$				
7	HEAT GAIN % + LEAK, GAIN % 1 PUNP % + PIPE LOSS %		Twee an	AT IN THE MINE, DETERMINE SOFFER CHE POR PERSON DEPARTMENT OF SEPTEM AND PROSENTAL.
	GRAND TOTAL HEAT		*****	PALLING SETURN AIR COLF, WAS DEMONIFIED CPW.

With Carrier Masthead Form E20. Without Carrier Mosthead Form E5024.

## الجدول التالي المعادلات المستخدمة في تحديد الاحمال الحرارية وذلك طبقا لما سابقا وكذلك بالجدول السابق:

اسم الحمل الحراري-Load name	المعادلة-Equation
الحرارة المكتسبة الشمسية الشبابيك-Window solar heat gain	Q=A*sc*q
الحرارة المكتسبة من الشمس والمنتقلة الي الغرفة عن طريق الحوائط والاسقف- &Solar Transmitted heat gain thru walls and roofs	$Q_2=A*U*\Delta T_{(equivalent)}$
الحرارة المنتقلة عبر الزجاج او الابواب او الاسقف الزجاجية- Transmitted heat gain thru doors and skylights and windows	$Q_1=A*U*\Delta T$
infiltration التسريب	$H_S = 1.08 \times CFM \times \Delta T$
حمل التهوية ventilation load	$H_S = 1.08 \times CFM \times \Delta T$



internal heat gain الاحمال الداخلية	
people الناس	
الاضاءة lights	
appliances الاجهزة	
المواتير الكهربية	
الممرات الهوائية duct heat gain	
الحرارة المخزنة	





## ٣-٤- المرجع

