

Assessing Options for an Aging Trickling Filter Wastewater Treatment Plant


David A. Burns, PE

TEC Inc.

Overview

- Moody AFB, Georgia treats its own wastewater and discharges to a small creek under an NPDES permit
- Wastewater Treatment Plant (WWTP) uses low-rate trickling filter for biological treatment
- WWTP built in the 1940s & recently had problems with filter distributor arms
- Problems led Base to look into long-term solutions to the aging treatment plant

Existing / Standard WWTP



MOODY AFB WWTP ASSESSMENT
FIGURE 1. FLOW DIAGRAM

TEC Inc.
619 Seven Ave Suite 202
Annapolis, MD 21401
(410) 290-0209

9/21/2009
S.A.C.
E.J.Y.

Overview



WWTP


- Design flow = 750,000 gallons per day (gpd)
- Actual flow ~ 400,000 gpd
- Actual flow consists of 300k gpd wastewater + 100k gpd excess water from the drinking water plant
- WWTP built in the 1940s & recently having problems with filter distributor arms

Base wanted to plan for long-term solutions to the aging treatment plant


NPDES Limits

Effluent Characteristic	Discharge Limitations (mg/L unless noted)		Monitoring Requirements		
	Monthly Avg.	Weekly Avg.	Frequency	Type	Location
Flow (mgd)	0.75	1.125	Daily	Continuous	Effluent
BOD ₅	15	22	2/week	Composite	Effluent
Fecal Coliform	200/100 ml	400/100 ml	1/week	Grab	Effluent
Suspended Solids	30	45	2/week	Composite	Effluent
Ammonia Nitrogen					
May-Oct	2.0	3.0	2/week	Composite	Effluent
Nov-April	4.0	6.0	2/week	Composite	Effluent
Tot. Residual Chlorine	-	-	Daily	Grab	Effluent

Ammonia N in Effluent



Ammonia N in Effluent



Regulatory Background (cont'd)

- Trickling Filter arm problems in 2007/2008 led to elevated ammonia-nitrogen discharge levels.
 - Exceeded NPDES permit limits 3 times in the summer of 2008
 - Base worked closely with GA regulators to avoid penalties while problem being fixed
- The base replaced the distributor assemblies (columns, bearings, arms, nozzles) in early 2009, which solved the ammonia problem.

Long Term Options

After acute problems resolved, Moody AFB was/is still operating a 70-year old plant and wanted long term options assessed.

TEC Inc. performed assessment of WWTP options in 2009/2010

1. Maintain existing plant
2. Replace plant with a new system
3. Connect to nearby municipal systems
 - a) Lowndes County (adjacent)
 - b) City of Valdosta (6 miles away)

Option 1 – Maintain Existing WWTP

- TEC Engineers assessed the WWTP
- Documented deficiencies with TEC's facilities management system (TECfms)
- Each deficiency includes a brief description, severity of deficiency, recommended solution, and cost estimate.
- Deficiencies listed in work packages, allowing for groups / project planning.
- TEC prioritizing work packages as immediate (1-2 years), short-term (in 5 years) and long-term (20 years).
- Includes new electrical and control systems



TEC Work Package Report
Upgrade Existing WWTP
Recommended Year 2011

Immediate
Repairs
(1-2 yr)

\$750,000

Deficiency Summary				
Asset Number	Def Num	Deficiency Name	Direct Cost	Direct Cost with Burden
1002	A10-31795	Floor discoloration	\$594.00	\$908.14
1002	B20-31793	Aging doors	\$800.00	\$1,223.09
1002	C10-31794	Discoloration/stains on walls and ceiling	\$1,158.00	\$1,770.42
1003	B20-31943	Aging door	\$800.00	\$1,223.09
1003	C10-31752	Replace ceiling/clean walls and floors	\$5,100.00	\$7,797.18
1004	D20-31941	No influent flow measurement	\$40,000.00	\$61,154.35
1004	G20-31942	missing handrail	\$1,575.00	\$2,407.95
1005	B20-31953	Windows and doors and poor condition	\$1,640.00	\$2,507.33
1005	B30-31645	Shingled roof to be replaced	\$1,969.00	\$3,010.32
1005	C10-31886	interior paint	\$4,032.00	\$6,164.36
1005	D50-31887	broken gas meter	\$1,500.00	\$2,293.29
1005	D50-31954	Aging electrical system to be replaced	\$50,000.00	\$76,442.94
1005	G20-31885	rehab exterior steps	\$15,050.00	\$23,009.32
1005	G30-31888	DIGESTER ROOF DETERIORATION	\$200,000.00	\$305,771.76
1005	G30-31889	Aging digester basin	\$143,325.00	\$219,123.69
1005	G30-31955	Gas piping	\$750.00	\$1,146.64
1013	A10-31803	Aging Floor	\$1,520.00	\$2,323.87
1013	B20-31959	Aging doors	\$800.00	\$1,223.09
1013	B30-31797	Deteriorating Roof	\$2,030.00	\$3,103.58
1013	C10-31801	Discoloration and stains on walls and ceiling	\$2,475.00	\$3,783.93
1013	D30-31958	Aging chlorine mixer	\$2,500.00	\$3,822.15
1013	D30-31960	Aging vent fans	\$5,000.00	\$7,644.29
1013	E10-31796	Breathing apparatus enclosure deterioration	\$1,000.00	\$1,528.86
1014	A10-31810	Floor discoloration	\$713.00	\$1,090.08
1014	B20-31811	Warped doors	\$1,600.00	\$2,446.17
1014	B30-31808	Aging Roof	\$1,190.00	\$1,819.34
1014	C10-31809	Discoloration and stains on walls and ceiling	\$1,440.00	\$2,201.56
SUBTOTAL			\$488,561.00	\$746,940.78

Short -Term
Repairs
(5 yr)

\$2,900,000



TEC Work Package Report
Upgrade Existing WWTP
Recommended Year 2015

Deficiency Summary				
Asset Number	Def Num	Deficiency Name	Direct Cost	Direct Cost with Burden
1004	B20-32557	Building 1004 Demolition/Reconstruction	\$65,000.00	\$99,375.82
1004	D20-31938	Yard hydrant in poor condition	\$2,000.00	\$3,057.72
1004	D20-31970	No capability to add chlorine to trickling filters	\$2,500.00	\$3,822.15
1004	D50-31944	Aging site electrical system	\$250,000.00	\$382,214.70
1004	D50-31962	Aging samplers	\$12,000.00	\$18,346.31
1004	F20-31947	Aging pumps	\$36,000.00	\$55,038.92
1004	F20-31967	Aging chain and flight for primary clarifiers	\$80,000.00	\$122,308.70
1004	F20-31968	Aging chain and flight for secondary clarifiers	\$80,000.00	\$122,308.70
1004	G30-31892	PRIMARY CLARIFIERS CONCRETE BASIN EROSION	\$94,520.00	\$144,507.73
1004	G30-31893	TRICKLING FILTER #1 CONCRETE BASIN EROSION	\$175,000.00	\$267,550.29
1004	G30-31894	TRICKLING FILTER #2 Concrete basin erosion	\$175,000.00	\$267,550.29
1004	G30-31895	SECONDARY CLARIFIERS Concrete basin erosion	\$71,450.00	\$109,236.96
1004	G30-31896	Chlorine Contact Tank Concrete Basin Erosion	\$28,975.00	\$44,298.68
1004	G30-31897	SEWAGE OUTFALL CONCRETE CHANNEL EROSION	\$63,000.00	\$96,318.10
1004	G30-31898	Rebuild sludge drying beds	\$90,000.00	\$137,597.29
1004	G30-31937	Scum valve replacement	\$8,000.00	\$12,230.87
1004	G30-31949	splitter box basin erosion	\$8,200.00	\$12,536.64
1004	G30-31951	Vent piping replacement - filter 1	\$8,000.00	\$12,230.87
1004	G30-31951	Vent piping replacement - filter 1	\$8,000.00	\$12,230.87
1004	G30-31952	Vent piping replacement - filter 2	\$8,000.00	\$12,230.87
1004	G30-31952	Vent piping replacement - filter 2	\$8,000.00	\$12,230.87
1004	G30-31965	Media replacement - filter 1	\$300,000.00	\$458,657.64
1004	G30-31966	Media replacement - filter 2	\$300,000.00	\$458,657.64
1013	D30-31961	Larger pump	\$3,000.00	\$4,586.58
SUBTOTAL			\$1,876,645.00	\$2,869,125.22



Example Short Term Repair

Primary
Clarifiers
chains
\$80,000

Deficiency Details

F20-31967 - Aging chain and flight for primary clarifiers



IMG_3622.JPG-Chain and flight at primary clarifier

Problem Statement:

The chain and flight mechanisms on the clarifiers are nearly 15 years old and are beginning to show signs of aging.

Solution Statement:

Remove the existing mechanisms and replace with new mechanisms.

Code Reference:

Uniformat Classification	
Uniformat Code:	Mechanical Systems
Inventory Item:	Chain and flight for Primary Clarifiers

Deficiency Impacts	
Severity Rating:	Moderate
Impact Type	Mission
Impact Severity:	The deficiency will result in partial loss of facility operations (<50%)
Impact Mishap Probability:	Failure is predicted within a year after the inspection.
Distress Type:	Deteriorated

Deficiency Specifications	
Recommended Execution Year:	2015
Deficiency Source:	FMS
Work Type:	Replace

Deficiency Cost	
Labor	\$0.00
Materials	\$80,000.00
Equipment	\$0.00
Total	\$80,000.00

Option 1 Summary (Maintain WWTP)

- Capital Costs = \$3.8 million (not all at once)
- Annual Operating Costs = \$225,000



Option 2 – Install a new Sequencing Batch Reactor Treatment System


- Influent Flow Metering
- Influent Control/Splitter Chamber
- Mechanical Fine Screen System with Manual Coarse Screen Backup
- Two Sequencing Batch Reactor Tanks with Equipment
- One Post Equalization Tank with Effluent Pumps
- Two Aerobic Digester Tanks with Equipment
- Blower Building with Equipment
- New Chlorine Disinfection System
- New Control Building

Option 2 Costs

Table 12. Construction Cost Estimate - Install New SBR Plant	
Item	Cost Estimate
Mobilization/Demobilization	\$50,000
Bonds and Insurances	\$50,000
Allowance for Construction Sequencing	\$25,000
Siteworks, earthwork and roadways	\$150,000
Yard Piping	\$250,000
Headworks (Influent chamber, flow meters, comminutor chamber)	\$250,000
SBR, Post EQ, Digester, Blower room structure	\$2,000,000
SBR digester equipment and controls	\$1,000,000
Chemical feed equipment	\$125,000
Post EQ Pumps	\$60,000
Chlorine contact chamber	\$80,000
Chlorination equipment	\$40,000
New Control Building	\$100,000
Electrical Construction	\$450,000
Demolition and renovation of existing plant	\$150,000
SUBTOTAL	\$4,780,000
Miscellaneous and Contingency @ 20%	\$956,000
Preliminary Construction Cost Estimate	\$5,736,000
Engineering and Administration @ 30%	\$1,720,800
Total Capital Cost	\$7,456,800

Option 2 Summary (Maintain WWTP)

- Capital Costs = \$7.5 million (not all at once)
- Annual Operating Costs = \$272,000



Option 3 – Connect to Municipality



City of Valdosta

- Adequate capacity
- 6 miles away/expensive connection

Lowndes County

- Collection system adjacent to base
- Capacity in question
- Other requirements not attractive to base

Project Overview



Option 3 Summary (Connect to Municipality)

- County
 - Capital Costs = \$2.01 million
 - Annual Operating Costs = \$328,000
- City
 - Capital Costs = \$2.44 million
 - Annual Operating Costs = \$376,000

Cost Summary of Options

ALTERNATIVE		CAPITAL COSTS	ANNUAL O&M COSTS
Upgrade Existing Plant		\$3.8 Million	\$225,000
Install New SBR Plant		7.5 Million	\$272,000
Connect to Local Municipality	Lowndes County	* \$2.01 Million	** \$328,500
	City of Valdosta	*\$2.44 Million	\$376,000

The Way Forward

- HQ ANG now has the information needed to make a decision as to what to do about the non-DLA approved contractors

— Direct bases to submit waivers?

ALTERNATIVE		CAPITAL COSTS	ANNUAL O&M COSTS
Upgrade Existing Plant		\$3.8 Million	\$225,000
Install New SBR Plant		7.5 Million	\$272,000
Connect to Local Municipality	Lowndes County	* \$2.01 Million	** \$328,500
	City of Valdosta	*\$2.44 Million	\$376,000

• E

C

compliance audit of their selected facility