


FIRE HYDRANT SYSTEM



**Naqash Kazmi (CFPS®) NFPA
CERTIFIED FIRE PROTECTION SPECIALIST(CFPS®)**

Standards & Codes of Fire Hydrants



The following norms and standards are used as design recommendations for fire hydrant systems:

- NFPA 14
- NFPA 20
- NFPA 25
- AWWA
- BS EN 14384
- BS 750

INTRODUCTION



Fire Hydrant System, the oldest and still one of the most effective ones, consists of the following components:


- ▶ Sufficiently large water reservoir / Tank.
- ▶ Fire pump sets (Main and Standby) UL/FM.
- ▶ Jockey pump set.
- ▶ Hydrant valves.
- ▶ Fire fighting hoses.
- ▶ Branch pipe with nozzles.
- ▶ Pipe & Fitting (Sch-40).

SYSTEM COMPONENTS



- ▶ Landing Valves
- ▶ Hoses
- ▶ Couplings
- ▶ Hose Reels
- ▶ Fire Brigade Connectors
- ▶ Branch Pipes & Nozzles
- ▶ Pump Set
- ▶ Water Tank

Fire Hydrant System



Storage Tanks & Water Reservoir



Storage tanks and water reservoir are tanks that supply water for the water based fire protection system.

Types of water tanks.

- 1- Gravity Tanks
- 2- Pressure Tanks
- 3- Suctions tanks

Gravity Tanks.



Gravity tanks are **elevated water tanks that utilize gravity to provide pressure**. They might be capable of providing the necessary pressure to operate a fire suppression system on their own, or they can be used to provide water to a fire pump.



Pressure Tanks.




Pressure tanks contain both water and air under pressure. When a system is actuated, the pressurized air pushes the water out of the tank. Because of this, a sufficient capacity of air must be available to discharge the water from the tank at the necessary rate. Pressure tanks are rarely used because they are typically no larger than 10,000 gallons (37,850 liters).



Suction Tanks.



Suction tanks are mounted on the ground or below ground. Because of this they do not utilize elevation as a primary means to increase the pressure. Suction tanks typically provide water to a fire pump, which then boosts the pressure. Special consideration is needed for below grade tanks because they must either have a vertical turbine pump or a pump located below the tank.



Types of Fire Hydrants.

1-Wet Barrel Hydrant

The wet barrel fire hydrant holds a constant water supply.

2-Dry Barrel Hydrant

The dry barrel fire hydrant needs to have a valve release to let water in.



Types of Fire Hydrants



Oblique Flanged
LV-OFB



Oblique Threaded
LV-OBT



Double Headed Hydrant
LV-DOT



Straight Flanged
LV-STF



Straight Threaded
LV-STT



Bib Nose Flanged
LV-BNF



Turn Down Flanged
LV-TDF



Right Angled Flanged
LV-RAF



Gate Valve
LV-GV

Fire Hydrant Working



Firefighters find fire hydrants, attach their hoses, and then pump a massive amount of pressurized water to extinguish the fire. The hydrant's valve cover is removed using a specific pentagonal wrench. The firefighters then open the valve to allow the water to flow after attaching the hoses.

They normally have a nut or bolt to turn on to start the flow and a connecting point to connect a fire hose to. Every fire hydrant is nothing more than a connection to the main water line. A riser pipe links the hydrant valve to the ground underneath it. Normal hydrants, on the other hand, do not affect the water pressure or flow. They act as valves, allowing firemen to use the existing pressure in the water lines. While all of this may appear to be straightforward, the underlying mechanics of a fire hydrant are more complicated and vary by area..

Fire Hydrant Colors



All fire hydrants are color-coded following NFPA regulations. These hues represent the predicted flow of the procedure.

The meaning of the colors on a fire hydrant's nozzle caps is something that emergency responders and utility personnel are typically familiar with. In general, the color red is reserved for specific tasks such as firefighting. White denotes that the hydrant is on the water utility's service, but not necessarily on the water main, whereas yellow indicates that the hydrant is on the water main with high pressure. Violet is most commonly associated with non-potable water that meets international standards, such as untreated water from a lake or pond.

Standpipes.



Standpipes.



Standpipes are a useful tool for firefighters, even though they work differently than traditional hydrants. Standpipes are a viable alternative to sprinkler systems because they allow firefighters to distribute water to a specific section of a building.

They are typically located in a fixed interior location in a large structure. This permits those who are unable to evacuate the building to self-extinguish a fire. Standpipes are therefore an important tool for firefighters, particularly in big structures where a huge number of hoses would be required to extinguish the fire.

Design of Fire Hydrant.



- How much water is needed for firefighting?
- How many hydrants are required?
- What type of hose connection is required?
- Current and future configuration of the fire apparatus.
- Operating characteristics of a hydrant.
- Pressure available in lines.

Design of Fire Hydrant.



- What are climate conditions?
- Hydrant outlet threads (Coupling) should meet standards.
- Shape and access to the fire hydrant.
- The discharge valve should be specified to open by turning counterclockwise and close by turning clockwise.
- Valves and outlets should be simple, and reliable to connect and operate.

Location of Fire Fire Hydrant.



- Standard practice for fire hydrant is to install at every Minor deviations.
- Appropriate as per the situation.
- A sufficient number of hydrants should be provided for the required fire flow and high-hazard areas.
- The safe minimum distance of fire hydrant should be from the protected/ involved structures.

Location of Fire Fire Hydrant.



- The competent authority of the fire wing/ department must be consulted to ensure the operational and practical issues, involved.
- Hydrants spacing should not create any obstruction.
- Hydrants' proximity to structures is protected.
- Fire hydrants must not be isolated by a fence, gate, or obstruction.
- Fire hydrant parking of vehicles Should be at a safe distance from the hydrant.
- connected must not block critical access Vehicles and hoses way.

Hydrant Installation.



- Comparison and monitoring of Preliminary grading design final grading.
- Coordination among all parties involved at the building site in fire hydrant Installation details.
- Coordination with utility companies for ensuring noninterference of utility poles, vaults, cabinets, sewerage lines, and encroachments, etc.

Inspection and Maintenance of Fire Hydrants.



Inspection of Fire Hydrant.

- Hydrants should be checked physically & operationally.
- Frequently but at least once a year.
- Valves, blanking caps couplings, main stop valves & mainline must be checked periodically.
- Hydrants should not be hidden by tall grass, brush, fences, debris, or any other obstruction.
- Check and ensure that all blank caps are present.
- All the inspection records of every periodical inspection must be documented.

Inspection and Maintenance of Fire Hydrants.



Maintenance of a Hydrant.

- Check the gasket in the caps to make sure they are not cracked, broken, or missed, if broken replace them with a new one.
- Lubricant any part of the hydrant if necessary or rusted.
- All the valves, delivery valve main stem nut valve, and mainline valve must be repaired or replaced if broken cracked, missed, or rusted.

Hydraulic Calculation



Fire Operating Scenario-1		
Operating Scenario	2-Hose Reel operating at 28M and 3-hydrants at ground floor in both new & old CFB area.	
Flow	880-GPM	Installed Capacity is 1000-GPM of which 880-GPM is required for fire scenario and 120 GPM are still available.
Available Pressure	4.74 @ 28M & 7.26 @ 2M	At 28M there are 2 hose reel connection (1") and at 2M there are 2-hydrants connection (2.5") are operated.
Required Pressure	4.5 @ 28M & 6.9 @ 2M	According to NFPA 1" connection requires min of 4.5 bar pressure and 2.5" connection requires 6.9 bar pressure.

Hydraulic Calculation



Fire Operating Scenario-2		
Operating scenario	2-hydrants operating in new CFB area and 2-hydrants operating in old CFB area.	
Flow	1000-GPM	Installed Capacity is 1000-GPM of which 1000-GPM is required for fire scenario.
Available Pressure	7.23 @ 2M	At 2M there are 4-hydrants connection (2.5") are operated.
Required Pressure	6.9 @ 2M	According to NFPA 2.5" connection requires 6.9 bar pressure.
Fire Operating Scenario-3	4-hydrants operating in new CFB area. (Results provided in separate hydraulic calculation report)	

Hydraulic Evaluation of Pump Capacity



Pump Specifications

Pump Type	Flow (GPM)	Head (m)	Quantity (set)	Drive
Motor driven fire pumps	1000	8-Bar	1	120hp-2p Siemens motor
Diesel fire pump	1000	8-Bar	1	Cummins,6BT5.9 G1-Diesel Engine
Jockey pump	45	9-Bar	1	10-hp/2p KSB Motor

Fire Ring Hydraulic Requirements according to calculations

Operating scenario-1: 880 GPM @ 7.29 bar (2M) and 4.7 bar (28M)

Operating scenario-2: 1000 GPM @ 7.23 bar (2M)

Operating scenario-3: 1000 GPM @ 7.06 bar (2M)


Operating scenario-4: 1000 GPM @ 7.25 bar (2M)

Operating scenario-5: 730 GPM @ 7.33 bar (2M) and 4.80 bar (28M)

Conclusion:

As existing pump specifications i.e., 1000 GPM @ 8 bar fulfills each operating scenario requirement mentioned above in this table hence it is recommended that existing installed pumps will suffice the extension of existing fire water ring and can be operate able for both old and new CFB area.

Node Diagram of Fire Hydrant System



Software Hydraulic Calculation



FIRE OPERATING SCENARIO

HAZARD AREA: COAL POWER PLANT

DISCHARGE FROM ONE HYDRANT DELIVERY: 250 GPM

TOTAL OPERATED FIRE HYDRANT DELIVERIES: 04 NOS

TOTAL DISCHARGE FROM HYDRANT DELIVERIES: 1000 GPM = 1000 GPM

REQUIRED PUMP CAPACITY : 1000-GPM

INSTALLED PUMP CAPACITY : 1000-GPM

AVAILABLE PRESSURE FOR HYDRANT DELIVERY : 7.3 BAR

REQUIRED PRESSURE FOR HYDRANT DELIVERY : 6.9 BAR

Software Hydraulic Calculation



WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (BAR)	RESID. PRESS. (BAR)	FLOW @ (LPM)	AVAIL. PRESS. (BAR)	TOTAL @ DEMAND (LPM)	REQ'D PRESS. (BAR)
107	8.00	7.90	3785.0	7.900	3784.0	7.900

AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	3784.0 LPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	0.0 LPM
OTHER HOSE STREAM ALLOWANCES	3784.0 LPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	0.0 LPM

NODE ANALYSIS DATA

NODE TAG	ELEVATION (M)	NODE TYPE	PRESSURE		DISCHARGE (L/MIN)
			TOTAL (BAR)	NORMAL (BAR)	
1	2.00	HOSE STREAM	7.258	7.258	946.0
2	-1.00	- - - -	7.558	7.555	- - -
3	-1.00	- - - -	7.559	7.555	- - -
4	-1.00	- - - -	7.574	7.570	- - -
5	-1.00	- - - -	7.600	7.597	- - -
6	-1.00	- - - -	7.605	7.602	- - -
7	-1.00	- - - -	7.619	7.616	- - -
8	1.00	- - - -	7.424	7.421	- - -
9	-1.00	- - - -	7.630	7.623	- - -
10	-1.00	- - - -	7.630	7.629	- - -
11	2.00	HOSE STREAM	7.335	7.335	946.0
12	-1.00	- - - -	7.629	7.629	- - -
13	-1.00	- - - -	7.630	7.629	- - -
14	-1.00	- - - -	7.632	7.631	- - -
15	-1.00	- - - -	7.632	7.631	- - -
16	-1.00	- - - -	7.634	7.633	- - -
17	-1.00	- - - -	7.637	7.636	- - -
18	28.00	- - - -	4.797	4.791	- - -
19	28.00	- - - -	4.840	4.783	- - -
20	-1.00	- - - -	7.680	7.680	- - -
21	-1.00	- - - -	7.640	7.633	- - -
22	-1.00	- - - -	7.642	7.600	- - -
23	-1.00	- - - -	7.623	7.617	- - -
24	-1.00	- - - -	7.623	7.623	- - -
25	-1.00	- - - -	7.613	7.606	- - -
26	-1.00	- - - -	7.602	7.595	- - -
27	-1.00	- - - -	7.577	7.570	- - -
28	-1.00	- - - -	7.569	7.562	- - -
29	-1.00	- - - -	7.557	7.550	- - -
30	-1.00	- - - -	7.556	7.556	- - -
31	2.00	HOSE STREAM	7.254	7.250	946.0
32	-1.00	- - - -	7.548	7.548	- - -

Software Hydraulic Calculation



NODE ANALYSIS DATA						
NODE TAG	ELEVATION (M)	NODE TYPE	PRESSURE		DISCHARGE (L/MIN)	
			TOTAL (BAR)	NORMAL (BAR)		
33	-1.00	- - - -	7.548	7.548	- - -	
34	28.00	- - - -	4.707	4.707	- - -	
35	-1.00	- - - -	7.548	7.548	- - -	
36	-1.00	- - - -	7.548	7.548	- - -	
37	-1.00	- - - -	7.548	7.548	- - -	
38	-1.00	- - - -	7.548	7.548	- - -	
39	2.00	HOSE STREAM	7.254	7.254	946.0	
40	-1.00	- - - -	7.551	7.550	- - -	
41	-1.00	- - - -	7.552	7.552	- - -	
42	-1.00	- - - -	7.552	7.552	- - -	
43	-1.00	- - - -	7.552	7.552	- - -	
44	-1.00	- - - -	7.552	7.552	- - -	
45	-1.00	- - - -	7.552	7.552	- - -	
46	-1.00	- - - -	7.552	7.552	- - -	
47	-1.00	- - - -	7.552	7.552	- - -	
48	-1.00	- - - -	7.552	7.552	- - -	
49	-1.00	- - - -	7.552	7.552	- - -	
50	-1.00	- - - -	7.554	7.554	- - -	
51	-1.00	- - - -	7.555	7.555	- - -	
52	-1.00	- - - -	7.555	7.555	- - -	
53	-1.00	- - - -	7.555	7.555	- - -	
54	-1.00	- - - -	7.555	7.555	- - -	
55	4.10	- - - -	7.056	7.056	- - -	
56	-1.00	- - - -	7.555	7.555	- - -	
57	-1.00	- - - -	7.554	7.552	- - -	
58	-1.00	- - - -	7.554	7.553	- - -	
59	-1.00	- - - -	7.560	7.559	- - -	
60	-1.00	- - - -	7.560	7.559	- - -	
61	-1.00	- - - -	7.565	7.564	- - -	
62	-1.00	- - - -	7.568	7.566	- - -	
63	-1.00	- - - -	7.573	7.571	- - -	
64	1.00	- - - -	7.383	7.382	- - -	
65	1.00	- - - -	7.385	7.384	- - -	
66	-1.00	- - - -	7.587	7.586	- - -	
67	1.00	- - - -	7.396	7.395	- - -	
68	1.00	- - - -	7.396	7.396	- - -	
69	-1.00	- - - -	7.592	7.592	- - -	
70	4.00	- - - -	7.103	7.103	- - -	
71	-1.00	- - - -	7.596	7.594	- - -	
72	1.00	- - - -	7.408	7.407	- - -	
73	-1.00	- - - -	7.606	7.606	- - -	
74	-1.00	- - - -	7.608	7.608	- - -	
75	-1.00	- - - -	7.609	7.609	- - -	
76	-1.00	- - - -	7.610	7.609	- - -	
77	-1.00	- - - -	7.610	7.610	- - -	
78	-1.00	- - - -	7.611	7.610	- - -	
79	-1.00	- - - -	7.613	7.613	- - -	
80	-1.00	- - - -	7.615	7.615	- - -	
81	-1.00	- - - -	7.616	7.616	- - -	
82	-1.00	- - - -	7.617	7.616	- - -	
83	-1.00	- - - -	7.607	7.606	- - -	

Software Hydraulic Calculation



NODE ANALYSIS DATA

NODE	TAG	ELEVATION (M)	NODE TYPE	PRESSURE		DISCHARGE (L/MIN)
				TOTAL (BAR)	NORMAL (BAR)	
84		1.00	- - - -	7.411	7.411	- - -
85		1.00	- - - -	7.413	7.413	- - -
86		1.00	- - - -	7.413	7.413	- - -
87		1.00	- - - -	7.415	7.414	- - -
88		1.00	- - - -	7.417	7.416	- - -
89		1.00	- - - -	7.418	7.418	- - -
90		1.00	- - - -	7.418	7.418	- - -
91		1.00	- - - -	7.418	7.418	- - -
92		1.00	- - - -	7.419	7.419	- - -
93		1.00	- - - -	7.419	7.419	- - -
94		7.00	- - - -	6.832	6.832	- - -
95		1.00	- - - -	7.421	7.420	- - -
96		-1.00	- - - -	7.619	7.617	- - -
97		7.00	- - - -	6.836	6.835	- - -
98		-1.00	- - - -	7.621	7.619	- - -
99		-1.00	- - - -	7.624	7.623	- - -
100		-1.00	- - - -	7.625	7.624	- - -
101		-1.00	- - - -	7.625	7.625	- - -
102		-1.00	- - - -	7.626	7.625	- - -
103		-1.00	- - - -	7.629	7.628	- - -
104		-1.00	- - - -	7.632	7.631	- - -
105		-1.00	- - - -	7.632	7.631	- - -
106		-1.00	- - - -	7.634	7.632	- - -
107		-3.00	SOURCE	7.900	7.900	3784.0

Software Hydraulic Calculation



PIPE DATA

PIPE TAG	END	ELEV.	PT	PN	DISC.	Q (LPM)	DIA (MM)	LENGTH	PRESS.
NODES		(M)	(BAR)	(BAR)	(LPM)	VEL (MPS)	HW (C)	(M)	SUM.
							FL/M		(BAR)
Pipe: 1									
1		2.00	7.258	7.258	946.0	-928.1 0.83	154.05 120	PL FTG	10.20 ----
2		-1.00	7.558	7.555	0.0		0.0006	TL	10.20 PF 0.006 PE 0.294 PV 0.003
Pipe: 2									
2		-1.00	7.558	7.555	0.0	-928.1 0.83	154.05 120	PL FTG	1.49 ----
3		-1.00	7.559	7.555	0.0		0.0006	TL	1.49 PF 0.001 PE 0.000 PV 0.003
Pipe: 3									
3		-1.00	7.559	7.555	0.0	-928.1 0.83	154.05 120	PL FTG	24.90 ----
4		-1.00	7.574	7.570	0.0		0.0006	TL	24.90 PF 0.015 PE 0.000 PV 0.003
Pipe: 4									
4		-1.00	7.574	7.570	0.0	-928.1 0.83	154.05 120	PL FTG	45.00 ----
5		-1.00	7.600	7.597	0.0		0.0006	TL	45.00 PF 0.027 PE 0.000 PV 0.003
Pipe: 5									
5		-1.00	7.600	7.597	0.0	-928.1 0.83	154.05 120	PL FTG	8.89 ----
6		-1.00	7.605	7.602	0.0		0.0006	TL	8.89 PF 0.005 PE 0.000 PV 0.003
Pipe: 6									
6		-1.00	7.605	7.602	0.0	-928.1 0.83	154.05 120	PL FTG	23.47 ----
7		-1.00	7.619	7.616	0.0		0.0006	TL	23.47 PF 0.014 PE 0.000 PV 0.003
Pipe: 7									
7		-1.00	7.619	7.616	0.0	-928.1 0.83	154.05 120	PL FTG	1.49 ----
8		1.00	7.424	7.421	0.0		0.0006	TL	1.49 PF 0.001 PE-0.196 PV 0.003
Pipe: 8									
8		1.00	7.424	7.421	0.0	-928.1 0.83	154.05 120	PL FTG	16.61 ----
9		-1.00	7.630	7.623	0.0		0.0006	TL	16.61 PF 0.010 PE 0.196 PV 0.003
Pipe: 9									
9		-1.00	7.630	7.623	0.0	416.7 0.37	154.05 120	PL FTG	1.49 ----
10		-1.00	7.630	7.629	0.0		0.0001	TL	1.49 PF 0.000 PE 0.000 PV 0.001
Pipe: 10									
10		-1.00	7.630	7.629	0.0	416.7 0.37	154.05 120	PL FTG	8.58 ----
11		2.00	7.335	7.335	946.0		0.0001	TL	8.58 PF 0.001 PE-0.294 PV 0.001
Pipe: 11									
11		2.00	7.335	7.335	946.0	0.0 0.00	154.05 120	PL FTG	0.30 ----
12		-1.00	7.629	7.629	0.0		0.0000	TL	0.30 PF 0.000 PE 0.294 PV 0.000
Pipe: 12									
11		2.00	7.335	7.335	946.0	-529.3 0.47	154.05 120	PL FTG	6.14 ----
13		-1.00	7.630	7.629	0.0		0.0002	TL	6.14 PF 0.001 PE 0.294 PV 0.001

PIPE TAG	END	ELEV.	PT	PN	DISC.	Q (LPM)	DIA (MM)	LENGTH	PRESS.
NODES		(M)	(BAR)	(BAR)	(LPM)	VEL (MPS)	HW (C)	(M)	SUM.
							FL/M		(BAR)
	Pipe: 13					-529.3	154.05	PL	PF 0.002
13		-1.00	7.630	7.629	0.0	0.47	120	FTG	PE 0.000
14		-1.00	7.632	7.631	0.0		0.0002	TL	PV 0.001
	Pipe: 14					-529.3	154.05	PL	PF 0.000
14		-1.00	7.632	7.631	0.0	0.47	120	FTG	PE 0.000
15		-1.00	7.632	7.631	0.0		0.0002	TL	PV 0.001
	Pipe: 15					-529.3	154.05	PL	PF 0.002
15		-1.00	7.632	7.631	0.0	0.47	120	FTG	PE 0.000
16		-1.00	7.634	7.633	0.0		0.0002	TL	PV 0.001
	Pipe: 16					-529.3	154.05	PL	PF 0.003
16		-1.00	7.634	7.633	0.0	0.47	120	FTG	PE 0.000
17		-1.00	7.637	7.636	0.0		0.0002	TL	PV 0.001
	Pipe: 17					-529.3	154.05	PL	PF 0.000
17		-1.00	7.637	7.636	0.0	0.47	120	FTG	PE-2.840
18		28.00	4.797	4.791	0.0		0.0002	TL	PV 0.001
	Pipe: 18					-529.3	102.26	PL	PF 0.043
18		28.00	4.797	4.791	0.0	1.07	120	FTG	PE 0.000
19		28.00	4.840	4.783	0.0		0.0015	TL	PV 0.006
	Pipe: 19					0.0	102.26	PL	PF 0.000
19		28.00	4.840	4.783	0.0	0.00	120	FTG	PE 2.840
20		-1.00	7.680	7.680	0.0		0.0000	TL	PV 0.000
	Pipe: 20					-1344.8	154.05	PL	PF 0.010
9		-1.00	7.630	7.623	0.0	1.20	120	FTG	PE 0.000
21		-1.00	7.640	7.633	0.0		0.0012	TL	PV 0.007
	Pipe: 21					-1344.8	154.05	PL	PF 0.002
21		-1.00	7.640	7.633	0.0	1.20	120	FTG	PE 0.000
22		-1.00	7.642	7.600	0.0		0.0012	TL	PV 0.007
	Pipe: 22					1319.8	154.05	PL	PF 0.018
22		-1.00	7.642	7.600	0.0	1.18	120	FTG	PE 0.000
23		-1.00	7.623	7.617	0.0		0.0011	TL	PV 0.007
	Pipe: 23					0.0	154.05	PL	PF 0.000
23		-1.00	7.623	7.617	0.0	0.00	120	FTG	PE 0.000
24		-1.00	7.623	7.623	0.0		0.0000	TL	PV 0.000
	Pipe: 24					1319.8	154.05	PL	PF 0.011
23		-1.00	7.623	7.617	0.0	1.18	120	FTG	PE 0.000
25		-1.00	7.613	7.606	0.0		0.0011	TL	PV 0.007
	Pipe: 25					1319.8	154.05	PL	PF 0.011
25		-1.00	7.613	7.606	0.0	1.18	120	FTG	PE 0.000
26		-1.00	7.602	7.595	0.0		0.0011	TL	PV 0.000

Software Hydraulic Calculation



PIPE TAG	END	ELEV.	PT	PN	DISC.	Q (LPM)	DIA (MM)	LENGTH	PRESS.
NODES		(M)	(BAR)	(BAR)	(LPM)	VEL (MPS)	HW (C)	(M)	SUM.
						FL/M			(BAR)
Pipe: 104						-590.1	154.05	PL	3.73
100		-1.00	7.625	7.624	0.0	0.53	120	FTG	PF 0.001
102		-1.00	7.626	7.625	0.0		0.0003	TL	PE 0.000
									PV 0.001
Pipe: 105						-590.1	154.05	PL	11.48
102		-1.00	7.626	7.625	0.0	0.53	120	FTG	PF 0.003
103		-1.00	7.629	7.628	0.0		0.0003	TL	PE 0.000
									PV 0.001
Pipe: 106						-590.1	154.05	PL	11.29
103		-1.00	7.629	7.628	0.0	0.53	120	FTG	PF 0.003
104		-1.00	7.632	7.631	0.0		0.0003	TL	PE 0.000
									PV 0.001
Pipe: 107						-590.1	154.05	PL	0.30
104		-1.00	7.632	7.631	0.0	0.53	120	FTG	PF 0.000
105		-1.00	7.632	7.631	0.0		0.0003	TL	PE 0.000
									PV 0.001
Pipe: 108						-590.1	154.05	PL	6.88
105		-1.00	7.632	7.631	0.0	0.53	120	FTG	PF 0.002
106		-1.00	7.634	7.632	0.0		0.0003	TL	PE 0.000
									PV 0.001
Pipe: 109						-590.1	154.05	PL	31.25
106		-1.00	7.634	7.632	0.0	0.53	120	FTG	PF 0.008
22		-1.00	7.642	7.600	0.0		0.0003	TL	PE 0.000
									PV 0.001
Pipe: 110						-3254.7	154.05	PL	6.39
22		-1.00	7.642	7.600	0.0	2.91	120	FTG	PF 0.038
19		28.00	4.840	4.783	0.0		0.0060	TL	PE-2.840
									PV 0.042
Pipe: 111						-3784.0	154.05	PL	3.00
19		28.00	4.840	4.783	0.0	3.38	120	FTG	PF 0.024
107		-3.00	7.900	7.900	(N/A)		0.0079	TL	PE 3.036
									PV 0.057

NOTES (HASS):

- Calculations were performed by the HASS 8.4 computer program under license no. 50031730 granted by HRS Systems, Inc.
208 Southside Square
Petersburg, TN 37144
(931) 659-9760
- The system has been calculated to provide an average imbalance at each node of 0.0010 lpm and a maximum imbalance at any node of 0.0035 lpm.
- Velocity pressures have been included in the calculation of the system pressures and flows. Maximum water velocity is 3.38 m/sec at pipe 111.
- Items listed in bold print on the cover sheet

Software Hydraulic Calculation



WATER SUPPLY CURVE





TAHANK YOU

**Naqash Kazmi (CFPS®) NFPA
CERTIFIED FIRE PROTECTION SPECIALIST(CFPS®)**