

**Advanced Membrane Technologies
Stanford University, May 07, 2008**



Bay Water SWRO Desalination: Challenges and Solutions

Val S. Frenkel, Ph.D.


All text, image and other materials contained or displayed in this document are proprietary to Kennedy/Jenks Consultants, Inc., constitute valuable intellectual property, and are protected by copyright laws. No part of this document may be transmitted, broadcast, reproduced distributed, displayed, published, or in any other way used or otherwise disseminated in any form to any person or entity, without the prior written permission of an officer of Kennedy/Jenks.



SWRO Provides New Water Sources



Water Resources



■ Oceans (Salinity > 35,000 ppm) ■ Ice at the Polar Caps ■ Atmosphere ■ Rivers and Lakes ■ Groundwater Aquifers (A half at depth > 2,600 ft)

SWRO Provides New Water Sources



Water Resources

President John F. Kennedy, April 1961:

97%
"If we could ever competitively, at a cheap rate, get freshwater from salt water, that would be in the long-range interest of humanity and would dwarf any other scientific accomplishments."

Seawater: The only long-term, completely reliable source of drinking water.

0.6%
0.1%
2%
0.3%

■ Oceans (Salinity > 35,000 ppm) ■ Ice at the Polar Caps ■ Atmosphere ■ Rivers and Lakes ■ Groundwater Aquifers (A half at depth > 2,600 ft)


Desalination in 1990 and today




SWRO Advances:

- ▶ **New commercial membrane pre-treatment – MF and UF**
- ▶ **Energy Recovery Devices from 30% energy savings up to 45%**
- ▶ **New SWRO membrane elements materials (TFC): higher porosity, more uniform pores, salt rejection up to 99.8%, 30% less energy**
- ▶ **New generation of chemicals, including Antiscalants, Dispersants and others, allowing operate SWRO at much higher recovery from 30% to 50% depending on chemistry and TDS**
- ▶ **SWRO membrane elements became commodity which led to reducing 8" x 40" element cost from ~ \$ 2,000 to ~ \$ 500.**
- ▶ **Overall reduction in capital cost and O&M makes SWRO acceptable standard in water desalination**
- ▶ **Number of SWRO plants overcomes thermal desalination**


The Technical Desalting Process...



...Is Balanced On Cost Considerations



Optimal Design Parameters Ensure the Lowest Cost of Water



Pilot plant program provides optimal performance data on the most critical process elements

SWRO Pilot Study



Desalination Pilot Study Major Generic Objectives:

- Evaluate and pilot pre-treatment (local issues) for the DESALINATION process - saves capital and O&M
- Evaluate and prove product water quality including emerging contaminants
- Evaluate quality and discharge criteria for the brine
- Provide public outreach and educate residents on desalination technology and quality of the produced water

SWRO Pilot Study



Desalination Pilot Study Benefits:

- Pilot study can save 5-10% of the capital investment and up to 20% of the O&M for the DESALINATION project
- Piloting technology provides smooth startup, operation and commissioning of the full scale system.
- Piloting provides complete picture on the product water quality major components and emerging contaminants, as well as on the discharged brine.

MMWD SWRO Pilot Plant Objectives:



- ▶ **Establish optimum operating conditions for both conventional and membrane pretreatment**
- ▶ **Determine which pretreatment system is best-suited for the SWRO process**
- ▶ **Demonstrate that SWRO can reliably desalt San Francisco Bay water**
- ▶ **Demonstrate that desalted seawater meets or exceeds state and federal drinking water standards**
- ▶ **Demonstrate the efficacy of the membrane process in removing trace compounds of concern**
- ▶ **Establish operating parameters for a 56,575 m³/d (15 mgd) full-scale facility**
- ▶ **Demonstrate that the desalinated water compares favorably with the low-TDS, low-sodium drinking water that MMWD customers currently supplied**
- ▶ **Conduct testing of pretreatment residuals to determine design of full-scale plant residuals handling and disposal**
- ▶ **Conduct a public outreach program to acquaint the public and media with the technology employed and the quality of the water produced**

SWRO Pilot Plant Treated Water Quality Objectives:



The treated water quality objectives for the SWRO Pilot plant are based on:


- ▶ Compliance with Federal and State regulatory requirements,
- ▶ Meeting MMWD's additional requirements for dissolved minerals (e.g., Sodium),
- ▶ Ensuring the treatment process can remove unregulated emerging contaminants, and
- ▶ Customer acceptance, i.e., taste.

The treated water objectives to ensure compliance with the current and upcoming water quality regulations include the requirements of the following:

- ▶ Surface Water Treatment Rule (SWTR),
- ▶ Interim Enhanced SWTR and Long-Term 2 Enhanced SWTR,
- ▶ Stage 1 and 2 Disinfectants and Disinfection By-Product Rules,
- ▶ Lead and Copper Rule,
- ▶ Boron Action Level,
- ▶ Total Coliform Rule, and
- ▶ The California Cryptosporidium Action Plan.

MMWD has additional requirements to ensure that the water from the SWRO plant is chemically compatible with and comparable in quality to the District's other water sources.

Variable Nature of Francisco Bay Water




There are daily and seasonal variations in salinity, suspended solids, and productivity levels in the North SF Bay

Salinity and Turbidity Vary Diurnally and Seasonally



MMWD Seawater Desalination Pilot Program


Source Water Turbidity and TDS



Source Water Organics Vary with Freshwater Runoff in Bay



MMWD Seawater Desalination Pilot Program
Source Water and Filtrate Total Organic Carbon (TOC)



Demonstrating SWRO is a Viable, Reliable Water Supply Solution



It is one of those rare days when everything is silent and an absence of people marks the streets. A public holiday where people are paying respect to their ancestors and eating feasts. Outside it rains and drizzles so that, sitting over by the duck pond in the small pavilion, there is only a softened landscape and the sound of water dripping from the eaves.

The Cycle of Water

from clouds to earth

collected at the desalination facility

and turned into drinking water

from oceans & seas

Why desalinate?

An infographic titled "The Cycle of Water" showing the process from clouds to earth, collection at a desalination facility, and turning into drinking water. It includes a globe and a diagram of a desalination plant. The text "Why desalinate?" is followed by several columns of small text.

Team When Project Started.....



Team When Project Started.....





Site Location Map




Site Location Map





Pilot Process Flow Diagram - PFD





Kennedy/Jenks Consultants
 622 Folsom Street
 San Francisco, CA 94107
 In association with
 CH2M HILL

MWD Seawater Desalination
 Pilot Program


FIGURE
1

SWRO Pilot Program Configuration




- ▶ To ensure optimum data for comparison and design, we have two SWRO trains fed by three pretreatment units.
- ▶ This approach successfully demonstrated similar pretreatment for SWRO at many places around the world.

Pilot Plant General Layout



MMWD Desalination: From Bay Water to Drinking Water



SWRO Pilot Intake 2,000 ft / 600 meters



Intake Screening



- ▶ **Designed to meet Federal and State criteria (316b) for fish protection**
 - **3/32-inch openings**
 - **<0.3 fps velocity**
 - **airburst cleaning**
- ▶ **Removes large particles and debris**



Feed Strainers Reduce Solids Loading and Protect MF/UF Systems



- ▶ **Bollfilter - 100 micron Wedgewire Strainer**
 - **Stainless steel**
 - **Water backwash**
- ▶ **Arkal - 100 micron Disk Strainer**
 - **Plastic disks and body**
 - **Air or water backwash**

Disk strainer provides better water quality with easier maintenance



100 micron
Wedgewire
Strainer

100 micron
Disk
Strainer

- ▶ Parallel 2-hr clogging capacity test of strainer effluent
- ▶ Disk Strainer effluent contained fewer solids
- ▶ Disk strainer permitted easy access to strainer elements
- ▶ Plastic materials for corrosion resistance

Membrane Pre-Treatment: MF & UF



Conventional Pre-Treatment



SWRO: 1st and 2nd Passes



2nd Pass RO



Post Treatment



Marin Independent Journal

MONDAY
JUNE 20, 2005
WWW.MARINIJ.COM

H₂O taste test

MMWD's desalinated bay water beats Marin competition



Stephanie Taubert of San Rafael tries one of the three samples of Marin Municipal Water District tap water, desalinated water and North Marin Water District tap water during a blind taste test at the U on Friday afternoon.

Tastings dispel desal's bad reputation

By Mark Prada

It reporter

Maybe drinking bay water is not such a bad idea after all. Desalinated water scored on par and even better than Marin tap water, according to an on-site blind taste test conducted Friday outside the Independent Journal's Novato office building. Unlabeled samples of Marin Municipal Water District's desalinated water, Marin Municipal tap water and North Marin Water District's tap water were offered and tasters were asked to rank the three water samples on a 1 to 5 scale, with 1 being the best, if the word.

Fifty people, many of them Independent Journal employees, stepped by the test table and signed from paper cups.

Of the 50 who sampled, 39 ranked the desalinated water as their top choice, with 18 preferring North Marin water and 12 indicating Marin Municipal tap as the best. Overall, desalinated water and North Marin water

Which water tastes best?

An on-site blind taste test conducted at the Marin U on Friday. Tasters ranked and employees sampled water samples from Marin Municipal Water District. Here are the results.



A. North Marin Water District tap water from the U in Novato
B. Desalinated water from MMWD's plant in San Rafael
C. MMWD tap water from a Terry Lewis home

First place votes	18	20	12
Total points*	180	200	120

*Total points were based on the 1-5 ranking system. A 1 is the best, 5 is the worst.

ranked the desalinated water as their top choice, with 18 preferring North Marin water and 12 indicating Marin Municipal tap as the best. Overall, desalinated water and North Marin water

Pipeline project could soon die

By Mark Prada

It reporter

Plans for a pipeline to move water from Sonoma County to Marin could die if the Marin Municipal Water District does not renew a contract that expires at the end of the month. The MMWD has a series of contracts with the Sonoma County Water Agency to provide it with water. The contracts are locked in and provide Marin with up to 3,000 acre-feet annually. MMWD's demand for that water is 8,000 acre-feet annually.

A third contract provides MMWD with 8,000 acre-feet on an "as available" basis. MMWD's next deadline is to lock in those water rights at a cost of \$1 million. The 8,000 acre-feet would be used for a pipeline to tap water from the Russian River

PIPE: Extension is sought

From page A1
But the project has been put on the back burner as the water district seeks desalination.

If MMWD does not renew the contract, the pipeline project is essentially dead. "We would like an extension for at least two years," said Jared Huffman, president of the Marin Municipal Water District board of directors.

It would cost the district \$200,000 for each year of an extension, officials said. There will be a series of meetings to determine the issue. The Sonoma County Water Advisory Committee will meet next Monday, then the water agency's board meets Tuesday.

"Ideally everyone will agree on this, but we will have to vote and see what they say," said Elizabeth Bennett, spokeswoman for the Sonoma water district. The Marin water district board will then hold a special meeting June 29.

Simply renewing the contract wouldn't mean the water from the Russian River would be available overnight, Huffman noted. First, Marin would have to

build a pipeline, and then Sonoma County would need facilities in place to deliver the water. The Sonoma facilities haven't been built and could take another 10 years to materialize.

"That is one reason we are asking for an extension," Huffman said. "Sonoma doesn't have everything together on their side. That's not our fault. It'd take a commitment \$6 million to something that is more long-term."

Beyond the physical issue of getting water from Sonoma, there are several legal issues as well. Environmental groups have sued, trying to block water pulled from the Russian and Eel rivers because of concerns about fish protection. Water from the Eel River is diverted into the Russian River.

The amount of water flowing from the rivers could be limited by the courts, preventing Marin from seeing an extra drop of water through the pipeline, Huffman noted.

"Whatever happens has to happen soon, because the options are coming down soon," Huffman said. Contact Mark Prada via e-mail at mprada@marinij.com.

TASTE: Desalinated water wins

From page A1

The desalinated water was named the best to come from the Marin Municipal Water District's \$1.2 million pilot desalination plant at the Marin Red and Gun Club site near the west end of the Richmond-San Rafael Bridge.

The pilot plant cleans water through a reverse osmosis process and mineralizers. "Testing for the next nine months will determine if desalinating bay water and pumping it to Marin homes is feasible. That could lead to construction of a \$77 million, full-scale facility capable of producing at least 1 million gallons of water daily.

"It's not good news that I liked it. Do you know what is in the bay? Toxins and contaminants," she said. "I think I'd start buying bottled water."

David Giambastiani also liked the desalinated water. "It is smooth. It didn't have any lingering flavor. It just tasted like bottled water," he said.

Giambastiani described MMWD tap as having a "metallic, unpleasant taste" and North Marin's as having a "tap water taste."

But sampler Fred Conner thought the desalinated water had a "chemical and chlorine taste" and favored North Marin's "neutral" flavor.


Fred Marcell favored the desalinated water because it was the only one to have a taste. "There was a flavor; the other two tasted like nothing," he said.

Contact Mark Prada via e-mail at mprada@marinij.com.

- ▶ Calcium and bicarbonate added to match stability and taste of current MMWD water
- ▶ Disinfection similar to current MMWD practices
- ▶ MMWD customers find taste of Desal water as good as water from local reservoirs



Pilot Automation: Master PLC Screen




SWRO Pilot Site First Visitor



Proper Pretreatment Meets Challenges of SF Bay Water Quality Fluctuations



550389 Marin DM - Turbidity



Prepared by ZenoTrac™
©ZENON Environmental Inc.

COMMENTS:


- BeforeBPPFeedTurbidity
- BeforeBPPPermeateTurbidity

MF/UF Provides Better Solids Removal and lower SDI



	Conventional Filtered Water	MF Filtrate	UF Filtrate
Average Turbidity	0.09	0.06	0.05
Average SDI	3.88	2.64	2.57
SDI Standard Deviation	0.55	0.51	0.49

Types of SWRO membrane fouling




- ▶ **Inorganic scale - control with antiscalant, system recovery**
- ▶ **Particulate fouling – minimize feed water turbidity and SDI**
- ▶ **Organic fouling – minimize feed water dissolved organics**
- ▶ **Biofouling – control with flux rate, shock Cl**

MF/UF SWRO has better permeate flow




MMWD Seawater Desalination Pilot Program
SWRO #1 and SWRO #2 Normalized Permeate Flow



Both systems show similar salt passage




MMWD Seawater Desalination Pilot Program
SWRO #1 and SWRO #2 Normalized Salt Passage




MF/UF SWRO has less fouling



MMWD Seawater Desalination Pilot Program
SWRO #1 and SWRO #2 Normalized Differential Pressure




Autopsy confirmed MF/UF SWRO has less fouling



MF/UF Pretreatment

Conventional Pretreatment

MF/UF SWRO had lower particulate and organic fouling



■ Dow A9906551, #1, MF/UF Pretreatment

■ Dow A9941802, #2, Conventional Pretreatment

MF/UF requires less area than conventional pretreatment



- ▶ For 10 MGD MMWD Desal Facility
- ▶ Conventional Pretreatment
 - Flocculation ~ 3,000 sf
 - Clarifiers ~7,000 sf
 - Filters ~14,000 sf
 - WW Recovery ~7,000 sf
 - Total Area ~31,000 sf
- ▶ MF/UF Pretreatment
 - Strainers ~2,000 sf
 - Flocculation ~2,000 sf
 - Membrane Bldg ~8,000 sf
 - WW Recovery ~2,000 sf
 - Total Area ~14,000 sf


SWRO: Pre-Treatment Performance



Membrane Pre-Treatment: MF, UF



Conventional Pre-Treatment: Clarifier, 2 stage Filtration



SWRO Membrane in Pressure Vessel



SWRO Elements Performance



Hydranautics RO Projection Program - [RO Design]

File Analysis RO Design UF Treatment Calculation Graphs Help

Welcome to
IMSDesign
INTEGRATED MEMBRANE SOLUTIONS™
Where Technology Flows

Design UF Design RO Design RO+UF

Hydranautics Membrane Solutions Design Software, v. 2006

TorayRO ver.2.0.28

Configuration: TorayRO
Chemical Dosing: Degassing
Feed Specs: Feed Specs
About

Flow Units: Gal/min
Pressure Units: Psi

Calculation Required

Concentrate
Product
% System Recovery: 45.0000

Rodesign 2006.15

ROSA

File Options Window Help

ROSA System Selection and Data Entry

Project Name: MMWD SWRO System Perm Flow: 2.32 gpm
System Feed Flow: 5.90 gpm
System Recovery: 40.00 %

Case Number: 1 Add Remove

of Pass(es): 1
Current Pass: Pass 1

Configuration for Pass 1

Number of Stages in Pass: 1 Perm Flow: 2.32 gpm Recirculation Losses
Recovery: 40.00 % Blood Pressure
Fouling Factor: 0.85 Feed Flow: 5.90 gpm Pass 1 Cont. to Pass 1 Feed
Operating Temp: 17.2 C Perm Flac: 6.96 gal

Configuration for Stage 1 in Pass 1

Select a Stage in the Pass: Stage 1

Feed Pressure: Name psi
Back Pressure: Name psi Pump Efficiency: 80 %

Same Back Pressure for all stages:

Number of Pressure Vessels in Stage: 1
Number of Elements in Each Vessel: 6
Total Number of Elements in Stage: 6

Product Name: SW30-4040 Specs

Use the Same Element in the pass:

System Configuration

Feed → Conc. → Permeate

Perform Calculations

Unit set used: gpm (Flow); psi (pressure) C:\Documents and Settings\Valp\My Documents\MMWD SWE 5/16/2006

ROSA Version 6.0

ROPRO 7.0 for Windows - OX-NO DEGAS NO ACID FSC

File Edit Tools Window Options Help

FlowSheet

Single Pass with Recycle

Feed Analysis

Item	mg/L	meq/L	as CaCO3	Name
Ca++	175.00	4.7952	137.15	Feed 1
Mg++	46.00	3.7852	105.43	Water Type: Well Water
Na+	97.00	4.2192	111.15	Temperature: 77.0 Deg F
Fe				Annual Avg Temp: 77.0 Deg F
NO3-				pH: 7.4
Si++				H+ Concentration: 0.0000 meq/L
Cl-				OH- Concentration: 0.0000 meq/L
SO4--	212.00	3.4740	173.90	Charge Balance: OK
CO3--	475.00	9.0892	494.93	Calcium: 14.7400
CO3--	46.00	1.2704	64.94	Ammonia: 14.0000
NO3-	12.00	0.1936	5.63	Difference: -0.1149
Species1				Percent: -0.4%
Species2				Extinct: OK
Species3				Cancel
Species4				Sum (mg/L): 1023.00

ROPRO 7.0

SWRO Elements Performance Evaluation:



- Salt Rejection, %
- Net Driving Pressure (Normalized), PSI
- Bio-Fouling/Scaling Rate
- Specific Ions Rejection (Boron, Emerging Contaminants), %

SWRO Elements Performance



MMWD SWRO Pilot Project							Kennedy/Jenks Consultants				
<i>Membranes Information List</i>											
Train #	Membrane Brand	Membrane Model	Standard Salt Rejection, %	Active area of 1 element, ft2	Number of Element per Train	Total Membrane area per train, ft2	FLUX, GFD	Recovery %	Permeate Flow, gpm	Feed Flow, gpm	Brine Flow, gpm
1	TORAY	TM-810	99.80%	65	6	390	8	40	2.167	5.42	3.25
2	HYDRANAUTICS	SWC4+	99.80%	80	6	480	8	40	2.667	6.67	4.00
3	DOW Filmtec	SW30HR LE-4040	99.75%	85	6	510	8	40	2.833	7.08	4.25
TOTAL					18	1380			7.667	19.167	11.5

SWRO Elements Performance




<i>Contaminant</i>	<i>% nominal rejection</i>	<i>Contaminant</i>	<i>% nominal rejection</i>
Aluminum	96-98	Ammonium	80-90
Bacteria	99+		
Boron	80-90 (up to 94)	Bromide	90-95
Cadmium	93-97	Calcium	93-98
Chloride	92-95	Chromate	85-95
Copper	96-98	Cyanide	85-95
Fluoride	92-95	Hardness Ca & Mg	93-97
Iron	96-98	Lead	95-98
Manganese	96-98	Magnesium	93-98
Mercury	94-97	Nickel	96-98
Nitrate	90-95	Orthophosphate	96-98
Phosphate	95-98	Polyphosphate	96-98
Potassium	93-97	Radioactivity	93-97
Silica	80-90	Silicate	92-95
Silver	93-96	Sodium	92-98
Sulfate	96-98	Thoisulfate	96-98
Zinc	96-98		

SWRO Elements Performance




MMWD Seawater Desalination Pilot Program
SWRO #1 Daily Permeate Conductivity and Feed Temp.



SWRO Elements Performance




MMWD Seawater Desalination Pilot Program
SWRO #1 Daily Feed Conductivity, Feed Pressure and Feed Temp.



SWRO Elements Performance




**MMWD Seawater Desalination Pilot Program
SWRO #2 Daily Feed Conductivity, Feed Pressure and Feed Temp.**



SWRO Elements Performance



MMWD Seawater Desalination Pilot Program
SWRO #1 Flux and Recovery




SWRO Elements Performance Boron



World Health Organization (WHO) recommended guideline level of 0.5 mg/L

California Drinking Water Action Level for boron is 1.0 mg/L

SWRO Elements Performance - Boron



1 mM boric acid behavior in aqueous solutions


SWRO Monitoring



SWRO Probing by Catheters



SWRO Probing by Catheters



SF Bay and Treated Water




SUMMARY:



A well-designed pilot testing program is a valuable tool to answer questions on the performance of the technology, to confirm the high quality of the water produced, and to conduct environmental studies to ensure the viability of desalination. The pilot program described herein provided the following valuable benefits:

- Confirmed that desalinated water is safe to drink
- Educated customers and showed that desalinated water tastes good
- Conducted environmental studies to support the EIR process
- Evaluated the best available treatment technologies
- Determined design criteria and costs for a full scale facility



Questions?