



# **El** Sayed Amer



01065860658



Eng20072007@gmail.com



/elsayedameer



- Bachelor's degree of Petroleum & Natural Gas Engineering 2012.
- Current Senior Process and Production Engineer at Suez Oil Co "SUCO" since 2014.
- Worked for Weatherford drilling international for 2 years as well drilling and completion engineer.
- Instructor for Oil & Gas Upstream and downstream courses at MTC Egypt, Egyptian syndicates of engineers, OGS & OPA.
- Member of SPE, AAPG, AACE, NACE, Environmental Geoscience.
- IWCF, HYSYS process modeling, Eclipse certified.



https://bit.ly/2UFSgpn





## What is piping?

Piping includes pipe, flanges, fittings, bolting, gaskets, valves, and the pressure containing portions of other piping components.



**PIPE** 



**BOLTING** 



**FLANGE** 



**GASKET** 



**FITTING** 



**VALVE** 




Eng. Elsayed Amer

## What is piping?

#### Piping system include:

- **Pipes**—to carry the fluid
- Fittings—to join sections of pipe and direct the flow of the fluid
- **Flanges**—to temporarily ioin sections of pipe and connect pipes to valves and equipment
- valves—to control the flow of fluid through pipes
- supports and hangers—to fix piping in position



Pipe • Valves • Flanges • Fittings • Steel




### Pipe dimensions are given in :

- Nominal pipe size
- Pipe schedule (the wall thickness)

Three different terms are used to define the size of the pipes.


- NPS Nominal Pipe Size
- NB Nominal Bore
- DN Diameter Nominal





- Nominal pipe size
- Pipe schedule (the wall thickness)
- Nominal pipe size (NPS) is A number to represent the outside diameter of pipe.
- For example, when you say 6" pipe, the 6" is the nominal size of that pipe.









## For Nominal Pipe Sizes (N.P.S.) 1/8" to 12" the N.P.S. and O.D. Values are Different

(0.D. > N.P.S. > I.D)


#### **6" SCHEDULE 80 PIPE SIZE & THICKNESS**



Wall Thickness: 6" - 5.761" = .864 / 2 = .432"



14" SCHEDULE 80 PIPE SIZE & THICKNESS





Wall Thickness: 14" - 12.5" = 1.5 / 2 = .750"

### Pipe dimensions are given in :

- Nominal pipe size
- Pipe schedule (the wall thickness)

**Schedules**: for higher-pressure, pipes were produced having thicker walls, which came to be

#### known as:


- extra strong (XS)
- extra heavy (XH).
- Double extra strong (XXS)
- double extra heavy (XXH).

### Schedule number = 1000 \* P/S

- P is the service pressure in (psi)
- S is the allowable stress in (psi)




- All pipes of one nominal size have the same OD but they come in different schedules.
- The ID depends on the nominal size and the wall thickness.



0.280" Pipe Wall Thickness

6" NPS Schedule 40 Thickness 6" NPS Schedule 80 Thickness



0.432" Pipe Wall Thickness





PIPE SCHEDULES & WEIGHTS											
		SCHED	ULE 40	SCHEDULE 80							
NOMINAL PIPE SIZE	OUTSIDE DIAMETER	Wall Thick.	Wt. Per Ft.	Wall Thick.	Weight Per Ft.						
1/8 1/4 3/8 1/2 3/4 1 1-1/4 1-1/2 2 2-1/2 3 3-1/2 4 5 6 8 10	0.405 0.540 0.675 0.840 1.050 1.315 1.660 1.900 2.375 2.875 3.500 4.000 4.500 5.563 6.625 8.625 10.750	0.068 0.088 0.091 0.109 0.113 0.133 0.140 0.145 0.154 0.203 0.216 0.226 0.237 0.258 0.280 0.322 0.365	0.245 0.425 0.568 0.851 1.131 1.679 2.273 2.718 3.653 5.793 7.576 9.109 10.790 14.620 18.970 28.550 40.480	0.095 0.119 0.126 0.147 0.154 0.179 0.191 0.200 0.218 0.275 0.300 0.318 0.337 0.375 0.432 0.500 0.500	0.315 0.535 0.739 1.088 1.474 2.172 2.997 3.631 5.022 7.661 10.250 12.510 14.980 20.780 28.570 43.390 54.740						
12	12.750	0.375	49.560	0.500	65.420						



## DIMENSIONS OF SEAM LESS & WELDED STEEL PIPE ACCORDANCE WITH ANSI B36.10 & B36.19

		NOMINAL WALL THICKNESS														
NOM. PIPE	OUT SIDE	Sche.	Sche.	Sche.	Sche.	Sche.	Standard	Sche.	Sche.	Extra	Sche.	Sche.	Sche.	Sche.	Sche.	ХХ
SIZE	DIAM.	5*S	10*S	10	20	30	Standard	40	60	Strong	80	100	120	140	160	Strong
20 mm	26.670	1.651	2.108				2.870	2.870		3.912	3.912				5.563	7.823
25 mm	33.401	1.651	2.769				3.378	3.378		4.547	4.547				6.350	9.093
32 mm	42.164	1.651	2.769				3.558	3.558		4.851	4.851				6.350	9.703
40 mm	48.260	1.651	2.769				3.683	3.683		5.080	5.080				7.137	10.160
50 mm	60.325	1.651	2.769				3.912	3.912		5.537	5.537				8.738	11.074
65 mm	73.025	2.108	3.048				5.158	5.158		7.010	7.010				9.525	14.021
80 mm	88.900	2.108	3.048				5.486	5.486		7.620	7.620				11.125	15.240
90 mm	101.600	2.108	3.048				5.740	5.740		8.077	8.077					
100 mm	114.300	2.108	3.048				6.020	6.020		8.560	8.560	<b></b>	11.125		13.487	17.12
125 mm	141.300	2.769	3.404				6.553	6.553		9.525	9.525		12.700		15.875	19.050
150 mm	168.275	2.769	3.404				7.112	7.112		10.973	10.973		14.275		18.263	21.946
200 mm	219.075	2.769	3.759		6.350	7.036	8.179	8.179	10312	12.700	12.700	15.088	18.263	20.625	23.012	22.225
250 mm	273.050	3.404	4.191		6.350	7.798	9.271	9.271	12.700	12.700	15.088	18.263	21.438	25.400	28.575	25.400
300 mm	323.850	3.962	4.572		6.350	8.382	9.525	10.312	14.275	12.700	17.475	21.438	25.400	28.575	33.325	25.400
350 mm	355.600	3.962	4.775	6.350	7.925	9.525	9.525	11.125	15.088	12.700	19.050	23.925	27.788	31.750	35.712	
400 mm	406.400	4.191	4.775	6.350	7.925	9.525	9.525	12.700	16.662	12.700	21.438	26.187	30.963	36.525	40.488	
450 mm	457.200	4.191	4.775	6.350	7.925	11.125	9.525	14.275	19.050	12.700	23.825	29.362	34.925	39.675	45.237	
500 mm	508.000	4.775	5.537	6.350	9.525	12.700	9.525	15.088	20.625	12.700	26.187	32.537	38.100	44.450	50.013	
550 mm	558.000	5.537	5.537	6.350	9.525	12.700	9.525		22.225	12.700	28.575	34.925	41.275	47.625	53.975	
600 mm	609.600	5.537	6.350	6.350	9.525	14.275	9.525	17.475	24.613	12.700	30.963	38.887	46.025	52.375	59.538	
650 mm	660.400			7.925	12.700		9.525			12.700						
750 mm	762.000	6.35	7.925	7.925	12.700	15.875	9.525			12.700						
850 mm	863.600			7.925	12.700	15.875	9.525			12.700						
900 mm	914.400			7.925	12.700	15.875	9.525			12.700						





## DIMENSIONS OF SEAM LESS & WELDED STEEL PIPE ACCORDANCE WITH ANSI B36.10 & B36.19

NOM. PIPE SIZE	OUT SIDE Diameter	NOMINAL WALL THICKNESS													
		Sche.	Sche.	Sche.	Sche.		Sche. 40	Sche.	Extra	Sche.	Sche.	Sche. 120	Sche. 140	Sche. 160	XX Strong
		5	10			Standard		60	Strong	80	100				
3/4	1.050	0.065	0.083			.0113	.0113		0.154	0.154				0.219	0.308
1	1.315	0.065	0.109			.0133	.0133		0.179	0.179				0.250	0.358
11/4	1.660	0.065	0.109			0.140	0.140		0.191	0.191				0.250	0.382
11/2	1.900	0.065	0.109			0.145	0.145		0.200	0.200				0.281	0.400
2	2.375	0.065	0.109			0.154	0.154		0.218	0.218				0.343	0.436
21/2	2.875	0.083	0.120			0.203	0.203		0.276	0.276				0.375	0.552
3	3.500	0.083	0.120			0.216	0.216		0.300	0.300				0.438	0.600
3 1/2	4.000	0.083	0.120			0.226	0.226		0.318	0.318					
4	4.500	0.083	0.120			0.237	0.237		0.337	0.337		0.438		0.531	0.674
5	5.563	0.109	0.134			0.258	0.258		0.375	0.375		0.500		0.625	0.750
6	6.625	0.109	0.134			0.280	0.280		0.432	0.432		0.562		0.718	0.864
8	8.625	0.109	0.148	0.250	0.277	0.322	0.322	0.406	0.500	0.500	0.593	0.718	0.812	0.906	0.875
10	10.75	0.134	0.165	0.250	0.307	0.365	0.365	0.500	0.500	0.593	0.718	0.843	1.000	1.125	
12	12.75	0.156	0.180	0.250	0.330	0.375	0.406	0.562	0.500	0.750	0.843	1.000	1.125	1.312	
14 OD	14		0.250	0.312	0.375	0.375	0.438	0.593	0.500	0.750	0.937	1.093	1.250	1.406	
16 OD	16		0.250	0.312	0.375	0.375	0.500	0.656	0.500	0.843	1.031	1.218	1.438	1.593	
18 OD	18		0.250	0.312	0.438	0.375	0.562	0.750	0.500	0.937	1.156	1.375	1.562	1.781	
20 OD	20		0.250	0.375	0.500	0.375	0.593	0.812	0.500	1.031	1.281	1.500	1.750	1.968	
22 OD	22		0.250			0.375			0.500						
24 OD	24		0.250	0.375	0.562	0.375	0.687	0.968	0.500	1.218	1.531	1.812	2.062	2.343	
26 OD	26					0.375			0.500						
30 OD	30		0.312	0.500	0.625	0.375			0.500						
34 OD	34					0.375			0.500						
36 OD	36					0.375		19.050	0.500						


Note:- All dimensions are given in decimals of and inch of the nominal pipe sizes. Thickness may vary due to mil tolerance.

Prepred By:- Syed Aftab Ahmed




Eng. Elsayed Amer

Pipe is specified by NPS



# Tube


Tube is specified by OD





## PIPE & Tube

### Pipe and tube





(a) Equal Wall Thickness

lower pressure

## **PIPE** Color code

Gases (other than air) including Yellow ochre Silver grey Steam liquefied gases Light blue Air Violet Acids and alkalis Trapped solids Black Green Water Yellow Red Used for chemicals in ADGAS Fire extinguishing materials

## **PIPE** materials

Piping material selection mainly depends on process conditions such as:

- I. Types of fluid
- II. Service temperature
- III. Operating pressure

carbon steel

Low alloy steel

Stainless steel

Titanium, Copper, Nickel

PVC, HDPE, GRE/GRP

- Corrosive fluids such as crude oil, Sea Water, H2S, Ammonia, Acids, etc. required high corrosion resistance material. On the other hand, normal carbon steel is enough for Non-Corrosive fluids such as – Lube oil, Air, Nitrogen, etc.
  - 2nd Process condition that will impact the selection of material is the Temperature of fluids
    - Cryogenic

Medium temperature

Low temperature

High temperature




Eng. Elsayed Amer

### **PIPE** materials

**Eng. Elsayed Amer** 

An increase or decrease in the service fluid temperature will greatly affect mechanical properties of the pipe material such as impact resistance, elongation, and tensile strength; hence, you required special material for both high temperature & Cryogenic services.





18


ס ע ט





### **What is Pipe Fittings?**


Fittings are Piping component which helps in Changes the direction of the flow such as elbows, tee. Changes the size of the pipe such as reducers, reducing tees. Connect to components together such as couplings and stop the flows such as Caps.






**Short Radius Elbow** 

- join together lengths of pipe —couplings, unions, nipples
- change the pipe size -- reducers, bushings.
- change the direction of a pipe run -- elbows
- join or separate flows of fluid (branch the pipe) tees and crosses
- Control flow through pipes valves,
- **Stop flow through pipes Spade**



### change the pipe size



### **Bushings**

Pipe bushings are used to join pipes of different sizes







Eng. Elsayed Amer


### change the direction of a pipe run

#### **Elbows**

A. B.



- A. 90° Elbow
- B. 45° Elbow
- C. Street Elbow









90° Ell



Eng. Elsayed Amer

### join or separate flows of fluid (branch the pipe)

#### tees and crosses






**Cross** 

## **PIPE** Thread


Tapered Thread Straight Thread






### **PIPE** Thread


NPT : stands for National Pipe Tapered NPS : stands for National Pipe straight



### **NPT Thread**









## Control flow through pipes — valves,






Needle valve Ball valve




### control flow through pipes






## control flow through pipes





### control flow through pipes


## **Blind flanges**






### control flow through pipes


## **Spectacle Blinds**







### control flow through pipes




### control flow through pipes


## **Spade**





### STUDS BOLTS & HEX BOLTS







# **PIPE** Fittings

#### STUDS BOLTS & HEX BOLTS








Compression fittings are used on small-diameter stainless steel, brass or copper tubing. They are only used on the plant for instrumentation hydraulic and air lines.

Compression Fittings

















1/8" NPT













A concrete block supports

A clamped pipe support

**Clamped Shoe** 




# **PIPE** Supports



**Clamped Jack Support** 









## **PIPE** End

### A pipe end is the description of how the section of pipe ends









**Plain End** 


**Bevel End** 

**Threaded End** 

Socket -spigot End




## **PIPE** End





## **PIPE** Connection


Flanges provide a bolted, separable joint in piping. Most piping connections to equipment are flanged for ease of installation and maintenance





### **PIPE** Connection

- A flange is a method of connecting pipes, valves, pumps and other equipment to form a piping system, It also provides easy access for cleaning, inspection or modification.
- Flanges are usually welded or screwed.
- Flanged joints are made by bolting together two flanges with a gasket to provide a seal.



# **PIPE** Flanges


## A flange is specified by the following information:

- Flange Specification and Identification
  - **Type and Facing** i.e. whether the flange is for example "Weld Neck, RTJ" or "Socket Weld, RF".
  - Nominal Pipe Size usually in inches.
  - **Pressure rating** e.g. Class 150, 300, 600, 900, 1500, 2500 etc.
  - **Standard** i.e. ANSI B16.5, BS 1560, API 6A, API 605 or ASME B16.47.
  - **Pipe Schedule.** A pipe's wall thickness 10, 30, 40, ,80, 120, 160, etc



### Pipe Class

- This word refers to ANSI class.
- ASME/ANSI B16.5 and B16.34 define the pressure/temperature relationships for steel flanges and fittings. Pressure ranges are defined by the classes.
- The class number (150, 300, 600, 900, 1500, 2500 for flanges)






# **Pressure** Rating

### working pressure

• **Pressure rating** is the maximum allowed pressure that a flange can withstand According to the ANSI/ASME B16.5 specification, there are 6 flange pressure ratings: 150, 300, 600, 900, 1500, and 2500.





## Pressure rating working pressure

Some piping components have a specific pressure rating and others do not:


- I. Pipe has no specific pressure rating. It must be calculated on the basis of wall thickness and allowable stress value.
- II. Fittings have no specific pressure rating, but it is generally the same as the pressure rating of straight pipe of the same material and schedule.
- III. Flanges and valves have specific pressure ratings, which are listed in ASME/ANSI B16.5 and B16.34 respectively.



# • Pressure rating working pressure


TABLE 2. WORKING PRESSURES BY CLASSES, PSIG							
Temp., °F	Class						
	150	300	400	600	900	1,500	2,500
-20 to 100	285	740	990	1,480	2,220	3,705	6,170
200	260	675	900	1,350	2,025	3,375	5,625
300	230	655	875	1,315	1,970	3,280	5,470
400	200	635	845	1,270	1,900	3,170	5,280
500	170	600	800	1,200	1,795	2,995	4,990
600	140	550	730	1,095	1,640	2,735	4,560
650	125	535	715	1,075	1,610	2,685	4,475
700	110	535	710	1,065	1,600	2,665	4,440
750	95	505	670	1,010	1,510	2,520	4,200
800	80	410	550	825	1,235	2,060	3,430
850	65	270	355	535	805	1,340	2,230
900	50	170	230	345	515	860	1,430
950	35	105	140	205	310	515	860
1,000	20	50	70	105	155	260	430





- Gasket Compressible material providing the seal
- Bolts Provide the force to compress the gasket and form the seal
- Flange Transmit the force from the bolts to the gasket (must not distort or deflect)





- 1. Threaded Flanges
- 2. Welding Neck Flanges
- 3. Socket Weld Flanges
- 4. Lap-joint Flanges with Stub-end
- 5. Slip-on Flanges
- 6. Blind Flanges

- 1. Flat Face (FF)
- 2. Raised Face (RF)
- 3. Ring Joint (RTJ)
- 4. Tongue and groove (T&G)
- 5. Male and Female type

## A. Types of Flanges



Welded neck flange



**Screwed flange** 



Slip on flange



Blind flanges



Lap joint flange




Spectacle blind flange



#### A. Flange End

### 1. Threaded Flanges

- Threaded Flange mostly used in utility services such as air and water
- It is not suitable for high presser and temperature applications
- It also available in limited Size of NPS 4" and below
- Threaded Flanges can be FF or RF
- It is a Low-cost flange.








#### A. Flange End

### 2. Socket-Weld Flanges

- Has a female socket in which the pipe is fitted.
- Used in small bore piping and only suitable for low pressure and temperature application.
- The cost of flange and fabrication is moderate.








#### A. Flange End

## 3. Slip-On Flanges

- Has a hole with matching outside diameter of pipe from which pipe can pass.
- welded from both inside and outside.
- Available in large size.
- It can be FF or RF.





stub end


Lap joint flange


# **Pipe Flanges**

#### A. Flange End

### Lap Joint Flanges

The lap flange is having two components, a stub end, and a Lap joint flange. The stub end is butt-welded to the pipe, and the backing flange freely moves over the pipe








#### A. Flange End

### 5. Weld Neck Flanges

- The most widely used type in process piping.
- It gives the highest level of joint integrity due to Butt-welded with a pipe.
- Used in high pressure and temperature application.







## 6. Blind Flanges

- The blind flange is a blank disc with a bolt hole.
- These types of flanges are used with another type of flange to isolate the piping system or to terminate the piping as an end.
- Blind flanges are also used as a manhole cover in the vessel.










## A. Flange End

## 6. Blind Flanges

#### **DETAILS OF BLIND FLANGE**



1. Blind flange 2. Stud Bolt 3. Gasket 4. Other flange



## A. Flange End

### 7. Reducing Flange


Reducing flange is used in place of a standard flange to allow for a change in pipe size.





### 63

### **B. Flange Face**
















- Has a flat face.
- Flat face flanges are used when the counterflanges are flat face.
- This condition occurs mainly in connection to Cast Iron equipment, valves, and specialties. Full face gasket is used when a flat face flange is used.






65



#### **Flat Face**









### 2. Raised Face Flanges

- Raised Face pipe flanges are the most commonly used flanges.
- Used for a wide range of pressure and temperature ratings.
- RF flanges are the most common type of flange employed in the Oil and Gas and chemical engineering industries.



### 2. Raised Face Flanges


The **height of the raised face** is dictated by the **flange's class** 

- classes 150 and 300 have a raised face height of 1/16 inch (1.6mm)
- flanges exceeding class 300 use a 1/4 inch (6.4mm) raised face.





# 2. Raised Face Flanges







3. Ring-Type Joint (RTJ)

The difference between an RTJ flange and a raised face flange is the way a seal is obtained. **Metal gaskets (hard)** are used with RTJ flanges, whilst raised face gaskets use soft or semi-metallic gaskets





### Pile gaskets

Pipe gaskets are manufactured in many different materials.

#### **Types Of Gasket by Material**


- 1.Non-metallic
- 2.Metallic
- 3.Composite



non-metallic gasket



EXCESS TO A PARTY OF THE PARTY





semi-metallic gasket




### Types of Gasket: Materials

#### 1. Non-metallic


These can be made from CNAF (Compresses non-asbestos fibre), PTFE, Rubber, Teflon or Graphite. Non-metallic gaskets can compress easily with low tension bolting. They're generally used for low pressure applications and low temperatures.



Rubber



**PTFE** 




**Asbestos** 

PTFE (Polytetrafluoroethylene)



### Types of Gasket: Materials

#### 1. Non-metallic





## Types of Gasket: Materials

### 1. non-metallic







#### Types of Gasket: Materials

### 2. Semi-metallic gaskets

Spiral wound: Spiral wound gaskets are semi-metallic gaskets that are used for high temperature and high-pressure applications. The main parts of spiral wound gasket are metallic windings and filler material.




ш


### Types of Gasket: Materials

### Spiral wound:





## Semi-metallic gaskets





#### **Ring-Type Joint**

#### 3. Ring-Type Joint (RTJ)

The Ring Type Joint flanges are typically used in high pressure (Class 600 and higher rating) and/or high temperature services above 800°F (427°C).










D Q G F




## **Pipe Flanges**

#### Ring Joint Gasket

Ring Type Joint gaskets are metallic sealing rings, suitable for high-pressure and high-temperature applications. They are always applied to special, accompanying flanges which ensure good, reliable sealing with the correct choice of profiles and material.










#### Ring Joint Gasket


There are three basic styles of API approved ring gaskets:

R-style includes both oval and octagonal cross sections, The API type "R" rig gasket is not a pressure energized gasket therefore this type does NOT recommend for BOP equipment or safety critical equipment as x-mas tree, wellhead valves, etc.



RX-style is a pressure energized ring joint gasket.

BX-style ring gaskets require a BX groove on the flange.







81

# **Pipe Flanges**

### Ring Joint Gasket
















Valves technology and operations

#### What is Valve?


#### Valve definition

- A device that regulates, directs or controls the flow of a fluid by opening, closing, or partially obstructing various passageways.
- Valves are designed to withstand pressure, temperature, and flow.



#### **Valve Cost**

- Valve cost is up to 20 to 30% of the piping cost for a plant, depending on the process; and the cost of a given type and size of valve can vary 100%, depending on its construction.
- The *size* of a *valve* is mainly *determined* by the *size* of its *ends*, which connect to the pipe



### **Valve Cost**

Size	ANSI 600 RF plug valve	ANSI 600 RF gate valve	ANSI 600 RF port ball valve
2"	\$1820	\$1075	\$1365
3"	\$2958	\$1505	\$1730
4"	\$4095	\$2480	\$2483
6"	\$8228	\$4583	\$4120

#### **Valve Manufactures**






















































































## Valve Flow





PAG

#### **Valve Functions**





Start and stop flow (On-off valves)



Control or regulate flow (Regulating valves)



Prevent back-flow (Check valves)




Relief over & under flow pressure.



### **Valve Components**

- Body.
- Bonnet.
- Stem.
- Disc.
- Seat.
- Stuffing Box.
- Packing.





#### 1. Body

- Main *pressure rating* part
- Hold all other parts
- Are cast or *forged structure* made.
- Valve body *must be strong* enough to hold the *maximum pressure* of the process fluid.
- *End connected* with *pipeline*






1. Body






#### 2. Bonnet

- Bonnet contains packing, gland and stem.
- The bonnet is attached to valve body by screws or bolts.



#### 3. Stem

- The stem, which connects the actuator and disc, is responsible for positioning the disc.
- Stems are typically forged and connected to the disc by threaded or welded joints.
- There are two types of valve stems: rising stems and non-rising stems.



### 4. DISC & SEAT


- Fluid flow control.
  - I. Start / allow
  - II. Throttle
  - III. Stop flow
- The type of disk define valve name.





#### 5. PACKING


- Stuffing box is a chamber that holds anti-seal material (packing).
- Most valves use some form of packing to prevent leakage from the space between the stem and the bonnet.
- Packing is commonly a fibrous material that forms a seal between the internal parts of a valve and the outside.



5. PACKING







Body

Packing

flange


Stem

Stud

Nut

#### 6. Valve Trim


• The internal elements of a valve which are in contact with fluids are collectively referred to as a valve's trim.





7. Valve Actuator

- A valve actuator is a mechanical device that uses a power source to operate a valve.
- This power source can be electric, pneumatic (compressed air), or hydraulic (the flow of oil).





### **Manual Valve Actuators**









**Chain Operated** 

**Gear Operated** 

Lever Operated

### **Automatic Valve Actuators**



a) Electric ACTUATORS




b) Hydraulic ACTUATORS



c) Pneumatic ACTUATORS







#### VALVE SPECIFICATION


#### 1. Pressure Temperature Rating.

is the maximum allowable sustained non-shock pressure at the corresponding tabulated temperature. These are listed in ANSI B 16.34 and ANSI B 16.5.

Series	75T, 75V	75 <b>E</b>
Material group Material name	2.2 CF3M, CF8M	
Temperature, °F	Working pressure, psig	
– 20 to 100	275	275
150	255	255
200	235	235
250	225	225
300	215	_
350	205	_
400	195	_
450	100₾	



#### Valve Classification






106

#### **Valve Classification**

### According to function





### **According to function**

• Isolation Valves

Sometimes referred to as block valves

used to start or stop the flow

gate, plug, ball, pressure-relief,




Safety relief valves





Ball valves





#### **Valve Classification**


### **According to function**

Nonreturn valve

A check valve, non-return valve, reflux valve, retention valve or one-way valve is a valve that normally allows fluid (liquid or gas) to flow through it in only one direction.




Check valve





# **According to function** *Nonreturn valve*

- Used to prevent backflow of fluid, which could damage equipment or upset the process.
- Useful in protecting a pump in liquid applications or a compressor in gas applications from backflow





# **According to function** *Throttling Valves*

used to regulate the flow, temperature, or pressure

Globe valve is the most common pressure regulation valves



Globe valve




# According to function Throttling Valves

Valve function may be completed by process and/or safety requirements:

- Normally open (NO) or normally closed (NC).
- Locked open (LO) or locked closed (LC).
- I Shutdown valve (SDV), emergency shutdown valve (ESDV), and blowdown valve (BDV).
- I Motor-operated valve (MOV) and remote-operated valve (ROV).



# **According to Applications**




# **According to Applications**

General service valves

#### Designed for the majority of applications that have:

- 1. lower-pressure ratings between Class 150 and 600
- 2. Temperature ratings between 46 and 343°C
- 3. Noncorrosive fluids, and common pressure drops that do not result in cavitation or flashing.



### **According to Applications**

#### Valve rating

The rating of valves defines as the pressure – temperature relationship within which the valve may be operated.

**≻WOG** (Water, oil, gas).

Rating used for small valves.

>WSP (Working Steam Pressure).

The high temperature rating.





Series	75 <b>T</b> , 75 <b>V</b>	75 <b>E</b>	
Material group Material name	2.2 CF3M, CF8M		
Temperature, °F	Working pre	essure, psig	
– 20 to 100	275	275	
150	255	255	
200	235	235	
250	225	225	
300	215	_	
350	205	_	
400	195	_	
450	100₾		



## **According to Applications**

Valve rating

#### NPS versus DN

inches	millimeters
0.25	6
0.5	15
1.0	25
2.0	50
4.0	100
8.0	200
16.0	400

#### ANSI Pressure versus PN

psi	bar
150	16
300	40
600	100
900	160
1500	250
2500	400
4500	700

Note: PN correlates to DIN (Deustche Industrie Norme) pressure-temperature rating standards, which may vary significantly from ANSI pres.-temp. ratings.



#### **Valve Selection Considerations**

# Valves are characterized by the following:

- Type.
- Nominal diameter (inches).
- ASME class number (150#, 300#, etc.).
- Body and trim material.

### **Valve Selection Considerations**

Valve	Stop- start	Throttling	Frequent operation	Low pressure drop	Size range mm	Pressure range (bar)	Temperature range (°C)
Gate	1			<b>✓</b>	3-1220	vac to 667	-270 to 680
Slide	1				50-1900	atm. to 27	-18 to 650
Ball	1		1	1	6-914	atm to 500	-55 to 500
Plug	1		1	1	6-406	atm to 200	-70 to 200
Globe (Z)	1	1	1		3-726	vac to 667	-270 to 540
Y-type	1	1	1	1	3-762	vac to 167	-270 to 540
Butterfly	1	1	1	1	50-914	vac to 80	-30 to 540
Diaphragm	1	1			3-610	vac to 20	-50 to 230
Needle		1			3-25	vac to 667	-70 to 260



#### **Valve Selection Considerations**

Table 12.2.3 Typical sizes and operating ranges of isolation valves

	S	ize	Pressure range		Temperature range		Pressure drop <sup>1</sup>
Valve type	Min. (mm)	Max. (mm)	Min. (bar)	Max. (bar)	Min. (° C)	Max. (° C)	bar
Gate	3	2 250	>0	700	-196	675	0.007
Globe	3	760	>0	700	-196	650	0.590
Diaphragm	3	610	>0	21	-50	175	0.021
Ball (full bore)	6	1 220	>0	525	-55	300	0.007
Butterfly	50	1 830	>0	102	-30	538	0.120

<sup>&</sup>lt;sup>1</sup> Note: Typical values for a DN150 bore valve passing saturated steam at 24 bar, flowing at 40 m/s.



#### **Valve material**

- It specifies the grade of steel used in the valve casting.
- There are actually 3 grades A,B & C which define the ductility & tensile strength.
   WCA, WCB, and WCC.
- WCB stands for "Wrought Carbon" with Grade B. Sometimes you can think "C" as casting.
- Grade B is having very good ductility & tensile strength as compare to Grade A & C.

W = Low-temperature water service

O = Low-temperature oil service

G = Low-temperature gas service

→ = Flow direction







11

AGE


# **According to Applications**

#### 2. Special service valves

1. Designed for a single application that is outside normal process applications (custom-engineered valves).

2. Handled a demanding temperature, high pressure

or a corrosive medium.






### **According to Applications**

#### 3. Severe service valves


- 1. Equipped with special features to handle volatile applications and high pressure drops (highly engineered trims).
- 2. Special actuation may be required to overcome the forces of the process.








# According to Motion





# **According to Motion** *Linear-motion Valves*

- 1. Had a sliding-stem design that pushes a closure element into an open or closed position.
- 2. Simple design, easy maintenance, and versatile with various sizes, pressure class and design options.
- 3. Example: gate, globe, diaphragm, three-way.



# According to Motion Linear-motion Valves


Valve types	Linear motion	Rotary motion	Quarter turn
Gate Valve	X		
Globe valve	X		
Plug valve		X	X
Ball valve		X	X
Butterfly valve		X	X
Diaphragm valve	X		
Pinch valve	X		



# According to Motion

# **Rotary-motion Valves**

- 1. Used a closure element that rotates through a quarter-turn range to open and block the flow.
- 2. Limited to certain pressure drops.
- 3. Prone to cavitation and flashing problems.






# **According to Motion** *Rotary-motion Valves*


- 1. Right tightly = close
- 2. Lefty Lucy = open

# Gate Valve OPEN Rising Stem Wedge Gate CLO




Stem & Wedge Gate Rise and Lower to Control Flow







# According to Port Size





# **According to Port Size**

**Full-Port Valves** 

allow for the use of a pig in the pipeline

Example: gate and ball valves




### **According to Port Size**


**Reduced-Port Valves** 

Α


valves whose closure elements restrict the flow.

flow area of that port of the closure element is less than the area of the inside diameter of the pipeline










Reduced-bore Channel Type









## Globe Valve

#### **Globe valve**

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 

A globe valve is a linear motion valve used to stop, start, and regulate the fluid flow.

This movement creates the annular space between the disk and seat ring that gradually close as the valve closed. This characteristic provides the globe valve good throttling ability required for regulating the flow.



#### **Valves Types**

# Globe Valve

#### Globe valve

Ball Valve

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve





Hand Wheel Nut

133

#### **Valves Types**

## Globe Valve

#### Valve components

**Globe valve** 

Ball Valve


Gate valve


Diaphragm Valve

Check valve

Plug Valve

Needle valve







# Globe Valve

#### Flow direction

#### **Globe valve**

**Ball Valve** 


Gate valve


Diaphragm Valve

Check valve

Plug Valve

Needle valve







#### Valves Types

## Globe Valve

Flow direction

**Globe valve** 

**Ball Valve** 

Gate valve


Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 



Stem & Plug Disc Rise and Lower to Control Flow



# Globe Valve

**Globe valve** 

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve


Needle valve

**Butterfly Valve** 

Body designs: Z-body, Y-body, and angle



Y-Pattern



<u>Angle</u>



**Z-body** 



₽ © Ø



## Globe Valve

#### **Globe valve**

**Ball Valve** 

Gate valve


Diaphragm Valve


Check valve


Plug Valve


Needle valve

**Butterfly Valve** 










(a) Ball Disc

(b) Plug Disc

(c) Composition Disc

#### Globe Valve Discs





137

U 4



#### **Valves Types**

# Globe Valve

#### Advantages & Disadvantages

**Globe valve** 

Ball Valve

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve

Advantages	Disadvantages
Recommended for throttling applications.	Flow path causes a significant pressure drop.
Good for frequent operation.	Globe valves are more costly than alternative valves.
Easy to repair.	High pressure drop
	Noisy in high pressure applications



Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 

Α -----


A Ball valve is a quarter-turn rotary motion valve that uses a ball shaped disk to stop or start the flow.

В -----

When the valve is opened the hole of disk is turned in-line with the direction of the flow. When the valve is shut, the ball is rotated so that the hole is perpendicular to flow direction.

Most ball valves are of the quick-acting type, which requires a 90° turn of the valve handle to operate the valve.







#### **Valves Types**

# Ball Valve

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve





# Valves Types

# Ball Valve

Valve components

Globe valve

**Ball Valve** 


Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve





#### Flow direction

Globe valve

**Ball Valve** 

Gate valve


Diaphragm Valve

Check valve


Plug Valve

Needle valve

**Butterfly Valve** 



#### Stem & Ball Rotate 90° from OPEN to CLOSED





## Ball Valve

Body design

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve


Plug Valve


Needle valve

**Butterfly Valve** 



Body designs: Float ball valve & Trunnion Mounted Ball Valve







## Ball Valve

Body design

Globe valve

Ball valves are manufactured in different body arrangements

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 



**Top entry** 



Side entry or split body



Three-piece body



ш

### Ball Valve

### Advantages & Disadvantages

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve

Advantages	Disadvantages
Low pressure drop	Poor throttling characteristics
Easy operation	Wear and tear
Fast acting	Temperature operation limitation
Two-way flow possible	
Low maintenance costs	
Ball is used for opening & closing	



### Gate Valve

#### Globe valve

**Ball Valve** 

**Gate valve** 

Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 



A gate valve can be defined as a type of valve that used a gate or wedge type disk and the disk moves perpendicular to flow to start or stop the fluid flow in piping.




It is a linear motion valve used to start or stop fluid flow.



These valves are either in fully open or fully closed position.





### Gate Valve

#### Globe valve

**Ball Valve** 

**Gate valve** 

Diaphragm Valve


Check valve


Plug Valve

Needle valve

**Butterfly Valve** 

### Valve components







### Gate Valve

Globe valve

**Ball Valve** 

**Gate valve** 

Diaphragm Valve


Check valve

Plug Valve

Needle valve

**Butterfly Valve** 

### Valve components





### Gate Valve

Flow direction

Globe valve

**Ball Valve** 

**Gate valve** 


Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 



Stem & Wedge Gate Rise and Lower to Control Flow



### Gate Valve

Globe valve

**Ball Valve** 

**Gate valve** 

Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 

### Valve operation





### Body design

Globe valve

**Ball Valve** 


**Gate valve** 


Diaphragm Valve


Check valve

Plug Valve


Needle valve













### Gate Valve

#### Globe valve

**Ball Valve** 

**Gate valve** 

Diaphragm Valve

Check valve

Plug Valve


Needle valve

**Butterfly Valve** 





#### **BASED ON GATE DESIGN**



### Gate Valve

Globe valve

**Ball Valve** 

**Gate valve** 

Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 

### Advantages & Disadvantages

Advantages	Disadvantages
Small Fluid Resistance	Flow changes nonlinearly with stem travel
Little torque required for opening and closing	Vibration/cavitation when partially open
Little pressure drop	Subject to wear
No flow restriction	Repair work is difficult
Good sealing when closed	

154

### Valves Types

## • Diaphragm Valve

Globe valve

**Ball Valve** 

Gate valve

**Diaphragm Valve** 

Check valve

Plug Valve


Needle valve

**Butterfly Valve** 

A diaphragm valve is a linear motion valve that is used to start, regulate, and stop fluid flow.

The name is derived from its flexible disk, which mates with a seat located in the open area at the top of the valve body to form a seal.

c ----- These valves are either in fully open or fully closed position.





U

P A

## • Diaphragm Valve

Valve components

Globe valve

**Ball Valve** 


Gate valve

**Diaphragm Valve** 

Check valve

Plug Valve

Needle valve





## • Diaphragm Valve

Globe valve

**Ball Valve** 

Gate valve

**Diaphragm Valve** 


Check valve


Plug Valve

Needle valve

**Butterfly Valve** 

#### Valve Flow direction







# • Diaphragm Valve

Valve operation

Globe valve

**Ball Valve** 


Gate valve

**Diaphragm Valve** 

Check valve

Plug Valve

Needle valve



## • Diaphragm Valve

#### Globe valve

**Ball Valve** 

Gate valve

**Diaphragm Valve** 

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 

### Advantages & Disadvantages

Advantages	Disadvantages
Quick Opening On/Off valve	operation temperature and pressure have limits
used for throttling service.	hydrostatic pressure that can be
Low Pressure drop	applied to the diaphragm is limited.
suited for the handling of corrosive fluids, slurries, radioactive fluids.	Dimensions of diaphragm valves are limited. They are produced in DN15-DN300 dimensions.
no packing glands to maintain	







Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

**Check valve** 

Plug Valve

Needle valve

**Butterfly Valve** 

known as non-return valves are valves that allow fluids to flow in only one way/direction.

Can protect equipment and minimize damage in case of a leak in the upstream line.







# Check Valve



### Valve operation

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

**Check valve** 

Plug Valve

Needle valve

**Butterfly Valve** 





160

U P A



#### Flow direction

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve


**Check valve** 


Plug Valve

Needle valve

**Butterfly Valve** 









PAG





### Valve component

Globe valve

**Ball Valve** 


Gate valve

Diaphragm Valve

**Check valve** 

Plug Valve

Needle valve







### Body design



#### **BASED ON STEM**

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

**Check valve** 

Plug Valve

Needle valve

**Butterfly Valve** 



DUAL DISC CHECK VALVE



SWING CHECK VALVE



LIFT /PISTON CHECK VALVE



**BALL CHECK VALVE** 



SILENT CHECK VALVE



NOZZLE TYPE CHECK VALVE



WAFER CHECK VALVE



TILTING DISC CHECK VALVE



163

U 4



Body design



**Swing Check Valve** 

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

**Check valve** 

Plug Valve

Needle valve





**Butterfly Valve** 



164

PAG

4

Body design

В

Spilt (wafer) Disk Check valve

**VALVE BODY** 

Globe valve

**Ball Valve** 


Gate valve

Diaphragm Valve

**Check valve** 

Plug Valve

Needle valve





Globe valve

**Ball Valve** 


Gate valve

Diaphragm Valve

**Check valve** 

Plug Valve

Needle valve







Body design



**Ball CHECK VALVE** 

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve


**Check valve** 


Plug Valve

Needle valve

**Butterfly Valve** 







167

Ш U P A





Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

**Check valve** 

Plug Valve

Needle valve

**Butterfly Valve** 

### Advantages & Disadvantages

Advantages	Disadvantages
Low pressure drop	difficult to determine whether the valve is open or closed
Quick opening	the condition of internal parts cannot be assessed.
Low maintenance costs	limitations on its installation configurations
Used for both high/low pressure	Valve disc can stick in open position.
Used for both horizontal & vertical flow	



168

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

**Plug Valve** 

Needle valve

**Butterfly Valve** 

Plug valve is Quarter-turn rotary motion Valve that uses a tapered or cylindrical plug to stop or start the flow.

The disk is in plug shape, which has a passage to pass the flow. In open position, this bored passage is in line with the flow.





Globe valve

**Ball Valve** 

Gate valve


Diaphragm Valve

Check valve


**Plug Valve** 

Needle valve

**Butterfly Valve** 



Stem & Plug Rotate 90° from OPEN to CLOSED







Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve


Check valve


**Plug Valve** 

Needle valve

**Butterfly Valve** 

### Valve component





Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

**Plug Valve** 

Needle valve

**Butterfly Valve** 

### **Advantages & Disadvantages**

Advantages	Disadvantages
simple design with few parts	first movement (opening-closing) requires a large amount of force
open and close easily	Require a gearbox or an actuator.
low flow resistance	costs are much larger than ball valves
Provide reliable leakage	
Smaller in size than most other valves	



## **Needle Valve**

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve

**Needle valve** 

**Butterfly Valve** 

A small type of globe valve,

Used in instrument systems for throttling of small volumes. They have metal-to-metal seats, but due to the small size, can be used for positive shut-off Passageways that may plug easily and limit their use to very small flow rates.





## **Needle Valve**

Flow direction

Globe valve

**Ball Valve** 


Gate valve

Diaphragm Valve

Check valve

Plug Valve

**Needle valve** 



## **Needle Valve**

Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve


Check valve

Plug Valve

**Needle valve** 

**Butterfly Valve** 

### Valve component



Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 

A Butterfly valve is a quarter-turn rotary motion valve, that is used to stop, regulate, and start the flow. Butterfly valves are a quick open type.

A 90° rotation of the handle can completely close or open the valve.







Globe valve

**Ball Valve** 


Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve





Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 



Square stem for easy assembly of actuator.

#### Body

In nodular cast iron (GGG40), red RAL 3011.

#### **Flange**

Connection for DIN, ANSI or JIS flange standard.

#### Lining

Injection moulded, vulcanized lining in NBR, EPDM or FPM/FKM.

#### Bushing

Low friction bushing to minimize actuation torque.

#### Stem sealing

To prevent any stem leakage, sealing between upper part of disc and valve body as well as between stem and inner body surface.

#### Pins

In duplex stainless steel, for durability and corrosion resistance.

#### Disc

In stainless steel (AISI316) or aluminium bronze (AB2).



178

(

Flow direction

Globe valve

**Ball Valve** 

Gate valve


Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 



Stem & Disc Rotate 90° from OPEN to CLOSED



Globe valve

**Ball Valve** 

Gate valve

Diaphragm Valve

Check valve

Plug Valve

Needle valve

**Butterfly Valve** 

### Advantages & Disadvantages

Advantages	Disadvantages
relatively inexpensive, quarter-turn valves.	Throttling is limited to low differential pressure
Easily/quickly operated	There is a chance for cavitation
Good for large flow/low pressure applications due to saving in weight/size/cost	
suitable for large valve applications due to Compact, lightweight design	
Little pressure drop	



180





## Solenoid Valve

- Α -----
- An <u>electrically operated</u> valve where an electromagnet is used as an actuator to change the valve state.
- Used only in an ON/OFF manner. In a two-way solenoid valve, the valve is open when the solenoid coil is energized.










## Solenoid Valve

#### Valve component




- 1. Valve Body
- 4. Coil / Solenoid
- 7. Plunger

- 2. Inlet Port
- 5. Coil Windings
- 8. Spring

- 3. Outlet Port
- 6. Lead Wires

9. Orifice

## Solenoid Valve







**Types of protection valves** 


- Overpressure relief valves.
- Pressure vacuum relief valves.
  - Rupture Disks





**PSV Locations** 

Blocked Outlet/ Blocked Discharge



**Process Vessel** 

**Compressor** 

**Pump** 


186



## **Protection Valves**

**PSV Locations** 

Thermal Expansion/ Thermal Relief




**Heat Exchanger** 

Line




**PSV Locations** 

**Tube Rupture** 








**Heat Exchanger** 



## **Protection Valves**

**PSV Locations** 






**Pool Fire** 

**Jet Fire** 



#### 1. Pressure relief valves PRV

- Are used mainly to relieve overpressure of *liquids*.
- Fluid pressure pushes against the spring to open the valve.
- The fluid pressure needed to push the valve open is called the *setpoint* pressure.
- The setpoint pressure is usually the maximum normal operating pressure of the liquid.






#### 1. Pressure relief valves PRV

• When the liquid pressure exceeds the setpoint pressure, the valve opens slowly. It releases just enough liquid to bring the pressure down to the normal operating pressure.








## **Protection Valves**

#### 1. Pressure relief valves PRV


Relief valves are characterized by:

- Slow response times (tenths of a second up to > 1 second)
- Risk of blockage
- Trace leakage






- 2. Pressure Safety Valves (PSVs)
- Used mainly to relieve overpressure of gases.
- When the fluid pressure exceeds the setpoint pressure, the valve pops fully open.
- This happens very quickly to release overpressure as quickly as possible.
- The PSV outlet diameter is greater than the inlet for the same reason as for the PRV







## **Protection Valves**

2. Pressure Safety Valves (PSVs)











Relief Valve	Safety Valve
A relief valve is a device used to limit the pressure in a system within a specific set level.	A safety valve is a device designed to actuate automatically to release excess pressure.
The opening of a relief valve is directly proportional to the increase in the vessel pressure.	A safety valve opens almost immediately and fully in order to prevent overpressure condition.
A relief valve opens when the pressure reached the specific set pressure limit and it is usually operated by an operator.	The purpose of a safety valve is to protect people, property, and environment. It is used to release excess pressure without operator assistance.
The setpoint of a relief valve is usually set at 10 percent above the working pressure limit.	The setpoint of a safety valve is usually set at 3 percent above the working pressure limit.
Relief valves are divided into pop- type, direct-operated, pilot-operated, and internal relief valves.	Safety valves are divided into a wide range of types based on applications and performance in different areas.  Difference Between net





196


<u>Safety Valve</u> - an automatic pressure relieving device actuated by the static pressure upstream of the valve and characterized by a full-opening pop action. It is used for gas or vapor service.

Relief Valve - an automatic pressure relieving device actuated by the static pressure upstream of the valve which opens further with increase in pressure over the opening pressure. It is used primarily for liquid service. A relief valve can be used in this application because water is non-compressible and the removal of a small amount of fluid from a solid system decreases the pressure dramatically.

Safety Relief Valve - an automatic pressure-actuated relieving device suitable for use either as a safety valve or relief valve, depending on application.



## **Protection Valves**





#### **Rupture Discs**

- Rupture discs, also called bursting discs, are a simple and cheap form of pressure safety device.
- A Rupture Disk is a non-reclosing pressure relief device actuated by static differential pressure between the inlet and outlet of the device and designed to function by the bursting of a rupture disk.




- *Breathing valve* special types of Relief Valves which are specifically designed for tank protection.
- used to protect low pressure tanks constructed for internal pressures less than 15 psig against overpressure and vacuum which occurs normally as a result of liquid movement into or out of the tanks.






## **Protection Valves**






## **Protection Valves**





## **Protection Valves**





## **Protection Valves**





## **Protection Valves**





206

# Special Valves Diverter Valves











## Valve

### **End Connections**

Classifications

1 Threaded ends

2 Welded ends

3 Flanged ends







## **Threaded Ends**


Classifications

Threaded (NPT)




## **Threaded Ends**


Classifications



Female x Female



Male x Male



Male x Female




## **Welded Ends**

Classifications



When zero leakage is required for environmental, safety, or any efficiency reasons the piping can be welded to the valve, providing one piece construction. Many users insist that high-pressure application requires a permanent end especially if they involve high temperatures







#### Valves Ends

## Flanged Ends

Classifications



The most expensive but are the best for installation and removal.

The main advantage of flanges is that the valve can be removed easily from the line








Flanged end





Classifications

## Raised Face (RF)






#### Valves Ends

## Flanged Ends

Classifications






## Flanged Ends

Classifications






Ring Type Joint (RTJ)



## Flanged Ends

Classifications

Clamp Connection






#### **Valves P&ID**

## **PID Symbols**

Drawing Engineering







## **Control valve parts**

Actuator

Valve BODY







## Control valve parts

#### **Actuator**

Provides the mechanical power necessary to move the components within the valve body


#### **Body**

Contains all the Mechanical components necessary to influence fluid flow




## Control valve parts

The internal elements of a valve are collectively referred to as a <u>valve's trim</u>.






## **Control valve Applications**







## **Control valve Applications**





















## **Types of Control Valves**




Globe valve




Ball sector valve











# \_\_\_\_\_

## **Types of Actuators**

- <u>Actuator</u>: An actuator is a pneumatic hydraulic, or electrically powered device which supplies force and motion to open or close a valve.
- There are six main types of actuator:
  - Manual
  - Electric motor
  - Electric solenoid
  - Pneumatic
  - Hydraulic
  - Self-actuated—check valves, PRVs and PSVs



229

A G E

#### **Manual Valve Actuators**









**Gear Operated** 



Lever Operated





#### C


## **Types of Actuators**


### Now P&ID Symbol as per Actuator






















## **Types of automatic Actuators**





a) Electric ACTUATORS



b) Hydraulic ACTUATORS



c) Pneumatic ACTUATORS 🖔




#### a. Pneumatic Actuators

Α -----


Use air pressure pushing against either a flexible diaphragm or a piston to move a valve mechanism.

В -----

Air pressure required to motivate a pneumatic actuator may come directly from the output of a pneumatic process control, or from signal transducer translating an electrical signal into an air pressure signal (I/P)



#### a. Pneumatic Actuators





## 236

#### **Automatic Valve Actuators**


#### a. Pneumatic Actuators


#### Failure mode

- Air to open
  - spring to close.
  - valve fails in the closed position if the air system goes down.
  - air supply located on the bottom of the dome.
- Air to close
- spring to open.
- valve fails in the open position, if the air system goes down.
- air supply located on the top of the dome





#### a. Pneumatic Actuators







#### Failure mode










Fail Close



**Control valve** 

## **Automatic Valve Actuators**


Fail Open







### **Manual Override**

- ATC/FO
  - Side Mounted H/W











# Control valve Control loop

#### Translate







Electrical – Pneumatic positioner



**Pneumatic Actuator** 




## Control loop

Process variables - Sensors



Electrical – Pneumatic positioner
Translate








PLC Logic



Pneumatic Actuator



## **Valve Arrangement**





#### b. Hydraulic actuators

- Uses liquid pressure rather than gas pressure to move the valve mechanism.
- use a piston rather than a diaphragm to convert fluid pressure into mechanical force
- More powerful than a pneumatic actuator of the same size






#### c. Electrical actuators

Electric actuators include electric motors and solenoid-actuated valves. Electric motors can be used to open, close, and position a valve manually, automatically, or semi-automatically.



#### **Control Valve motion**




## Reciprocating


- Globe
- Angle
- Severe Service

## Rotary

- Butterfly
- Ball
- Rotary Globe




### **Actuator Mechanism**






### **Actuator Mechanism**






#### **Actuator Mechanism**

Pneumatic Piston Actuator Single Acting





## **Valve Operation**






253

## **Valve Operation**







## **Actuators Component**

### Limit switch

Α ----•

A limit switch is a device that is used to prove the open or closed position of a valve.







## **Control Valve sizing**

### a. Valve flow Coefficient

#### Valve Flow Coefficient (Cv)

- is a valve's capacity for a liquid or gas to flow through it.
- It is technically defined as "the volume of water at 60°F (in US gallons) that will flow through a valve per minute with a pressure drop of 1 psi across the valve."
- In simpler terms, the larger the opening in a valve, the larger the Cv. As a valve is opening, the Cv increases until the valve is fully open, where it reaches its highest possible Cv, or 100% open Cv.




## **Control Valve sizing**

### a. Valve flow Coefficient

$$C_v = Q \sqrt{rac{ ext{SG}}{\Delta P}}$$


where:

Q is the rate of flow (expressed in US gallons per minute), SG is the specific gravity of the fluid (for water = 1),  $\Delta P$  is the pressure drop across the valve (expressed in psi).



**Fig. 2.** Calculating the flow rate through a valve is much more complex. The valve flow coefficient  $(C_v)$  takes into account all the dimensions and other factors—including size and direction changes—that affect fluid flow.





Flow, L/min


#### Example:

- Enter the vertical scale with the pressure drop across the valve ( $\Delta p = 30$  bar).
- Read across to the desired flow rate (q = 0.2 L/min).
- The diagonal line is the desired  $C_v$  value ( $C_v = 0.0025$ ).



## Flow Coefficient (Cv) at Stem Travel (% Open)






Stem Travel (% Open)

## Flow Coefficient (Cv) at Stem Travel (% Open)








Fill in your conditions and click "Calculate C<sub>v</sub>" to display applicable products.

Instructional Video


View Formula





## **Control Valve sizing**

### a. Valve flow Coefficient





### **Control Valve Failure**

## a. Valve flow Coefficient

- 1. Cavitation
- 2. Flashing
- 3. Trim erosion
- 4. Vibration
- 5. Corrosion
- 6. Packing leakage



#### **Control valve**

### **Control Valve Failure**

### a. Valve flow Coefficient

- 1. Cavitation
- 2. Flashing
- 3. Trim erosion
- 4. Vibration
- 5. Corrosion
- 6. Packing leakage





https://instrumentationtools.com/valve-quiz/



#### The purpose of valve packing is to:

- (A) Help reduce cavitation in the valve trim
- (B) Increase stiction
- (C) Cushion the valve against harm during shipment
- (D) Seal process fluid from escaping past the stem
- (E) Lubricate the valve trim

# 11. Regardless of type, all valves have the following basic parts, with the exception of \_\_\_\_

- a) bonnet
- b) nipple
- c) actuator
- d) body

## The proper "fail safe" status of a valve should always be dictated by:

- (A) economic savings
- (B) the configuration of the positioner
- (C) the controller's tuning
- (D) the controller's action (direct or reverse)
- (E) the nature of the process
- 12. The body of a valve typically receives inlet and outlet piping through any of the following types of joints EXCEPT:.
- a) glued
- b) welded
- c) threaded





- 14. The manually operated handwheel, manual lever, motor operator, solenoid operator, pneumatic operator, or hydraulic ram are all examples of
- a) a yoke
- b) a stem
- c) a bonnet
- d) an actuator
- 17.Most valves use\_\_\_\_\_ to prevent leakage from the space between the stem and the bonnet.
- a) o- rings
- b) a liquid seal
- c) a metal to metal seal
- d) packing

- 16. The stem in a valve, which connects the actuator and disk, is responsible for positioning the disk.
- a) True
- b) False

- 24.A globe valve is suitable for stopping and starting fluid flow, but not for regulating flow.
- a) True
- b) False





25. Which of the following is the globe valve body design that is the simplest and most common for water applications?

- a. Z-body
- b. X-body
- c. Angle
- d. Y-body

28. Which of the following valve types has an <u>actuator</u> that is of the quick-acting type, requiring only a 90 deg turn of the handle to fully open or close the valve?

- a) gate valve
- b) globe valve
- c) ball valve
- d) pinch valve

29. Which of the following valve types is well suited for an application where corrosion or metal contamination of the fluid might be a problem, because the operating mechanism is completely isolated from the fluid?

- a) pinch valve
- b) gate valve
- c) butterfly valve
- d) reducing valve

30. Which of the following types of valve causes the greatest head loss when completely open?

- a) ball valve
- b) gate valve
- c) butterfly valve
- d) globe valve





#### 31. Which of the following is a disadvantage of ball valves?

- a) They are large and heavy.
- b) They have high maintenance costs.
- c) They have relatively poor throttling characteristics
- d) They are among the most expensive of the valve types.

#### 32. The gland of a plug valve is equivalent to the of a gate or globe valve.

- a) body
- b) packing
- c) seat
- d) bonnet

#### 33. Which type of valve has advantages over other valve designs in weight, space and cost for large valve applications?

- a) butterfly valve
- b) globe valve
- c) diaphragm valves
- d) gate valves

#### 34.All of the following are general types of check valves **EXCEPT**.

- a) butterfly
- b) plug
- c) swing
- d) tilting disc





35.Relief and safety valves prevent equipment damage by relieving accidental over-pressurization of fluid systems.

- a) True
- b) False

